

RECEIVED

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

JUN 26 2018

PUBLIC SERVICE
COMMISSION


IN THE MATTER OF:

CITY OF FLEMINGSBURG AND CITY OF)
FLEMINGSBURG UTILITY SYSTEM)
ALLEGED FAILURE TO COMPLY WITH)
KRS 278.495 AND 49 CFR PART 192.605 (a);)
49 CFR PART 192.721; 49 CFR PART 199.105:)
AND 49 CFR 199.225)

CASE NO. 2017-00079

CERTIFICATION OF TRAINING BY CITY OF FLEMINGSBURG


Comes the City of Flemingsburg and City of Flemingsburg Utility Systems, by and through counsel, and pursuant to an Order entered May 3, 2018, certifies in writing that the City has completed training as set forth in paragraphs three and four of the Order entered May 3, 2018. This training was conducted on June 13, 2018 by ARCRANDOLFF AND ASSOCIATES, LLC and said documentation of training is attached hereto.



Kimberly Leet Razor, City Attorney

CERTIFICATE OF SERVICE

The undersigned hereby certifies that the foregoing document was filed with the Commission by mailing the original and ten copies to Talina R. Matthews, Executive Director, Public Service Commission, 211 Sower Boulevard, Frankfort, KY 40601, and to parties of record this 22 day of June 2018.



Kimberly Leet Razor, City Attorney

City of Flemingsburg
“Removing Potential Ignition Sources” / “Post Incident Drug & Alcohol Testing”
Wednesday, June 13, 2018

Training Agenda

1. Introduction
2. Review of O&M Manual
3. Review of DOT Regulations:
 - Procedural Manual For Operations, Maintenance, And Emergencies
 - 49 CFR 192.605a
 - Prevention Of Accidental Ignition
 - 49 CFR 192.751a
 - Drug Testing Required
 - 49 CFR 199.105b
 - Alcohol Testing Required
 - 49 CFR 199.225a
4. Characteristics of Natural Gas
5. Causes of Emergency Situations
6. Potential Ignition Sources
7. Removing Potential Ignition Sources / Making Situations Safe
8. Indications of a Gas Leak
9. Gas Leakage Migration Patterns
10. Investigating Natural Gas Leaks
11. “Table Top Exercises”
 - ✓ Dig-In #1
 - ✓ Odor of Gas #2
12. Hidden Dangers “Static Electricity”
13. Conclusion

Flemingsburg Utility

"Removing Potential Ignition Sources" / "Post Incident Drug and Alcohol Testing"

Training Class Conducted June 13, 2018

"Employee Statements End Of Day On What They Learned From The Class"

- 1 Always Remember no matter the situation is to establish a perimeter of the
For monitoring gas leakage and people control
- 2 Always remember to call for help
- 3 Don be afraid to ask questions
- 4 Drug & Alcohol Testing within 32 hours
- 5 Establish a perimeter on a gas call
- 6 On a leak don't hesitate to call for help
- 7 Mandatory drug/alcohol Testing
- 8 Importance for checking for migrating gas
- 9 Importance of following our O & M Manual
- 10 Have 32 hours to drug/Alcohol test post accident
- 11 Table Top Exercises - Good to see what everyone would do
- 12 Natural gas 1000 BTU per cubic foot
- 13 Propane heavier than air
- 14 Remember to establish perimeter
- 15 Static Electric is a "Hidden Danger"
- 16 Only takes a minute to do the right thing
- 17 Establish Perimeter

ARC RANDOLPH & ASSOCIATES, LLC

This is to confirm that:

Joe Dunaway Jr.

Attended the following workshop provided
for "*Flemingsburg Utilities*":

**"Removing Potential Ignition Sources" &
"Understanding Post Incident Drug & Alcohol Testing"**

Dated the 13th day of June in the year 2018



D.J. Nedelk M.S., President

ARC RANDOLPH & ASSOCIATES, LLC

This is to confirm that:

Greg Hinton

Attended the following workshop provided
for *"Flemingsburg Utilities"*:

**"Removing Potential Ignition Sources" &
"Understanding Post Incident Drug & Alcohol Testing"**

Dated the 13th day of June in the year 2018



D.J. Nedelk M.S., President

ARC RANDOLPH & ASSOCIATES, LLC

This is to confirm that:

Travis Engle

Attended the following workshop provided
for "*Flemingsburg Utilities*":

**"Removing Potential Ignition Sources" &
"Understanding Post Incident Drug & Alcohol Testing"**

Dated the 13th day of June in the year 2018



D.J. Nedelk M.S. President

ARC RANDOLPH & ASSOCIATES, LLC

This is to confirm that:

David Shrout

Attended the following workshop provided
for "*Flemingsburg Utilities*":

**"Removing Potential Ignition Sources" &
"Understanding Post Incident Drug & Alcohol Testing"**

Dated the 13th day of June in the year 2018



D.J. Nedelk M.S., President

ARC RANDOLPH & ASSOCIATES, LLC

This is to confirm that:

Danny Shrout

Attended the following workshop provided
for "*Flemingsburg Utilities*":

**"Removing Potential Ignition Sources" &
"Understanding Post Incident Drug & Alcohol Testing"**

Dated the 13th day of June in the year 2018



D.J. Nedelk M.S., President

ARC RANDOLPH & ASSOCIATES, LLC

This is to confirm that:

Coty Hunt

Attended the following workshop provided
for "*Flemingsburg Utilities*":

**"Removing Potential Ignition Sources" &
"Understanding Post Incident Drug & Alcohol Testing"**

Dated the 13th day of June in the year 2018



D.J. Nedelk M.S., President

ARC RANDOLPH & ASSOCIATES, LLC

This is to confirm that:

Colby McCloud

Attended the following workshop provided
for "*Flemingsburg Utilities*":

**"Removing Potential Ignition Sources" &
"Understanding Post Incident Drug & Alcohol Testing"**

Dated the 13th day of June in the year 2018



D.J. Nedelk M.S., President