

**Goss
Samford**

ATTORNEYS AT LAW | PLLC

David S. Samford
(859) 368-7740
david@gosssamfordlaw.com

October 27, 2017

VIA HAND DELIVERY

Ms. Gwen R. Pinson
Executive Director
Kentucky Public Service Commission
P.O. Box 615
211 Sower Boulevard
Frankfort, KY 40602

RECEIVED

OCT 27 2017

PUBLIC SERVICE
COMMISSION

Re: East Kentucky Power Cooperative, Inc.'s Post-Hearing Data Request;
PSC Case No. 2017-00283

Dear Ms. Pinson:

Please find enclosed for filing with the Commission in the above-referenced case an original and ten copies of the response of East Kentucky Power Cooperative, Inc. ("EKPC"), to the information requests from the hearing held on October 16, 2017.

Please return a file-stamped copy of this filing to my office.

Sincerely,


David S. Samford

Enclosures

RECEIVED

OCT 27 2017

PUBLIC SERVICE
COMMISSION

**COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION**

In the Matter of:

**AN EXAMINATION OF THE APPLICATION OF)
THE FUEL ADJUSTMENT CLAUSE OF EAST)
KENTUCKY POWER COOPERATIVE, INC.)
FROM NOVEMBER 1, 2016 THROUGH APRIL)
30, 2017)**

**CASE NO.
2017-00283**

**RESPONSE OF EAST KENTUCKY POWER COOPERATIVE, INC.
TO COMMISSION'S DATA REQUEST FROM
HEARING HELD ON OCTOBER 16, 2017**

EAST KENTUCKY POWER COOPERATIVE, INC.

PSC CASE NO. 2017-00283

FUEL ADJUSTMENT CLAUSE

RESPONSE TO POST HEARING DATA REQUEST

COMMISSION'S DATA REQUEST FROM HEARING HELD ON 10/16/17

REQUEST 1

RESPONSIBLE PARTY: Craig Johnson

Request 1. Refer to East Kentucky's response to the Commission's August 30, 2017 request for information, Item 7, page 6 of 57. There are various outages labeled "miscellaneous." Provide an explanation of what these outages are.

Response 1. Please refer to page 2 of this response for the explanation of outages previous labeled "miscellaneous".



East Kentucky Power

Production Management Reporting System

Appendix B

From: November 1, 2016 thru April 30, 2017

PSC Request 7

Page 6 of 57

Spurlock Power Station

Unit 003

Date	Time Off/On	Available MW	Forced or Scheduled	Status	Actual		Cause or Reason
					Hours	Minutes	
11/06/2016	0022	0.0	Scheduled	Maintenance	107	38	REPAIR PLANT DRAIN LINE ON UNIT 2.
11/22/2016	0254	0.0	Scheduled	Maintenance	13	51	CONTROL VALVES.
11/23/2016	0011	0.0	Forced	Maintenance	26	50	BYPASS WARM-UP ISOLATION VALVE REPAIR.
12/31/2016	0501	0.0	Scheduled	Maintenance	18	59	BOILER TUBE LEAKS.
01/01/2017	0000	0.0	Forced	Maintenance	41	0	BOILER TUBE LEAKS.
01/02/2017	1700	0.0	Scheduled	Maintenance	70	17	TUBE LEAK IN PLATEN SUPERHEATER.
01/06/2017	1245	0.0	Forced	Failed Start	55	27	TUBE LEAK IN PLATEN SUPERHEATER.
01/10/2017	0505	0.0	Forced	Maintenance	6	32	EXCITER PROBLEMS.
01/10/2017	2211	0.0	Forced	Maintenance	80	59	TUBE LEAK IN PLATEN SUPERHEATER.
01/14/2017	0710	0.0	Scheduled	Maintenance	113	15	TUBE LEAK IN PLATEN SUPERHEATER.
01/20/2017	1232	0.0	Forced	Maintenance	92	58	TUBE LEAK IN PLATEN SUPERHEATER.
01/24/2017	0930	0.0	Scheduled	Maintenance	182	30	TUBE LEAK IN PLATEN SUPERHEATER.
02/01/2017	0000	0.0	Scheduled	Maintenance	19	6	TUBE LEAK IN PLATEN SUPERHEATER.
02/16/2017	1022	0.0	Forced	Maintenance	17	38	MAIN STEAM VALVES.
04/22/2017	0001	0.0	Scheduled	Maintenance	215	59	BOILER INSPECTIONS - SCHEDULED OR ROUTINE.