

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

STUART I. GROSS, SR.	)	
	)	
COMPLAINANT	)	
	)	
V.	)	CASE NO.
	)	2019-00258
	)	
GREEN RIVER VALLEY WATER DISTRICT	)	
	)	
DEFENDANT	)	

ORDER

The Commission finds that no action can be taken upon the formal complaint filed by Stuart I. Gross, Sr. against Green River Valley Water District (Green River Valley District) until the conclusion of Case No. 2020-00026.<sup>1</sup> The instant case involves allegations that water pressure at the Complainant's meter falls below 30 psig.<sup>2</sup> Case No. 2020-00026 involves Green River Valley District's proposed amendment to its tariff allowing it to deviate from 807 KAR 5:066, Section 5(1), which requires a water utility to ensure that the pressure at the customer's service pipe under normal conditions not fall below 30 psig, in low pressure areas. Therefore, the Commission on its own motion, **HEREBY ORDERS** that this case shall be held in abeyance pending a final decision in Case No. 2020-00026.

---

<sup>1</sup> Case No. 2020-00026, *Proposed Filing of Green River Valley Water District to Amend its Tariff* (filed Dec. 11, 2019).

<sup>2</sup> See Complaint at unnumbered page 2 (filed June 11, 2019).

By the Commission

ENTERED  
FEB 12 2020  
KENTUCKY PUBLIC  
SERVICE COMMISSION

ATTEST:



Executive Director

for Kent A. Chandler

Case No. 2019-00258

Stuart I. Gross, Sr.  
3013 Leitchfield Road  
Cecilia, KENTUCKY 42724

\*David Paige  
General Manager  
Green River Valley Water District  
P. O. Box 460  
Horse Cave, KY 42749

\*Green River Valley Water District  
1180 E Main Street  
P. O. Box 460  
Horse Cave, KY 42749