

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

KENTUCKY FRONTIER GAS, LLC

ALLEGED VIOLATION OF UNDERGROUND
FACILITY DAMAGE PREVENTION ACT

)
)
)
)
)
)

CASE NO.
2019-00309

NOTICE OF FILING

Notice is given to all parties that the Gas Excavation Damage Report for Incident 21123 has been filed into the record for this proceeding.



Gwen R. Pinson
Executive Director
Public Service Commission
P.O. Box 615
Frankfort, KY 40602

DATED OCT 31 2019

cc: Parties of Record

Gas Excavation Damage Report

Kentucky Frontier Gas, LLC

Submitted 11/7/2018 Incident ID: 21123

[Set back to Edit](#)

[Staff Edit](#)

[Print](#)

Reported By:

Name:

Heather Music

Phone:

606-886-2431 ext 100

Email:

hmusic@kyfrontiergas.com

Gas Line Incident Occured:

Date:

10/9/2018

Time:

4:30 PM

Details:

Reported Date: 11/7/2018 11:07 AM

Incident Location Address:

Location:

37.63036 -82.71957

Address:

Ky Rt 1428

City:

Allen

State:

KY

County:

Floyd

Zip:

41601

Confirm Code:

Address	City	State
ZipCode	County	State

Number of Customers out: 0

Locate Request Ticket No.: 1810080605

Excavator: Contractor

Organization ID	Company	Status	Company Type
-----------------	---------	--------	--------------

Excavator Address:

First Name:

Ty

Last Name:

Jervis

Organization ID:

Company:

Phone:

304-928-8875

Email:

Address:

145 Whitehouse Hollow

City:

Grayson

State:

Kentucky

Zip:

41143

Confirm Code:

Address	City	State
ZipCode	County	State

Excavation Damage: One Call notification practices not sufficient

Description of Incident While installing a sewer line 2 KFG service lines were hit. Company did called 811 on 10/8/18, but did not give the full 48 hours for line marking.

Summary Information 11/7/2018

Full details such as the cause During construction of a new sewer line project for Prestonsburg City Utilities, we received a report about a gas line break. Upon arrival our field technician discovered that a 1" service line was broken in a small section

	and was repaired. During the repair another service line was broken and was able to be just capped off.
Extent of the damage	Minimal, 1 service line was repaired with 1ft of pipe and fittings, the other one was capped off.
Cost of the damage	\$280.00
Steps taken to prevent re-occurrence	Informed the construction supervisor about new dig law
Amount billed to excavator	\$0.00

CT Corporation System Register Agent
306 W Main Street, Suite 512
Frankfort, KENTUCKY 40601

*Honorable John N Hughes
Attorney at Law
124 West Todd Street
Frankfort, KENTUCKY 40601

*Kentucky Frontier Gas, LLC
4891 Independence Street, Suite 200
Wheat Ridge, CO 80033

*Kentucky Frontier Gas, LLC
Kentucky Frontier Gas, LLC
4891 Independence Street, Suite 200
Wheat Ridge, CO 80033