


COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

CHRIS SAGESER)	
_____)	
ALLEGED VIOLATION OF UNDERGROUND)	CASE NO.
FACILITY DAMAGE PREVENTION ACT)	2019-00333

NOTICE OF FILING

Notice is given to all parties that a Gas Excavation Damage Report for Incident 31359 has been filed into the record of this proceeding.



Gwen R. Pinson
Executive Director
Public Service Commission
P.O. Box 615
Frankfort, KY 40602

DATED NOV 08 2019

cc: Parties of Record

Gas Excavation Damage Report

Louisville Gas and Electric Company

Submitted 3/7/2019 Incident ID: 31359

[Set back to Edit](#)[Staff Edit](#)[Print \(PDFForm.aspx?Rpt=GasInvestigation&IG=31359\)](#)

Reported By:

Name: Mike Jones
Phone: (502) 364-8281
Email: Mike.Jones@lge-KU.com

Gas Line Incident Occured:

Date: 2/10/2019
Time: 5:18 PM

Details:

Reported Date: 3/7/2019 10:14 AM

Incident Location Address:

Location:
Address: 735 Compton St
City: Louisville
State: KY
County: Jefferson
Zip: 40208
Confirm Code: Y
Number of Customers out: 1
Locate Request Ticket No.: n/a
Excavator: Contractor

Excavator Address:

First Name: Chris
Last Name: Sageser
Organization ID:
Company: Chris Sageser
Phone: 502-507-7916
Email:
Address: 4214 Sirate Ln
City: Louisville
State: KY
Zip: 40229

Confirm Code: Y

Excavation Damage: No notification made to the One
Call Center

Description of Incident Excavator hit service while trenching.

Summary Information

3/7/2019

Full details such as the cause	Excavator installing new water service was trenching when they hit the 1/2" plastic gas service.
Extent of the damage	1/2" plastic service
Cost of the damage	\$335.00
Steps taken to prevent re-occurrence	Excavator given brochure to educate on dig law and need to contact 811; letter sent to excavator office.
Amount billed to excavator	\$0.00

Chris Sageser
4214 Sirate Ln.
Louisville, KENTUCKY 40229