

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

UNDERGROUND AMERICA INC)
)
)
)

CASE NO.
2019-00338

ALLEGED VIOLATION OF UNDERGROUND
FACILITY DAMAGE PREVENTION ACT)
)

NOTICE OF FILING

Notice is given to all parties that the Gas Excavation Damage Report for Incident
No. 31318 has been filed into the record of this proceeding.

for 
Gwen R. Pinson
Executive Director
Public Service Commission
P.O. Box 615
Frankfort, KY 40602

DATED JAN 31 2020

cc: Parties of Record

Gas Excavation Damage Report

Louisville Gas and Electric Company

Submitted 2/8/2019 Incident ID: 31318

[Set back to Edit](#)[Staff Edit](#)[Print \(PDFForm.aspx?Rpt=GasInvestigation&IG=31318\)](#)

Reported By:

Name: Mike Jones
Phone: (502) 364-8281
Email: Mike.Jones@lge-KU.com

Gas Line Incident Occured:

Date: 1/10/2019
Time: 1:35 PM

Details:

Reported Date: 2/8/2019 10:03 AM

Incident Location Address:

Location:
Address: 17209 Ash Hill Dr
City: Louisville
State: KY
County: Jefferson
Zip: 40245
Confirm Code: Y
Number of Customers out: 3
Locate Request Ticket No.: 1812270621
Excavator: Contractor

Excavator Address:

First Name: Marten
Last Name: Deleen
Organization ID:
Company: Underground America Inc
Phone: 404-925-4835
Email:
Address: 3111 Moon Station Rd NW Unit B
City: Kennesaw
State: GA
Zip: 30144

Confirm Code: S

Excavation Damage: Other insufficient excavation practices

Description of Incident Excavator damaged 2" plastic main with punch.

Summary Information

2/8/2019

Full details such as the cause	Contractor damaged accurately marked 2" plastic gas main when paralleling the gas main with a punch to install telecom fiber. Contractor did not expose all of main where they were excavating nor did they maintain a safe distance from the gas main.
Extent of the damage	7' of 2" plastic gas main had to be replaced.
Cost of the damage	\$2,082.00
Steps taken to prevent re-occurrence	Instructed excavator to be more mindful of proximity of activity to gas main. Offered to meet with employees to discuss 811 and safe digging practices.
Amount billed to excavator	\$0.00

Michael Tarabula
700 White Road
white, GEORGIA 30184