

FOR Hart, Barren, Larue, Green & Metcalfe
Community, Town or City

P.S.C. KY. NO. 1

Original SHEET NO. 26

Green River Valley Water District
(Name of Utility)

CANCELLING P.S.C. KY. NO. _____

_____ SHEET NO. _____

RATES & CHARGES

AG. Rules and Regulations for Low Pressure Areas

(N)

1. New Customers:

The water district will not set a meter for any new customer where the utility cannot maintain at or above 30 PSI at the water meter. The only exception will be if the prospective customer agrees to install and maintain a pump at their own expense that will provide them with the minimum pressure required by the Public Service Commission (PSC).

2. Existing Customers:

For all customers that had a meter installed by the water district prior to February 1, 2020, where the system pressure was below the required 30 PSI, the water district will install an individual pressure pump and maintain for a period of no more than a year.



DATE OF ISSUE December 18, 2019
Month / Date / Year

DATE EFFECTIVE February 1, 2020
Month / Date / Year

ISSUED BY David Page
(Signature of Officer)

TITLE _____

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION
IN CASE NO. _____ DATED _____

FOR Hart, Barren, Larue, Green & Metcalfe
County, Kentucky

P.S.C. KY. NO. 1

First Revised SHEET NO. 3

CANCELLING P.S.C. KY. NO. 1

Original SHEET NO. 3

Green River Valley Water District
(Name of Utility)

CONTENTS

- Z. Legal Disclaimers
- AA. Fire Departments
- AB. Fire Hydrants
- AC. Not Applicable (T)
- AD. Not Applicable (T)
- AE. Water Main Extensions
- AF. Not Applicable (T)
- AG. Rules and Regulations for Low Pressure Areas (N)

III. ATTACHMENTS

- A. Sample Bill
- B. Water Shortage Plan

DATE OF ISSUE December 18, 2019
Month / Date / Year

DATE EFFECTIVE February 1, 2020
Month / Date / Year

ISSUED BY *David Augs*
(Signature of Officer)

TITLE _____

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION
IN CASE NO. _____ DATED _____