



Andy Beshear
Governor

Kent A. Chandler
Chairman

Rebecca W. Goodman
Secretary
Energy and Environment Cabinet

Commonwealth of Kentucky
**Kentucky State Board on
Electric Generation and
Transmission Siting**
211 Sower Blvd.
P.O. Box 615
Frankfort, Kentucky 40602-0615
Telephone: (502) 564-3940

August 22, 2022

Gregory Dutton
Frost Brown
Todd, LLC
400 W. Market Street
Louisville, KY 40202

RE: Stonefield Solar, LLC
Case No. 2022-00011 - Filing Deficiency

The Siting Board Staff has reviewed the application in the above case. This filing is rejected for the reason set forth below.

Filing deficiency pursuant to:

1. KRS 278.704 (3): Setback requirements; the Hardin County Solar Ordinance was found invalid by Hardin Circuit Court. Therefore, the county setbacks listed in the application are not correct. The setbacks in KRS 278.704(2) apply unless a deviation is requested.

You are requested to submit the information necessary to cure the deficiencies within 10 days of the date of this letter. If you need further assistance, please contact my staff at 502-564-3940.

Sincerely,

Linda C. Bridwell
Executive Director
On behalf of
The Kentucky State Board on Electric
Generation and Transmission Siting

*Gregory T Dutton
Frost Brown Todd, LLC
400 West Market Street
32nd Floor
Louisville, KENTUCKY 40202-3363