

Andy Beshear
Governor

Rebecca W. Goodman
Secretary
Energy and Environment Cabinet



Commonwealth of Kentucky
Public Service Commission

211 Sower Blvd.
P.O. Box 615
Frankfort Kentucky 40602-0615
Telephone: (502) 564-3940
Fax: (502) 564-3460
psc.ky.gov

Kent A. Chandler
Chairman

Mary Pat Regan
Commissioner

October 28, 2022

PARTIES OF RECORD

RE: Case No. **2022-00314**

The Commission staff has reviewed the application in the above case and finds that it meets the minimum filing requirements and has been accepted for filing.

Enclosed please find a stamped filed copy of the first page of your filing. This case has been docketed and will be processed as expeditiously as possible.

If you need further assistance, please contact my staff at 502-564-3940.

Sincerely,

A handwritten signature in blue ink that reads "Linda C. Bridwell".

Linda C. Bridwell
Executive Director

LCB/AH

**COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION**

In the Matter of:

**ELECTRONIC APPLICATION OF EAST)
KENTUCKY POWER COOPERATIVE, INC.)
FOR A (1) CERTIFICATE OF PUBLIC)
CONVENIENCE AND NECESSITY FOR)
THE CONSTRUCTION OF TRANSMISSION)
FACILITIES IN MADISON COUNTY)
KENTUCKY; (2) DECLARATORY ORDER)
CONFIRMING THAT A CERTIFICATE)
OF PUBLIC CONVENIENCE AND)
NECESSITY IS NOT REQUIRED FOR)
CERTAIN FACILITIES)**

**CASE NO.
2022-00314**

APPLICATION

Comes now East Kentucky Power Cooperative, Inc., (“EKPC” or the "Company”) by and through the undersigned counsel, pursuant to KRS 278.020, 807 KAR 5:001, 807 KAR 5:120 and other applicable law, and hereby tenders its Application with the Kentucky Public Service Commission (“Commission”) requesting approval for a Certificate of Public Convenience and Necessity (“CPCN”) to construct a 138 kV transmission line as part of a double circuit transmission line with a 69 kV transmission line rebuild in Madison County, Kentucky. EKPC additionally requests a declaratory order confirming that a CPCN is not required for: (1) the expansion of the EKPC Fawkes substation (“Fawkes Expansion”); (2) construction of the Madison County 69 kV Switching Station near the Duncannon Lane Tap (“Madison County Switching Station”); (3) placement of a 138 kV to 69 kV step-down transformer; and (4) construction of a new substation to serve potential industrial customers (the “New Industrial Substation”).

*L. Allyson Honaker
Honaker Law Office, PLLC
1795 Alysheba Way
Suite 6202
Lexington, KENTUCKY 40509

*Brittany H. Koenig
Honaker Law Office, PLLC
1795 Alysheba Way
Suite 6202
Lexington, KENTUCKY 40509

*Chris Adams
East Kentucky Power Cooperative, Inc.
P. O. Box 707
Winchester, KY 40392-0707

*East Kentucky Power Cooperative, Inc.
4775 Lexington Road
P. O. Box 707
Winchester, KY 40392-0707