

Kentucky Power Company
KPSC Case No. 2025-00027
Commission Staff's First Set of Data Requests
Dated April 14, 2025
Page 1 of 3

DATA REQUEST

KPSC 1_1 Provide a list of all telephone calls, written communications and on-site visits made by Kentucky Power personnel to the Peterman's residence at 51 Woodland Way, Grayson, Kentucky 41143, prior to the September 3, 2024 visit listed in response to the Commission's February 12, 2025 Order. Identify the purpose of each communication, the persons involved and provide a summary as well as all documentation of same.

RESPONSE

Upon receipt of this data request, Kentucky Power examined its records associated with 51 Woodland Way, Grayson, KY 41143, including those associated with the prior customer. Upon examination of those records, Kentucky Power determined that on or around May 13, 2020, Kentucky Power received a report that a camper had driven under the cable tv line running from the primary pole that serves 51 Woodland Way (pole number 38830182D46082). The cable tv line was believed to have been hanging below the required minimum clearance and both the cable tv line and the camper were damaged as a result of the contact. As a result of this incident, Kentucky Power replaced the primary pole and, out of an abundance of caution, raised its existing conductor to provide additional clearance. Upon replacing the pole, Kentucky Power conducted all necessary testing to confirm that its facilities were installed properly and were in proper and safe working order. All of Kentucky Power's tests confirmed that they were. After Kentucky Power replaced the pole and raised its conductor, all of the other service providers likewise re-attached their permitted service lines to the new pole. According to Kentucky Power's records, the other providers with permitted facilities attached to this primary pole are: Windstream Communications and Suddenlink Communications.

KPSC_R_KPSC_1_1_Attachment1 contains the Kentucky Power work order for the new primary pole installation.

KPSC_R_KPSC_1_1_Attachment2 contains a list of all telephone calls and reports of on-site visits made by Kentucky Power personnel to 51 Woodland Way during the time period that the prior customer lived there and took service from Kentucky Power (June 5, 2020 through November 1, 2023) and from the time that the Peterman's lived there and took service from Kentucky Power (beginning November 1, 2023). The attachment also contains a summary of the same. Please also see the After Action Report attached as Exhibit 1 to Kentucky Power's response to the Petermans' formal complaint, filed herein on February 24, 2025.

Kentucky Power Company
KPSC Case No. 2025-00027
Commission Staff's First Set of Data Requests
Dated April 14, 2025
Page 2 of 3

On June 8, 2020, Kentucky Power received a call at its customer service center from the customer living at 51 Woodland Way at that time, who reported being shocked when in their pool. According to Kentucky Power's records, this call is the first report Kentucky Power received concerning potential stray voltage at 51 Woodland Way. Upon receipt of that call, Kentucky Power dispatched a line servicer to 51 Woodland Way, who checked the voltage at the house and added an extra neutral connection at the transformer for extra precaution. All testing showed no issues with Kentucky Power's facilities. The customer indicated they would have an electrician perform testing on the customer's side. Kentucky Power did not receive at its customer service center any additional calls from the prior customer at 51 Woodland Way regarding potential stray voltage or shocking in the pool.

On June 21, 2024, Kentucky Power received a call at its customer service center from Mr. Peterman, who reported feeling a small electrical charge when he touches his pool and concrete at the same time. The same line servicer who visited 51 Woodland Way upon the previous customer's report of potential stray voltage, and who determined after testing that the issue was not coming from Kentucky Power's facilities, again visited the residence, documented Mr. Peterman's issue, and advised Mr. Peterman to contact an electrician.

On August 27, 2024, Kentucky Power received another call from Mr. Peterman, who reported that he had contacted an electrician who found no issues on the customer's side. The same line servicer again performed testing at the Petermans' residence and all testing showed no issues with Kentucky Power's facilities that could be causing potential stray voltage. Regardless, the line servicer indicated that an engineer also would perform additional testing at the Petermans' residence in a few days.

The remaining site visits and testing of Kentucky Power's facilities at 51 Woodland Way beginning September 3, 2024, are detailed in the After Action Report attached as Exhibit 1 to Kentucky Power's response to the Petermans' formal complaint, filed herein on February 24, 2025.

All of the Company's records and testing performed support the Company's initial determination that the stray voltage at 51 Woodland Way is not resulting from Kentucky Power's facilities. Instead, the stray voltage appears to be resulting from the cable tv service. After the incident on or around May 13, 2020 that resulted in damage to the cable tv service line, subsequent replacement of the primary pole, and re-attachment of all permitted pole attachment services, any one of the other service providers, including the cable tv service provider could have installed their facilities improperly resulting in the stray voltage.

Kentucky Power Company
KPSC Case No. 2025-00027
Commission Staff's First Set of Data Requests
Dated April 14, 2025
Page 3 of 3

The Company's testing performed in September 2024, in fact, shows that any stray voltage appears to be resulting from the cable tv service line. (*See* Kentucky Power's Response and Motion to Dismiss at 2-4.) Specifically, during its September 3, 2024 visit to 51 Woodland Way, Kentucky Power performed isolation testing and, while the Kentucky Power facilities were completely disconnected, also disconnected the cable service running from the secondary pole to the residence. After disconnecting the cable service, Kentucky Power took voltage readings in the pool and recorded 0.0 volts at the pool slide, 0.0 volts at the pool ladder, and 0.1 volts in the middle of the pool. Thus, after the cable service was disconnected the voltage readings in the pool went to zero or very near zero. The isolation testing performed by Kentucky Power confirmed that the voltage in the pool was not originating from Kentucky Power facilities. Rather, Kentucky Power believes the voltage to be originating from the cable service. Kentucky Power advised Mr. Peterman of its investigation findings and stated that the identified causes of the voltage in the pool likely were that the cable service ground was not connected properly by the cable service provider at the top of the secondary pole and/or that the in-ground pool may not have been bonded properly at installation, which, if installed properly, would have prevented stray voltage from entering the pool.

Witness: Tanner S. Wolfram

Compatible Units Work Order

Job Information													
Work Order: DKY0109665		Work Request: 74132191											
OPCO: 110 Kentucky Power Company		District: Ashland											
Project No: 000007818 - KP/Small Local Asset Improv		CrewHQ: 10216											
WR Type: DESG		State: KY											
OPS Orders:		Priority: 6											
PPR:		J.U. Proposal: 2019-012-0732											
Other: _____		Related Work Request: 2019-012-0733											
Station Circuit: 3116102 - GRAYSON / DIXIEPARK		Est. Jobsite Hours: 39.49 41.34											
Work Description: A/ ASSET IMPROVEMENT- SMALL LOCAL ASSET IMPROV		URGENT											
Extra Info:													
Special Instructions: Existing 38830182D46082, Replace in line primary poles to raise lines, Truck ok, no flagging set up in driveways, no row, dig required/****A customer drove through this road and the cable tv line damaged their fifth wheel camper in July 2019, customer currently suing windstream over damage issue. We are at our minimum clearance on this road when measured, but just barely. Just a heads up if asked													
Engineered by: Oper ID: S257875		Name: Hatfield, Amber D											
Contractor Information		Inspector Information											
		Operator ID: Name: Physically Inspected: Y / N											
		 74132191											
Customer Information													
Customer Name:		Contact Name: Amber Hatfield											
Work Phone: () -		Phone: (606) 929-1458											
Job Address: 52 Woodland Way		Home Phone: () -											
		Cellular Phone: () -											
Grayson, KY													
Mail Address:													
Customer Ready: Yes No		Line Work Complete: Yes No											
What does customer need to do:		Customer Informed: Yes No											
Cost/Billing Information													
Type of Billing:		Billing Performed by: No Billing											
<input type="checkbox"/> Actual Cost <input type="checkbox"/> Firm Price <input type="checkbox"/> CIAC <input type="checkbox"/> Damage Claim <input type="checkbox"/> CIAC RLX		R/W Cap/O&M:											
		R/W Clearing: No											
Bill to: Name:		Address:											
		City:											
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th>Est Cost</th> <th>Construction</th> <th>Retirement</th> <th>Maintenance</th> <th>Total</th> </tr> <tr> <td>Total amt</td> <td>8135.17</td> <td>1866.62</td> <td>3615.04</td> <td>13616.83</td> </tr> </table>		Est Cost	Construction	Retirement	Maintenance	Total	Total amt	8135.17	1866.62	3615.04	13616.83		
Est Cost	Construction	Retirement	Maintenance	Total									
Total amt	8135.17	1866.62	3615.04	13616.83									
Job Flow		Date	By										
Job Received by Crew:													
Day 1: Field Completion/In-service: 6-1-20													
Day 5: Packet Checked and Complete; Forms attached: Face sheet, job card, sketch, pole sheet, Xfrmr/equipment authorization, R/W agreement, time sheets, etc. 6/2/20 TRC													
Day 7: Received from field: 6/2/20 TRC													
	Date	By	I&M Only										
Day 9: Received by Information			Day 9: Received by Graphics										
Day 14: Received by Graphics			Day 14: Posted by Graphics										
Day 20: Posted by Graphics			Day 20: Posted by Information										

Date: 05/13/2020

DIG SENT 05/13/2020 15:29 2005131711 VJR

Page 1 of 27



A unit of American Electric Power

CREW JOB BRIEFING FORM

DATE:

ORDER #: DKY0109665 / WR#74132191

Overview of job to replace primary poles

Location: 52 Woodland Way City / County: Grayson / Carter Co
Station / Circuit: 3116102-GRAYSON / DIXIEPARK Pole #: 38830182D46082
Time Logged On: Off: NA Dispatcher:

ENERGY SOURCE CONTROLS (Switching & Tagging)

Switch Order #: Hold Order issued by CREW ☐ or DDC ☐ NRO ☐ Grounds Required ☐

Protection Device Discussed: List Pole / Structure:

Protection Device Location / Address:

Check Type: Station Breaker ☐ Recloser ☐ Blade ☐ Fuse ☐ Other ☐

Human Performance:

SAFER Model

Summarize the critical steps

- ☐ De-Energize / Disconnect ☐ Re-Energize / Reconnect
☐ Line of Fire ☐ Felling Trees / Poles
☐ Working with Conductors ☐ Others
☐ Route Selection

Foresee probable & worst case consequences

- ☐ Slips / Trips / Falls ☐ Equip Damage
☐ Crushing Injury ☐ Others
☐ Electrical Flash

Anticipate errors or mistakes. List error traps

- ☐ Fatigue ☐ Task Unfamiliarity
☐ Stress ☐ Incorrect Guidance
☐ Time Pressure ☐ Imprecise Communication
☐ Complacency ☐ Energy Source Controls
☐ Improper LOP's ☐ Others

Evaluate layers of protection needed

- ☐ IPE / PIPE ☐ Observer ☐ Traffic Control
☐ Stretching Completed

Review previous relevant experience

Job	Name					
	Assignment					
	Initial					
Re-brief	Assignment					
Time	Initial					

Hazard recognition discussed:

Voltage being worked: F.R. Calorie Required (circle one) 4 8 12

Class PIPE Required (circle one) 0 2 3 On Ground: 0 2 3 Cover Up Rating: 2 4

Topics To Be Discussed (Check all that apply)

- ☐ Condition of Vehicles / Equip (Including Stability) ☐ Canned Switching ☐ Other Workers / Public in the Area
☐ Work Area Protection ☐ HPI Tools ☐ Condition of Insulated Tools
☐ Utility Locates ☐ Performance Mode ☐ JHA / JIT ☐ Exit Strategy / Emergency Action Plan

Position Review:

Qualified Observer required? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Barricading Required	
(Observer)	(Employee working on)
have discussed cover up requirements for this job as well as the following:	
<input type="checkbox"/> Class of Cover & IPE to be used	<input type="checkbox"/> What order cover-up will be installed (Employee working on)
<input type="checkbox"/> What needs to be covered	<input type="checkbox"/> Hazards associated with completing the work
ANY DEVIATION FROM THE PLAN DISCUSSED WILL RESULT IN STOPPAGE OF THE JOB BY THE OBSERVER !	

(Crew Lead)

(Job Briefing by)

(Field Observation)

Rev: 20200106

Tech ADH

5/13/20 10:37 AM

Page 1 of 2

52754X1214

KENTUCKY POWER 811 DIG NOTICE - ONLINE ENTRY FORM					
Work Done For:		AEP DKY ____ 0109665			
Site Contact:		Amber Hatfield	Amber Hatfield	Mobile: 606-465-5119	
State:	County:	Place/City:		Type of Place:	
KY	Carer	Grayson		Community	
Subdivision:		Lot #:			
N/A					
Address:	Dir Prefix:	Street:	Type:	Dir Suffix:	
	< All >	52 Woodland Way		< All >	
Near Street					
Prefix:	Near Street:		Type:	Suffix:	
< All >	CatTail Court				
Please select an item from the list and/or enter your locate instructions in the Locate Where field:					
< Select ... >					
Locate Where:					
near existing poles 182-6082 and 182-6083 left side of road // 38.33536,-82.92195					
Lon(X):		Lat(Y): (in decimal coordinates)			
38.33536,-82.92195					
How deep will the digging be? (i.e. 1 foot, 5 feet, etc):		7 ft			
Will you be using any explosives or blasting material?		NO			
What type of work is being completed? (i.e. install fence, repair electric, etc)		replace 2 poles			
Ticket Header Information:					
<<< NO AEP UG FACILITIES AT SITE >>>					
AEP #74132191 // DKY0109665 // take us 60 towards grayson, turn right onto plantation drive, turn left onto woodland way // Pole 38830182D46082					
Amber Hatfield		FOREMAN - DON'T FORGET TO SUBMIT YOUR POLE TICKET WITH THE POLE TRACKER APP!			
Rev: 20200106					

CREW JOB BRIEFING FORM

DKY0109665 / WR#74132191

Human Performance Concepts	
Error-Likely Situations - A work situation where there is a greater chance for error when performing a specific action or task due to the presence of error precursors.	
Error Precursors	
1. Overconfidence/complacency	6. Day prior to & first day back after days off
2. Time pressure	7. One half-hour after waking up or having a meal
3. Distractive environment	8. Vague or incorrect guidance
4. Fatigue	9. Imprecise communication
5. Task unfamiliarity	10. Stress
Performance Modes	
Performance Mode frames the individual's competence to perform without unintentional error. Tasks are categorized based on the level of mental processing required.	
Skilled-Based Performance -	Behavior associated with highly practiced actions in a familiar situation usually executed from memory without significant thought.
Rule-Based Performance -	Behavior based on selection of prescribed rules derived from one's recognition of the situation; in the rule based mode, individuals typically rely on written guidance to perform the work activity. Task is performed by using existing procedures, training or experience.
Knowledge-Based Performance -	Behavior based on unfamiliarity. Knowledge-based tasks are those that are new, unfamiliar or unique to the performer. Individuals should utilize HP tools and available resources to eliminate unknowns & shift to the Skill-based or Rule-based mode.
Critical Steps - steps that create a point of no return. Have consequences that are irrecoverable. Categories of critical steps for distribution line work include (but are not limited to): energizing & de-energizing lines, suspended loads, felling poles/trees, handling conductors (including cutting), making connections, pole handling, installing defenses.	
Human Performance Tools	
Task Preview -	Use the SAFER Model to identify the risks associated with the task's critical steps. Summarize the critical steps. Identify the steps that if done incorrectly or not at all, would impact personal or crew safety. Anticipate errors or mistakes. Identify areas where confusion is likely or steps that are easy to skip. Foresee probable and worst-case consequences should an error occur during the performance of the task. Evaluate defenses, barriers, contingencies and level of risk at each critical step to eliminate or reduce the consequences of error. Review previous experiences relevant to the task to ensure critical steps are identified and properly performed.
Self Checking -	Is a tool that helps you to focus on the task at hand by raising the level of individual awareness. Self-checking provides a means to create deliberate thought prior to the performance of a task. Use STAR - Stop-Think-Act-Review.
Stop When Uncertain -	To move from the Knowledge-based mode to either the Skill-based or the Rule-based mode.
Peer Coaching -	The sharing of insights to reinforce positive behaviors and demonstrating concern by providing feedback when behaviors do not meet expectations.

Job	Name				
	Assignment				
	Initial				
Re-brief	Assignment				
Time	Initial				

Reviewed by: _____

Date: _____

DKY0109665 / WR#74132191

52 Woodland Way

Grayson / Carer Co


Rev: 20200106

Tech ADH

5/13/20 10:37 AM


Page 2 of 2

52754X1214



A DDS Worksketch

Date Requested:		Bucket Truck?:	
Date Required: 07/31/2019		Truck to Site?:	
Job Name: A/ ASSET IMPROVEMENT- SMALL LOCAL ASSET IMPROV		4WQ?:	
Location: 52 Woodland Way		County:	
Division: KY	District:	Crew HQ: 10216	Station No.: Circuit No.:
WR#: 74132191	WO#:	Sta/Circuit Name:	Map: KentuckyAEPLogan
JU Proposal(s):		Voltage:	Quadr:
P/W#:		Phases:	
Comments:	Date: 5/13/2020	Print#:	Scale: 1:90
	Drawn By: Amber Hatfield		Page: Page 1 of 1



Point / Material Sheet

District: Ashland
Work Req: 74132191
Project: KP/Small Local Asset Improv
Point: 001.00 Design Note:
ID: 38830182D460

Sub Area:
Work Order: DKY0109665
Pole No: 38830182D46083

The quantity shown for the material item (CID) nos. are the total quantities (CU quantity times material item quantity per CU).
Material item nos. that are marked as consumable are excluded below.

Capital Installs and Removals

Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Asset Ind.	Description
ANC-SHM8-84-D34	1	0	0	0	M	ANC,Sgl Hlx Mach,8in,84in,Db Eye 3/4in
_____ 1 0047051501						ANCHOR, EARTH, SINGLE HELIX, 8 IN, 8000 LB MAX TORQUE,
_____ 1 0047847701						ROD, ANCHOR, DOUBLE EYE NUT, 3/4 IN DIA, 7 FT LG, GALV,
ANC-SHM-8-84-D34	0	1	0	0	M	ANC,Sgl Hlx Mach,8in,84in,Db Eye 3/4in
_____ 1 0047051501						ANCHOR, EARTH, SINGLE HELIX, 8 IN, 8000 LB MAX TORQUE,
_____ 1 0047847701						ROD, ANCHOR, DOUBLE EYE NUT, 3/4 IN DIA, 7 FT LG, GALV,
ARR-10-X	1	0	0	0	M	ARR,10kV,Transformer
_____ 1 0061026000						ARRESTER, ELECTRICAL, 10KV, DISTRIBUTION, MOV, HEAVY, P
ARR-10-X	0	1	0	0	M	ARR,10kV,Transformer
_____ 1 0061026000						ARRESTER, ELECTRICAL, 10KV, DISTRIBUTION, MOV, HEAVY, P
BKT-AC18-F	1	0	0	0	M	BKT,Arrestor/CO 18in (1Ph),Fbrgls
_____ 1 0047342218						BRACKET, CUTOUT/ARRESTER, 18 IN LG X 1-1/2 IN DIA, FIBE
BKT-AC18-F	0	1	0	0	M	BKT,Arrestor/CO 18in (1 Ph),Fbrgls
_____ 1 0047342218						BRACKET, CUTOUT/ARRESTER, 18 IN LG X 1-1/2 IN DIA, FIBE
CNA-TR	4	0	0	0	M	CNA,Transfer Conductor
CNC-NTI-40	0	2	0	0	M	CNC,splice Non-Tension Insul,#1/0-#4/0
CNC-SNB-40	0	1	0	0	M	CNC,Splice Non-Tension Bare,#1/0-#4/0
CND-HLC2	1	0	0	0	M	CND,Hot Line clamp #6-#2
_____ 1 0063056000						CLAMP, HOT LINE, 150AMP, 6-1/0AWG COPPER LINE, 6-1/0A
CND-HLC2	0	1	0	0	M	CND,Hot Line clamp #6-#2
_____ 1 0063056000						CLAMP, HOT LINE, 150AMP, 6-1/0 AWG COPPER LINE, 6-1/0 A
CND-S2O	1	0	0	0	M	CND,Stirrup #2 Open
_____ 1 0063921100						STIRRUP, WIRE, 15 IN, 2AWG SOL CU COND

Labor Adders (Quantity)

CNA-TM	CNA-SWITCH	UCNA-SWITCH	PLA-DLOC	PLA-FLAG	PLA-HDIG	PLA-ROCK	PLA-CUT
Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Description		
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

Date: 05/13/2020

Page 2 of 27

Point / Material Sheet

District: Ashland
Work Req: 74132191
Project: KP/Small Local Asset Improv
Point: 001.00 Design Note:
ID: 38830182D460

Sub Area:
Work Order: DKY0109665
Pole No: 38830182D46083

The quantity shown for the material item (CID) nos. are the total quantities (CU quantity times material item quantity per CU).
Material item nos. that are marked as consumable are excluded below.

Capital Installs and Removals

Assembly Unit/CU Code					Asset	Description
	Inst	Rem	Tran	Aban	Ind.	
CND-S2O	0	1	0	0	M	CND,Stirrup #2 Open
_____ 1 0063921100						STIRRUP, WIRE, 15 IN, 2AWG SOL CU COND
DEG-10-SPA	1	0	0	0	M	DEG,1/0,Slack Span Alum
_____ 1 0063424601						DEADEND, GRIP, SLACK SPAN, #1/0 COND, 0.3650.409 IN DI
DEG-10-SPA	0	1	0	0	M	DEG, 1/0,Slack Span Alum
_____ 1 0063424601						DEADEND, GRIP, SLACK SPAN, #1/0 COND, 0.3650.409 IN DI
EQL-1-4-C-10-S-X	0	1	0	0	M	EQL,1 Ph,#4,CU Sol,1/0,CU Str,Xfr
_____ 8 0055568501						WIRE, COPPER, COVERED, #4 COND, 1/C, SOL SD, F/ PRI RIS
_____ 20 0055653500						WIRE, COPPER, COVERED, #1/0 COND, 1/C, 7 STR MHD, F/ TR
EQL-1-4-C-2-S-X	1	0	0	0	M	EQL,1 Ph,#4,CU Sol,#2,CU Str,Xfr
_____ 8 0055568501						WIRE, COPPER, COVERED, #4 COND, 1/C, SOL SD, F/ PRI RIS
_____ 20 0055602001						WIRE, COPPER, COVERED, #2 COND, 1/C, 7 STR MHD, F/TRAN
GND-CA-4	2	0	0	0	M	GND,Cu Rod Adr,#4
_____ 2 0047858000						ROD, GROUND, 5/8 IN DIA, 8 FT LG, COPPER BONDED, REF 19
_____ 2 0063048300						CLAMP, GROUNDING, ROD, 5/8 IN, COPPER OR STEEL, SQUARE
GND-CA-4	0	2	0	0	M	GND,Cu Rod Adr,#4
_____ 2 0047858000						ROD, GROUND, 5/8 IN DIA, 8 FT LG, COPPER BONDED, REF 19
_____ 2 0063048300						CLAMP, GROUNDING, ROD, 5/8 IN, COPPER OR STEEL, SQUARE
GND-CR-4	1	0	0	0	A	GND,Cu Clad Rod,#4
_____ 1 0047858000						ROD, GROUND, 5/8 IN DIA, 8 FT LG, COPPER BONDED, REF 19
_____ 1 0063048300						CLAMP, GROUNDING, ROD, 5/8 IN, COPPER OR STEEL, SQUARE
GND CR 4	0	1	0	0	A	GND,Cu Clad Rod,#4
_____ 1 0047858000						ROD, GROUND, 5/8 IN DIA, 8 FT LG, COPPER BONDED, REF 19
_____ 1 0063048300						CLAMP, GROUNDING, ROD, 5/8 IN, COPPER OR STEEL, SQUARE
GND-EE-4	1	0	0	0	M	GND,Extend Gnd To Guy/Eq,#4

Labor Adders (Quantity)

CNA-TM	CNA-SWITCH	UCNA-SWITCH	PLA-DLOC	PLA-FLAG	PLA-HDIG	PLA-ROCK	PLA-CUT
Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Description		
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

Date: 05/13/2020

Page 3 of 27

Point / Material Sheet

District: Ashland
Work Req: 74132191
Project: KP/Small Local Asset Improv
Point: 001.00 Design Note:
ID: 38830182D460

Sub Area:
Work Order: DKY0109665
Pole No: 38830182D46083

The quantity shown for the material item (CID) nos. are the total quantities (CU quantity times material item quantity per CU).
Material item nos. that are marked as consumable are excluded below.

Capital Installs and Removals

Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Asset	
					Ind.	Description
GND-EE-4	0	1	0	0	M	GND,Extend Gnd To Guy/Eq,#4
GYD-MPY	1	0	0	0	M	GYD,Marker-Plastic-Yellow
_____ 1 0047816100						PROTECTOR, GUY MARKER, 8 FT, YELLOW POLYETHYLENE, HIGH
GYD-MPY	0	1	0	0	M	GYD,Marker-Plastic-Yellow
_____ 1 0047816100						PROTECTOR, GUY MARKER, 8 FT, YELLOW POLYETHYLENE, HIGH
GYF-38-D-78P-EP	1	0	0	0	M	GYF,3/8,Down,78in Pole mt,EyePlate
_____ 1 0047065200						ATTACHMENT, GUY, EYE, 3/4 & 7/8 IN, 21000 LB MAX RATED,
_____ 1 0049592800						INSULATOR, STRAIN, GUY, 78 IN ROD, 600KV BIL, FIBERGLAS
GYF38-D-78P-EP	0	1	0	0	M	GYF,3/8,Down,78in Pole mt,EyePlate
_____ 1 0047065200						ATTACHMENT, GUY, EYE, 3/4 & 7/8 IN, 21000 LB MAX RATED,
_____ 1 0049592800						INSULATOR, STRAIN, GUY, 78 IN ROD, 600KV BIL, FIBERGLAS
GYW-38	40	0	0	0	M	GYW,3/8 in. EHS (15,400 lbs)
GYW-38	0	40	0	0	M	GYW,3/8 in. EHS (15,400 lbs)
INS-15-P-S	1	0	0	0	M	INS,15kV,Pin,Silicon Polymer
_____ 1 0063459000						INSULATOR, PIN, F NECK, 25KV, GRAY POLYMER, ANSI 55-5,
INS-15-P-S	0	1	0	0	M	INS,15kV,Pin,Silicon Polymer
_____ 1 0063459000						INSULATOR, PIN, F NECK, 25KV, GRAY POLYMER, ANSI 55-5,
PIN-35-PTP	1	0	0	0	M	Pin,35kV,Pole Top
_____ 1 0047758700						PIN, INSULATOR, POLE TOP, 24 IN, 1 IN DIA NYLON THD, GA
PIN-35-PTP	0	1	0	0	M	Pin,35kV,Pole Top
_____ 1 0047758700						PIN, INSULATOR, POLE TOP, 24 IN, 1 IN DIA NYLON THD, GA
PLA-CUT	1	0	0	0	M	PLA,Cut Off Pole Top

Labor Adders (Quantity)

CNA-TM	CNA-SWITCH	UCNA-SWITCH	PLA-DLOC	PLA-FLAG	PLA-HDIG	PLA-ROCK	PLA-CUT
Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Description		
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

Date: 05/13/2020

Page 4 of 27

Point / Material Sheet

District: Ashland
Work Req: 74132191
Project: KP/Small Local Asset Improv
Point: 001.00 Design Note:
ID: 38830182D460

Sub Area:
Work Order: DKY0 109665
Pole No: 38830182D46083

The quantity shown for the material item (CID) nos. are the total quantities (CU quantity times material item quantity per CU).
Material item nos. that are marked as consumable are excluded below.

Capital Installs and Removals

Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Asset Ind.	Description
POL-40-R	0	1	0	0	A	POL, 40ft, Remove
POL-50-2	1	0	0	0	A	Pole, 50ft, Class 2
1 0045550200						POLE, WOOD, 50 FT LG, CLASS 2, PENTA, SOUTHERN YELLOW P
SAA-3-CV	3	0	0	0	M	SAA, 3 inch, Clevis
3 0047523100						CLEVIS, INSULATOR, SECONDARY, GALV STEEL, F/ 3 OR 4 IN
3 0062537000						INSULATOR, SPOOL, 3 IN, GRAY POLYMER, ANSI 53-2
SAA-3-CV	0	3	0	0	M	SAA, 3 inch, Clevis
3 0047523100						CLEVIS, INSULATOR, SECONDARY, GALV STEEL, F/ 3 OR 4 IN
3 0062537000						INSULATOR, SPOOL, 3 IN, GRAY POLYMER, ANSI 53-2
TIE-6-ALH-F	12	0	0	0	M	TIE, 6 AWG, AL Hand Tie, F Neck
TIE-6-ALH-F	0	12	0	0	M	TIE, 6 AWG, AL Hand Tie, F Neck
UCTA-PCEC-S	40	0	0	0	M	UCTA, Plc CbInExstgCdt, Svc
UCTA-PCEC-S	0	40	0	0	M	UCTA, Plc CbInExstgCdt, Svc
UCTA-RPR-S	40	0	0	0	M	UCTA, Rodding and Pulling Rope, Serv
XCO-15-100-7	1	0	0	0	A	XCO, 15kVPolymer, 100 Amp, 7kA
1 0061197000						CUTOUT, FUSE, OPEN, 100AMP, 7KA IC, 15KV, 110KV BIL, PO

Maintenance

Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Asset Ind.	Description
XFR-50-72-120-1B	1	0	0	0	P	XFR, 50KVA, 7.2/12.4kVY, 120/240, 1BG
1 0091501980						TRANSFORMER, 1PH OVERHEAD, 50KVA, 12470GRDY/7200V PRI,

Labor Adders (Quantity)

CNA-TM	CNA-SWITCH	UCNA-SWITCH	PLA-DLOC	PLA-FLAG	PLA-HDIG	PLA-ROCK	PLA-CUT
Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Description		
UCOR-350-A2-56000 60'					350 ft wire		
VERK-600-RD-PC-14-R1	1				Red.		
UTRH-2412-HR2-2	1				Head dig		

Date: 05/13/2020

Page 5 of 27

Point / Material Sheet

District: Ashland
Work Req: 74132191
Project: KP/Small Local Asset Improv
Point: 001.00 **Design Note:**
ID: 38830182D460

Sub Area:
Work Order: DKY0109665
Pole No: 38830182D46083

The quantity shown for the material item (CID) nos. are the total quantities (CU quantity times material item quantity per CU).
Material item nos. that are marked as consumable are excluded below.

Maintenance

Maintenance					Asset	
Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Ind.	Description
XFR-50-72-120-1B	0	1	0	0	P	XFR,50KVA,7.2/12.4kVY,120/240,1BG
1 0091501980						TRANSFORMER, 1PH OVERHEAD, 50KVA, 12470GRDY/7200V PRI,
XFR-50-72-120-1B	0	0	0	1	P	XFR,50KVA,7.2/12.4kVY,120/240,1BG

Labor Adders (Quantity)

CNA-TM	CNA-SWITCH	UCNA-SWITCH	PLA-DLOC	PLA-FLAG	PLA-HDIG	PLA-ROCK	PLA-CUT
Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Description		

Date: 05/13/2020

Page 6 of 27

Point / Material Sheet

District: Ashland
Work Req: 74132191
Project: KP/Small Local Asset Improv
Point: 002.00 Design Note:
ID: 38830182D460

Sub Area:
Work Order: DKY0109665
Pole No: 38830182D46083

The quantity shown for the material item (CID) nos. are the total quantities (CU quantity times material item quantity per CU).
Material item nos. that are marked as consumable are excluded below.

Capital Installs and Removals

Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Asset Ind.	Description
CNA-TR	2	0	0	0	M	CNA, Transfer Conductor
UGND-TAG-S	12	0	0	0	M	UGND, TAG CABLE MARKER (WHITE), Svc
UGND-TAG-S	0	12	0	0	M	UGND, TAG CABLE MARKER (WHITE), Svc
URSG-S-125	2	0	0	0	M	URSG, Service, 1in to 1.25in
2 0050703200						GRIP, CABLE, SUPPORT, 1 TO 1-1/4 IN CABLE, OFFSET EYE,
URSG-S-125	0	2	0	0	M	URSG, Service, 1in to 1.25in
2 0050703200						GRIP, CABLE, SUPPORT, 1 TO 1-1/4 IN CABLE, OFFSET EYE,
URSG-S-CGS1	2	0	0	0	M	URSG, Serv, Cable Grip Support 1grip
2 0047322200						BRACKET, CONDUIT STANDOFF, 7 IN, 6061-T6 ALUM ALLOY, 9-
2 0047391300						CLAMP, AERIAL CABLE, 1/4 IN STR MESSENGER, FIG 8 TYPE
URSG-S-CGS1	0	2	0	0	M	URSG, Serv, Cable Grip Support 1grip
2 0047322200						BRACKET, CONDUIT STANDOFF, 7 IN, 6061-T6 ALUM ALLOY, 9-
2 0047391300						CLAMP, AERIAL CABLE, 1/4 IN STR MESSENGER, FIG 8 TYPE
URSR-3-SSO	2	0	0	0	M	URSR, 3in, Service, Stand Off
8 0047322200						BRACKET, CONDUIT STANDOFF, 7 IN, 6061-T6 ALUM ALLOY, 9-
60 0080492300						CONDUIT, RIGID, 3 IN, SCH 80, HIGH IMPACT PVC, COUPLING
8 0080906300						STRAP, CONDUIT, (2) HOLE, 3 IN CONDUIT, KIT, W/ BOLTS,
URSR-3-SSO	0	2	0	0	M	URSR, 3in, Service, Stand Off
8 0047322200						BRACKET, CONDUIT STANDOFF, 7 IN, 6061-T6 ALUM ALLOY, 9-
60 0080492300						CONDUIT, RIGID, 3 IN, SCH 80, HIGH IMPACT PVC, COUPLING
8 0080906300						STRAP, CONDUIT, (2) HOLE, 3 IN CONDUIT, KIT, W/ BOLTS,
USVC-NTS-40	6	0	0	0	M	USVC, Non Tension Splice, 4/0

Labor Adders (Quantity)

CNA-TM	CNA-SWITCH	UCNA-SWITCH	PLA-DLOC	PLA-FLAG	PLA-HDIG	PLA-ROCK	PLA-CUT
Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Description		

Date: 05/13/2020

Page 7 of 27

Point / Material Sheet

District: Ashland
Work Req: 74132191
Project: KP/Small Local Asset Improv
Point: 002.00 **Design Note:**
ID: 38830182D460

Sub Area:
Work Order: DKY0109665
Pole No: 38830182D46083

The quantity shown for the material item (CID) nos. are the total quantities (CU quantity times material item quantity per CU).
Material item nos. that are marked as consumable are excluded below.

Capital Installs and Removals

Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Asset	Description
					Ind.	
USVC-NTS-40	0	6	0	0	M	USVC, Non Tension Splice, 4/0
USVC-TRM	2	0	0	0	A	USVC, Terminate at Meter (per service)
USVC-TRM	0	2	0	0	A	USVC, Terminate at Meter (per service)

Maintenance

Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Asset	Description
					Ind.	
SVD-3-WEATHERHEAD-PVC _____ 1 0080422800	1	0	0	0	M	SVD, 3" PVC Weatherhead HEAD, SERVICE ENTRANCE, CAP, 3 IN, PVC, SS B/M ITEM #40
SVD-3-WEATHERHEAD-PVC _____ 1 0080422800	0	1	0	0	M	SVD, 3" PVC Weatherhead HEAD, SERVICE ENTRANCE, CAP, 3 IN, PVC, SS B/M ITEM #40

Labor Adders (Quantity)

CNA-TM	CNA-SWITCH	UCNA-SWITCH	PLA-DLOC	PLA-FLAG	PLA-HDIG	PLA-ROCK	PLA-CUT
Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Description		
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

Date: 05/13/2020

Page 8 of 27

Point / Material Sheet

District: Ashland
Work Req: 74132191
Project: KP/Small Local Asset Improv
Point: 003.00 Design Note:
ID: 38830182D460

Sub Area:
Work Order: DKY0109665
Pole No: 38830182D46082

The quantity shown for the material item (CID) nos. are the total quantities (CU quantity times material item quantity per CU).
Material item nos. that are marked as consumable are excluded below.

Capital Installs and Removals

Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Asset Ind.	Description
ANC-SHM8-84-D34	1	0	0	0	M	ANC,Sgl Hlx Mach,8in,84in,Db Eye 3/4in
_____ 1 0047051501						ANCHOR, EARTH, SINGLE HELIX, 8 IN, 8000 LB MAX TORQUE,
_____ 1 0047847701						ROD, ANCHOR, DOUBLE EYE NUT, 3/4 IN DIA, 7 FT LG, GALV,
ANC-SHM-8-84-D34	0	1	0	0	M	ANC,Sgl Hlx Mach,8in,84in,Db Eye 3/4in
_____ 1 0047051501						ANCHOR, EARTH, SINGLE HELIX, 8 IN, 8000 LB MAX TORQUE,
_____ 1 0047847701						ROD, ANCHOR, DOUBLE EYE NUT, 3/4 IN DIA, 7 FT LG, GALV,
ARR-10-X	1	0	0	0	M	ARR,10kV,Transformer
_____ 1 0061026000						ARRESTER, ELECTRICAL, 10KV, DISTRIBUTION, MOV, HEAVY, P
ARR-10-X	0	1	0	0	M	ARR,10kV,Transformer
_____ 1 0061026000						ARRESTER, ELECTRICAL, 10KV, DISTRIBUTION, MOV, HEAVY, P
BKT-AC18-F	1	0	0	0	M	BKT,Arrestor/CO 18in (1Ph),Fbrgls
_____ 1 0047342218						BRACKET, CUTOUT/ARRESTER, 18 IN LG X 1-1/2 IN DIA, FIBE
BKT-AC18-F	0	1	0	0	M	BKT,Arrestor/CO 18in (1 Ph),Fbrgls
_____ 1 0047342218						BRACKET, CUTOUT/ARRESTER, 18 IN LG X 1-1/2 IN DIA, FIBE
CNA-TR	6	0	0	0	M	CNA,Transfer Conductor
CND-HLC2	1	0	0	0	M	CND,Hot Line clamp #6-#2
_____ 1 0063056000						CLAMP, HOT LINE, 150AMP, 6-1/0 AWG COPPER LINE, 6-1/0 A
CND-HLC2	0	1	0	0	M	CND,Hot Line clamp #6-#2
_____ 1 0063056000						CLAMP, HOT LINE, 150AMP, 6-1/0 AWG COPPER LINE, 6-1/0 A
CND-S2O	1	0	0	0	M	CND,Stirrup #2 Open
_____ 1 0063921100						STIRRUP, WIRE, 15 IN, 2 AWG SOL CU COND
CND-S2O	0	1	0	0	M	CND,Stirrup #2 Open
_____ 1 0063921100						STIRRUP, WIRE, 15 IN, 2 AWG SOL CU COND
DEG-10-SNA	2	0	0	0	M	DEG,1/0,Secondary Neutral Al

Labor Adders (Quantity)

CNA-TM	CNA-SWITCH	UCNA-SWITCH	PLA-DLOC	PLA-FLAG	PLA-HDIG	PLA-ROCK	PLA-CUT
Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Description		
_____	_____	_____	_____	_____	_____		
_____	_____	_____	_____	_____	_____		
_____	_____	_____	_____	_____	_____		
_____	_____	_____	_____	_____	_____		

Date: 05/13/2020

Page 9 of 27

Point / Material Sheet

District: Ashland
Work Req: 74132191
Project: KP/Small Local Asset Improv
Point: 003.00 Design Note:
ID: 38830182D460

Sub Area:
Work Order: DKY0109665
Pole No: 38830182D46082

The quantity shown for the material item (CID) nos. are the total quantities (CU quantity times material item quantity per CU).
Material item nos. that are marked as consumable are excluded below.

Capital Installs and Removals

Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Asset	
					Ind.	Description
DEG-10-SNA	0	2	0	0	M	DEG, 1/0, Secondary Neutral Al
EQL-1-4-C-10-S-X	1	0	0	0	M	EQL, 1 Ph, #4, CU Sol, 1/0, CU Str, Xfr
_____ 8 0055568501						WIRE, COPPER, COVERED, #4 COND, 1/C, SOL SD, F/ PRI RIS
_____ 20 0055653500						WIRE, COPPER, COVERED, #1/0 COND, 1/C, 7 STR MHD, F/ TR
EQL-1-4-C-2-S-X	0	1	0	0	M	EQL, 1 Ph, #4, CU Sol, #2, CU Str, Xfr
_____ 8 0055568501						WIRE, COPPER, COVERED, #4 COND, 1/C, SOL SD, F/ PRI RIS
_____ 20 0055602001						WIRE, COPPER, COVERED, #2 COND, 1/C, 7 STR MHD, F/ TRAN
GND-CA-4	1	0	0	0	M	GND, Cu Rod Adr, #4
_____ 1 0047858000						ROD, GROUND, 5/8 IN DIA, 8 FT LG, COPPER BONDED, REF 19
_____ 1 0063048300						CLAMP, GROUNDING, ROD, 5/8 IN, COPPER OR STEEL, SQUARE
GND-CA-4	0	1	0	0	M	GND, Cu Rod Adr, #4
_____ 1 0047858000						ROD, GROUND, 5/8 IN DIA, 8 FT LG, COPPER BONDED, REF 19
_____ 1 0063048300						CLAMP, GROUNDING, ROD, 5/8 IN, COPPER OR STEEL, SQUARE
GND-CR-4	1	0	0	0	A	GND, Cu Clad Rod, #4
_____ 1 0047858000						ROD, GROUND, 5/8 IN DIA, 8 FT LG, COPPER BONDED, REF 19
_____ 1 0063048300						CLAMP, GROUNDING, ROD, 5/8 IN, COPPER OR STEEL, SQUARE
GND-CR-4	0	1	0	0	A	GND, Cu Clad Rod, #4
_____ 1 0047858000						ROD, GROUND, 5/8 IN DIA, 8 FT LG, COPPER BONDED, REF 19
_____ 1 0063048300						CLAMP, GROUNDING, ROD, 5/8 IN, COPPER OR STEEL, SQUARE
GND-EE-4	1	0	0	0	M	GND, Extend Gnd To Guy/Eq, #4
GND-EE-4	0	1	0	0	M	GND, Extend Gnd To Guy/Eq, #4
GYD-MPY	1	0	0	0	M	GYD, Marker-Plastic-Yellow
_____ 1 0047816100						PROTECTOR, GUY MARKER, 8 FT, YELLOW POLYETHYLENE, HIGH

Labor Adders (Quantity)

CNA-TM	CNA-SWITCH	UCNA-SWITCH	PLA-DLOC	PLA-FLAG	PLA-HDIG	PLA-ROCK	PLA-CUT
Assembly Unit/CU Code		Inst	Rem	Tran	Aban	Description	

Date: 05/13/2020

Page 10 of 27

Point / Material Sheet

District: Ashland
Work Req: 74132191
Project: KP/Small Local Asset Improv
Point: 003.00 Design Note:
ID: 38830182D460

Sub Area:
Work Order: DKY0109665
Pole No: 38830182D46082

The quantity shown for the material item (CID) nos. are the total quantities (CU quantity times material item quantity per CU).
Material item nos. that are marked as consumable are excluded below.

Capital Installs and Removals

Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Asset	
					Ind.	Description
GYD-MPY	0	1	0	0	M	GYD,Marker-Plastic-Yellow
_____ 1 0047816100						PROTECTOR, GUY MARKER, 8 FT, YELLOW POLYETHYLENE, HIGH
GYF-38-D-78P-EP	1	0	0	0	M	GYF,3/8,Down,78in Pole mt,EyePlate
_____ 1 0047065200						ATTACHMENT, GUY, EYE, 3/4 & 7/8 IN, 21000 LB MAX RATED,
_____ 1 0049592800						INSULATOR, STRAIN, GUY, 78 IN ROD, 600KV BIL, FIBERGLAS
GYF-38-D-78P-EP	0	1	0	0	M	GYF,3/8,Down,78in Pole mt,EyePlate
_____ 1 0047065200						ATTACHMENT, GUY, EYE, 3/4 & 7/8 IN, 21000 LB MAX RATED,
_____ 1 0049592800						INSULATOR, STRAIN, GUY, 78 IN ROD, 600KV BIL, FIBERGLAS
GYW-38	40	0	0	0	M	GYW,3/8 in. EHS (15,400 lbs)
GYW-38	0	40	0	0	M	GYW,3/8 in. EHS (15,400 lbs)
INS-15-P-S	1	0	0	0	M	INS,15kV,Pin,Silicon Polymer
_____ 1 0063459000						INSULATOR, PIN, F NECK, 25KV, GRAY POLYMER, ANSI55-5,
INS-15-P-S	0	1	0	0	M	INS,15kV,Pin,Silicon Polymer
_____ 1 0063459000						INSULATOR, PIN, F NECK, 25KV, GRAY POLYMER, ANSI55-5,
PIN-35-PTP	1	0	0	0	M	Pin,35kV,Pole Top
_____ 1 0047758700						PIN, INSULATOR, POLE TOP, 24 IN, 1 IN DIA NYLON THD, GA
PIN-35-PTP	0	1	0	0	M	Pin,35kV,Pole Top
_____ 1 0047758700						PIN, INSULATOR, POLE TOP, 24 IN, 1 IN DIA NYLON THD, GA
PLA-CUT	1	0	0	0	M	PLA,Cut Off Pole Top
POL-40-R	0	1	0	0	A	POL,40ft,Remove
POL-45-4	1	0	0	0	A	Pole,45ft,Class 4
_____ 1 0045545400						POLE, WOOD, 45 FT LG, CLASS 4, PENTA, SOUTHERN YELLOW P

Labor Adders (Quantity)

CNA-TM	CNA-SWITCH	UCNA-SWITCH	PLA-DLOC	PLA-FLAG	PLA-HDIG	PLA-ROCK	PLA-CUT
Assembly Unit/CU Code		Inst	Rem	Tran	Aban	Description	
_____		_____	_____	_____	_____	_____	
_____		_____	_____	_____	_____	_____	
_____		_____	_____	_____	_____	_____	
_____		_____	_____	_____	_____	_____	

Date: 05/13/2020

Page 11 of 27

Point / Material Sheet

District: Ashland
Work Req: 74132191
Project: KP/Small Local Asset Improv
Point: 003.00 Design Note:
ID: 38830182D460

Sub Area:
Work Order: DKY0109665
Pole No: 38830182D46082

The quantity shown for the material item (CID) nos. are the total quantities (CU quantity times material item quantity per CU).
Material item nos. that are marked as consumable are excluded below.

Capital Installs and Removals

Assembly Unit/CU Code		Inst	Rem	Tran	Aban	Asset Ind.	Description
SAA-3-CV		3	0	0	0	M	SAA,3 inch,Clevis
_____	3 0047523100						CLEVIS, INSULATOR, SECONDARY, GALV STEEL, F/ 3 OR 4 IN
_____	3 0062537000						INSULATOR, SPOOL, 3 IN, GRAY POLYMER, ANSI 53-2
SAA-3-CV		0	3	0	0	M	SAA,3 inch,Clevis
_____	3 0047523100						CLEVIS, INSULATOR, SECONDARY, GALV STEEL, F/ 3 OR 4 IN
_____	3 0062537000						INSULATOR, SPOOL, 3 IN, GRAY POLYMER, ANSI 53-2
TIE-6-ALH-F		12	0	0	0	M	TIE,6 AWG,AL Hand Tie,F Neck
TIE-6-ALH-F		0	12	0	0	M	TIE,6 AWG,AL Hand Tie,F Neck
UCTA-PCEC-S		40	0	0	0	M	UCTA,Plc CblINExstgCdt,Svc
UCTA-PCEC-S		0	40	0	0	M	UCTA,Plc CblINExstgCdt,Svc
UCTA-RPR-S		40	0	0	0	M	UCTA,Rodding and Pulling Rope,Serv
UGND-TAG-S		6	0	0	0	M	UGND,TAG CABLE MARKER (WHITE),Svc
UGND-TAG-S		0	6	0	0	M	UGND,TAG CABLE MARKER (WHITE),Svc
URSG-S-125		1	0	0	0	M	URSG,Service,1in to 1.25in
_____	1 0050703200						GRIP, CABLE, SUPPORT, 1 TO 1-1/4 IN CABLE, OFFSET EYE,
URSG-S-125		0	1	0	0	M	URSG,Service,1in to 1.25in
_____	1 0050703200						GRIP, CABLE, SUPPORT, 1 TO 1-1/4 IN CABLE, OFFSET EYE,

Labor Adders (Quantity)

CNA-TM	CNA-SWITCH	UCNA-SWITCH	PLA-DLOC	PLA-FLAG	PLA-HDIG	PLA-ROCK	PLA-CUT
Assembly Unit/CU Code		Inst	Rem	Tran	Aban	Description	
_____	_____	_____	_____	_____	_____	_____	
_____	_____	_____	_____	_____	_____	_____	
_____	_____	_____	_____	_____	_____	_____	
_____	_____	_____	_____	_____	_____	_____	

Date: 05/13/2020

Page 12 of 27

Point / Material Sheet

District: Ashland
Work Req: 74132191
Project: KP/Small Local Asset Improv
Point: 003.00 Design Note:
ID: 38830182D460

Sub Area:
Work Order: DKY0109665
Pole No: 38830182D46082

The quantity shown for the material item (CID) nos. are the total quantities (CU quantity times material item quantity per CU).
Material item nos. that are marked as consumable are excluded below.

Capital Installs and Removals

Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Asset		Description
					Ind.		
URSR-3SSO	1	0	0	0	M		URSR,3in,Service,Stand Off
_____ 4 0047322200							BRACKET, CONDUIT STANDOFF, 7 IN, 6061-T6 ALUM ALLOY, 9-
_____ 30 0080492300							CONDUIT, RIGID, 3 IN, SCH 80, HIGH IMPACT PVC, COUPLING
_____ 4 0080906300							STRAP, CONDUIT, (2) HOLE, 3 IN CONDUIT, KIT, W/ BOLTS,
URSR-3-SSO	0	1	0	0	M		URSR,3in,Service,Stand Off
_____ 4 0047322200							BRACKET, CONDUIT STANDOFF, 7 IN, 6061-T6 ALUM ALLOY, 9-
_____ 30 0080492300							CONDUIT, RIGID, 3 IN, SCH 80, HIGH IMPACT PVC, COUPLING
_____ 4 0080906300							STRAP, CONDUIT, (2) HOLE, 3 IN CONDUIT, KIT, W/ BOLTS,
USVC-NTS-40	1	0	0	0	M		USVC, Non Tension Splice,4/0
USVC-NTS-40	0	1	0	0	M		USVC, Non Tension Splice,4/0
USVC-TRM	1	0	0	0	A		USVC,Terminate at Meter (per service)
USVC-TRM	0	1	0	0	A		USVC,Terminate at Meter (per service)
XCO-15-100-7	1	0	0	0	A		XCO,15kVPolymer,100 Amp,7kA
_____ 1 0061197000							CUTOUT, FUSE, OPEN, 100AMP, 7KA IC, 15KV, 110KV BIL, PO
XCO-15-100-7	0	1	0	0	A		XCO,15kVPolymer,100 Amp,7kA
_____ 1 0061197000							CUTOUT, FUSE, OPEN, 100AMP, 7KA IC, 15KV, 110KV BIL, PO

Maintenance

Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Asset		Description
					Ind.		
XFR-25-72-120-1B	0	1	0	0	P		XFR,25KVA,7.2/12.4kVY,120/240,1BG
_____ 1 0091251980							TRANSFORMER, 1PH OVERHEAD, 25KVA, 12470GRDY/7200V PRI,
XFR-37-72-120-1B	1	0	0	0	P		XFR,37.5KVA,7.2/12.4kVY,120/240,1BG
_____ 1 0091371980							TRANSFORMER, 1PH OVERHEAD, 37.5KVA, 12470GRDY/7200V PRI

Labor Adders (Quantity)

CNA-TM	CNA-SWITCH	UCNA-SWITCH	PLA-DLOC	PLA-FLAG	PLA-HDIG	PLA-ROCK	PLA-CUT
Assembly Unit/CU Code	Inst	Rem	Tran	Aban	Description		
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

Date: 05/13/2020

Page 13 of 27

STORMS: Material Requisition Document Material Issues

Document No: **Job Address:** 52 Woodland Way
Work Req.#: 74132191
GIS Circuit Code: 3116102 Grayson, KY
Crew Hq: 10216 **Requested By:**
Project Name: GRAYSON / DIXIEPARK
Storeroom:
Budget ID: 000007818 **Material Needed By:** 00/00/0000
Delivery Instructions: **On:**

Work Order Number: DKY0109665

Material Item	Equipment	Usage	Quantity	Return Qty.	Truck Stock
0045545400		POL	1.00		N
POLE, WOOD, 45 FT LG, CLASS 4, PENTA, SOUTHERN YELLOW P					
0045550200		POL	1.00		N
POLE, WOOD, 50 FT LG, CLASS 2, PENTA, SOUTHERN YELLOW P					
0047051501		POL	2.00		N
ANCHOR, EARTH, SINGLE HELIX, 8 IN, 8000 LB MAX TORQUE,					
0047065200		POL	2.00		N
ATTACHMENT, GUY, EYE, 3/4 & 7/8 IN, 21000 LB MAX RATED,					
0047199400		USVC	4.00		N
BOLT, MACHINE, 1/2 IN DIA, UNC THD, 2-1/2 IN LG, HEX HD					
0047322200		USVC	14.00		N
BRACKET, CONDUIT STANDOFF, 7 IN, 6061-T6 ALUM ALLOY, 9-					
0047342218		POL	2.00		N
BRACKET, CUTOFF/ARRESTER, 18 IN LG X 1-1/2 IN DIA, FIBE					
0047391300		USVC	2.00		N
CLAMP, AERIAL CABLE, 1/4 IN STR MESSENGER, FIG 8 TYPE					
0047523100		POL	6.00		N
CLEVIS, INSULATOR, SECONDARY, GALV STEEL, F/ 3 OR 4 IN					
0047758700		POL	2.00		N
PIN, INSULATOR, POLE TOP, 24 IN, 1 IN DIA NYLON THD, GA					
0047816100		POL	2.00		N
PROTECTOR, GUY MARKER, 8 FT, YELLOW POLYETHYLENE, HIGH					
0047847701		POL	2.00		N
ROD, ANCHOR, DOUBLE EYE NUT, 3/4 IN DIA, 7 FT LG, GALV,					
0047858000		CON	5.00		N
ROD, GROUND, 5/8 IN DIA, 8 FT LG, COPPER BONDED, REF 19					
0047960600		USVC	2.00		N
WASHER, LOCK, SINGLE COIL, 1/2 IN NOM, 11/64 IN THK, GA					
0049592800		POL	2.00		N
INSULATOR, STRAIN, GUY, 78 IN ROD, 600KV BIL, FIBERGLAS					

Date: 05/13/2020

Page 14 of 27

STORMS: Material Requisition Document **Material Issues**

Document No: **Job Address:** 52 Woodland Way
Work Req. #: 74132191
GIS Circuit Code: 3116102 Grayson, KY
Crew Hq: 10216 **Requested By:**
Project Name: GRAYSON / DIXIEPARK
Storeroom:
Budget ID: 000007818 **Material Needed By:** 00/00/0000
Delivery Instructions: **On:**

Work Order Number: DKY0109665

Material Item	Equipment	Usage	Quantity	Return Qty.	Truck Stock
0050703200		USVC	3.00		N
GRIP, CABLE, SUPPORT, 1 TO 1-1/4 IN CABLE, OFFSET EYE,					
0055568501		XFRMD	16.00		N
WIRE, COPPER, COVERED, #4 COND, 1/C, SOL SD, F/ PRI RIS					
0055602001		XFRMD	20.00		N
WIRE, COPPER, COVERED, #2 COND, 1/C, 7 STR MHD, F/ TRAN					
0055653500		XFRMD	20.00		N
WIRE, COPPER, COVERED, #1/0 COND, 1/C, 7 STR MHD, F/ TR					
0061026000		XFRMD	2.00		N
ARRESTER, ELECTRICAL, 10KV, DISTRIBUTION, MOV, HEAVY, P					
0061197000		XFRMD	2.00		N
CUTOUT, FUSE, OPEN, 100AMP, 7KA IC, 15KV, 110KV BIL, PO					
0062537000		POL	6.00		N
INSULATOR, SPOOL, 3 IN, GRAY POLYMER, ANSI 53-2					
0063048300		CON	5.00		N
CLAMP, GROUNDING, ROD, 5/8 IN, COPPER OR STEEL, SQUARE					
0063056000		CON	2.00		N
CLAMP, HOT LINE, 150AMP, 6-1/0 AWG COPPER LINE, 6-1/0 A					
0063424601		CON	1.00		N
DEADEND, GRIP, SLACK SPAN, #1/0 COND, 0.365-0.409 IN DI					
0063459000		CON	2.00		N
INSULATOR, PIN, F NECK, 25KV, GRAY POLYMER, ANSI 55-5,					
0063921100		CON	2.00		N
STIRRUP, WIRE, 15 IN, 2 AWG SOL CU COND					
0064320100		CON	2.00		N
DEADEND, GRIP, #1/0 STR BARE ALUM COND, F/ SERVICE DROP					
0066728000		USVC	18.00		N
TAG, CABLE MARKING, 2 IN X 2-1/2 IN X 0.040 IN THK, ABS					
0080422800		SVC	1.00		N
HEAD, SERVICE ENTRANCE, CAP, 3 IN, PVC, SS B/M ITEM #40					

Date: 05/13/2020

Page 15 o 27

STORMS: Material Requisition Document
Material Issues

Document No: **Job Address:** 52 Woodland Way
Work Req. #: 74132191
GIS Circuit Code: 3116102 Grayson, KY
Crew Hq: 10216 **Requested By:**
Project Name: GRAYSON / DIXIEPARK
Storeroom:
Budget ID: 000007818 **Material Needed By:** 00/00/0000
Delivery Instructions: **On:**

Work Order Number: DKY0109665

Material Item	Equipment	Usage	Quantity	Return Qty.	Truck Stock
0080492300		USVC	90.00		N
CONDUIT, RIGID, 3 IN, SCH 80, HIGH IMPACT PVC, COUPLING					
0080906300		USVC	12.00		N
STRAP, CONDUIT, (2) HOLE, 3 IN CONDUIT, KIT, W/ BOLTS,					
0087071000		POL	10.00		N
BOLT, MACHINE, 5/8 IN DIA, UNC THD, 10 IN LG, GALV, 124					
0087071000		USVC	14.00		N
BOLT, MACHINE, 5/8 IN DIA, UNC THD, 10 IN LG, GALV, 124					
0087071200		POL	2.00		N
BOLT, MACHINE, 5/8 IN DIA, UNC THD, 12 IN LG, GALV, 124					
0087071200		XFRMD	4.00		N
BOLT, MACHINE, 5/8 IN DIA, UNC THD, 12 IN LG, GALV, 124					
0087072414		POL	2.00		N
BOLT, MACHINE, 3/4 IN DIA, UNC THD, 14 IN LG, GALV, 183					
0087124600		POL	2.00		N
SCREW, LAG, 1/2 IN DIA, 4 IN LG, SQUARE HD, PILOT POINT					
0087124600		USVC	14.00		N
SCREW, LAG, 1/2 IN DIA, 4 IN LG, SQUARE HD, PILOT POINT					
0087129510		POL	2.00		N
WASHER, CURVED, SQUARE, 3/4 IN NOM, 13/16 IN ID, 4 IN X					
0087130400		POL	2.00		N
WASHER, LOCK, DOUBLE, 1/2 IN NOM, GALV					
0087130400		USVC	14.00		N
WASHER, LOCK, DOUBLE, 1/2 IN NOM, GALV					
0087130800		POL	12.00		N
WASHER, LOCK, DOUBLE COIL, 5/8 IN NOM, GALV					
0087130800		USVC	14.00		N
WASHER, LOCK, DOUBLE COIL, 5/8 IN NOM, GALV					
0087130800		XFRMD	4.00		N
WASHER, LOCK, DOUBLE COIL, 5/8 IN NOM, GALV					

Date: 05/13/2020

Page 16 of 27

STORMS: Material Requisition Document

Material Issues

Document No: **Job Address:** 52 Woodland Way
Work Req. #: 74132191
GIS Circuit Code: 3116102 Grayson, KY
Crew Hq: 10216 **Requested By:**
Project Name: GRAYSON / DIXIEPARK
Storeroom:
Budget ID: 000007818 **Material Needed By:** 00/00/0000
Delivery Instructions: **On:**

Work Order Number: DKY0109665

Material Item	Equipment	Usage	Quantity	Return Qty.	Truck Stock
0087130805		POL	2.00		N
WASHER, LOCK, DOUBLE, 3/4 IN NOM, GALV					
0087132400		POL	2.00		N
WASHER, FLAT, ROUND, 1/2 IN NOM, 9/16 IN ID, 1-3/8 IN O					
0087132400		USVC	16.00		N
WASHER, FLAT, ROUND, 1/2 IN NOM, 9/16 IN ID, 1-3/8 IN O					
0087134500		POL	12.00		N
WASHER, FLAT, SQUARE, 3/4 IN NOM, 13/16 IN ID, 2-1/4 IN					
0087134500		USVC	14.00		N
WASHER, FLAT, SQUARE, 3/4 IN NOM, 13/16 IN ID, 2-1/4 IN					
0087134500		XFRMD	4.00		N
WASHER, FLAT, SQUARE, 3/4 IN NOM, 13/16 IN ID, 2-1/4 IN					
0087345000		CON	11.00		Y
CONNECTOR, P R I C I N G * O N L Y, #4/O & UNDER RUN, C					
0087345000		POL	2.00		Y
CONNECTOR, P R I C I N G * O N L Y, #4/O & UNDER RUN, C					
0087345000		XFRMD	10.00		Y
CONNECTOR, P R I C I N G * O N L Y, #4/O & UNDER RUN, C					
0087795000		USVC	7.00		Y
SPLICE, P R I C I N G * O N L Y, #4/O & UNDER, NON TENS					
0087829200		CON	74.00		N
STAPLE, GROUND WIRE, 1-1/2 IN LG X 1/4 IN WD X 0.148 IN					
0087842500		CON	24.00		N
WIRE, ALUMINUM, BARE, #6 COND, 1/C, SOL, SD, TIE WIRE,					
0087843600		CON	123.00		N
WIRE, COPPER, BARE, #4 COND, 1/C, SOL, SD, TIE WIRE, MI					
0087860600		POL	80.00		N
WIRE, GUY, 3/8 IN DIA, 7 STR, 15400 LB EXTRA HIGH STREN					
0087860950		POL	4.00		N
DEADEND, GRIP, GUY WIRE, 3/8 IN HS & EHS GALV COND, CLA					

Date: 05/13/2020

Page 17 of 27

STORMS: Material Requisition Document
Material Issues

Document No: **Job Address:** 52 Woodland Way
Work Req. #: 74132191
GIS Circuit Code: 3116102 Grayson, KY
Crew Hq: 10216 **Requested By:**
Project Name: GRAYSON / DIXIEPARK
Storeroom:
Budget ID: 000007818 **Material Needed By:** 00/00/0000
Delivery Instructions: **On:**

Work Order Number: DKY0109665

Material Item	Equipment	Usage	Quantity	Return Qty.	Truck Stock
0087995000		XFRMD	2.00		Y
LINK, FUSE, P R I C I N G * O N L Y, OVERHEAD DISTRIBUT					
0091371980		XFRM	1.00		N
TRANSFORMER, 1PH OVERHEAD, 37.5KVA, 12470GRDY/7200V PRI					
0091501980		XFRM	1.00		N
TRANSFORMER, 1PH OVERHEAD, 50KVA, 12470GRDY/7200V PRI,					

STORMS: Material Requisition Document
Material Returns

Document No: **Job Address:** 52 Woodland Way
Work Req. #: 74132191
GIS Circuit Code: 3116102 Grayson, KY
Crew Hq: 10216 **Requested By:**
Project Name: GRAYSON / DIXIEPARK
Storeroom:
Budget ID: 000007818 **Material Needed By:** 00/00/0000
Delivery Instructions: **On:**

Work Order Number: DKY0109665

Material Item	Equipment	Usage	Quantity	Return Qty.	Truck Stock
0047051501		POL	2.00		N
ANCHOR, EARTH, SINGLE HELIX, 8 IN, 8000 LB MAX TORQUE,					
0047065200		POL	2.00		N
ATTACHMENT, GUY, EYE, 3/4 & 7/8 IN, 21000 LB MAX RATED,					
0047199400		USVC	4.00		N
BOLT, MACHINE, 1/2 IN DIA, UNC THD, 2-1/2 IN LG, HEX HD					
0047322200		USVC	14.00		N
BRACKET, CONDUIT STANDOFF, 7 IN, 6061-T6 ALUM ALLOY, 9-					
0047342218		POL	2.00		N
BRACKET, CUTOFF/ARRESTER, 18 IN LG X 1-1/2 IN DIA, FIBE					
0047391300		USVC	2.00		N
CLAMP, AERIAL CABLE, 1/4 IN STR MESSENGER, FIG 8 TYPE					
0047523100		POL	6.00		N
CLEVIS, INSULATOR, SECONDARY, GALV STEEL, F/3 OR 4 IN					
0047758700		POL	2.00		N
PIN, INSULATOR, POLE TOP, 24 IN, 1 IN DIA NYLON THD, GA					
0047816100		POL	2.00		N
PROTECTOR, GUY MARKER, 8 FT. YELLOW POLYETHYLENE, HIGH					
0047847701		POL	2.00		N
ROD, ANCHOR, DOUBLE EYE NUT, 3/4 IN DIA, 7 FT LG, GALV,					
0047858000		CON	5.00		N
ROD, GROUND, 5/8 IN DIA, 8 FT LG, COPPER BONDED, REF 19					
0047960600		USVC	2.00		N
WASHER, LOCK, SINGLE COIL, 1/2 IN NOM, 11/64 IN THK, GA					
0049592800		POL	2.00		N
INSULATOR, STRAIN, GUY, 78 IN ROD, 600KV BIL, FIBERGLAS					
0050703200		USVC	3.00		N
GRIP, CABLE, SUPPORT, 1 TO 1-1/4 IN CABLE, OFFSET EYE,					
0055568501		XFRMD	16.00		N
WIRE, COPPER, COVERED, #4 COND, 1/C, SOL SD, F/ PRI RIS					

Date: 05/13/2020

Page 19 of 27

STORMS: Material Requisition Document
Material Returns

Document No: **Job Address:** 52 Woodland Way
Work Req. #: 74132191
GIS Circuit Code: 3116102 Grayson, KY
Crew Hq: 10216 **Requested By:**
Project Name: GRAYSON / DIXIEPARK
Storeroom:
Budget ID: 000007818 **Material Needed By:** 00/00/0000
Delivery Instructions: **On:**

Work Order Number: DKY0109665

<u>Material Item</u>	<u>Equipment</u>	<u>Usage</u>	<u>Quantity</u>	<u>Return Qty.</u>	<u>Truck Stock</u>
0055602001		XFRMD	20.00		N
WIRE, COPPER, COVERED, #2 COND, 1/C, 7 STR MHD, F/ TRAN					
0055653500		XFRMD	20.00		N
WIRE, COPPER, COVERED, #1/0 COND, 1/C, 7 STR MHD, F/ TR					
0061026000		XFRMD	2.00		N
ARRESTER, ELECTRICAL, 10KV, DISTRIBUTION, MOV, HEAVY, P					
0061197000		XFRMD	1.00		N
CUTOUT, FUSE, OPEN, 100AMP, 7KA IC, 15KV, 110KV BIL, PO					
0062537000		POL	6.00		N
INSULATOR, SPOOL, 3 IN, GRAY POLYMER, ANSI 53-2					
0063048300		CON	5.00		N
CLAMP, GROUNDING, ROD, 5/8 IN, COPPER OR STEEL, SQUARE					
0063056000		CON	2.00		N
CLAMP, HOT LINE, 150AMP, 6-1/0 AWG COPPER LINE, 6-1/0 A					
0063424601		CON	1.00		N
DEADEND, GRIP, SLACK SPAN, #1/0 COND, 0.365-0.409 IN DI					
0063459000		CON	2.00		N
INSULATOR, PIN, F NECK, 25KV, GRAY POLYMER, ANSI 55-5,					
0063921100		CON	2.00		N
STIRRUP, WIRE, 15 IN, 2 AWG SOL CU COND					
0064320100		CON	2.00		N
DEADEND, GRIP, #1/0 STR BARE ALUM COND, F/ SERVICE DROP					
0066728000		USVC	18.00		N
TAG, CABLE MARKING, 2 IN X 2-1/2 IN X 0.040 IN THK, ABS					
0080422800		SVC	1.00		N
HEAD, SERVICE ENTRANCE, CAP, 3 IN, PVC, SS B/M ITEM #40					
0080492300		USVC	90.00		N
CONDUIT, RIGID, 3 IN, SCH 80, HIGH IMPACT PVC, COUPLING					
0080906300		USVC	12.00		N
STRAP, CONDUIT, (2) HOLE, 3 IN CONDUIT, KIT, W/ BOLTS,					

Date: 05/13/2020

Page 20 of 27

STORMS: Material Requisition Document
Material Returns

Document No: **Job Address:** 52 Woodland Way
Work Req. #: 74132191
GIS Circuit Code: 3116102 Grayson, KY
Crew Hq: 10216 **Requested By:**
Project Name: GRAYSON / DIXIEPARK
Storeroom:
Budget ID: 000007818 **Material Needed By:** 00/00/0000
Delivery Instructions: **On:**

Work Order Number: DKY0109665

<u>Material Item</u>	<u>Equipment</u>	<u>Usage</u>	<u>Quantity</u>	<u>Return Qty.</u>	<u>Truck Stock</u>
0087071000		POL	10.00		N
BOLT, MACHINE, 5/8 IN DIA, UNC THD, 10 IN LG, GALV, 124					
0087071000		USVC	14.00		N
BOLT, MACHINE, 5/8 IN DIA, UNC THD, 10 IN LG, GALV, 124					
0087071200		POL	2.00		N
BOLT, MACHINE, 5/8 IN DIA, UNC THD, 12 IN LG, GALV, 124					
0087071200		XFRMD	4.00		N
BOLT, MACHINE, 5/8 IN DIA, UNC THD, 12 IN LG, GALV, 124					
0087072414		POL	2.00		N
BOLT, MACHINE, 3/4 IN DIA, UNC THD, 14 IN LG, GALV, 183					
0087124600		POL	2.00		N
SCREW, LAG, 1/2 IN DIA, 4 IN LG, SQUARE HD, PILOT POINT					
0087124600		USVC	14.00		N
SCREW, LAG, 1/2 IN DIA, 4 IN LG, SQUARE HD, PILOT POINT					
0087129510		POL	2.00		N
WASHER, CURVED, SQUARE, 3/4 IN NOM, 13/16 IN ID, 4 IN X					
0087130400		POL	2.00		N
WASHER, LOCK, DOUBLE, 1/2 IN NOM, GALV					
0087130400		USVC	14.00		N
WASHER, LOCK, DOUBLE, 1/2 IN NOM, GALV					
0087130800		POL	12.00		N
WASHER, LOCK, DOUBLE COIL, 5/8 IN NOM, GALV					
0087130800		USVC	14.00		N
WASHER, LOCK, DOUBLE COIL, 5/8 IN NOM, GALV					
0087130800		XFRMD	4.00		N
WASHER, LOCK, DOUBLE COIL, 5/8 IN NOM, GALV					
0087130805		POL	2.00		N
WASHER, LOCK, DOUBLE, 3/4 IN NOM, GALV					
0087132400		POL	2.00		N
WASHER, FLAT, ROUND, 1/2 IN NOM, 9/16 IN ID, 1-3/8 IN O					

Date: 05/13/2020

Page 21 of 27

STORMS: Material Requisition Document
Material Returns

Document No: **Job Address:** 52 Woodland Way
Work Req. #: 74132191
GIS Circuit Code: 3116102 Grayson, KY
Crew Hq: 10216 **Requested By:**
Project Name: GRAYSON / DIXIEPARK
Storeroom:
Budget ID: 000007818 **Material Needed By:** 00/00/0000
Delivery Instructions: **On:**

Work Order Number: DKY0109665

<u>Material Item</u>	<u>Equipment</u>	<u>Usage</u>	<u>Quantity</u>	<u>Return Qty.</u>	<u>Truck Stock</u>
0087132400		USVC	16.00		N
WASHER, FLAT, ROUND, 1/2 IN NOM, 9/16 IN ID, 1-3/8 IN O					
0087134500		POL	12.00		N
WASHER, FLAT, SQUARE, 3/4 IN NOM, 13/16 IN ID, 2-1/4 IN					
0087134500		USVC	14.00		N
WASHER, FLAT, SQUARE, 3/4 IN NOM, 13/16 IN ID, 2-1/4 IN					
0087134500		XFRMD	4.00		N
WASHER, FLAT, SQUARE, 3/4 IN NOM, 13/16 IN ID, 2-1/4 IN					
0087345000		CON	12.00		Y
CONNECTOR, P R I C I N G * O N L Y, #4/0 & UNDER RUN, C					
0087345000		POL	2.00		Y
CONNECTOR, P R I C I N G * O N L Y, #4/0 & UNDER RUN, C					
0087345000		XFRMD	10.00		Y
CONNECTOR, P R I C I N G * O N L Y, #4/0 & UNDER RUN, C					
0087795000		CON	2.00		Y
SPLICE, P R I C I N G * O N L Y, #4/0 & UNDER, NON TENS					
0087795000		USVC	7.00		Y
SPLICE, P R I C I N G * O N L Y, #4/0 & UNDER, NON TENS					
0087829200		CON	74.00		N
STAPLE, GROUND WIRE, 1-1/2 IN LG X 1/4 IN WD X 0.148 IN					
0087842500		CON	24.00		N
WIRE, ALUMINUM, BARE, #6 COND, 1/C, SOL, SD, TIE WIRE,					
0087843600		CON	123.00		N
WIRE, COPPER, BARE, #4 COND, 1/C, SOL, SD, TIE WIRE, MI					
0087860600		POL	80.00		N
WIRE, GUY, 3/8 IN DIA, 7 STR, 15400 LB EXTRA HIGH STREN					
0087860950		POL	4.00		N
DEADEND, GRIP, GUY WIRE, 3/8 IN HS & EHS GALV COND, CLA					
0087995000		XFRMD	1.00		Y
LINK, FUSE, P R I C I N G * O N L Y, OVERHEAD DISTRIBUT					

Date: 05/13/2020

Page 22 of 27

STORMS: Material Requisition Document
Material Returns

Document No: **Job Address:** 52 Woodland Way
Work Req.#: 74132191
GIS Circuit Code: 3116102 Grayson, KY
Crew Hq: 10216 **Requested By:**
Project Name: GRAYSON / DIXIEPARK
Storeroom:
Budget ID: 000007818 **Material Needed By:** 00/00/0000
Delivery Instructions: **On:**

Work Order Number: DKY0109665

<u>Material Item</u>	<u>Equipment</u>	<u>Usage</u>	<u>Quantity</u>	<u>Return Qty.</u>	<u>Truck Stock</u>
0091251980		XFRM	1.00		N
TRANSFORMER, 1PH OVERHEAD, 25KVA, 12470GRDY/7200V PRI,					
0091501980		XFRM	1.00		N
TRANSFORMER, 1PH OVERHEAD, 50KVA, 12470GRDY/7200V PRI,					

Equipment Authorization - Transformer

WO NO: DKY0109665 WR NO: 74132191
WORK DESCRIPTION: A/ ASSET IMPROVEMENT- SMALL LOCAL ASSET IMPROV
WORK ORDER DIV: _____ S/R: _____ PRINT NO: _____
ISSUING DIV: _____ S/R: _____
SR EMPL: _____ LINE EMPL: _____ MRNO: _____
TRANSACTION CODE: _____ TANK MOUNTED ARRESTER: { Y / N } INSTALL: ☐ REMOVE: ☒
CID NUMBER: 0091251980 Size: XFR,25KVA,7.2/12.4kVY,120/240,1BG CO Number: _____
MFG CODE: _____ MFG SERIAL NO: _____ PHASE (A B C): _____

POLE NO: 38830182D46082 STATION/CIRCUIT: 3116102
WORK ORDER NO: DKY0109665 CREW HQ: Ashland Const ACTIVITY: _____
PROJECT: _____ AFF.: _____ JUR.: _____
000007818 - KP/Small Local Asset Improv
TRACKING: _____ PRODUCT: _____ EQUIP CLASS: _____ BILL TO: _____
Customer Name: _____ Address: 52 Woodland Way
Grayson,KY

REMARKS: _____

TRANSACTION CODES:	
INSTALL	REMOVE
510 - DAMAGE REPLACEMENT	800 - DAMAGE - LIGHTNING
515 - DEFECTIVE REPLACEMENT	805 - DEFECTIVE - OVERLOAD FAILURE
520 - OTHER ACCIDENT	806 - DEFECTIVE - EQUIPMENT FAILURE
530 - EQUIPMENT TESTING	809 - DAMAGE - VEHICLE ACCIDENT
540 - MAINTENANCE REPLACEMENT	810 - DAMAGE (ALL OTHER)
550 - NEW INSTALLATION	812 - DEFECTIVE (ALL OTHER)
551 - LOAD INCREASE	820 - OTHER
555 - CIRCUIT REBUILD/CONVERSION	830 - EQUIPMENT TESTING
820 - OTHER - COMPANY USE	831 - OH TO UG CONVERSION
	840 - MAINTENANCE REPLACEMENT
	855 - CIRCUIT REBUILD/CONVERSION
	857 - OVERLOAD - ANTICIPATED

PLANNED BY: S257875 - Hatfield,Amber D DATE: 05/13/2020
WORK DONE BY: _____ DATE: _____

Equipment Authorization - Transformer

WO NO: DKY0109665 WR NO: 74132191
WORK DESCRIPTION: A/ ASSET IMPROVEMENT- SMALL LOCAL ASSET IMPROV
WORK ORDER DIV: _____ S/R: _____ PRINT NO: _____
ISSUING DIV: _____ S/R: _____
SR EMPL: _____ LINE EMPL: _____ MRNO: _____
TRANSACTION CODE: _____ TANK MOUNTED ARRESTER: { Y / N } INSTALL: ☒ REMOVE: ☐
CID NUMBER: 0091371980 Size: XFR,37.5KVA,7.2/12.4kVY,120/240,1BG CO Number: _____
MFG CODE: _____ MFG SERIAL NO: _____ PHASE (A B C): _____

POLE NO: 38830182D46082 STATION/CIRCUIT: 3116102
WORK ORDER NO: DKY0109665 CREW HQ: Ashland Const ACTIVITY: _____
PROJECT: _____ AFF.: _____ JUR.: _____
000007818 - KP/Small Local Asset Improv
TRACKING: _____ PRODUCT: _____ EQUIP CLASS: _____ BILL TO: _____
Customer Name: _____ Address: 52 Woodland Way
Grayson,KY

REMARKS: _____

TRANSACTION CODES:	
INSTALL	REMOVE
510 - DAMAGE REPLACEMENT	800 - DAMAGE - LIGHTNING
515 - DEFECTIVE REPLACEMENT	805 - DEFECTIVE - OVERLOAD FAILURE
520 - OTHER ACCIDENT	806 - DEFECTIVE - EQUIPMENT FAILURE
530 - EQUIPMENT TESTING	809 - DAMAGE - VEHICLE ACCIDENT
540 - MAINTENANCE REPLACEMENT	810 - DAMAGE (ALL OTHER)
550 - NEW INSTALLATION	812 - DEFECTIVE (ALL OTHER)
551 - LOAD INCREASE	820 - OTHER
555 - CIRCUIT REBUILD/CONVERSION	830 - EQUIPMENT TESTING
820 - OTHER - COMPANY USE	831 - OH TO UG CONVERSION
	840 - MAINTENANCE REPLACEMENT
	855 - CIRCUIT REBUILD/CONVERSION
	857 - OVERLOAD - ANTICIPATED

PLANNED BY: S257875 - Hatfield,Amber D DATE: 05/13/2020
WORK DONE BY: _____ DATE: _____

Equipment Authorization - Transformer

WO NO: DKY0109665 WR NO: 74132191
WORK DESCRIPTION: A/ ASSET IMPROVEMENT- SMALL LOCAL ASSET IMPROV
WORK ORDER DIV: _____ S/R: _____ PRINT NO: _____
ISSUING DIV: _____ S/R: _____
SR EMPL: _____ LINE EMPL: _____ MRNO: _____
TRANSACTION CODE: _____ TANK MOUNTED ARRESTER: { Y / N } INSTALL: ☒ REMOVE: ☐
CID NUMBER: 0091501980 Size: XFR,50KVA,7.2/12.4kVY,120/240,1BG CO Number: _____
MFG CODE: _____ MFG SERIAL NO: _____ PHASE (A B C): _____

POLE NO: 38830182D46083 STATION/CIRCUIT: 3116102
WORK ORDER NO: DKY0109665 CREW HQ: Ashland Const ACTIVITY: _____
PROJECT: _____ AFF.: _____ JUR.: _____
000007818 - KP/Small Local Asset Improv
TRACKING: _____ PRODUCT: _____ EQUIP CLASS: _____ BILL TO: _____
Customer Name: _____ Address: 52 Woodland Way
Grayson,KY

REMARKS: _____

TRANSACTION CODES:	
INSTALL	REMOVE
510 - DAMAGE REPLACEMENT	800 - DAMAGE - LIGHTNING
515 - DEFECTIVE REPLACEMENT	805 - DEFECTIVE - OVERLOAD FAILURE
520 - OTHER ACCIDENT	806 - DEFECTIVE - EQUIPMENT FAILURE
530 - EQUIPMENT TESTING	809 - DAMAGE - VEHICLE ACCIDENT
540 - MAINTENANCE REPLACEMENT	810 - DAMAGE (ALL OTHER)
550 - NEW INSTALLATION	812 - DEFECTIVE (ALL OTHER)
551 - LOAD INCREASE	820 - OTHER
555 - CIRCUIT REBUILD/CONVERSION	830 - EQUIPMENT TESTING
820 - OTHER - COMPANY USE	831 - OH TO UG CONVERSION
	840 - MAINTENANCE REPLACEMENT
	855 - CIRCUIT REBUILD/CONVERSION
	857 - OVERLOAD - ANTICIPATED

PLANNED BY: S257875 - Hatfield,Amber D DATE: 05/13/2020
WORK DONE BY: _____ DATE: _____

Equipment Authorization - Transformer

WO NO: DKY0109665 WR NO: 74132191
WORK DESCRIPTION: A/ ASSET IMPROVEMENT- SMALL LOCAL ASSET IMPROV
WORK ORDER DIV: _____ S/R: _____ PRINT NO: _____
ISSUING DIV: _____ S/R: _____
SR EMPL: _____ LINE EMPL: _____ MRNO: _____
TRANSACTION CODE: _____ TANK MOUNTED ARRESTER: { Y / N } INSTALL: ☐ REMOVE: ☒
CID NUMBER: 0091501980 Size: XFR,50KVA,7.2/12.4kVY,120/240,1BG CO Number: _____
MFG CODE: _____ MFG SERIAL NO: _____ PHASE (A B C): _____

POLE NO: 38830182D46083 STATION/CIRCUIT: 3116102
WORK ORDER NO: DKY0109665 CREW HQ: Ashland Const ACTIVITY: _____
PROJECT: _____ AFF: _____ JUR.: _____
000007818 - KP/Small Local Asset Improv
TRACKING: _____ PRODUCT: _____ EQUIP CLASS: _____ BILL TO: _____
Customer Name: _____ Address: 52 Woodland Way
Grayson,KY

REMARKS: _____

TRANSACTION CODES:	
INSTALL	REMOVE
510 - DAMAGE REPLACEMENT	800 - DAMAGE - LIGHTNING
515 - DEFECTIVE REPLACEMENT	805 - DEFECTIVE - OVERLOAD FAILURE
520 - OTHER ACCIDENT	806 - DEFECTIVE - EQUIPMENT FAILURE
530 - EQUIPMENT TESTING	809 - DAMAGE - VEHICLE ACCIDENT
540 - MAINTENANCE REPLACEMENT	810 - DAMAGE (ALL OTHER)
550 - NEW INSTALLATION	812 - DEFECTIVE (ALL OTHER)
551 - LOAD INCREASE	820 - OTHER
555 - CIRCUIT REBUILD/CONVERSION	830 - EQUIPMENT TESTING
820 - OTHER - COMPANY USE	831 - OH TO UG CONVERSION
	840 - MAINTENANCE REPLACEMENT
	855 - CIRCUIT REBUILD/CONVERSION
	857 - OVERLOAD - ANTICIPATED

PLANNED BY: S257875 - Hatfield,Amber D DATE: 05/13/2020
WORK DONE BY: _____ DATE: _____

Joint Use and Construction Proposal

From AEP : Kentucky Power Company

AEP Proposal # : 2019-012-0732



To (Company) : Windstream Communications (Alltel)
30001

Exchange Area: _____

Ref. # : 078/74132191

Project Location : Grayson

Area : Carter-KY

County : Carter

AEP District : ASHLAND

WR # : 74132191

WO # : VARIOUS

WO Comp Date :

Address: 52 Woodland Way

Sent/Received Date : 07/31/2019

American Electric Power Company propose the pole work details below as shown on the sketch attached

Grid or Pole #	Foreign Pole #	Address/ New Pole #	Existing Pole			Latitude	Longitude	Proposed Work	Billing To Other Company	Transfer	Rentals	
			Ht. & Class	Year Set	Now joint in record						+	-
AEP Poles												
38830182D46082		Woodland Ave, Grayson	40-5	2000	Y	38.335389	-82.921975	change to 45' 4 Mainline		Yes		
38830182D46083		Woodland Ave, Graysnol	45-5	2000	Y	38.335546	-82.920810	change to 50'2 Mainline		Yes		
Total Billing To Other Company												

Approval to attach will be granted on a conditional basis. All other parties must complete the required work before you attach. Attacher must obtain all permits and easements prior to attaching. Attacher accepts/represents the work and associated costs as described.

Submitted By : Amber Hatfield Phone #: (606)-929-1458 Date: 07/31/2019

Email : adhatfield@aep.com

Approved By : _____ Date : _____ Recapped Date : _____

Completion Notice Sent By : _____ Date : _____

JU Submitted By : _____

Other Co. Dwg. No. : _____

Approved By : _____ Date : _____

Rejected Rsn : _____ Date : _____

Work Completed By : BT Date : 6-1-20

Joint Use and Construction Proposal

From AEP : Kentucky Power Company

AEP Proposal # : 2019-012-0733



To (Company) : Suddenlink Comm. (Cebriidge) KY 3040

Exchange Area: _____

Ref. # : 078/74132191

Project Location : Grayson

Area : Carter-KY

County : Carter

AEP District : ASHLAND

WR # : 74132191

WO # : VARIOUS

WO Comp Date :

Address : 52 Woodland Way

Sent/Received Date : 07/31/2019

American Electric Power Company propose the pole work details below as shown on the sketch attached

Grid or Pole #	Foreign Pole #	Address/ New Pole #	Existing Pole			Latitude	Longitude	Proposed Work	Billing To Other Company	Transfer	Rentals	
			Ht. & Class	Year Set	Now joint in record						+	-
AEP Poles												
38830182D46082		Woodland Way, Grayson	40-5	2000	Y	38.335389	-82.921975	replace with 45' 4 Mainline		Yes		
38830182D46083		Woodland Way, Grayson	45-5	2000	Y	38.335546	-82.920810	replace with 50' 2 Mainline		Yes		
Total Billing To Other Company												

Approval to attach will be granted on a conditional basis. All other parties must complete the required work before you attach. Attacher must obtain all permits and easements prior to attaching. Attacher accepts/represents the work and associated costs as described.

Submitted By : Amber Hatfield Phone #: (606)-929-1458 Date: 07/31/2019

Email : adhatfield@aep.com

Approved By : _____ Date : _____ Recapped Date : _____

Completion Notice Sent By : _____ Date : _____

JU Submitted By : _____

Other Co. Dwg. No. : _____

Approved By : _____ Date : _____

Rejected Rsn : _____ Date : _____

Work Completed By : BT Date : 6-1-20

IRTH One Call

KY State law requires the underground lines to be remarked in 21 days providing the 2 business day notice, IF the project is not complete OR SOONER IF the markings are no longer visible or the work location has changed. Please write down the confirmation number for your records.

NORMAL NOTICE

Ticket : 2005131711 Date: 05/13/2020 Time: 15:29 Oper: VICKIE.BAILEY Chan:000

State: KY Cnty: CARTER City: GRAYSON
Subdivision:

Address : 52
Street : WOODLAND WAY
Cross 1 : CATTAIL CT
Location: NO AEP UNDERGROUND FACILITIES TO LOCATE REPLACING 2 POLES 182-6082 AND 182-6083 LOCATED ON LEFT SIDE OF THE ROAD FROM US RT 60 TOWARDS GRAYSON TURN RIGHT ONTO PLANTATION DRIVE THEN TURN LEFT ON WOODLAND WAY LAT 38.33536 LONG -82.92195 KPC WR 74132191
:
Boundary: n 38.335925 s 38.334814 w -82.922654 e -82.921240

Work type : REPLACING 2 POLES
Done for : AEP DKY 7,8&M 109665
Start date: 05/15/2020 Time: 16:00 Hours notice: 48/48 Priority: NORM
Ug/Oh/Both: U Blasting: NO Emergency: N
Duration : N/A Depth: 7 FEET

Company : AEP - AMERICAN ELECTRIC POWER Type: MEMB
Co addr : 3249 NORTH MAYO TRAIL
City : PIKEVILLE State: KY Zip: 41501
Caller : VICKIE BAILEY Phone: (606) 929-1468
Contact : BOBBY TACKETT Phone:
Mobile : (606) 694-5073
Fax : (606) 929-1446
Email : VJBAILEY@AEP.COM

Remarks : ANY QUESTIONS ABOUT LOCATION CONTACT AMBER HATFIELD 606-465-5119
:

Submitted date: 05/13/2020 Time: 15:29
Members: 0023 0221 0367

Member Name	Facility Types
CITY OF GRAYSON UTILITIES	WATER, SEWER, GAS
KENTUCKY POWER - AEP	ELECTRIC
TIME WARNER CABLE	COMMUNICATIONS

Call Summary - 51 Woodland Way Grayson, KY 41143		
Customer	Call Date	Call Summary
Prior Customer - Service Dates - 6/5/2014-11/1/2023	6/8/2020	Spouse called to report being shocked when in pool. Agent entered trouble ticket. Servicer, Derrick McKinney, checked voltage at house with beast (service conductor tester) and added extra neutral connection for extra precaution at transformer, everything tested good. The customer planned to have an electrician check equipment on their side. Trouble ticket was completed.
	2/24/2023	Spouse called to inquire about balance and advised making payment via website that day.
	6/16/2023	Spouse called to place new install order. Agent transferred the caller to Kentucky Escheduling group. Agent placed order for customer's new address.
	7/26/2023	Spouse called to inquire about appointment with technician for new install order. Agent advised appointment is scheduled for 7/31/2023.
	8/9/2023	Spouse called to inquire on when meter and service would be installed. Agent advised due to weather we were behind on scheduling and that order is scheduled to be worked between 8/14/2023 & 9/1/2023.
	10/19/2023	Spouse called to verify new account number for new address and the new bill amount.
	10/30/2023	Close order placed for 11/1/2023.
Customer	Call Date	Call Summary
Debra Peterman- Service Dates- 11/1/2023-current	10/30/2023	Open order created for Debra Peterman on Kentucky Power website with open start date of 11/1/2023.
	6/21/2024	Larry Peterman reported feeling a small electrical charge when he touches his pool and concrete at the same time. Agent entered a trouble ticket. Servicer, Derrick McKinney, documented customer was having issues with their pool. Advised them to contact an electrician.
	7/12/2024	Larry Peterman called to ask for a record of how many times our servicer had been to the location to investigate the voltage issue because last time the AEP servicer was at the location he advised he has been out multiple times for the same issue and the problem was on the customer's side. Mr Peterman stated previous owners did not disclose any issues prior to sale of the home. Agent advised we cannot disclose the information.
	8/27/2024	Larry Peterman reported he and his family are having issues with feeling electric charge when in swimming pool. He contacted an electrician and no issues found on the customer's side. Customer stated neighbor is having same issues. Trouble ticket entered. Servicer, Derrick McKinney, noted, checked voltage and all tested good. Noted engineering would followup on Thursday.
	8/29/2024	Larry Peterman called to advise we had three field emplooyees at his home which he saw on ring camera, he needed to get in touch with the field employees. Field employees called while he was on the phone with call center agent. Mr. Peterman switched over to talk with field employes.

4/23/25, 4:31 PM

omd.aep.com/Outages/HistoricalOutageLog?submitButton=Detailed Log&hidSelectedJurisdiction=&outage=&selectedJurisdiction=...

[Close this window to return to Outage Summary screen](#)

Outage Log for Area			
from Monday, June 01,2020 to Tuesday, June 02,2020			
Total Outages: 1			
1.			
Location	366 PLANTATION DR, GRAYSON, KY 41143-1757	Extent	Transformer
Outage Date	Monday, June 01,2020 10:12	Outage No	4939431
Est.Date		Restore Date	Monday, June 01,2020 13:45
Stat/Circ	3116102 GRAYSON DIXIEPARK	Crew Supv	Tackett_Bobby_A_3314_PIAS
Max Cust Out	4	Duration mins	165
Customer Mins	660	Iso.Pole #	38830182D46083
Major Cause Category	Distribution Line	Fault Pole	
Cause	SCHEDULED COMPANY	Materials	POLE
Device	TRANSFORMER FUSE		
Dispatched			
Remarks	CREW REPLACING POLE COD-4 ISO TF 38830182D46083 OFF@1100 ON@1345		
Step Date	Customers Duration		

TERS TICKET DETAILS



Company	03	Account		Account Status	A
Name		Phone		Call Back	
Address	51 WOODLAND WAY	Premise	034980115	Life Support	
City	GRAYSON	State	KY	Zip	41143-8135
Station ID/Name	1161 - GRAYSON	Circuit ID/Name	02 - DIXIE PARK	Service Pole	38830182D46121
Tariff	015	RevClass	020	Xfmr Pole	38830182D46083
Meter Code	EA006	Meter Mfg Code	04	Meter No	533124905
Meter Cycle	10	Meter Route	53	Meter Seq	02470

Ticket No 0010274
Prev. Ticket:
Call Taken By BLW - WILLIS,B.L.
Caller
Non CustCall Ind N
Outage No [4979911](#)
OMS AREA 1267
Outage Reported 6/8/2020 11:48:00 AM
Restored 6/8/2020 1:22:00 PM

CALL DETAILS:

Srl	Date	Time	Call Type	Trouble Types
1.	6/8/2020	11:48:00 AM	INITIAL	READ IMPORTANT COMMENTS
2.	6/8/2020	11:51:25 AM	ACKNOWLEDGMNT	
3.	6/8/2020	1:22:00 PM	COMPLETED	
4.	6/9/2020	10:19:21 PM	ARCHIVED	

Trouble Reported: None

Equipment Affected: None

Hazard Situations: None

Remarks: ClosedN.CUST 0 BACK ON 06-08-2020 13:26

Instructions: POLES REPLACED ABOUT 1 WK AGO AND IT KICKED THEIR BREAKER NOW EVER SINCE THEIR POOL IS SHOCKING THEM POOL PEOPLE SAID ALL OK ON POOL END

4/23/25, 4:34 PM

omd.aep.com/Outages/HistoricalOutageLog?submitButton=Detailed Log&hidSelectedJurisdiction=&outage=&selectedJurisdiction=...

[Close this window to return to Outage Summary screen](#)

Outage Log for Area			
from Monday, June 08,2020 to Wednesday, June 10,2020			
Total Outages: 1			
1.			
Location	366 PLANTATION DR, GRAYSON, KY 41143-1757	Extent	Transformer
Outage Date	Monday, June 08,2020 11:48	Outage No	4979911
Est.Date		Restore Date	Monday, June 08,2020 13:26
Stat/Circ	3116102 GRAYSON DIXIEPARK	Crew Supv	McKinney,Derrick_3346_PIAS
Max Cust Out	0	Duration mins	98
Customer Mins	0	Iso.Pole #	38830182D46083
Major Cause Category	No Interruption	Fault Pole	38830182D46083
Cause	NO CUST OUT - OTHER	Materials	NONE
Device	NO INTERRUPTION		
Dispatched			
Remarks	checked voltage at house with beast ,,and added extra neutral connection for extra percaution at xfr,, everything tested good,,customer was gonna get electrician to check,,,complete		
Step Date	Customers Duration		

4/23/25, 4:37 PM omd.aep.com/Outages/HistoricalOutageLog?submitButton=Detailed Log&hidSelectedJurisdiction=&outage=&selectedJurisdiction=...

[Close this window to return to Outage Summary screen](#)

Outage Log for Area
from Monday, February 15,2021 to Monday, February 15,2021

Total Outages: 1

1.

Location	730 N CAROL MALONE BLVD, GRAYSON, KY 41143-1126	Extent	Transformer
Outage Date	Monday, February 15,2021 19:15	Outage No	4123801
Est.Date		Restore Date	Tuesday, February 16,2021 21:43
Stat/Circ	3116102 GRAYSON DIXIEPARK	Crew Supv	
Max Cust Out	0	Duration mins	0
Customer Mins	0	Iso.Pole #	38830182B33012
Major Cause Category	No Interruption	Fault Pole	
Cause	MAP MANIPULATION	Materials	NONE
Device	NO INTERRUPTION		
Dispatched			
Remarks			
Step Date	Customers	Duration	

Outage Log for Area				
from Monday, February 15,2021 to Monday, February 15,2021				
Total Outages: 1				
1.				
Location	LANDSDOWNE AVE - INTERSTATE DR, GRAYSON, KY		Extent	Feeder
Outage Date	Monday, February 15,2021 22:28		Outage No	4075881
Est.Date			Restore Date	Tuesday, February 16,2021 21:45
Stat/Circ	3116102	GRAYSON DIXIEPARK	Crew Supv	
Max Cust Out	610		Duration mins	1397
Customer Mins	852170		Iso.Pole #	3116102
Major Cause Category	Distribution Line		Fault Pole	0
Cause	WEATHER - ICE (1/2 INCH OR > 6 " SNOW)		Materials	NONE
Device	FEEDER BREAKER			
Dispatched				
Remarks	DOL 1091282 // Tripped CB via SCADA @ 2228 2/15/21 // Grayson station outaged at 2157 2/15/21 // taking control of ckt breakers so EKPC can energize Argentum-Leon 69kV line and heat up Grayson station // hazards exist on this ckt // CB will remain open // Station energized At 2058 2/16/21 // after much isolating of hazards, closed CB B @ 2145 //			
Step Date	Customers Duration			

4/23/25, 4:40 PM omd.aep.com/Outages/HistoricalOutageLog?submitButton=Detailed Log&hidSelectedJurisdiction=&outage=&selectedJurisdiction=...

[Close this window to return to Outage Summary screen](#)

Outage Log for Area
from Tuesday, February 16,2021 to Tuesday, February 16,2021

Total Outages: 1

1.			
Location	RIVERWOOD DR - MOCKINGBIRD LN, GRAYSON, KY	Extent	Lateral
Outage Date	Tuesday, February 16,2021 22:36	Outage No	4132971
Est.Date		Restore Date	Wednesday, February 17,2021 17:45
Stat/Circ	3116102 GRAYSON DIXIEPARK	Crew Supv	McKinney,Derrick_7018_PIAS
Max Cust Out	51	Duration mins	1149
Customer Mins	58599	Iso.Pole #	38830182D06016
Major Cause Category	Distribution Line	Fault Pole	38830182D06016
Cause	TREE OUT OF ROW	Materials	CONDUCTOR OVERHEAD
Device	LINE FUSE		
Dispatched			
Remarks	Tree on line that was remove		
Step Date	Customers	Duration	

4/23/25, 4:44 PM omd.aep.com/Outages/HistoricalOutageLog?submitButton=Detailed Log&hidSelectedJurisdiction=&outage=&selectedJurisdiction=...

[Close this window to return to Outage Summary screen](#)

Outage Log for Area
from Sunday, June 25,2023 to Sunday, June 25,2023

Total Outages: 1

1.			
Location	RIVERWOOD DR - MOCKINGBIRD LN, GRAYSON, KY	Extent	Lateral
Outage Date	Sunday, June 25,2023 23:21	Outage No	4321341
Est.Date		Restore Date	Monday, June 26,2023 00:21
Stat/Circ	3116102 GRAYSON DIXIEPARK	Crew Supv	McKinney,Derrick_7018_PIAS
Max Cust Out	51	Duration mins	60
Customer Mins	3060	Iso.Pole #	38830182D06016
Major Cause Category	Distribution Line	Fault Pole	38830182D06056
Cause	TREE OUT OF ROW	Materials	FUSE
Device	LINE FUSE		
Dispatched			
Remarks	line fuse 182-6016 restored @ 00:21 complete		
Step Date	Customers	Duration	

TERS TICKET DETAILS



Company	03	Account	██████████	Account Status	A
Name	██████████	Phone	██████████	Call Back	██████████
Address	51 WOODLAND WAY	Premise	034980115	Life Support	
City	GRAYSON	State	KY	Zip	41143-8135
Station ID/Name	1161 - GRAYSON	Circuit ID/Name	02 - DIXIE PARK	Service Pole	38830182D46121
Tariff	015	RevClass	020	Xfmr Pole	38830182D46083
Meter Code	EA006	Meter Mfg Code	04	Meter No	533124905
Meter Cycle	10	Meter Route	53	Meter Seq	02470

Ticket No 0011596
Prev. Ticket:
Call Taken By LEI - IVEY, L.E.
Caller PETERMAN DEBRA A
Non CustCall Ind N
Outage No [4109311](#)
OMS AREA 1267
Outage Reported 6/21/2024 12:40:00 PM
Restored 6/21/2024 2:04:03 PM

CALL DETAILS:

Srl	Date	Time	Call Type	Trouble Types
1.	6/21/2024	12:40:00 PM	INITIAL	
2.	6/21/2024	12:44:22 PM	ACKNOWLEDGMNT	
3.	6/21/2024	2:04:03 PM	COMPLETED	
4.	6/22/2024	10:45:41 PM	ARCHIVED	

Trouble Reported: Other

Equipment Affected: None

Hazard Situations: None

Remarks: ClosedN.CUST 0 BACK ON 06-21-2024 14:02

Instructions: DID NOT RESET BREAKERS CUST HAS A POOL AND WHEN HE TOUCHES THE CONCRETE AND POOL AT THE SAME TIME HE GET A TINGLING FEELING. OTHER PEOPLE HAS FELT IT AS WELL.

[Close this window to return to Outage Summary screen](#)

Outage Log for Area
from Friday, June 21,2024 to Friday, June 21,2024

Total Outages: 1

1.			
Location	366 PLANTATION DR, GRAYSON, KY 41143-1757		Extent
Outage Date	Friday, June 21,2024	12:44	Outage No 4109311
Est.Date			Restore Date Friday, June 21,2024 14:02
Stat/Circ	3116102	GRAYSON DIXIEPARK	Crew Supv McKinney, Derrick L. (Kyas s2490
Max Cust Out	0		Duration mins 0
Customer Mins	0		Iso.Pole #
Major Cause Category	No Interruption		Fault Pole
Cause	NO CUST OUT - OTHER		Materials NONE
Device	NO INTERRUPTION		
Dispatched			
Remarks	customer is having issues with there pool ,,advised them to call electrician,,complete dlm		
Step Date	Customers Duration		

TERS TICKET DETAILS



Company	03	Account		Account Status	A
Name		Phone		Call Back	
Address	51 WOODLAND WAY	Premise	034980115	Life Support	
City	GRAYSON	State	KY	Zip	41143-8135
Station ID/Name	1161 - GRAYSON	Circuit ID/Name	02 - DIXIE PARK	Service Pole	38830182D46121
Tariff	015	RevClass	020	Xfmr Pole	38830182D46083
Meter Code	EA006	Meter Mfg Code	04	Meter No	533124905
Meter Cycle	10	Meter Route	53	Meter Seq	02470

Ticket No 0015962
Prev. Ticket:
Call Taken By K.R - ROSBOROUGH,K..
Caller LARRY PETERMAN
Non CustCall Ind N
Outage No [4502001](#)
OMS AREA 1267
Outage Reported 8/27/2024 3:16:00 PM
Restored 8/27/2024 4:04:00 PM

CALL DETAILS:

Srl	Date	Time	Call Type	Trouble Types
1.	8/27/2024	3:16:00 PM	INITIAL	READ IMPORTANT COMMENTS
2.	8/27/2024	3:20:41 PM	ACKNOWLEDGMNT	
3.	8/27/2024	4:04:00 PM	COMPLETED	
4.	8/28/2024	10:15:42 PM	ARCHIVED	

Trouble Reported: None

Equipment Affected: None

Hazard Situations: None

Remarks: ClosedN.CUST 0 BACK ON 08-27-2024 16:05

Instructions: CUST HAVING ISSUES WITH AN ELEC CHRG IN SWIMMING POOL. CUST CONTACTED ELECTRICIAN & NO ISSUES FOUND. CUST REPORTED NEIGHBOR IS

HAVING A SIMILIAR ISSUE & BELIEVES THERE IS A STRAY CURRENT & PROB
WITH UNDERGROUND SV

Close

4/23/25, 4:45 PM

omd.aep.com/Outages/HistoricalOutageLog?submitButton=Detailed Log&hidSelectedJurisdiction=&outage=&selectedJurisdiction=...

[Close this window to return to Outage Summary screen](#)

Outage Log for Area			
from Saturday, June 22,2024 to Tuesday, September 03,2024			
Total Outages: 1			
1.			
Location	366 PLANTATION DR, GRAYSON, KY 41143-1757	Extent	Transformer
Outage Date	Tuesday, August 27,2024 15:16	Outage No	4502001
Est.Date		Restore Date	Tuesday, August 27,2024 16:05
Stat/Circ	3116102 GRAYSON DIXIEPARK	Crew Supv	McKinney, Derrick L. (Kyas s2490
Max Cust Out	0	Duration mins	49
Customer Mins	0	Iso.Pole #	38830182D46083
Major Cause Category	No Interruption	Fault Pole	38830182D46083
Cause	POWER QUALITY (FLICKERING, DIM, BRIGHT LIGHTS ETC>)	Materials	NONE
Device Dispatched	NO INTERRUPTION		
Remarks	checked voltage all tested good ,,,engineer is going to come out thursday to follow up ,,complete dlm		
Step Date	Customers Duration		

Kentucky Power Company
KPSC Case No. 2025-00027
Commission Staff's First Set of Data Requests
Dated April 14, 2025

DATA REQUEST

KPSC 1_2 Provide evidence, including information, documentation and metadata that demonstrates that the photograph sent to Kentucky Power personnel on or around September 12, 2024, was taken in February 2024.

RESPONSE

After further investigation, the Company agrees the photograph was taken in September 2024. The Company's initial determination that the photograph was taken in February 2024 was an unintentional error. The Company is filing an amended response contemporaneously with its responses to these data requests to remove that statement.

Witness: Tanner S. Wolfram

Kentucky Power Company
KPSC Case No. 2025-00027
Commission Staff's First Set of Data Requests
Dated April 14, 2025

DATA REQUEST

KPSC 1_3 Provide all documentation, including date stamps, supporting Kentucky Power's claim that they removed the two hot legs and neutral wires leading to the residence at Kentucky Power's pole.

RESPONSE

Please see Exhibit 1 to the Company's Response and Motion to Dismiss for the After Action Report that documents the Company's actions at the customer's property. Further, Company Witnesses Burton, Tolliver, McKinney, and Bowe were all present at the property when the two hot legs and neutral wires were disconnected and affirm that, when disconnected, the Company still identified stray voltage at or near the customer's pool as demonstrated in the Company's Response and Motion to Dismiss.

Witness: Craig A. Bowe
Travis R. Burton
Derrick L. McKinney
Phillip R. Tolliver
Tanner S. Wolfram

Kentucky Power Company
KPSC Case No. 2025-00027
Commission Staff's First Set of Data Requests
Dated April 14, 2025
Page 1 of 2

DATA REQUEST

KPSC 1_4 Describe the size and type of service neutral wire Kentucky Power typically uses to divert voltage at a residence.

RESPONSE

The Company does not use a standard size of neutral wire for residential properties. The size and type of neutral wire used in residential electrical systems are critical components that ensure safety and efficiency, and sizing is fundamentally based on the expected electrical load at a given residence, taking into account several key factors.

1. Expected Load:

- **Load Calculation:** The anticipated load is calculated based on the total wattage of all electrical appliances, lighting, heating, and other systems that will be used in the home. This includes factors such as:
 - **Major Appliances:** Refrigerators, HVAC systems, water heaters, etc.
 - **Lighting:** Total wattage of light fixtures.
 - **Additional Loads:** Electronic devices, home entertainment systems, and any other electrical equipment.

2. NESC Code Compliance:

- **National Electrical Safety Code (NESC):** Sizing of the neutral wire is performed in accordance with the standards set forth by the NESC. This code provides guidelines that ensure:
 - **Safety:** Proper sizing helps to prevent overheating and potential electrical hazards.
 - **Efficiency:** Adequate wire sizing minimizes voltage drop, ensuring that appliances receive the necessary voltage for optimal performance.

3. Service Wire Sizing:

- **Methodology:** Once the expected load is determined, the service wire, including the neutral wire, is sized appropriately. This sizing process involves:
 - **Determining the Service Rating:** Based on the calculated load, the appropriate service rating (e.g., 100 amp or 200 amp) is selected.
 - **Selecting Wire Gauge:** The wire gauge is chosen based on the load requirements and the NESC guidelines, ensuring that the wire can handle the expected current without exceeding its capacity.

In summary, the size and type of neutral wire used in residential services are directly influenced by the expected electrical load and must comply with the NESC code. This systematic approach ensures both safety and efficiency in electrical installations, providing reliable service to residential properties. Proper sizing not only protects against electrical hazards but also enhances the overall performance of the electrical system.

When designing electrical systems, it is essential to thoroughly consider the type of property, anticipated electrical load, and compliance with applicable codes to determine the suitable size and type of neutral wiring. Our standard practice is to size services based on expected load requirements and the other above factors. In this instance, the customer is appropriately sized according to NEC standards for a 200-amp load.

Witness: Craig A. Bowe

Kentucky Power Company
KPSC Case No. 2025-00027
Commission Staff's First Set of Data Requests
Dated April 14, 2025
Page 1 of 3

DATA REQUEST

KPSC 1_5 Explain whether the size and type of service neutral wiring change depending on the type of property served or the amount of electricity used.

RESPONSE

Yes, the size and type of service neutral wiring can vary depending on the type of property served and the amount of electricity used. Below is a breakdown of the factors that influence these decisions:

1. Type of Property:

- **Residential vs. Commercial:** Residential properties typically use smaller gauge wires compared to commercial properties, which may require larger gauges due to higher power demands.
- **Industrial Facilities:** These often have specialized wiring needs, including heavier gauge wires and specific materials to handle substantial electrical loads.

2. Amount of Electricity Used:

- **Load Calculation:** The total load of the property, determined by the appliances and equipment used, influences the size of the neutral wire. Higher loads require larger neutral wires to safely carry the return current.
- **Diversity Factor:** In commercial settings, the diversity factor (the likelihood that all devices will not be used simultaneously) can also affect wire sizing.

3. Code Compliance:

- **National Electrical Code (NEC):** Compliance with NEC guidelines is essential. The NEC specifies minimum wire sizes based on the expected load and type of service, which must be adhered to for safety.
 - According to NEC (2008) 220.61B, the sizing of the neutral for a dwelling can be based on a 70% loading. For a single-family residence with a 200-amp service, this results in a calculated neutral load of 140 amps ($200 * 0.70$). The existing 2/0 underground neutral is sufficient to handle this load. 2/0 aluminum conductor is capable of carrying over 191 amps of current.

Kentucky Power Company
KPSC Case No. 2025-00027
Commission Staff's First Set of Data Requests
Dated April 14, 2025
Page 2 of 3

- If the customer asserts that their expected load exceeds the 200-amp capacity, such as with a 400-amp panel, it is crucial to highlight that the main conductor (4/0 aluminum with 2/0 neutral) currently supplying their residence would be inadequate, as it is only capable of delivering a maximum of 289 amps. Any loading beyond 289 amps would have resulted in the overheating and failure of the conductor at this time. The service is sized in accordance with NEC (2008) 310.15(B) based on a 200-amp service which calls for installing 4/0 conductor.
- Should the customer persist in claiming that their dwelling can accommodate a higher load and needs to be sized as such, it will be necessary to transition them to a different tariff structure and apply the appropriate charges based on their possible demand.

4. Configuration:

- **Single-phase vs. Three-phase:** The configuration of the electrical service can also determine the type and size of neutral wiring. Three-phase systems may require different sizing considerations than single-phase systems.

In conclusion, when designing electrical systems, it is essential to thoroughly consider the type of property, anticipated electrical load, and compliance with applicable codes to determine the suitable size and type of neutral wiring. Our standard practice is to size services based on expected load requirements and the other above factors. In this instance, the customer is appropriately sized according to NEC standards for a 200-amp load.

Please see KPCO_R_KPSC_1_5_Attachment1, which provides a screenshot of the September 26, 2024 voltage recording from the Petermans' residence.¹ As explained in the attachment, the voltage recording shows that the neutral wire is properly sized for the Petermans' residence. The screenshot is a representative reading from time period that the voltage recorder was installed, and throughout the duration of the recording, there were no issues shown.

¹ The voltage recorder was installed on September 24, 2024 and removed on September 27, 2024.

Kentucky Power Company
KPSC Case No. 2025-00027
Commission Staff's First Set of Data Requests
Dated April 14, 2025
Page 3 of 3

It is crucial to emphasize that the customer and the Commission should also strongly consider the bonding of the pool. The primary concern is the safety of the customer. After thorough testing, the Company has established that the issue does not originate from the Company's equipment. Regardless, upon information and belief, the pool was not properly bonded, which would insulate the pool water from the stray electric voltage complained of. Therefore, regardless of where the voltage results from, if the pool had been properly bonded and installed, the voltage would not be present in the pool.


Should Kentucky Power increase the conductor size to accommodate the customer's request, it may actually create a lesser path of resistance, depending on the source of the stray voltage.

Our foremost priority must remain the safety of the customer, which, in their best interest, involves:

1. Properly bonding the pool.
2. Identifying and eliminating the source of the stray voltage. The Company's thorough testing has eliminated its facilities as a potential source of the stray voltage. Additional testing of other service providers' facilities may identify the source of the stray voltage.

Moreover, it may also be the case that addressing the source of the stray voltage may mitigate its immediate effects but may not guarantee that the stray voltage will not reemerge from another source in the future. Therefore, properly bonding the pool represents the safest and most prudent strategy for the customer, both now and in the long term.

Witness: Craig A. Bowe



The left y-axis presents voltage readings, while the right y-axis reflects current measurements in amps. Voltage levels consistently remain within tariff guidelines, which range between 126V to 114V. Should a neutral issue exist, a decrease in voltage on channel 1 (V) would typically correlate with an increase on channel 2 (V). Voltage dips that do not coincide with a corresponding spike in amps may be attributed to the operation of neighboring equipment. In contrast, voltage fluctuations that occur simultaneously are likely a result of the customer's equipment cycling on and off. Overall, the recorder does not reveal any issues. However, it is important to highlight that the recorder is unable to detect stray voltage or ascertain its source.

Kentucky Power Company
KPSC Case No. 2025-00027
Commission Staff's First Set of Data Requests
Dated April 14, 2025

DATA REQUEST

KPSC 1_6 Refer to Kentucky Power's tariff sheets P.S.C. Ky. No. 13 Original Sheet 2-5 to 2-7. Confirm that even though customer has offered to pay for replacement of the ground wire as if installing for new construction, Kentucky Power is refusing to replace the ground wires. If confirmed, provide the tariff provision allowing Kentucky Power to decline to replace the ground wire.

RESPONSE

The Company confirms that the customer did offer to pay for replacement of the ground wire that is currently serving their property. The Company is not refusing to replace the underground service; however, the Company did advise the customer that replacing the underground would not address the customer's issue based on its investigation and, as such, initially denied the request in favor of identifying the cause of the stray voltage so the customer did not incur additional costs without addressing the root cause of the stray voltage. As explained in the Company's response to KPSC 1-5, there is a potential that increasing the size of the neutral could create a lesser path of resistance to the customer's metering point.

That said, the Company is willing to replace the underground service at the customer's cost and the understanding that the replacement will likely not address the customer's concern and is not recommended. Specifically, the assessment of the current Underground ("UG") service indicates that there are no issues, indicating that any proposed replacement would likely be an unnecessary expense. The findings from the Kentucky Power investigation by the district engineer confirm replacement would not address Mr. Peterman's concerns.

Witness: Tanner S. Wolfram

VERIFICATION

The undersigned, Craig A. Bowe, being duly sworn, deposes and says he is an Engineer for Kentucky Power, that he has personal knowledge of the matters set forth in the foregoing responses and the information contained therein is true and correct to the best of his information, knowledge, and belief.




Craig A. Bowe

Commonwealth of Kentucky)
)
County of Boyd)


Case No. 2025-00027

Subscribed and sworn to before me, a Notary Public in and before said County and State, by Craig A. Bowe, on April 25, 2025.


Notary Public

My Commission Expires May 5, 2027

Notary ID Number KYNP71841



VERIFICATION

The undersigned, Travis R. Burton, being duly sworn, deposes and says he is the Meter Electrician Supervisor for Kentucky Power, that he has personal knowledge of the matters set forth in the foregoing responses and the information contained therein is true and correct to the best of his information, knowledge, and belief.




Travis R. Burton

Commonwealth of Kentucky)
County of Boyd)


Case No. 2025-00027

Subscribed and sworn to before me, a Notary Public in and before said County and State, by Travis R. Burton, on April 21, 2025.


Notary Public


My Commission Expires May 5, 2027

Notary ID Number KYNP71841



VERIFICATION


The undersigned, Derrick L. McKinney, being duly sworn, deposes and says he is the Line Servicer for Kentucky Power, that he has personal knowledge of the matters set forth in the foregoing responses and the information contained therein is true and correct to the best of his information, knowledge, and belief.


Derrick L. McKinney

Commonwealth of Kentucky)
County of Boyd)


Case No. 2025-00027

Subscribed and sworn to before me, a Notary Public in and before said County and State, by Derrick L. McKinney, on April 28, 2025.


Notary Public

My Commission Expires May 5, 2027

Notary ID Number KYNP71841



VERIFICATION

The undersigned, Phillip R. Tolliver, being duly sworn, deposes and says he is the Manager of Distribution System Design and Scheduling for Kentucky Power, that he has personal knowledge of the matters set forth in the foregoing responses and the information contained therein is true and correct to the best of his information, knowledge, and belief.




Phillip R. Tolliver


Commonwealth of Kentucky)
)
County of Boyd)

Case No. 2025-00027

Subscribed and sworn to before me, a Notary Public in and before said County
and State, by Phillip R. Tolliver, on April 29, 2025.



Marilyn Michelle Caldwell
Notary Public



My Commission Expires May 5, 2027

Notary ID Number KYNP71841

VERIFICATION


The undersigned, Tanner S. Wolffram, being duly sworn, deposes and says he is the Director of Regulatory Services for Kentucky Power, that he has personal knowledge of the matters set forth in the foregoing responses and the information contained therein is true and correct to the best of his information, knowledge, and belief.



Tanner S. Wolffram

Commonwealth of Kentucky)
County of Boyd)

Case No. 2025-00027

Subscribed and sworn to before me, a Notary Public in and before said County and State, by Tanner S. Wolffram, on April 29, 2025.


Notary Public



My Commission Expires May 5, 2027

Notary ID Number KYNP71841