



115 Jackson Energy Lane
McKee, Kentucky 40447
Telephone (606) 364-1000 • Fax (606) 364-1007

RECEIVED

APR 07 2026

**PUBLIC SERVICE
COMMISSION**

April 7, 2026

Linda C. Bridwell
Kentucky Public Service Commission
211 Sower Boulevard
Frankfort, KY 40602

RE: Case No. 2026-00028 – David Ethington V. Jackson Energy Cooperative Corporation

Ms. Bridwell,

Please find below the meter test results for Mr. David Ethington, as requested by the member.

Meter #66978801 was removed on November 6, 2025, for testing. The results are as follows:

- FL: 99.926
- LL: 99.962
- PF: 99.901
- WA: 99.94

Amperage was also checked on site. At the time, the load was high, with the dryer pulling over 26 amps.

Meter Test Result: PASSED

A new combo meter was installed on the trailer after the original meter was removed for testing.

If you require any additional information, please feel free to contact our office.

Sincerely,

A handwritten signature in black ink that reads "April Renner".

April Renner
Vice President of Corporate Services