



RECEIVED

APR 29 2026

PUBLIC SERVICE  
COMMISSION

April 28, 2026

Ms, Linda Bridwell, Executive Director  
Kentucky Public Service Commission  
211 Sower Boulevard  
Frankfort, KY 40601

RE: Sample Meter Test Plan – Annual Report  
Case No. 2004-00121

Dear Ms. Bridwell:

Atmos Energy Corporation (Company) herewith submits its 2025 annual report for the Sample Meter Testing Program to be in compliance with the Commission's Order in the above referenced case.

Please contact myself at 270.685.8024 or Jimmy Cates at 615.330.7368 if the Commission or Staff has any questions regarding the enclosed report.

Sincerely,

A handwritten signature in blue ink that reads "Mark A. Martin".

Mark A. Martin  
Vice President, Rates & Regulatory Affairs

cc: Joel Grugin  
Ryan Austin  
Jimmy Cates

Enclosures



April 25, 2026

ATMOS ENERGY KENTUCKY DIVISION  
2025 METER SAMPLING ANNUAL REPORT

Atmos Energy's Kentucky Division completed the 25<sup>th</sup> year of its statistical sampling of their meter population with the following results:

A total of 4058 meters were sampled, as set forth in the Kentucky Public Service Commission's Order (Case Number 99-059), dated August 24, 1999.

The meter sampling program continues to be excellent for both the Company and our customers, identifying poor performing meters and allowing quality meters to remain in service for an extended length of time.

Included are the results of the 2025 Meter Sampling Program. We are happy to report that all but two groups tested have passed as indicated on the attached spreadsheet and as outlined in the ANSI Z1.4 sampling process. We have identified an opportunity to execute a targeted replacement of two meter types within specific years to further improve our track record of providing safe, reliable and accurate measurement to our customers.

Pease feel free to contact me if you have any additional questions.

Respectfully,

A handwritten signature in black ink, appearing to read "Jimmy Cates", written over a horizontal line.

Jimmy Cates  
Manager, Compliance

**KENTUCKY 2025**

Family Group	Description	Meters Sampled	Meters Failed	Failures Allowed	Total meters in Family
AL175(A)	Work Center	200	10	21	10,000
AL175(B)	Work Center	125	5	15	1,478
R200	All	125	8	15	2799
AC250(A)	Work Center	200	19	21	10,000
AC250(B)	Work Center	200	15	21	10,000
AC250(C)	Work Center	200	17	21	10,000
AC250(D)	Work Center	200	10	21	10,000
AC250(E)	Work Center	200	18	21	10,000
AC250(F)	Work Center	200	20	21	10,000
AC250(G)	Work Center	200	15	21	10,000
AC250(H)	Work Center	125	12	15	1,219
R275(A)	Work Center	200	8	21	10,000
R275(B)	Work Center	200	10	21	10,000
R275(C)	Work Center	200	5	21	10,000
R275(D)	Work Center	200	2	21	10,000
R275(F)	Work Center	200	18	21	10,000
R275(G)	Work Center	200	12	21	10,000
R275(H)	Work Center	200	16	21	10,000
R275(I)	Work Center	8	1	1	128
R415	All	125	1	15	2611
AL425	All	200	26	21	3730
AC630	All	125	27	15	1492
AL800	All	20	2	3	145
AL1000	All	125	8	15	2069

<b>TOTAL</b>	<b>3978</b>
--------------	-------------

**285**

**165,671**