



a PPL company

Jeff DeRouen  
Executive Director  
Kentucky Public Service Commission  
211 Sower Boulevard  
Frankfort, Kentucky 40601

RECEIVED

FEB 28 2011

PUBLIC SERVICE  
COMMISSION

Louisville Gas and Electric  
Company  
State Regulation and Rates  
220 W. Main Street  
Louisville, KY 40202  
[www.lge-ku.com](http://www.lge-ku.com)

Martin J. Reinert  
Sr. Regulatory Analyst  
O 502-627-4173  
[marty.reinert@lge-ku.com](mailto:marty.reinert@lge-ku.com)

February 28, 2011

Re: *In the Matter of: Joint Application of Inter County Energy Cooperative, Kentucky Power Company, Kentucky Utilities Company, Louisville Gas and Electric Company, Owen Electric Cooperative, Shelby Energy Cooperative, Inc., and the Union Light, Heat & Power Company for Approval of a Pilot Meter Testing Plan Pursuant 807 KAR 5:041, Section 13, 15, 16, 17, and 22, Case No. 2005-00276*

**Annual Report – Louisville Gas and Electric Company**

Dear Mr. DeRouen:

The Kentucky Public Service Commission (“Commission”) originally approved a pilot sample meter testing plan for participating electric utilities in its Order of December 12, 2000, in Case Number 99-441. On November 10, 2005, in Case No. 2005-00276, the Commission approved the 2006 Sample Meter Testing Plan submitted by participating electric utilities on a permanent basis effective January 1, 2006.

Pursuant to the 2006 Sample Meter Testing Plan (originally filed on July 1, 2005), Section I(4) and Section II(D)(4), **Louisville Gas and Electric Company** submits the following:

The Certified Test Results of all new meters received  
(Attachment A)

2010 Statistical Sampling Test Results and Summary  
(Attachment B)


(

(

(

If you have any questions please do not hesitate to contact me.

Sincerely,

A handwritten signature in black ink that reads "Marty J. Reinert". The signature is written in a cursive style with a large initial "M".

Marty J. Reinert

Cc: Reggie Chaney, Engineering Director PSC

Attachments



ATTACHMENT  
A

Certified Test Results

( )

( )

( )

5040 Annual Report  
of New Single Phase  
Meters

Last Data Update:

02/17/2011 03:04:41

Dynamic Filters

Plant LG&E

Calendar Month/Year 01/2010 - 12/2010

Plant	Manf. Model Number	Serial Number	Calendar Month/Year	Test Date	As Left Full Load	As Left Light Load	As Left Power Factor	Number of records
LG&E	C1S	856211	01/2010	12/09/2009	100.10	100.03	100.13	1
LG&E	C1S	856212	01/2010	12/09/2009	100.05	99.86	100.03	1
LG&E	C1S	856213	01/2010	12/09/2009	100.06	99.92	99.92	1
LG&E	C1S	856214	01/2010	12/09/2009	100.08	99.94	100.05	1
LG&E	C1S	856215	01/2010	12/09/2009	100.09	99.92	99.93	1
LG&E	C1S	856216	01/2010	12/09/2009	100.10	100.06	100.15	1
LG&E	C1S	856217	01/2010	12/09/2009	100.07	99.91	99.95	1
LG&E	C1S	856218	01/2010	12/09/2009	100.08	100.00	99.91	1
LG&E	C1S	856219	01/2010	12/09/2009	100.08	99.94	99.97	1
LG&E	C1S	856220	01/2010	12/09/2009	100.06	99.90	100.02	1
LG&E	C1S	856221	01/2010	12/09/2009	100.09	99.94	100.02	1
LG&E	C1S	856222	01/2010	12/09/2009	100.06	99.87	99.94	1
LG&E	C1S	856223	01/2010	12/09/2009	100.06	99.89	99.90	1
LG&E	C1S	856224	01/2010	12/09/2009	100.08	100.06	100.13	1
LG&E	C1S	856225	01/2010	12/09/2009	100.09	99.94	100.07	1
LG&E	C1S	856226	01/2010	12/09/2009	100.09	99.90	100.06	1
LG&E	C1S	856227	01/2010	12/09/2009	100.09	100.03	100.16	1
LG&E	C1S	856228	01/2010	12/09/2009	100.05	99.85	99.90	1
LG&E	C1S	856229	01/2010	12/09/2009	100.06	99.88	99.84	1
LG&E	C1S	856230	01/2010	12/09/2009	100.09	100.08	100.07	1
LG&E	C1S	856231	01/2010	12/09/2009	100.08	99.90	100.03	1

LG&E	C1S	856232	01/2010	09/2009	100.09	99.91	100.08	1
LG&E	C1S	856233	01/2010	12/09/2009	100.07	100.04	100.06	1
LG&E	C1S	856234	01/2010	12/09/2009	100.07	99.86	99.97	1
LG&E	C1S	856235	01/2010	12/09/2009	100.07	100.04	100.12	1
LG&E	C1S	856236	01/2010	12/09/2009	100.09	100.05	100.04	1
LG&E	C1S	856237	01/2010	12/09/2009	100.10	99.92	100.05	1
LG&E	C1S	856238	01/2010	12/09/2009	100.05	99.89	99.99	1
LG&E	C1S	856239	01/2010	12/09/2009	100.10	99.86	100.08	1
LG&E	C1S	856240	01/2010	12/09/2009	100.08	99.88	100.04	1
LG&E	C1S	856241	01/2010	12/09/2009	100.08	99.94	99.89	1
LG&E	C1S	856242	01/2010	12/09/2009	100.06	99.92	99.95	1
LG&E	C1S	856243	01/2010	12/09/2009	100.08	100.03	100.14	1
LG&E	C1S	856244	01/2010	12/09/2009	100.06	99.91	100.04	1
LG&E	C1S	856245	01/2010	12/09/2009	100.09	99.85	100.09	1
LG&E	C1S	856246	01/2010	12/09/2009	100.06	99.81	99.91	1
LG&E	C1S	856247	01/2010	12/09/2009	100.10	99.97	99.98	1
LG&E	C1S	856248	01/2010	12/09/2009	100.05	100.03	100.01	1
LG&E	C1S	856249	01/2010	12/09/2009	100.10	99.83	99.98	1
LG&E	C1S	856250	01/2010	12/09/2009	100.09	100.12	100.17	1
LG&E	C1S	856251	01/2010	12/09/2009	100.06	99.99	99.95	1
LG&E	C1S	856252	01/2010	12/09/2009	100.06	99.84	100.05	1
LG&E	C1S	856253	01/2010	12/09/2009	100.10	100.03	99.97	1
LG&E	C1S	856254	01/2010	12/09/2009	100.08	99.99	100.05	1
LG&E	C1S	856255	01/2010	12/09/2009	100.10	99.94	99.97	1
LG&E	C1S	856256	01/2010	12/09/2009	100.07	99.95	99.93	1
LG&E	C1S	856257	01/2010	12/09/2009	100.06	100.05	100.09	1
LG&E	C1S	856258	01/2010	12/09/2009	100.07	99.84	100.02	1
LG&E	C1S	856259	01/2010	12/09/2009	100.08	99.92	100.08	1
LG&E	C1S	856260	01/2010	12/09/2009	100.06	100.03	99.86	1
LG&E	C1S	856261	01/2010	12/09/2009	100.08	100.04	100.21	1
LG&E	C1S	856262	01/2010	12/09/2009	100.09	99.87	99.92	1
LG&E	C1S	856263	01/2010	12/09/2009	100.10	99.92	100.16	1
LG&E	C1S	856264	01/2010	12/09/2009	100.07	99.94	100.03	1
LG&E	C1S	856265	01/2010	12/09/2009	100.08	100.09	100.08	1
LG&E	C1S	856266	01/2010	12/09/2009	100.06	100.05	99.98	1
LG&E	C1S	856267	01/2010	12/09/2009	100.06	99.84	99.92	1



LG&E	C1S	856268	01/2010	9/2009	100.10	99.99	100.10	1
LG&E	C1S	856269	01/2010	12/09/2009	100.06	100.04	100.13	1
LG&E	C1S	856270	01/2010	12/09/2009	100.07	99.97	99.86	1
LG&E	C1S	856271	01/2010	12/09/2009	100.09	100.14	100.15	1
LG&E	C1S	856272	01/2010	12/09/2009	100.05	100.02	100.08	1
LG&E	C1S	856273	01/2010	12/09/2009	100.09	100.08	100.16	1
LG&E	C1S	856274	01/2010	12/09/2009	100.07	99.84	100.04	1
LG&E	C1S	856275	01/2010	12/09/2009	100.09	99.90	100.09	1
LG&E	C1S	856276	01/2010	12/09/2009	100.06	100.02	100.00	1
LG&E	C1S	856277	01/2010	12/09/2009	100.10	99.81	100.03	1
LG&E	C1S	856278	01/2010	12/09/2009	100.08	100.06	100.11	1
LG&E	C1S	856279	01/2010	12/09/2009	100.06	99.84	100.08	1
LG&E	C1S	856280	01/2010	12/09/2009	100.06	100.00	99.98	1
LG&E	C1S	856281	01/2010	12/09/2009	100.10	100.09	100.15	1
LG&E	C1S	856282	01/2010	12/09/2009	100.08	99.90	100.06	1
LG&E	C1S	856283	01/2010	12/09/2009	100.10	100.08	100.19	1
LG&E	C1S	856284	01/2010	12/09/2009	100.05	99.85	99.91	1
LG&E	C1S	856285	01/2010	12/09/2009	100.08	100.02	100.13	1
LG&E	C1S	856286	01/2010	12/09/2009	100.07	99.93	100.00	1
LG&E	C1S	856287	01/2010	12/09/2009	100.09	100.08	100.13	1
LG&E	C1S	856288	01/2010	12/09/2009	100.06	100.06	100.12	1
LG&E	C1S	856289	01/2010	12/09/2009	100.07	99.89	100.02	1
LG&E	C1S	856290	01/2010	12/09/2009	100.05	100.03	100.12	1
LG&E	C1S	856291	01/2010	12/09/2009	100.10	99.92	99.97	1
LG&E	C1S	856292	01/2010	12/09/2009	100.08	100.05	100.14	1
LG&E	C1S	856293	01/2010	12/09/2009	100.08	99.95	99.90	1
LG&E	C1S	856294	01/2010	12/09/2009	100.06	99.95	100.02	1
LG&E	C1S	856295	01/2010	12/09/2009	100.10	99.86	99.98	1
LG&E	C1S	856296	01/2010	12/09/2009	100.07	99.97	100.06	1
LG&E	C1S	856297	01/2010	12/09/2009	100.08	100.06	100.08	1
LG&E	C1S	856298	01/2010	12/09/2009	100.10	100.01	99.97	1
LG&E	C1S	856299	01/2010	12/09/2009	100.08	99.88	99.93	1
LG&E	C1S	856300	01/2010	12/09/2009	100.06	100.01	100.08	1
LG&E	C1S	856301	01/2010	12/09/2009	100.10	99.91	100.11	1
LG&E	C1S	856302	01/2010	12/09/2009	100.07	99.93	99.92	1
LG&E	C1S	856303	01/2010	12/09/2009	100.06	99.92	99.86	1

LG&E	CIS	856304	01/2010	12/09/2009	100.08	100.09	100.16	1
LG&E	CIS	856305	01/2010	12/09/2009	100.06	99.91	99.85	1
LG&E	CIS	856306	01/2010	12/09/2009	100.07	100.09	100.17	1
LG&E	CIS	856307	01/2010	12/09/2009	100.08	100.06	100.08	1
LG&E	CIS	856308	01/2010	12/09/2009	100.06	99.99	99.89	1
LG&E	CIS	856309	01/2010	12/09/2009	100.09	99.88	100.04	1
LG&E	CIS	856310	01/2010	12/09/2009	100.09	100.00	100.09	1
LG&E	CIS	856311	01/2010	12/09/2009	100.10	99.93	99.93	1
LG&E	CIS	856312	01/2010	12/09/2009	100.07	99.94	99.92	1
LG&E	CIS	856313	01/2010	12/09/2009	100.07	100.02	100.14	1
LG&E	CIS	856314	01/2010	12/09/2009	100.10	100.10	100.17	1
LG&E	CIS	856315	01/2010	12/09/2009	100.08	99.91	100.11	1
LG&E	CIS	856316	01/2010	12/09/2009	100.10	100.10	100.20	1
LG&E	CIS	856317	01/2010	12/09/2009	100.10	99.92	100.03	1
LG&E	CIS	856318	01/2010	12/09/2009	100.09	100.01	99.99	1
LG&E	CIS	856319	01/2010	12/09/2009	100.08	99.85	100.04	1
LG&E	CIS	856320	01/2010	12/09/2009	100.08	100.00	100.04	1
LG&E	CIS	856321	01/2010	12/09/2009	100.10	100.09	100.16	1
LG&E	CIS	856322	01/2010	12/09/2009	100.10	100.03	100.16	1
LG&E	CIS	856323	01/2010	12/09/2009	100.08	99.97	100.08	1
LG&E	CIS	856324	01/2010	12/09/2009	100.07	99.92	99.96	1
LG&E	CIS	856325	01/2010	12/09/2009	100.10	99.94	100.11	1
LG&E	CIS	856326	01/2010	12/09/2009	100.06	99.87	99.95	1
LG&E	CIS	856327	01/2010	12/09/2009	100.09	100.10	100.15	1
LG&E	CIS	856328	01/2010	12/09/2009	100.08	99.96	100.15	1
LG&E	CIS	856329	01/2010	12/09/2009	100.06	99.86	99.91	1
LG&E	CIS	856330	01/2010	12/09/2009	100.10	100.06	100.20	1
LG&E	CIS	856331	01/2010	12/09/2009	100.06	99.97	100.09	1
LG&E	CIS	856332	01/2010	12/09/2009	100.07	100.00	100.02	1
LG&E	CIS	856333	01/2010	12/09/2009	100.05	100.05	100.06	1
LG&E	CIS	856334	01/2010	12/09/2009	100.07	100.05	100.11	1
LG&E	CIS	856335	01/2010	12/09/2009	100.06	100.01	100.09	1
LG&E	CIS	856336	01/2010	12/09/2009	100.06	100.00	100.06	1
LG&E	CIS	856337	01/2010	12/09/2009	100.09	100.11	100.21	1
LG&E	CIS	856338	01/2010	12/09/2009	100.06	99.94	100.06	1
LG&E	CIS	856339	01/2010	12/09/2009	100.05	99.89	100.01	1

LG&E		C1S	856340	01/2010	12/09/2009	100.07	100.02	100.15	1
LG&E		C1S	856341	01/2010	12/09/2009	100.07	99.96	99.98	1
LG&E		C1S	856342	01/2010	12/09/2009	100.09	99.90	100.09	1
LG&E		C1S	856343	01/2010	12/09/2009	100.10	100.02	100.11	1
LG&E		C1S	856344	01/2010	12/09/2009	100.07	100.02	99.95	1
LG&E		C1S	856345	01/2010	12/09/2009	100.06	100.00	100.02	1
LG&E		C1S	856346	01/2010	12/09/2009	100.08	100.02	100.08	1
LG&E		C1S	856347	01/2010	12/09/2009	100.08	99.95	100.05	1
LG&E		C1S	856348	01/2010	12/09/2009	100.09	99.86	99.96	1
LG&E		C1S	856349	01/2010	12/09/2009	100.07	99.96	99.95	1
LG&E		C1S	856350	01/2010	12/09/2009	100.10	100.11	100.16	1
LG&E		C1S	856351	01/2010	12/09/2009	100.06	99.94	99.94	1
LG&E		C1S	856352	01/2010	12/09/2009	100.05	99.96	100.07	1
LG&E		C1S	856353	01/2010	12/09/2009	100.07	100.12	100.20	1
LG&E		C1S	856354	01/2010	12/09/2009	100.09	99.97	100.09	1
LG&E		C1S	856355	01/2010	12/09/2009	100.06	100.07	100.14	1
LG&E		C1S	856356	01/2010	12/09/2009	100.09	100.02	100.03	1
LG&E		C1S	856357	01/2010	12/09/2009	100.10	100.08	100.12	1
LG&E		C1S	856358	01/2010	12/09/2009	100.06	100.13	100.13	1
LG&E		C1S	856359	01/2010	12/09/2009	100.09	100.08	100.11	1
LG&E		C1S	856360	01/2010	12/09/2009	100.09	100.08	100.12	1
LG&E		C1S	856361	01/2010	12/09/2009	100.08	100.02	100.06	1
LG&E		C1S	856362	01/2010	12/09/2009	100.05	99.92	99.92	1
LG&E		C1S	856363	01/2010	12/09/2009	100.06	99.94	100.02	1
LG&E		C1S	856364	01/2010	12/09/2009	100.06	99.92	99.95	1
LG&E		C1S	856365	01/2010	12/09/2009	100.10	100.04	100.01	1
LG&E		C1S	856366	01/2010	12/09/2009	100.07	100.06	100.12	1
LG&E		C1S	856367	01/2010	12/09/2009	100.08	100.02	100.01	1
LG&E		C1S	856368	01/2010	12/09/2009	100.07	100.06	99.95	1
LG&E		C1S	856369	01/2010	12/09/2009	100.08	100.09	100.14	1
LG&E		C1S	856370	01/2010	12/09/2009	100.09	99.92	100.11	1
LG&E		C1S	856371	01/2010	12/09/2009	100.06	99.94	100.09	1
LG&E		C1S	856372	01/2010	12/09/2009	100.08	100.11	100.22	1
LG&E		C1S	856373	01/2010	12/09/2009	100.05	99.81	100.00	1
LG&E		C1S	856374	01/2010	12/09/2009	100.07	99.87	100.16	1
LG&E		C1S	856375	01/2010	12/09/2009	100.06	99.96	99.95	1

LG&E	CIS	856376	01/2010	12/09/2009	100.05	99.88	99.90	1
LG&E	CIS	856377	01/2010	12/09/2009	100.06	99.82	100.04	1
LG&E	CIS	856378	01/2010	12/09/2009	100.08	100.06	100.17	1
LG&E	CIS	856379	01/2010	12/09/2009	100.06	99.98	99.87	1
LG&E	CIS	856380	01/2010	12/09/2009	100.08	99.97	99.96	1
LG&E	CIS	856381	01/2010	12/09/2009	100.06	100.02	100.09	1
LG&E	CIS	856382	01/2010	12/09/2009	100.06	100.06	100.15	1
LG&E	CIS	856383	01/2010	12/09/2009	100.10	100.03	100.12	1
LG&E	CIS	856384	01/2010	12/09/2009	100.06	100.02	100.06	1
LG&E	CIS	856385	01/2010	12/09/2009	100.08	99.91	100.10	1
LG&E	CIS	856386	01/2010	12/09/2009	100.10	99.95	100.16	1
LG&E	CIS	856387	01/2010	12/09/2009	100.07	99.92	100.08	1
LG&E	CIS	856388	01/2010	12/09/2009	100.08	99.95	99.92	1
LG&E	CIS	856389	01/2010	12/09/2009	100.10	99.92	99.93	1
LG&E	CIS	856390	01/2010	12/09/2009	100.06	99.96	99.94	1
LG&E	CIS	856391	01/2010	12/09/2009	100.08	99.93	100.11	1
LG&E	CIS	856392	01/2010	12/09/2009	100.07	100.02	99.93	1
LG&E	CIS	856393	01/2010	12/09/2009	100.06	99.86	99.89	1
LG&E	CIS	856394	01/2010	12/09/2009	100.09	99.98	100.15	1
LG&E	CIS	856395	01/2010	12/09/2009	100.08	100.04	100.16	1
LG&E	CIS	856396	01/2010	12/09/2009	100.07	99.86	100.03	1
LG&E	CIS	856397	01/2010	12/09/2009	100.08	99.97	100.10	1
LG&E	CIS	856398	01/2010	12/09/2009	100.08	100.04	100.14	1
LG&E	CIS	856399	01/2010	12/09/2009	100.08	99.88	99.89	1
LG&E	CIS	856400	01/2010	12/09/2009	100.06	99.85	100.00	1
LG&E	CIS	856401	01/2010	12/09/2009	100.09	100.06	100.16	1
LG&E	CIS	856402	01/2010	12/09/2009	100.06	99.99	100.09	1
LG&E	CIS	856403	01/2010	12/09/2009	100.06	99.89	100.09	1
LG&E	CIS	856404	01/2010	12/09/2009	100.07	100.06	100.10	1
LG&E	CIS	856405	01/2010	12/09/2009	100.08	99.87	100.07	1
LG&E	CIS	856406	01/2010	12/09/2009	100.07	99.83	100.04	1
LG&E	CIS	856407	01/2010	12/09/2009	100.07	99.93	100.06	1
LG&E	CIS	856408	01/2010	12/09/2009	100.08	100.09	100.10	1
LG&E	CIS	856409	01/2010	12/09/2009	100.07	100.02	100.07	1
LG&E	CIS	856410	01/2010	12/09/2009	100.06	99.86	100.05	1
LG&E	CIS	856411	01/2010	12/09/2009	100.07	100.03	99.93	1

LG&E	C1S	856412	01/2010	12/09/2009	100.09	100.03	100.01	1
LG&E	C1S	856413	01/2010	12/09/2009	100.08	99.89	99.97	1
LG&E	C1S	856414	01/2010	12/09/2009	100.07	100.08	100.19	1
LG&E	C1S	856415	01/2010	12/09/2009	100.06	99.93	99.90	1
LG&E	C1S	856416	01/2010	12/09/2009	100.08	99.95	100.03	1
LG&E	C1S	856417	01/2010	12/09/2009	100.10	99.99	99.98	1
LG&E	C1S	856418	01/2010	12/09/2009	100.08	99.91	100.06	1
LG&E	C1S	856419	01/2010	12/09/2009	100.06	99.81	100.04	1
LG&E	C1S	856420	01/2010	12/09/2009	100.07	100.03	100.09	1
LG&E	C1S	856421	01/2010	12/09/2009	100.09	100.08	100.08	1
LG&E	C1S	856422	01/2010	12/09/2009	100.07	99.85	99.99	1
LG&E	C1S	856423	01/2010	12/09/2009	100.08	100.00	99.91	1
LG&E	C1S	856424	01/2010	12/09/2009	100.05	100.02	100.08	1
LG&E	C1S	856425	01/2010	12/09/2009	100.08	100.02	100.20	1
LG&E	C1S	856426	01/2010	12/09/2009	100.08	99.94	100.00	1
LG&E	C1S	856427	01/2010	12/09/2009	100.09	100.00	100.10	1
LG&E	C1S	856428	01/2010	12/09/2009	100.09	99.83	100.03	1
LG&E	C1S	856429	01/2010	12/09/2009	100.08	100.09	100.14	1
LG&E	C1S	856430	01/2010	12/09/2009	100.10	100.00	100.19	1
LG&E	C1S	856431	01/2010	12/09/2009	100.08	100.07	100.09	1
LG&E	C1S	856432	01/2010	12/09/2009	100.06	99.98	99.95	1
LG&E	C1S	856433	01/2010	12/09/2009	100.08	100.07	100.02	1
LG&E	C1S	856434	01/2010	12/09/2009	100.08	99.87	100.08	1
LG&E	C1S	856435	01/2010	12/09/2009	100.07	99.95	99.96	1
LG&E	C1S	856436	01/2010	12/09/2009	100.06	100.05	100.05	1
LG&E	C1S	856437	01/2010	12/09/2009	100.07	100.01	99.93	1
LG&E	C1S	856438	01/2010	12/09/2009	100.07	99.95	99.90	1
LG&E	C1S	856439	01/2010	12/09/2009	100.08	100.01	99.91	1
LG&E	C1S	856440	01/2010	12/09/2009	100.09	100.00	99.95	1
LG&E	C1S	856441	01/2010	12/09/2009	100.07	99.83	99.94	1
LG&E	C1S	856442	01/2010	12/09/2009	100.06	99.97	100.01	1
LG&E	C1S	856443	01/2010	12/09/2009	100.10	100.07	100.11	1
LG&E	C1S	856444	01/2010	12/09/2009	100.08	100.04	100.11	1
LG&E	C1S	856445	01/2010	12/09/2009	100.07	99.93	100.00	1
LG&E	C1S	856446	01/2010	12/09/2009	100.07	99.96	100.06	1
LG&E	C1S	856447	01/2010	12/09/2009	100.06	100.02	100.14	1

LG&E	C1S	856448	01/2010	12/09/2009	100.09	100.10	100.17	1
LG&E	C1S	856449	01/2010	12/09/2009	100.09	99.83	100.06	1
LG&E	C1S	856450	01/2010	12/09/2009	100.07	99.99	100.00	1
LG&E	C1S	856451	01/2010	12/09/2009	100.09	100.11	100.16	1
LG&E	C1S	856452	01/2010	12/09/2009	100.06	100.08	100.11	1
LG&E	C1S	856453	01/2010	12/09/2009	100.08	99.89	99.93	1
LG&E	C1S	856454	01/2010	12/09/2009	100.06	99.81	100.01	1
LG&E	C1S	856455	01/2010	12/09/2009	100.07	99.92	100.09	1
LG&E	C1S	856456	01/2010	12/09/2009	100.07	100.04	100.12	1
LG&E	C1S	856457	01/2010	12/09/2009	100.10	100.03	100.09	1
LG&E	C1S	856458	01/2010	12/09/2009	100.10	99.91	100.11	1
LG&E	C1S	856459	01/2010	12/09/2009	100.06	100.08	100.13	1
LG&E	C1S	856460	01/2010	12/09/2009	100.08	99.92	99.87	1
LG&E	C1S	856461	01/2010	12/09/2009	100.10	100.05	100.09	1
LG&E	C1S	856462	01/2010	12/09/2009	100.10	99.95	100.04	1
LG&E	C1S	856463	01/2010	12/09/2009	100.06	99.83	100.06	1
LG&E	C1S	856464	01/2010	12/09/2009	100.08	99.98	99.96	1
LG&E	C1S	856465	01/2010	12/09/2009	100.07	99.92	99.90	1
LG&E	C1S	856466	01/2010	12/09/2009	100.06	99.89	99.95	1
LG&E	C1S	856467	01/2010	12/09/2009	100.09	99.97	100.08	1
LG&E	C1S	856468	01/2010	12/09/2009	100.06	100.03	100.14	1
LG&E	C1S	856469	01/2010	12/09/2009	100.09	100.07	100.12	1
LG&E	C1S	856470	01/2010	12/09/2009	100.07	100.03	100.05	1
LG&E	C1S	856471	01/2010	12/09/2009	100.06	99.84	100.02	1
LG&E	C1S	856472	01/2010	12/09/2009	100.10	100.08	100.05	1
LG&E	C1S	856473	01/2010	12/09/2009	100.09	99.83	100.04	1
LG&E	C1S	856474	01/2010	12/09/2009	100.09	99.88	100.15	1
LG&E	C1S	856475	01/2010	12/09/2009	100.05	100.01	100.06	1
LG&E	C1S	856476	01/2010	12/09/2009	100.07	100.02	100.15	1
LG&E	C1S	856477	01/2010	12/09/2009	100.08	99.95	99.92	1
LG&E	C1S	856478	01/2010	12/09/2009	100.08	99.84	100.02	1
LG&E	C1S	856479	01/2010	12/09/2009	100.08	99.91	99.88	1
LG&E	C1S	856480	01/2010	12/09/2009	100.07	99.95	100.18	1
LG&E	C1S	856481	01/2010	12/09/2009	100.05	99.96	100.07	1
LG&E	C1S	856482	01/2010	12/09/2009	100.09	100.06	100.20	1
LG&E	C1S	856483	01/2010	12/09/2009	100.06	99.84	99.92	1

LG&E		C1S	856484	01/2010	09/2009	100.10	100.06	100.14	1
LG&E		C1S	856485	01/2010	12/09/2009	100.09	100.05	99.91	1
LG&E		C1S	856486	01/2010	12/09/2009	100.07	99.93	100.05	1
LG&E		C1S	856487	01/2010	12/09/2009	100.06	99.86	100.04	1
LG&E		C1S	856488	01/2010	12/09/2009	100.09	99.91	100.01	1
LG&E		C1S	856489	01/2010	12/09/2009	100.05	99.85	99.96	1
LG&E		C1S	856490	01/2010	12/09/2009	100.10	100.11	100.21	1
LG&E		C1S	856491	01/2010	12/09/2009	100.08	100.06	100.10	1
LG&E		C1S	856492	01/2010	12/09/2009	100.09	99.90	100.06	1
LG&E		C1S	856493	01/2010	12/09/2009	100.10	100.08	100.17	1
LG&E		C1S	856494	01/2010	12/09/2009	100.08	99.99	99.86	1
LG&E		C1S	856495	01/2010	12/09/2009	100.09	100.01	99.97	1
LG&E		C1S	856496	01/2010	12/09/2009	100.06	99.90	100.04	1
LG&E		C1S	856497	01/2010	12/09/2009	100.07	99.99	100.04	1
LG&E		C1S	856498	01/2010	12/09/2009	100.09	99.96	99.97	1
LG&E		C1S	856499	01/2010	12/09/2009	100.07	99.93	100.07	1
LG&E		C1S	856500	01/2010	12/09/2009	100.09	99.98	99.99	1
LG&E		C1S	856501	01/2010	12/09/2009	100.08	100.00	100.14	1
LG&E		C1S	856502	01/2010	12/09/2009	100.09	99.97	99.96	1
LG&E		C1S	856503	01/2010	12/09/2009	100.07	100.00	99.96	1
LG&E		C1S	856504	01/2010	12/09/2009	100.09	100.06	100.16	1
LG&E		C1S	856505	01/2010	12/09/2009	100.10	100.01	100.05	1
LG&E		C1S	856506	01/2010	12/09/2009	100.10	99.90	100.07	1
LG&E		C1S	856507	01/2010	12/09/2009	100.08	99.92	99.95	1
LG&E		C1S	856508	01/2010	12/09/2009	100.09	99.98	99.95	1
LG&E		C1S	856509	01/2010	12/09/2009	100.06	100.08	100.14	1
LG&E		C1S	856510	01/2010	12/09/2009	100.06	99.87	100.06	1
LG&E		C1S	856511	01/2010	12/09/2009	100.07	100.12	100.17	1
LG&E		C1S	856512	01/2010	12/09/2009	100.09	99.94	100.08	1
LG&E		C1S	856513	01/2010	12/09/2009	100.09	99.98	100.08	1
LG&E		C1S	856514	01/2010	12/09/2009	100.06	99.91	99.89	1
LG&E		C1S	856515	01/2010	12/09/2009	100.08	99.89	99.98	1
LG&E		C1S	856516	01/2010	12/09/2009	100.10	99.94	100.06	1
LG&E		C1S	856517	01/2010	12/09/2009	100.07	100.06	100.14	1
LG&E		C1S	856518	01/2010	12/09/2009	100.06	99.97	99.90	1
LG&E		C1S	856519	01/2010	12/09/2009	100.06	100.02	100.01	1

LG&E	CIS	856520	01/2010	12/09/2009	100.05	99.86	100.05	1
LG&E	CIS	856521	01/2010	12/09/2009	100.09	100.07	100.14	1
LG&E	CIS	856522	01/2010	12/09/2009	100.07	100.13	100.08	1
LG&E	CIS	856523	01/2010	12/09/2009	100.09	100.09	100.07	1
LG&E	CIS	856524	01/2010	12/09/2009	100.09	99.93	100.08	1
LG&E	CIS	856525	01/2010	12/09/2009	100.07	100.02	99.98	1
LG&E	CIS	856526	01/2010	12/09/2009	100.08	99.93	99.95	1
LG&E	CIS	856527	01/2010	12/09/2009	100.10	100.05	100.21	1
LG&E	CIS	856528	01/2010	12/09/2009	100.06	99.92	99.97	1
LG&E	CIS	856529	01/2010	12/09/2009	100.09	100.03	100.06	1
LG&E	CIS	856530	01/2010	12/09/2009	100.09	99.97	99.95	1
LG&E	CIS	856531	01/2010	12/09/2009	100.06	99.88	100.03	1
LG&E	CIS	856532	01/2010	12/09/2009	100.06	99.87	99.96	1
LG&E	CIS	856533	01/2010	12/09/2009	100.07	100.00	100.01	1
LG&E	CIS	856534	01/2010	12/09/2009	100.05	99.85	99.85	1
LG&E	CIS	856535	01/2010	12/09/2009	100.07	100.05	100.09	1
LG&E	CIS	856536	01/2010	12/09/2009	100.08	100.09	100.11	1
LG&E	CIS	856537	01/2010	12/09/2009	100.05	99.84	100.02	1
LG&E	CIS	856538	01/2010	12/09/2009	100.06	100.01	100.05	1
LG&E	CIS	856539	01/2010	12/09/2009	100.10	99.96	99.97	1
LG&E	CIS	856540	01/2010	12/09/2009	100.08	99.90	99.95	1
LG&E	CIS	856541	01/2010	12/09/2009	100.07	99.83	99.95	1
LG&E	CIS	856542	01/2010	12/09/2009	100.05	99.95	100.07	1
LG&E	CIS	856543	01/2010	12/09/2009	100.08	100.09	100.16	1
LG&E	CIS	856544	01/2010	12/09/2009	100.10	100.05	100.13	1
LG&E	CIS	856545	01/2010	12/09/2009	100.07	100.11	100.15	1
LG&E	CIS	856546	01/2010	12/09/2009	100.08	100.06	100.14	1
LG&E	CIS	856547	01/2010	12/09/2009	100.08	100.02	100.07	1
LG&E	CIS	856548	01/2010	12/09/2009	100.08	99.91	100.04	1
LG&E	CIS	856549	01/2010	12/09/2009	100.06	100.00	100.14	1
LG&E	CIS	856550	01/2010	12/09/2009	100.08	99.98	100.00	1
LG&E	CIS	856551	01/2010	12/09/2009	100.09	100.12	100.13	1
LG&E	CIS	856552	01/2010	12/09/2009	100.10	99.85	99.98	1
LG&E	CIS	856553	01/2010	12/09/2009	100.05	99.92	99.99	1
LG&E	CIS	856554	01/2010	12/09/2009	100.11	99.94	100.15	1
LG&E	CIS	856555	01/2010	12/09/2009	100.07	99.87	100.01	1



LG&E	C1S	856556	01/2010	12/09/2009	100.09	100.00	100.05	1
LG&E	C1S	856557	01/2010	12/09/2009	100.07	100.06	100.11	1
LG&E	C1S	856558	01/2010	12/09/2009	100.10	100.09	100.15	1
LG&E	C1S	856559	01/2010	12/09/2009	100.10	99.90	99.96	1
LG&E	C1S	856560	01/2010	12/09/2009	100.08	99.89	100.05	1
LG&E	C1S	856561	01/2010	12/09/2009	100.10	99.94	100.03	1
LG&E	C1S	856562	01/2010	12/09/2009	100.10	99.96	100.09	1
LG&E	C1S	856563	01/2010	12/09/2009	100.07	100.06	100.14	1
LG&E	C1S	856564	01/2010	12/09/2009	100.10	99.83	100.01	1
LG&E	C1S	856565	01/2010	12/09/2009	100.06	99.88	100.00	1
LG&E	C1S	856566	01/2010	12/09/2009	100.08	100.04	100.15	1
LG&E	C1S	856567	01/2010	12/09/2009	100.06	99.86	100.05	1
LG&E	C1S	856568	01/2010	12/09/2009	100.08	99.81	99.99	1
LG&E	C1S	856569	01/2010	12/09/2009	100.07	99.85	100.02	1
LG&E	C1S	856570	01/2010	12/09/2009	100.08	100.09	100.24	1
LG&E	C1S	856571	01/2010	12/09/2009	100.06	100.09	100.14	1
LG&E	C1S	856572	01/2010	12/09/2009	100.07	100.09	100.18	1
LG&E	C1S	856573	01/2010	12/09/2009	100.09	99.95	99.94	1
LG&E	C1S	856574	01/2010	12/09/2009	100.08	99.96	100.11	1
LG&E	C1S	856575	01/2010	12/09/2009	100.07	100.14	100.17	1
LG&E	C1S	856576	01/2010	12/09/2009	100.09	99.91	100.09	1
LG&E	C1S	856577	01/2010	12/09/2009	100.06	99.97	99.95	1
LG&E	C1S	856578	01/2010	12/09/2009	100.06	100.06	100.08	1
LG&E	C1S	856579	01/2010	12/09/2009	100.09	100.07	100.12	1
LG&E	C1S	856580	01/2010	12/09/2009	100.07	100.02	100.08	1
LG&E	C1S	856581	01/2010	12/09/2009	100.06	99.83	99.90	1
LG&E	C1S	856582	01/2010	12/09/2009	100.10	100.02	100.10	1
LG&E	C1S	856583	01/2010	12/09/2009	100.09	99.94	100.12	1
LG&E	C1S	856584	01/2010	12/09/2009	100.06	100.03	100.14	1
LG&E	C1S	856585	01/2010	12/09/2009	100.06	100.02	100.06	1
LG&E	C1S	856586	01/2010	12/09/2009	100.10	99.89	99.92	1
LG&E	C1S	856587	01/2010	12/09/2009	100.07	100.06	100.08	1
LG&E	C1S	856588	01/2010	12/09/2009	100.07	100.06	100.07	1
LG&E	C1S	856589	01/2010	12/09/2009	100.05	99.92	99.92	1
LG&E	C1S	856590	01/2010	12/09/2009	100.06	99.82	100.07	1
LG&E	C1S	856591	01/2010	12/09/2009	100.06	99.81	99.92	1

LG&E	CIS	856592	01/2010	12/09/2009	100.06	99.87	100.05	1
LG&E	CIS	856593	01/2010	12/09/2009	100.09	100.07	100.07	1
LG&E	CIS	856594	01/2010	12/09/2009	100.09	100.05	100.19	1
LG&E	CIS	856595	01/2010	12/09/2009	100.07	99.92	99.94	1
LG&E	CIS	856596	01/2010	12/09/2009	100.10	99.95	100.07	1
LG&E	CIS	856597	01/2010	12/09/2009	100.05	99.88	99.85	1
LG&E	CIS	856598	01/2010	12/09/2009	100.06	99.98	100.08	1
LG&E	CIS	856599	01/2010	12/09/2009	100.09	100.01	100.11	1
LG&E	CIS	856600	01/2010	12/09/2009	100.06	100.05	100.10	1
LG&E	CIS	856601	01/2010	12/09/2009	100.08	100.06	100.10	1
LG&E	CIS	856602	01/2010	12/09/2009	100.09	99.91	100.02	1
LG&E	CIS	856603	01/2010	12/09/2009	100.05	99.90	99.91	1
LG&E	CIS	856604	01/2010	12/09/2009	100.08	100.10	100.16	1
LG&E	CIS	856605	01/2010	12/09/2009	100.08	99.96	99.88	1
LG&E	CIS	856606	01/2010	12/09/2009	100.07	99.96	100.17	1
LG&E	CIS	856607	01/2010	12/09/2009	100.06	100.03	99.92	1
LG&E	CIS	856608	01/2010	12/09/2009	100.08	100.00	100.02	1
LG&E	CIS	856609	01/2010	12/09/2009	100.08	100.02	100.00	1
LG&E	CIS	856610	01/2010	12/09/2009	100.10	99.94	100.15	1
LG&E	CIS	856611	01/2010	12/09/2009	100.07	99.88	100.08	1
LG&E	CIS	856612	01/2010	12/09/2009	100.07	100.13	100.11	1
LG&E	CIS	856613	01/2010	12/09/2009	100.06	100.00	100.08	1
LG&E	CIS	856614	01/2010	12/09/2009	100.07	100.03	100.11	1
LG&E	CIS	856615	01/2010	12/09/2009	100.08	99.86	100.00	1
LG&E	CIS	856616	01/2010	12/09/2009	100.09	100.02	100.11	1
LG&E	CIS	856617	01/2010	12/09/2009	100.09	99.92	99.90	1
LG&E	CIS	856618	01/2010	12/09/2009	100.08	100.07	100.12	1
LG&E	CIS	856619	01/2010	12/09/2009	100.10	99.95	99.85	1
LG&E	CIS	856620	01/2010	12/09/2009	100.09	99.84	99.98	1
LG&E	CIS	856621	01/2010	12/09/2009	100.06	99.91	99.89	1
LG&E	CIS	856622	01/2010	12/09/2009	100.07	99.92	100.11	1
LG&E	CIS	856623	01/2010	12/09/2009	100.07	99.92	100.00	1
LG&E	CIS	856624	01/2010	12/09/2009	100.07	100.02	100.19	1
LG&E	CIS	856625	01/2010	12/09/2009	100.09	100.01	99.92	1
LG&E	CIS	856626	01/2010	12/09/2009	100.09	99.84	100.08	1
LG&E	CIS	856627	01/2010	12/09/2009	100.10	100.04	100.14	1

LG&E	C1S	856628	01/2010	12/09/2009	100.08	99.94	99.89	1
LG&E	C1S	856629	01/2010	12/09/2009	100.06	99.89	99.91	1
LG&E	C1S	856630	01/2010	12/09/2009	100.06	99.95	99.86	1
LG&E	C1S	856631	01/2010	12/09/2009	100.07	99.92	100.01	1
LG&E	C1S	856632	01/2010	12/09/2009	100.06	99.93	100.12	1
LG&E	C1S	856633	01/2010	12/09/2009	100.05	99.94	99.89	1
LG&E	C1S	856634	01/2010	12/09/2009	100.10	99.89	100.11	1
LG&E	C1S	856635	01/2010	12/09/2009	100.09	100.01	100.13	1
LG&E	C1S	856636	01/2010	12/09/2009	100.09	100.11	100.17	1
LG&E	C1S	856637	01/2010	12/09/2009	100.08	100.06	100.19	1
LG&E	C1S	856638	01/2010	12/09/2009	100.05	99.90	100.00	1
LG&E	C1S	856639	01/2010	12/09/2009	100.09	100.03	100.09	1
LG&E	C1S	856640	01/2010	12/09/2009	100.06	100.11	100.12	1
LG&E	C1S	856641	01/2010	12/09/2009	100.08	99.94	100.04	1
LG&E	C1S	856642	01/2010	12/09/2009	100.10	99.85	99.99	1
LG&E	C1S	856643	01/2010	12/09/2009	100.07	100.01	99.91	1
LG&E	C1S	856644	01/2010	12/09/2009	100.07	99.99	100.14	1
LG&E	C1S	856645	01/2010	12/09/2009	100.09	99.92	100.04	1
LG&E	C1S	856646	01/2010	12/09/2009	100.07	99.93	100.14	1
LG&E	C1S	856647	01/2010	12/09/2009	100.10	99.90	100.06	1
LG&E	C1S	856648	01/2010	12/09/2009	100.07	99.92	100.02	1
LG&E	C1S	856649	01/2010	12/09/2009	100.09	99.93	99.92	1
LG&E	C1S	856650	01/2010	12/09/2009	100.09	99.93	100.05	1
LG&E	C1S	856651	01/2010	12/09/2009	100.07	100.02	100.15	1
LG&E	C1S	856652	01/2010	12/09/2009	100.07	99.88	99.94	1
LG&E	C1S	856653	01/2010	12/09/2009	100.08	100.06	100.18	1
LG&E	C1S	856654	01/2010	12/09/2009	100.06	99.93	100.04	1
LG&E	C1S	856655	01/2010	12/09/2009	100.05	99.84	99.98	1
LG&E	C1S	856656	01/2010	12/09/2009	100.07	100.04	100.10	1
LG&E	C1S	856657	01/2010	12/09/2009	100.08	100.02	100.01	1
LG&E	C1S	856658	01/2010	12/09/2009	100.08	99.90	99.99	1
LG&E	C1S	856659	01/2010	12/09/2009	100.10	100.09	100.14	1
LG&E	C1S	856660	01/2010	12/09/2009	100.06	99.94	99.91	1
LG&E	C1S	856661	01/2010	12/09/2009	100.09	99.99	100.16	1
LG&E	C1S	856662	01/2010	12/09/2009	100.06	99.98	100.07	1
LG&E	C1S	856663	01/2010	12/09/2009	100.08	100.01	100.11	1

LG&E	CIS	856664	01/2010	12/09/2009	100.09	99.91	100.16	1
LG&E	CIS	856665	01/2010	12/09/2009	100.07	99.99	100.12	1
LG&E	CIS	856666	01/2010	12/09/2009	100.07	99.86	100.03	1
LG&E	CIS	856667	01/2010	12/09/2009	100.07	100.07	100.09	1
LG&E	CIS	856668	01/2010	12/09/2009	100.06	99.83	100.12	1
LG&E	CIS	856669	01/2010	12/09/2009	100.10	99.89	99.97	1
LG&E	CIS	856670	01/2010	12/09/2009	100.06	99.96	100.00	1
LG&E	CIS	856671	01/2010	12/09/2009	100.05	99.91	99.86	1
LG&E	CIS	856672	01/2010	12/09/2009	100.07	99.98	100.03	1
LG&E	CIS	856673	01/2010	12/09/2009	100.09	100.03	100.15	1
LG&E	CIS	856674	01/2010	12/09/2009	100.06	100.08	100.10	1
LG&E	CIS	856675	01/2010	12/09/2009	100.09	100.03	100.01	1
LG&E	CIS	856676	01/2010	12/09/2009	100.06	100.02	100.07	1
LG&E	CIS	856677	01/2010	12/09/2009	100.07	99.94	100.05	1
LG&E	CIS	856678	01/2010	12/09/2009	100.10	100.15	100.19	1
LG&E	CIS	856679	01/2010	12/09/2009	100.09	99.91	100.07	1
LG&E	CIS	856680	01/2010	12/09/2009	100.08	100.01	100.13	1
LG&E	CIS	856681	01/2010	12/09/2009	100.09	99.92	99.97	1
LG&E	CIS	856682	01/2010	12/09/2009	100.08	99.98	100.00	1
LG&E	CIS	856683	01/2010	12/09/2009	100.07	99.93	100.02	1
LG&E	CIS	856684	01/2010	12/09/2009	100.07	99.85	100.01	1
LG&E	CIS	856685	01/2010	12/09/2009	100.06	99.88	99.97	1
LG&E	CIS	856686	01/2010	12/09/2009	100.09	99.90	100.09	1
LG&E	CIS	856687	01/2010	12/09/2009	100.09	100.02	100.07	1
LG&E	CIS	856688	01/2010	12/09/2009	100.10	100.07	100.10	1
LG&E	CIS	856689	01/2010	12/09/2009	100.10	100.01	100.08	1
LG&E	CIS	856690	01/2010	12/09/2009	100.08	100.07	100.16	1
LG&E	CIS	856883	03/2010	02/10/2010	100.10	100.02	100.07	1
LG&E	CIS	856884	03/2010	02/10/2010	100.09	100.00	100.01	1
LG&E	CIS	856885	03/2010	02/10/2010	100.06	100.10	100.19	1
LG&E	CIS	856886	03/2010	02/10/2010	100.10	100.13	100.22	1
LG&E	CIS	856887	03/2010	02/10/2010	100.07	100.11	100.15	1
LG&E	CIS	856888	03/2010	02/10/2010	100.07	100.01	100.15	1
LG&E	CIS	856889	03/2010	02/10/2010	100.08	100.16	100.12	1
LG&E	CIS	856890	03/2010	02/10/2010	100.09	99.87	100.06	1
LG&E	CIS	856891	03/2010	02/10/2010	100.09	99.97	100.10	1

LG&E		C1S	856892	03/2010	02/10/2010	100.07	99.84	100.03	1
LG&E		C1S	856893	03/2010	02/10/2010	100.08	100.03	100.17	1
LG&E		C1S	856894	03/2010	02/10/2010	100.09	100.11	100.22	1
LG&E		C1S	856895	03/2010	02/10/2010	100.07	99.99	100.04	1
LG&E		C1S	856896	03/2010	02/10/2010	100.10	100.09	100.27	1
LG&E		C1S	856897	03/2010	02/10/2010	100.09	99.98	100.09	1
LG&E		C1S	856898	03/2010	02/10/2010	100.05	100.07	100.16	1
LG&E		C1S	856899	03/2010	02/10/2010	100.10	99.92	100.10	1
LG&E		C1S	856900	03/2010	02/10/2010	100.06	100.01	100.04	1
LG&E		C1S	856901	03/2010	02/10/2010	100.06	99.92	100.06	1
LG&E		C1S	856902	03/2010	02/10/2010	100.09	99.93	100.03	1
LG&E		C1S	856903	03/2010	02/10/2010	100.10	100.11	100.21	1
LG&E		C1S	856904	03/2010	02/10/2010	100.08	99.95	100.06	1
LG&E		C1S	856905	03/2010	02/10/2010	100.09	100.03	100.15	1
LG&E		C1S	856906	03/2010	02/10/2010	100.09	100.07	100.21	1
LG&E		C1S	856907	03/2010	02/10/2010	100.10	99.98	100.12	1
LG&E		C1S	856908	03/2010	02/10/2010	100.10	99.99	100.07	1
LG&E		C1S	856909	03/2010	02/10/2010	100.08	99.89	100.05	1
LG&E		C1S	856910	03/2010	02/10/2010	100.07	100.06	100.14	1
LG&E		C1S	856911	03/2010	02/10/2010	100.06	99.94	99.95	1
LG&E		C1S	856912	03/2010	02/10/2010	100.10	99.98	100.03	1
LG&E		C1S	856913	03/2010	02/10/2010	100.07	99.97	100.02	1
LG&E		C1S	856914	03/2010	02/10/2010	100.10	100.11	100.18	1
LG&E		C1S	856915	03/2010	02/10/2010	100.06	100.00	100.10	1
LG&E		C1S	856916	03/2010	02/10/2010	100.08	100.05	100.14	1
LG&E		C1S	856917	03/2010	02/10/2010	100.06	99.90	100.05	1
LG&E		C1S	856918	03/2010	02/10/2010	100.08	99.97	100.03	1
LG&E		C1S	856919	03/2010	02/10/2010	100.09	100.06	100.16	1
LG&E		C1S	856920	03/2010	02/10/2010	100.07	100.02	100.06	1
LG&E		C1S	856921	03/2010	02/10/2010	100.09	99.92	100.12	1
LG&E		C1S	856922	03/2010	02/10/2010	100.10	100.02	100.21	1
LG&E		C1S	856923	03/2010	02/10/2010	100.06	100.03	100.19	1
LG&E		C1S	856924	03/2010	02/10/2010	100.06	100.08	100.14	1
LG&E		C1S	856925	03/2010	02/10/2010	100.07	100.12	100.15	1
LG&E		C1S	856926	03/2010	02/10/2010	100.10	100.08	100.21	1
LG&E		C1S	856927	03/2010	02/10/2010	100.08	100.04	100.18	1

LG&E	CIS	856928	03/2010	02/10/2010	100.08	99.91	100.12	1
LG&E	CIS	856929	03/2010	02/10/2010	100.07	100.03	100.20	1
LG&E	CIS	856930	03/2010	02/10/2010	100.08	99.93	100.08	1
LG&E	CIS	856931	03/2010	02/10/2010	100.06	100.10	100.18	1
LG&E	CIS	856932	03/2010	02/10/2010	100.08	99.93	100.03	1
LG&E	CIS	856933	03/2010	02/10/2010	100.10	100.02	100.02	1
LG&E	CIS	856934	03/2010	02/10/2010	100.06	99.97	100.06	1
LG&E	CIS	856935	03/2010	02/10/2010	100.06	99.98	100.14	1
LG&E	CIS	856936	03/2010	02/10/2010	100.06	99.95	100.02	1
LG&E	CIS	856937	03/2010	02/10/2010	100.10	100.01	100.01	1
LG&E	CIS	856938	03/2010	02/10/2010	100.09	100.02	100.11	1
LG&E	CIS	856939	03/2010	02/10/2010	100.08	100.09	100.22	1
LG&E	CIS	856940	03/2010	02/10/2010	100.09	99.94	100.07	1
LG&E	CIS	856941	03/2010	02/10/2010	100.06	99.93	100.05	1
LG&E	CIS	856942	03/2010	02/10/2010	100.08	100.06	100.09	1
LG&E	CIS	856943	03/2010	02/10/2010	100.09	100.04	100.14	1
LG&E	CIS	856944	03/2010	02/10/2010	100.07	100.07	100.10	1
LG&E	CIS	856945	03/2010	02/10/2010	100.08	99.87	100.08	1
LG&E	CIS	856946	03/2010	02/10/2010	100.07	99.82	100.00	1
LG&E	CIS	856947	03/2010	02/10/2010	100.09	99.87	100.02	1
LG&E	CIS	856948	03/2010	02/10/2010	100.06	99.91	99.98	1
LG&E	CIS	856949	03/2010	02/10/2010	100.07	100.01	100.15	1
LG&E	CIS	856950	03/2010	02/10/2010	100.07	99.92	100.13	1
LG&E	CIS	856951	03/2010	02/10/2010	100.08	99.97	100.09	1
LG&E	CIS	856952	03/2010	02/10/2010	100.06	99.84	100.05	1
LG&E	CIS	856953	03/2010	02/10/2010	100.10	100.14	100.18	1
LG&E	CIS	856954	03/2010	02/10/2010	100.09	99.91	100.02	1
LG&E	CIS	856955	03/2010	02/10/2010	100.07	100.00	100.13	1
LG&E	CIS	856956	03/2010	02/10/2010	100.06	99.91	100.02	1
LG&E	CIS	856957	03/2010	02/10/2010	100.08	99.95	99.96	1
LG&E	CIS	856958	03/2010	02/10/2010	100.05	99.96	99.94	1
LG&E	CIS	856959	03/2010	02/10/2010	100.07	99.90	100.06	1
LG&E	CIS	856960	03/2010	02/10/2010	100.10	99.97	100.09	1
LG&E	CIS	856961	03/2010	02/10/2010	100.07	99.93	100.04	1
LG&E	CIS	856962	03/2010	02/10/2010	100.09	100.00	100.07	1
LG&E	CIS	856963	03/2010	02/10/2010	100.10	100.19	100.14	1

LG&E		C1S	856964	03/2010	02/10/2010	100.06	99.95	100.07	1
LG&E		C1S	856965	03/2010	02/10/2010	100.06	100.04	100.12	1
LG&E		C1S	856966	03/2010	02/10/2010	100.08	100.02	100.05	1
LG&E		C1S	856967	03/2010	02/10/2010	100.09	99.95	100.12	1
LG&E		C1S	856968	03/2010	02/10/2010	100.07	99.94	100.06	1
LG&E		C1S	856969	03/2010	02/10/2010	100.08	99.95	100.05	1
LG&E		C1S	856970	03/2010	02/10/2010	100.08	100.03	100.02	1
LG&E		C1S	856971	03/2010	02/10/2010	100.11	99.93	100.02	1
LG&E		C1S	856972	03/2010	02/10/2010	100.08	99.88	100.05	1
LG&E		C1S	856973	03/2010	02/10/2010	100.06	100.08	100.16	1
LG&E		C1S	856974	03/2010	02/10/2010	100.10	99.89	100.02	1
LG&E		C1S	856975	03/2010	02/10/2010	100.07	99.87	100.00	1
LG&E		C1S	856976	03/2010	02/10/2010	100.09	100.14	100.13	1
LG&E		C1S	856977	03/2010	02/10/2010	100.06	100.06	100.14	1
LG&E		C1S	856978	03/2010	02/10/2010	100.08	100.01	100.20	1
LG&E		C1S	856979	03/2010	02/10/2010	100.10	100.11	100.19	1
LG&E		C1S	856980	03/2010	02/10/2010	100.06	99.90	100.06	1
LG&E		C1S	856981	03/2010	02/10/2010	100.07	99.90	100.00	1
LG&E		C1S	856982	03/2010	02/10/2010	100.07	99.92	100.08	1
LG&E		C1S	856983	03/2010	02/10/2010	100.06	99.92	99.99	1
LG&E		C1S	856984	03/2010	02/10/2010	100.10	100.07	100.18	1
LG&E		C1S	856985	03/2010	02/10/2010	100.07	100.02	100.14	1
LG&E		C1S	856986	03/2010	02/10/2010	100.05	100.02	100.08	1
LG&E		C1S	856987	03/2010	02/10/2010	100.07	100.08	100.12	1
LG&E		C1S	856988	03/2010	02/10/2010	100.10	99.94	100.11	1
LG&E		C1S	856989	03/2010	02/10/2010	100.10	99.99	100.02	1
LG&E		C1S	856990	03/2010	02/10/2010	100.08	100.04	100.11	1
LG&E		C1S	856991	03/2010	02/10/2010	100.09	100.12	100.21	1
LG&E		C1S	856992	03/2010	02/10/2010	100.06	100.07	100.20	1
LG&E		C1S	856993	03/2010	02/10/2010	100.05	100.04	100.12	1
LG&E		C1S	856994	03/2010	02/10/2010	100.08	100.00	100.02	1
LG&E		C1S	856995	03/2010	02/10/2010	100.07	100.04	100.18	1
LG&E		C1S	856996	03/2010	02/10/2010	100.09	100.05	100.18	1
LG&E		C1S	856997	03/2010	02/10/2010	100.10	99.98	100.06	1
LG&E		C1S	856998	03/2010	02/10/2010	100.09	100.04	100.16	1
LG&E		C1S	856999	03/2010	02/10/2010	100.06	99.98	100.08	1

LG&E	CIS	857000	03/2010	02/10/2010	100.10	100.03	100.09	1
LG&E	CIS	857001	03/2010	02/10/2010	100.09	99.99	100.00	1
LG&E	CIS	857002	03/2010	02/10/2010	100.09	99.87	100.09	1
LG&E	CIS	857003	03/2010	02/10/2010	100.08	99.92	100.12	1
LG&E	CIS	857004	03/2010	02/10/2010	100.07	99.88	100.03	1
LG&E	CIS	857005	03/2010	02/10/2010	100.07	99.98	99.97	1
LG&E	CIS	857006	03/2010	02/10/2010	100.08	100.04	100.12	1
LG&E	CIS	857007	03/2010	02/10/2010	100.06	99.93	100.06	1
LG&E	CIS	857008	03/2010	02/10/2010	100.06	99.86	100.01	1
LG&E	CIS	857009	03/2010	02/10/2010	100.10	100.14	100.23	1
LG&E	CIS	857010	03/2010	02/10/2010	100.06	99.90	100.13	1
LG&E	CIS	857011	03/2010	02/10/2010	100.08	100.10	100.15	1
LG&E	CIS	857012	03/2010	02/10/2010	100.08	99.97	100.10	1
LG&E	CIS	857013	03/2010	02/10/2010	100.09	99.91	99.89	1
LG&E	CIS	857014	03/2010	02/10/2010	100.08	100.05	100.18	1
LG&E	CIS	857015	03/2010	02/10/2010	100.09	99.94	100.16	1
LG&E	CIS	857016	03/2010	02/10/2010	100.07	99.97	100.04	1
LG&E	CIS	857017	03/2010	02/10/2010	100.10	99.94	100.02	1
LG&E	CIS	857018	03/2010	02/10/2010	100.08	99.90	100.07	1
LG&E	CIS	857019	03/2010	02/10/2010	100.10	99.99	100.16	1
LG&E	CIS	857020	03/2010	02/10/2010	100.09	99.94	100.08	1
LG&E	CIS	857021	03/2010	02/10/2010	100.07	99.91	99.99	1
LG&E	CIS	857022	03/2010	02/10/2010	100.09	99.97	100.06	1
LG&E	CIS	857023	03/2010	02/10/2010	100.06	99.95	100.01	1
LG&E	CIS	857024	03/2010	02/10/2010	100.06	100.04	100.21	1
LG&E	CIS	857025	03/2010	02/10/2010	100.09	100.07	100.19	1
LG&E	CIS	857026	03/2010	02/10/2010	100.06	100.00	100.02	1
LG&E	CIS	857027	03/2010	02/10/2010	100.07	99.88	100.04	1
LG&E	CIS	857028	03/2010	02/10/2010	100.09	100.09	100.19	1
LG&E	CIS	857029	03/2010	02/10/2010	100.09	99.97	100.03	1
LG&E	CIS	857030	03/2010	02/10/2010	100.07	99.92	100.01	1
LG&E	CIS	857031	03/2010	02/10/2010	100.08	99.96	100.12	1
LG&E	CIS	857032	03/2010	02/10/2010	100.06	99.91	100.01	1
LG&E	CIS	857033	03/2010	02/10/2010	100.08	99.98	100.08	1
LG&E	CIS	857034	03/2010	02/10/2010	100.06	100.00	100.04	1
LG&E	CIS	857035	03/2010	02/10/2010	100.09	99.97	99.96	1



LG&E		C1S	857036	03/2010	02/10/2010	100.09	99.97	100.06	1
LG&E		C1S	857037	03/2010	02/10/2010	100.06	100.04	100.22	1
LG&E		C1S	857038	03/2010	02/10/2010	100.10	100.09	100.11	1
LG&E		C1S	857039	03/2010	02/10/2010	100.07	99.91	100.00	1
LG&E		C1S	857040	03/2010	02/10/2010	100.10	99.92	100.09	1
LG&E		C1S	857041	03/2010	02/10/2010	100.08	100.02	100.01	1
LG&E		C1S	857042	03/2010	02/10/2010	100.09	100.12	100.06	1
LG&E		C1S	857043	03/2010	02/10/2010	100.06	99.87	100.08	1
LG&E		C1S	857044	03/2010	02/10/2010	100.09	99.97	100.14	1
LG&E		C1S	857045	03/2010	02/10/2010	100.07	99.95	100.00	1
LG&E		C1S	857046	03/2010	02/10/2010	100.05	99.82	100.05	1
LG&E		C1S	857047	03/2010	02/10/2010	100.09	100.01	100.03	1
LG&E		C1S	857048	03/2010	02/10/2010	100.08	99.95	100.04	1
LG&E		C1S	857049	03/2010	02/10/2010	100.09	99.94	100.02	1
LG&E		C1S	857050	03/2010	02/10/2010	100.06	99.95	100.08	1
LG&E		C1S	857051	03/2010	02/10/2010	100.08	99.95	100.02	1
LG&E		C1S	857052	03/2010	02/10/2010	100.08	99.97	100.08	1
LG&E		C1S	857053	03/2010	02/10/2010	100.06	100.03	99.98	1
LG&E		C1S	857054	03/2010	02/10/2010	100.06	100.02	99.98	1
LG&E		C1S	857055	03/2010	02/10/2010	100.09	99.96	100.11	1
LG&E		C1S	857056	03/2010	02/10/2010	100.09	100.09	100.11	1
LG&E		C1S	857057	03/2010	02/10/2010	100.07	99.95	100.16	1
LG&E		C1S	857058	03/2010	02/10/2010	100.10	100.08	100.22	1
LG&E		C1S	857059	03/2010	02/10/2010	100.06	99.91	100.09	1
LG&E		C1S	857060	03/2010	02/10/2010	100.08	99.95	100.11	1
LG&E		C1S	857061	03/2010	02/10/2010	100.05	99.95	100.03	1
LG&E		C1S	857062	03/2010	02/10/2010	100.07	100.10	100.17	1
LG&E		C1S	857063	03/2010	02/10/2010	100.05	99.94	99.98	1
LG&E		C1S	857064	03/2010	02/10/2010	100.10	99.95	100.06	1
LG&E		C1S	857065	03/2010	02/10/2010	100.09	100.05	100.19	1
LG&E		C1S	857066	03/2010	02/10/2010	100.06	99.98	100.03	1
LG&E		C1S	857067	03/2010	02/10/2010	100.07	100.01	100.01	1
LG&E		C1S	857068	03/2010	02/10/2010	100.10	99.98	100.00	1
LG&E		C1S	857069	03/2010	02/10/2010	100.07	100.05	100.19	1
LG&E		C1S	857070	03/2010	02/10/2010	100.09	100.09	100.16	1
LG&E		C1S	857071	03/2010	02/10/2010	100.05	99.92	100.08	1

LG&E	C1S	857072	03/2010	10/2010	100.07	100.08		100.08	1
LG&E	C1S	857073	03/2010	02/10/2010	100.08	100.11		100.15	1
LG&E	C1S	857074	03/2010	02/10/2010	100.06	100.06		100.16	1
LG&E	C1S	857075	03/2010	02/10/2010	100.10	100.09		100.27	1
LG&E	C1S	857076	03/2010	02/10/2010	100.10	99.98		100.06	1
LG&E	C1S	857077	03/2010	02/10/2010	100.06	100.05		100.20	1
LG&E	C1S	857078	03/2010	02/10/2010	100.10	99.98		100.06	1
LG&E	C1S	857079	03/2010	02/10/2010	100.09	99.93		100.02	1
LG&E	C1S	857080	03/2010	02/10/2010	100.05	99.87		99.95	1
LG&E	C1S	857081	03/2010	02/10/2010	100.08	100.04		100.13	1
LG&E	C1S	857082	03/2010	02/10/2010	100.07	99.90		99.97	1
LG&E	C1S	857083	03/2010	02/10/2010	100.06	99.94		100.03	1
LG&E	C1S	857084	03/2010	02/10/2010	100.08	99.96		100.03	1
LG&E	C1S	857085	03/2010	02/10/2010	100.11	100.09		100.21	1
LG&E	C1S	857086	03/2010	02/10/2010	100.09	99.84		100.05	1
LG&E	C1S	857087	03/2010	02/10/2010	100.06	99.90		100.01	1
LG&E	C1S	857088	03/2010	02/10/2010	100.07	99.91		100.00	1
LG&E	C1S	857089	03/2010	02/10/2010	100.05	99.89		100.07	1
LG&E	C1S	857090	03/2010	02/10/2010	100.06	99.95		100.03	1
LG&E	C1S	857091	03/2010	02/10/2010	100.07	99.85		100.05	1
LG&E	C1S	857092	03/2010	02/10/2010	100.09	100.04		100.07	1
LG&E	C1S	857093	03/2010	02/10/2010	100.08	99.96		100.07	1
LG&E	C1S	857094	03/2010	02/10/2010	100.07	100.00		100.06	1
LG&E	C1S	857095	03/2010	02/10/2010	100.05	100.09		100.16	1
LG&E	C1S	857096	03/2010	02/10/2010	100.09	99.98		100.03	1
LG&E	C1S	857097	03/2010	02/10/2010	100.09	100.17		100.18	1
LG&E	C1S	857098	03/2010	02/10/2010	100.06	99.94		100.08	1
LG&E	C1S	857099	03/2010	02/10/2010	100.10	100.04		100.06	1
LG&E	C1S	857100	03/2010	02/10/2010	100.09	99.94		100.08	1
LG&E	C1S	857101	03/2010	02/10/2010	100.07	99.91		100.06	1
LG&E	C1S	857102	03/2010	02/10/2010	100.08	100.01		100.12	1
LG&E	C1S	857103	03/2010	02/10/2010	100.10	99.99		100.12	1
LG&E	C1S	857104	03/2010	02/10/2010	100.08	99.82		100.07	1
LG&E	C1S	857105	03/2010	02/10/2010	100.07	100.00		99.90	1
LG&E	C1S	857106	03/2010	02/10/2010	100.08	100.09		100.21	1
LG&E	C1S	857107	03/2010	02/10/2010	100.08	100.07		100.13	1

LG&E	C1S	857108	03/2010	02/10/2010	100.07	99.97	100.18	1
LG&E	C1S	857109	03/2010	02/10/2010	100.09	100.01	100.06	1
LG&E	C1S	857110	03/2010	02/10/2010	100.06	99.94	99.96	1
LG&E	C1S	857111	03/2010	02/10/2010	100.10	99.96	100.02	1
LG&E	C1S	857112	03/2010	02/10/2010	100.06	100.07	100.23	1
LG&E	C1S	857113	03/2010	02/10/2010	100.07	99.94	100.00	1
LG&E	C1S	857114	03/2010	02/10/2010	100.07	99.90	100.01	1
LG&E	C1S	857115	03/2010	02/10/2010	100.07	100.05	100.19	1
LG&E	C1S	857116	03/2010	02/10/2010	100.08	100.00	100.06	1
LG&E	C1S	857117	03/2010	02/10/2010	100.08	99.97	100.11	1
LG&E	C1S	857118	03/2010	02/10/2010	100.09	99.90	100.09	1
LG&E	C1S	857119	03/2010	02/10/2010	100.07	100.02	99.98	1
LG&E	C1S	857120	03/2010	02/10/2010	100.10	100.07	100.15	1
LG&E	C1S	857121	03/2010	02/10/2010	100.08	99.83	100.07	1
LG&E	C1S	857122	03/2010	02/10/2010	100.07	99.83	100.09	1
LG&E	C1S	857123	03/2010	02/10/2010	100.10	100.09	100.18	1
LG&E	C1S	857124	03/2010	02/10/2010	100.07	99.91	100.11	1
LG&E	C1S	857125	03/2010	02/10/2010	100.08	99.96	100.05	1
LG&E	C1S	857126	03/2010	02/10/2010	100.07	100.03	100.19	1
LG&E	C1S	857127	03/2010	02/10/2010	100.07	99.92	100.07	1
LG&E	C1S	857128	03/2010	02/10/2010	100.07	100.08	100.11	1
LG&E	C1S	857129	03/2010	02/10/2010	100.08	100.07	100.10	1
LG&E	C1S	857130	03/2010	02/10/2010	100.07	100.06	100.18	1
LG&E	C1S	857131	03/2010	02/10/2010	100.09	100.00	100.13	1
LG&E	C1S	857132	03/2010	02/10/2010	100.08	99.86	100.07	1
LG&E	C1S	857133	03/2010	02/10/2010	100.08	99.97	100.03	1
LG&E	C1S	857134	03/2010	02/10/2010	100.10	99.92	100.05	1
LG&E	C1S	857135	03/2010	02/10/2010	100.08	99.92	99.98	1
LG&E	C1S	857136	03/2010	02/10/2010	100.08	99.88	100.08	1
LG&E	C1S	857137	03/2010	02/10/2010	100.07	99.95	100.07	1
LG&E	C1S	857138	03/2010	02/10/2010	100.06	99.83	100.08	1
LG&E	C1S	857139	03/2010	02/10/2010	100.06	100.05	100.17	1
LG&E	C1S	857140	03/2010	02/10/2010	100.10	100.07	100.26	1
LG&E	C1S	857141	03/2010	02/10/2010	100.10	99.93	100.00	1
LG&E	C1S	857142	03/2010	02/10/2010	100.08	99.87	100.02	1
LG&E	C1S	857143	03/2010	02/10/2010	100.06	99.92	100.03	1

LG&E	CIS	857144	03/2010	02/10/2010	100.07	99.96	99.91	1
LG&E	CIS	857145	03/2010	02/10/2010	100.08	99.97	99.98	1
LG&E	CIS	857146	03/2010	02/10/2010	100.10	99.94	100.10	1
LG&E	CIS	857147	03/2010	02/10/2010	100.07	99.96	100.00	1
LG&E	CIS	857148	03/2010	02/10/2010	100.08	99.94	100.12	1
LG&E	CIS	857149	03/2010	02/10/2010	100.06	99.94	100.02	1
LG&E	CIS	857150	03/2010	02/10/2010	100.08	99.95	100.04	1
LG&E	CIS	857151	03/2010	02/10/2010	100.09	99.87	100.06	1
LG&E	CIS	857152	03/2010	02/10/2010	100.08	100.00	100.00	1
LG&E	CIS	857153	03/2010	02/10/2010	100.08	99.97	100.04	1
LG&E	CIS	857154	03/2010	02/10/2010	100.10	100.06	100.19	1
LG&E	CIS	857155	03/2010	02/10/2010	100.10	99.99	100.02	1
LG&E	CIS	857156	03/2010	02/10/2010	100.09	99.99	100.02	1
LG&E	CIS	857157	03/2010	02/10/2010	100.08	99.93	100.07	1
LG&E	CIS	857158	03/2010	02/10/2010	100.08	100.01	100.08	1
LG&E	CIS	857159	03/2010	02/10/2010	100.08	100.01	100.01	1
LG&E	CIS	857160	03/2010	02/10/2010	100.07	100.09	100.18	1
LG&E	CIS	857161	03/2010	02/10/2010	100.06	99.97	100.04	1
LG&E	CIS	857162	03/2010	02/10/2010	100.09	99.98	100.03	1
LG&E	CIS	857163	03/2010	02/10/2010	100.08	99.94	100.11	1
LG&E	CIS	857164	03/2010	02/10/2010	100.10	100.09	100.04	1
LG&E	CIS	857165	03/2010	02/10/2010	100.07	99.94	100.07	1
LG&E	CIS	857166	03/2010	02/10/2010	100.08	99.94	100.06	1
LG&E	CIS	857167	03/2010	02/10/2010	100.06	99.98	100.03	1
LG&E	CIS	857168	03/2010	02/10/2010	100.08	100.08	100.16	1
LG&E	CIS	857169	03/2010	02/10/2010	100.09	99.92	100.10	1
LG&E	CIS	857170	03/2010	02/10/2010	100.06	100.05	100.19	1
LG&E	CIS	857171	03/2010	02/10/2010	100.07	100.03	100.18	1
LG&E	CIS	857172	03/2010	02/10/2010	100.06	100.00	100.14	1
LG&E	CIS	857173	03/2010	02/10/2010	100.06	100.02	100.12	1
LG&E	CIS	857174	03/2010	02/10/2010	100.10	99.93	100.00	1
LG&E	CIS	857175	03/2010	02/10/2010	100.09	99.98	100.06	1
LG&E	CIS	857176	03/2010	02/10/2010	100.08	99.95	100.01	1
LG&E	CIS	857177	03/2010	02/10/2010	100.08	99.94	100.09	1
LG&E	CIS	857178	03/2010	02/10/2010	100.07	100.07	100.14	1
LG&E	CIS	857179	03/2010	02/10/2010	100.10	99.97	100.09	1

LG&E	C1S	857180	03/2010	02/10/2010	100.08	99.91	100.02	1
LG&E	C1S	857181	03/2010	02/10/2010	100.09	99.95	100.03	1
LG&E	C1S	857182	03/2010	02/10/2010	100.08	99.94	100.11	1
LG&E	C1S	857183	03/2010	02/10/2010	100.06	99.89	100.02	1
LG&E	C1S	857184	03/2010	02/10/2010	100.08	100.02	100.01	1
LG&E	C1S	857185	03/2010	02/10/2010	100.06	99.95	100.01	1
LG&E	C1S	857186	03/2010	02/10/2010	100.10	99.92	100.01	1
LG&E	C1S	857187	03/2010	02/10/2010	100.09	99.93	100.08	1
LG&E	C1S	857188	03/2010	02/10/2010	100.05	100.03	100.18	1
LG&E	C1S	857189	03/2010	02/10/2010	100.07	99.86	100.07	1
LG&E	C1S	857190	03/2010	02/10/2010	100.07	99.92	100.05	1
LG&E	C1S	857191	03/2010	02/10/2010	100.07	99.90	100.03	1
LG&E	C1S	857192	03/2010	02/10/2010	100.06	100.03	100.22	1
LG&E	C1S	857193	03/2010	02/10/2010	100.06	99.82	100.03	1
LG&E	C1S	857194	03/2010	02/10/2010	100.08	99.88	100.04	1
LG&E	C1S	857195	03/2010	02/10/2010	100.10	100.06	100.18	1
LG&E	C1S	857196	03/2010	02/10/2010	100.09	99.95	100.02	1
LG&E	C1S	857197	03/2010	02/10/2010	100.09	99.97	100.12	1
LG&E	C1S	857198	03/2010	02/10/2010	100.08	100.10	100.18	1
LG&E	C1S	857199	03/2010	02/10/2010	100.06	99.94	99.92	1
LG&E	C1S	857200	03/2010	02/10/2010	100.06	99.92	99.88	1
LG&E	C1S	857201	03/2010	02/10/2010	100.09	99.95	100.03	1
LG&E	C1S	857202	03/2010	02/10/2010	100.09	99.86	100.10	1
LG&E	C1S	857203	03/2010	02/10/2010	100.06	99.96	100.05	1
LG&E	C1S	857204	03/2010	02/10/2010	100.07	99.93	100.03	1
LG&E	C1S	857205	03/2010	02/10/2010	100.07	99.98	100.01	1
LG&E	C1S	857206	03/2010	02/10/2010	100.08	100.09	100.19	1
LG&E	C1S	857207	03/2010	02/10/2010	100.06	99.97	100.04	1
LG&E	C1S	857208	03/2010	02/10/2010	100.10	100.09	100.02	1
LG&E	C1S	857209	03/2010	02/10/2010	100.09	99.91	100.08	1
LG&E	C1S	857210	03/2010	02/10/2010	100.08	100.11	100.13	1
LG&E	C1S	857211	03/2010	02/10/2010	100.08	100.05	100.10	1
LG&E	C1S	857212	03/2010	02/10/2010	100.09	99.92	99.94	1
LG&E	C1S	857213	03/2010	02/10/2010	100.09	99.88	99.99	1
LG&E	C1S	857214	03/2010	02/10/2010	100.10	99.98	100.11	1
LG&E	C1S	857215	03/2010	02/10/2010	100.08	99.99	100.01	1

LG&E	C1S	857216	03/2010	10/2010	100.07	100.08	100.23	1
LG&E	C1S	857217	03/2010	02/10/2010	100.06	99.99	100.00	1
LG&E	C1S	857218	03/2010	02/10/2010	100.06	99.95	100.13	1
LG&E	C1S	857219	03/2010	02/10/2010	100.06	100.02	100.17	1
LG&E	C1S	857220	03/2010	02/10/2010	100.09	100.04	100.01	1
LG&E	C1S	857221	03/2010	02/10/2010	100.07	99.91	100.08	1
LG&E	C1S	857222	03/2010	02/10/2010	100.07	100.06	100.09	1
LG&E	C1S	857223	03/2010	02/10/2010	100.08	99.96	100.02	1
LG&E	C1S	857224	03/2010	02/10/2010	100.08	100.07	100.18	1
LG&E	C1S	857225	03/2010	02/10/2010	100.09	99.95	100.07	1
LG&E	C1S	857226	03/2010	02/10/2010	100.06	99.98	100.15	1
LG&E	C1S	857227	03/2010	02/10/2010	100.09	99.90	100.07	1
LG&E	C1S	857228	03/2010	02/10/2010	100.06	100.05	100.14	1
LG&E	C1S	857229	03/2010	02/10/2010	100.05	99.99	100.18	1
LG&E	C1S	857230	03/2010	02/10/2010	100.06	99.94	99.97	1
LG&E	C1S	857231	03/2010	02/10/2010	100.09	99.94	100.11	1
LG&E	C1S	857232	03/2010	02/10/2010	100.10	100.08	100.23	1
LG&E	C1S	857233	03/2010	02/10/2010	100.06	99.95	100.03	1
LG&E	C1S	857234	03/2010	02/10/2010	100.10	99.98	99.98	1
LG&E	C1S	857235	03/2010	02/10/2010	100.05	99.95	100.09	1
LG&E	C1S	857236	03/2010	02/10/2010	100.10	99.91	100.10	1
LG&E	C1S	857237	03/2010	02/10/2010	100.08	99.98	100.02	1
LG&E	C1S	857238	03/2010	02/10/2010	100.08	100.00	100.13	1
LG&E	C1S	857239	03/2010	02/10/2010	100.07	99.97	99.98	1
LG&E	C1S	857240	03/2010	02/10/2010	100.09	100.05	100.17	1
LG&E	C1S	857241	03/2010	02/10/2010	100.09	100.10	100.14	1
LG&E	C1S	857242	03/2010	02/10/2010	100.07	100.01	100.08	1
LG&E	C1S	857243	03/2010	02/10/2010	100.07	99.86	100.08	1
LG&E	C1S	857244	03/2010	02/10/2010	100.10	99.87	99.96	1
LG&E	C1S	857245	03/2010	02/10/2010	100.06	99.92	100.08	1
LG&E	C1S	857246	03/2010	02/10/2010	100.07	100.02	100.08	1
LG&E	C1S	857247	03/2010	02/10/2010	100.10	100.06	100.22	1
LG&E	C1S	857248	03/2010	02/10/2010	100.06	100.03	100.23	1
LG&E	C1S	857249	03/2010	02/10/2010	100.06	100.03	100.10	1
LG&E	C1S	857250	03/2010	02/10/2010	100.06	99.95	99.91	1
LG&E	C1S	857251	03/2010	02/10/2010	100.09	99.87	100.06	1

LG&E	C1S	857252	03/2010	02/10/2010	100.07	100.03	100.12	1
LG&E	C1S	857253	03/2010	02/10/2010	100.09	100.11	100.11	1
LG&E	C1S	857254	03/2010	02/10/2010	100.08	99.98	100.02	1
LG&E	C1S	857255	03/2010	02/10/2010	100.09	99.97	100.02	1
LG&E	C1S	857256	03/2010	02/10/2010	100.08	100.09	100.25	1
LG&E	C1S	857257	03/2010	02/10/2010	100.07	99.93	100.03	1
LG&E	C1S	857258	03/2010	02/10/2010	100.05	100.03	100.12	1
LG&E	C1S	857259	03/2010	02/10/2010	100.07	99.94	100.03	1
LG&E	C1S	857260	03/2010	02/10/2010	100.07	99.97	100.00	1
LG&E	C1S	857261	03/2010	02/10/2010	100.10	100.03	100.19	1
LG&E	C1S	857262	03/2010	02/10/2010	100.06	100.00	99.96	1
LG&E	C1S	857263	03/2010	02/10/2010	100.09	100.02	100.16	1
LG&E	C1S	857264	03/2010	02/10/2010	100.08	100.03	99.95	1
LG&E	C1S	857265	03/2010	02/10/2010	100.05	99.98	100.04	1
LG&E	C1S	857266	03/2010	02/10/2010	100.10	99.97	100.07	1
LG&E	C1S	857267	03/2010	02/10/2010	100.09	100.13	100.20	1
LG&E	C1S	857268	03/2010	02/10/2010	100.10	99.97	100.08	1
LG&E	C1S	857269	03/2010	02/10/2010	100.06	99.84	100.01	1
LG&E	C1S	857270	03/2010	02/10/2010	100.10	100.08	100.15	1
LG&E	C1S	857271	03/2010	02/10/2010	100.10	99.93	100.06	1
LG&E	C1S	857272	03/2010	02/10/2010	100.06	99.90	100.04	1
LG&E	C1S	857273	03/2010	02/10/2010	100.07	99.83	100.08	1
LG&E	C1S	857274	03/2010	02/10/2010	100.06	100.08	100.15	1
LG&E	C1S	857275	03/2010	02/10/2010	100.08	100.02	100.15	1
LG&E	C1S	857276	03/2010	02/10/2010	100.06	99.99	100.14	1
LG&E	C1S	857277	03/2010	02/10/2010	100.06	99.97	99.96	1
LG&E	C1S	857278	03/2010	02/10/2010	100.07	99.94	99.97	1
LG&E	C1S	857279	03/2010	02/10/2010	100.09	99.99	100.01	1
LG&E	C1S	857280	03/2010	02/10/2010	100.08	99.97	100.01	1
LG&E	C1S	857281	03/2010	02/10/2010	100.09	99.83	100.07	1
LG&E	C1S	857282	03/2010	02/10/2010	100.09	99.92	100.00	1
LG&E	C1S	857283	03/2010	02/10/2010	100.09	100.05	100.05	1
LG&E	C1S	857284	03/2010	02/10/2010	100.07	99.83	100.06	1
LG&E	C1S	857285	03/2010	02/10/2010	100.07	100.00	100.13	1
LG&E	C1S	857286	03/2010	02/10/2010	100.09	99.84	100.08	1
LG&E	C1S	857287	03/2010	02/10/2010	100.10	100.10	100.18	1

LG&E	C1S	857288	03/2010	02/10/2010	100.08	100.11	100.13	1
LG&E	C1S	857289	03/2010	02/10/2010	100.09	100.01	100.11	1
LG&E	C1S	857290	03/2010	02/10/2010	100.08	100.01	100.09	1
LG&E	C1S	857291	03/2010	02/10/2010	100.07	99.93	100.04	1
LG&E	C1S	857292	03/2010	02/10/2010	100.08	100.06	100.07	1
LG&E	C1S	857293	03/2010	02/10/2010	100.05	100.03	100.07	1
LG&E	C1S	857294	03/2010	02/10/2010	100.05	99.88	100.03	1
LG&E	C1S	857295	03/2010	02/10/2010	100.07	99.99	99.95	1
LG&E	C1S	857296	03/2010	02/10/2010	100.05	100.06	100.18	1
LG&E	C1S	857297	03/2010	02/10/2010	100.09	100.03	100.18	1
LG&E	C1S	857298	03/2010	02/10/2010	100.06	99.92	100.06	1
LG&E	C1S	857299	03/2010	02/10/2010	100.08	100.00	100.08	1
LG&E	C1S	857300	03/2010	02/10/2010	100.06	99.90	100.08	1
LG&E	C1S	857301	03/2010	02/10/2010	100.08	100.01	100.06	1
LG&E	C1S	857302	03/2010	02/10/2010	100.08	100.01	100.04	1
LG&E	C1S	857303	03/2010	02/10/2010	100.07	99.97	99.91	1
LG&E	C1S	857304	03/2010	02/10/2010	100.06	99.91	100.10	1
LG&E	C1S	857305	03/2010	02/10/2010	100.06	100.00	100.14	1
LG&E	C1S	857306	03/2010	02/10/2010	100.10	99.93	100.03	1
LG&E	C1S	857307	03/2010	02/10/2010	100.05	100.02	100.06	1
LG&E	C1S	857308	03/2010	02/10/2010	100.07	99.95	100.00	1
LG&E	C1S	857309	03/2010	02/10/2010	100.06	99.99	99.93	1
LG&E	C1S	857310	03/2010	02/10/2010	100.09	100.00	100.14	1
LG&E	C1S	857311	03/2010	02/10/2010	100.09	100.10	100.11	1
LG&E	C1S	857312	03/2010	02/10/2010	100.10	100.07	100.20	1
LG&E	C1S	857313	03/2010	02/10/2010	100.08	100.12	100.22	1
LG&E	C1S	857314	03/2010	02/10/2010	100.06	100.09	100.17	1
LG&E	C1S	857315	03/2010	02/10/2010	100.07	100.06	100.15	1
LG&E	C1S	857316	03/2010	02/10/2010	100.06	99.94	99.96	1
LG&E	C1S	857317	03/2010	02/10/2010	100.08	100.05	100.17	1
LG&E	C1S	857318	03/2010	02/10/2010	100.08	100.07	100.22	1
LG&E	C1S	857319	03/2010	02/10/2010	100.09	99.86	100.08	1
LG&E	C1S	857320	03/2010	02/10/2010	100.05	100.04	100.12	1
LG&E	C1S	857321	03/2010	02/10/2010	100.08	99.96	100.02	1
LG&E	C1S	857322	03/2010	02/10/2010	100.10	100.01	100.13	1
LG&E	C1S	857323	03/2010	02/10/2010	100.05	99.90	100.02	1



LG&E	C1S	857324	03/2010	02/10/2010	100.06	99.83	100.06	100.06	1
LG&E	C1S	857325	03/2010	02/10/2010	100.10	99.95	100.05	100.05	1
LG&E	C1S	857326	03/2010	02/10/2010	100.08	99.96	100.11	100.11	1
LG&E	C1S	857327	03/2010	02/10/2010	100.07	99.97	100.02	100.02	1
LG&E	C1S	857328	03/2010	02/10/2010	100.10	100.04	100.24	100.24	1
LG&E	C1S	857329	03/2010	02/10/2010	100.08	99.95	100.01	100.01	1
LG&E	C1S	857330	03/2010	02/10/2010	100.06	99.91	100.05	100.05	1
LG&E	C1S	857331	03/2010	02/10/2010	100.06	99.95	100.01	100.01	1
LG&E	C1S	857332	03/2010	02/10/2010	100.08	100.01	100.13	100.13	1
LG&E	C1S	857333	03/2010	02/10/2010	100.09	99.98	99.97	99.97	1
LG&E	C1S	857334	03/2010	02/10/2010	100.07	99.95	100.06	100.06	1
LG&E	C1S	857335	03/2010	02/10/2010	100.10	99.91	100.06	100.06	1
LG&E	C1S	857336	03/2010	02/10/2010	100.09	100.03	100.08	100.08	1
LG&E	C1S	857337	03/2010	02/10/2010	100.07	99.92	100.03	100.03	1
LG&E	C1S	857338	03/2010	02/10/2010	100.08	100.05	100.11	100.11	1
LG&E	C1S	857339	03/2010	02/10/2010	100.07	100.00	100.09	100.09	1
LG&E	C1S	857340	03/2010	02/10/2010	100.06	99.99	100.17	100.17	1
LG&E	C1S	857341	03/2010	02/10/2010	100.07	99.91	100.02	100.02	1
LG&E	C1S	857342	03/2010	02/10/2010	100.06	100.05	100.16	100.16	1
LG&E	C1S	857343	03/2010	02/10/2010	100.07	99.87	100.07	100.07	1
LG&E	C1S	857344	03/2010	02/10/2010	100.10	100.12	100.19	100.19	1
LG&E	C1S	857345	03/2010	02/10/2010	100.06	99.92	99.98	99.98	1
LG&E	C1S	857346	03/2010	02/10/2010	100.10	99.97	100.14	100.14	1
LG&E	C1S	857347	03/2010	02/10/2010	100.09	99.91	100.05	100.05	1
LG&E	C1S	857348	03/2010	02/10/2010	100.09	99.98	100.00	100.00	1
LG&E	C1S	857349	03/2010	02/10/2010	100.09	99.97	100.01	100.01	1
LG&E	C1S	857350	03/2010	02/10/2010	100.09	99.90	100.07	100.07	1
LG&E	C1S	857351	03/2010	02/10/2010	100.06	99.83	100.06	100.06	1
LG&E	C1S	857352	03/2010	02/10/2010	100.08	100.00	100.02	100.02	1
LG&E	C1S	857353	03/2010	02/10/2010	100.08	100.05	100.13	100.13	1
LG&E	C1S	857354	03/2010	02/10/2010	100.10	100.08	100.18	100.18	1
LG&E	C1S	857355	03/2010	02/10/2010	100.08	100.07	100.20	100.20	1
LG&E	C1S	857356	03/2010	02/10/2010	100.10	99.93	100.12	100.12	1
LG&E	C1S	857357	03/2010	02/10/2010	100.09	100.06	100.10	100.10	1
LG&E	C1S	857358	03/2010	02/10/2010	100.06	100.05	100.10	100.10	1
LG&E	C1S	857359	03/2010	02/10/2010	100.06	100.08	100.15	100.15	1

LG&E	C1S	857360	03/2010	02/10/2010	100.06	99.94	99.98	1
LG&E	C1S	857361	03/2010	02/10/2010	100.09	99.93	100.00	1
LG&E	C1S	857362	03/2010	02/10/2010	100.06	100.00	100.15	1
LG&E	C1S	857363	03/2010	02/10/2010	100.08	99.94	100.05	1
LG&E	C1S	857364	03/2010	02/10/2010	100.06	100.03	100.18	1
LG&E	C1S	857365	03/2010	02/10/2010	100.08	99.92	100.03	1
LG&E	C1S	857366	03/2010	02/10/2010	100.06	100.05	100.15	1
LG&E	C1S	857367	03/2010	02/10/2010	100.06	99.91	99.99	1
LG&E	C1S	857368	03/2010	02/10/2010	100.09	100.04	100.08	1
LG&E	C1S	857369	03/2010	02/10/2010	100.07	100.09	100.25	1
LG&E	C1S	857370	03/2010	02/10/2010	100.08	100.02	100.04	1
LG&E	C1S	857371	03/2010	02/10/2010	100.06	100.01	100.07	1
LG&E	C1S	857372	03/2010	02/10/2010	100.08	99.95	99.95	1
LG&E	C1S	857373	03/2010	02/10/2010	100.10	100.04	99.97	1
LG&E	C1S	857374	03/2010	02/10/2010	100.07	100.01	100.04	1
LG&E	C1S	857375	03/2010	02/10/2010	100.07	99.80	100.08	1
LG&E	C1S	857376	03/2010	02/10/2010	100.06	100.10	100.20	1
LG&E	C1S	857377	03/2010	02/10/2010	100.08	99.91	100.03	1
LG&E	C1S	857378	03/2010	02/10/2010	100.07	99.83	100.05	1
LG&E	C1S	857379	03/2010	02/10/2010	100.06	99.94	100.05	1
LG&E	C1S	857380	03/2010	02/10/2010	100.10	100.00	99.97	1
LG&E	C1S	857381	03/2010	02/10/2010	100.09	99.94	100.08	1
LG&E	C1S	857382	03/2010	02/10/2010	100.05	99.90	99.99	1
LG&E	C1S	857383	03/2010	02/10/2010	100.09	99.98	99.98	1
LG&E	C1S	857384	03/2010	02/10/2010	100.10	99.96	100.07	1
LG&E	C1S	857385	03/2010	02/10/2010	100.10	99.90	99.99	1
LG&E	C1S	857386	03/2010	02/10/2010	100.09	100.05	100.17	1
LG&E	C1S	857387	03/2010	02/10/2010	100.08	99.94	100.08	1
LG&E	C1S	857388	03/2010	02/10/2010	100.07	99.87	100.01	1
LG&E	C1S	857389	03/2010	02/10/2010	100.07	100.04	100.17	1
LG&E	C1S	857390	03/2010	02/10/2010	100.08	100.07	100.16	1
LG&E	C1S	857391	03/2010	02/10/2010	100.06	99.87	100.03	1
LG&E	C1S	857392	03/2010	02/10/2010	100.06	100.04	100.08	1
LG&E	C1S	857393	03/2010	02/10/2010	100.05	99.86	100.04	1
LG&E	C1S	857394	03/2010	02/10/2010	100.08	99.88	100.10	1
LG&E	C1S	857395	03/2010	02/10/2010	100.06	99.90	100.01	1

LG&E	C1S	857396	03/2010	02/10/2010	100.07	99.97	100.06	1
LG&E	C1S	857397	03/2010	02/10/2010	100.08	99.86	100.00	1
LG&E	C1S	857398	03/2010	02/10/2010	100.09	99.98	100.10	1
LG&E	C1S	857399	03/2010	02/10/2010	100.09	99.93	100.03	1
LG&E	C1S	857400	03/2010	02/10/2010	100.08	100.02	100.06	1
LG&E	C1S	857401	03/2010	02/10/2010	100.10	100.10	100.13	1
LG&E	C1S	857402	03/2010	02/10/2010	100.09	99.96	100.04	1
LG&E	C1S	857403	03/2010	02/10/2010	100.05	99.92	100.00	1
LG&E	C1S	857404	03/2010	02/10/2010	100.09	100.05	100.14	1
LG&E	C1S	857405	03/2010	02/10/2010	100.09	100.04	100.15	1
LG&E	C1S	857406	03/2010	02/10/2010	100.10	99.96	100.06	1
LG&E	C1S	857407	03/2010	02/10/2010	100.09	99.96	100.06	1
LG&E	C1S	857408	03/2010	02/10/2010	100.09	99.96	100.02	1
LG&E	C1S	857409	03/2010	02/10/2010	100.10	100.06	100.22	1
LG&E	C1S	857410	03/2010	02/10/2010	100.05	100.06	100.17	1
LG&E	C1S	857411	03/2010	02/10/2010	100.08	99.97	99.92	1
LG&E	C1S	857412	03/2010	02/10/2010	100.10	100.06	100.13	1
LG&E	C1S	857413	03/2010	02/10/2010	100.08	99.81	100.09	1
LG&E	C1S	857414	03/2010	02/10/2010	100.10	99.87	100.05	1
LG&E	C1S	857415	03/2010	02/10/2010	100.06	99.94	99.99	1
LG&E	C1S	857416	03/2010	02/10/2010	100.06	99.89	99.95	1
LG&E	C1S	857417	03/2010	02/10/2010	100.05	99.98	100.09	1
LG&E	C1S	857418	03/2010	02/10/2010	100.08	100.06	100.08	1
LG&E	C1S	857419	03/2010	02/10/2010	100.07	100.06	100.17	1
LG&E	C1S	857420	03/2010	02/10/2010	100.09	99.98	100.00	1
LG&E	C1S	857421	03/2010	02/10/2010	100.07	99.92	100.08	1
LG&E	C1S	857422	03/2010	02/10/2010	100.10	99.91	100.09	1
LG&E	C1S	857423	03/2010	02/10/2010	100.06	99.93	99.94	1
LG&E	C1S	857424	03/2010	02/10/2010	100.10	99.88	100.01	1
LG&E	C1S	857425	03/2010	02/10/2010	100.06	99.96	99.92	1
LG&E	C1S	857426	03/2010	02/10/2010	100.08	100.00	100.04	1
LG&E	C1S	857427	03/2010	02/10/2010	100.07	99.98	100.00	1
LG&E	C1S	857428	03/2010	02/10/2010	100.09	100.04	100.13	1
LG&E	C1S	857429	03/2010	02/10/2010	100.08	99.96	100.12	1
LG&E	C1S	857430	03/2010	02/10/2010	100.08	99.94	100.04	1
LG&E	C1S	857431	03/2010	02/10/2010	100.07	99.91	99.95	1

LG&E	C1S	857432	03/2010	02/10/2010	100.08	99.95	99.92	1
LG&E	C1S	857433	03/2010	02/10/2010	100.06	99.94	99.88	1
LG&E	C1S	857434	03/2010	02/10/2010	100.10	99.94	100.06	1
LG&E	C1S	857435	03/2010	02/10/2010	100.08	100.02	100.10	1
LG&E	C1S	857436	03/2010	02/10/2010	100.09	99.90	100.11	1
LG&E	C1S	857437	03/2010	02/10/2010	100.08	99.86	100.08	1
LG&E	C1S	857438	03/2010	02/10/2010	100.09	99.87	100.08	1
LG&E	C1S	857439	03/2010	02/10/2010	100.10	100.05	100.15	1
LG&E	C1S	857440	03/2010	02/10/2010	100.10	100.06	100.16	1
LG&E	C1S	857441	03/2010	02/10/2010	100.11	99.94	100.02	1
LG&E	C1S	857442	03/2010	02/10/2010	100.06	99.89	99.93	1
LG&E	C1S	857443	03/2010	02/10/2010	100.06	99.98	100.06	1
LG&E	C1S	857444	03/2010	02/10/2010	100.08	100.07	100.20	1
LG&E	C1S	857445	03/2010	02/10/2010	100.09	100.11	100.18	1
LG&E	C1S	857446	03/2010	02/10/2010	100.05	99.93	100.01	1
LG&E	C1S	857447	03/2010	02/10/2010	100.07	99.96	100.05	1
LG&E	C1S	857448	03/2010	02/10/2010	100.10	100.09	100.17	1
LG&E	C1S	857449	03/2010	02/10/2010	100.08	100.14	100.12	1
LG&E	C1S	857450	03/2010	02/10/2010	100.08	100.13	100.25	1
LG&E	C1S	857451	03/2010	02/10/2010	100.06	99.91	99.97	1
LG&E	C1S	857452	03/2010	02/10/2010	100.08	100.08	100.23	1
LG&E	C1S	857453	03/2010	02/10/2010	100.05	100.07	100.13	1
LG&E	C1S	857454	03/2010	02/10/2010	100.07	99.99	100.05	1
LG&E	C1S	857455	03/2010	02/10/2010	100.05	100.03	100.15	1
LG&E	C1S	857456	03/2010	02/10/2010	100.09	100.11	100.14	1
LG&E	C1S	857457	03/2010	02/10/2010	100.06	99.84	100.01	1
LG&E	C1S	857458	03/2010	02/10/2010	100.06	100.00	100.16	1
LG&E	C1S	857459	03/2010	02/10/2010	100.06	99.98	100.08	1
LG&E	C1S	857460	03/2010	02/10/2010	100.10	100.05	99.96	1
LG&E	C1S	857461	03/2010	02/10/2010	100.06	99.87	100.07	1
LG&E	C1S	857462	03/2010	02/10/2010	100.09	99.94	100.11	1
LG&E	C1S	857463	03/2010	02/10/2010	100.09	100.15	100.22	1
LG&E	C1S	857464	03/2010	02/10/2010	100.10	99.99	100.02	1
LG&E	C1S	857465	03/2010	02/10/2010	100.06	99.89	99.95	1
LG&E	C1S	857466	03/2010	02/10/2010	100.07	100.07	100.07	1
LG&E	C1S	857467	03/2010	02/10/2010	100.08	100.02	100.09	1

LG&E	CIS	857468	03/2010	02/10/2010	100.09	100.06	100.14	1
LG&E	CIS	857469	03/2010	02/10/2010	100.07	100.13	100.16	1
LG&E	CIS	857470	03/2010	02/10/2010	100.10	100.05	100.21	1
LG&E	CIS	857471	03/2010	02/10/2010	100.06	99.81	99.98	1
LG&E	CIS	857472	03/2010	02/10/2010	100.09	100.02	100.12	1
LG&E	CIS	857473	03/2010	02/10/2010	100.07	100.04	100.16	1
LG&E	CIS	857474	03/2010	02/10/2010	100.08	99.97	100.01	1
LG&E	CIS	857475	03/2010	02/10/2010	100.05	99.81	99.97	1
LG&E	CIS	857476	03/2010	02/10/2010	100.09	99.93	99.99	1
LG&E	CIS	857477	03/2010	02/10/2010	100.06	99.99	100.06	1
LG&E	CIS	857478	03/2010	02/10/2010	100.07	99.92	100.06	1
LG&E	CIS	857479	03/2010	02/10/2010	100.10	100.11	100.18	1
LG&E	CIS	857480	03/2010	02/10/2010	100.10	100.07	100.26	1
LG&E	CIS	857481	03/2010	02/10/2010	100.10	100.08	100.15	1
LG&E	CIS	857482	03/2010	02/10/2010	100.10	99.92	100.09	1
LG&E	CIS	857483	03/2010	02/10/2010	100.07	99.95	100.04	1
LG&E	CIS	857484	03/2010	02/10/2010	100.05	99.90	99.93	1
LG&E	CIS	857485	03/2010	02/10/2010	100.08	100.05	100.21	1
LG&E	CIS	857486	03/2010	02/10/2010	100.07	99.89	100.00	1
LG&E	CIS	857487	03/2010	02/10/2010	100.09	99.98	100.04	1
LG&E	CIS	857488	03/2010	02/10/2010	100.09	99.96	99.98	1
LG&E	CIS	857489	03/2010	02/10/2010	100.05	99.85	100.04	1
LG&E	CIS	857490	03/2010	02/10/2010	100.08	100.11	100.20	1
LG&E	CIS	857491	03/2010	02/10/2010	100.06	99.85	99.93	1
LG&E	CIS	857492	03/2010	02/10/2010	100.08	99.93	100.06	1
LG&E	CIS	857493	03/2010	02/10/2010	100.09	99.98	100.06	1
LG&E	CIS	857494	03/2010	02/10/2010	100.08	99.95	99.93	1
LG&E	CIS	857495	03/2010	02/10/2010	100.06	99.98	100.02	1
LG&E	CIS	857496	03/2010	02/10/2010	100.06	100.07	100.15	1
LG&E	CIS	857497	03/2010	02/10/2010	100.06	100.05	100.12	1
LG&E	CIS	857498	03/2010	02/10/2010	100.09	100.04	100.19	1
LG&E	CIS	857499	03/2010	02/10/2010	100.08	100.00	100.08	1
LG&E	CIS	857500	03/2010	02/10/2010	100.08	100.00	100.08	1
LG&E	CIS	857501	03/2010	02/10/2010	100.10	99.96	100.07	1
LG&E	CIS	857502	03/2010	02/10/2010	100.06	100.09	100.18	1
LG&E	CIS	857503	03/2010	02/10/2010	100.09	100.04	100.18	1

LG&E	CIS	857504	03/2010	02/10/2010	100.07	99.88	100.02	1
LG&E	CIS	857505	03/2010	02/10/2010	100.06	99.82	100.03	1
LG&E	CIS	857506	03/2010	02/10/2010	100.06	99.94	100.06	1
LG&E	CIS	857507	03/2010	02/10/2010	100.07	99.94	100.00	1
LG&E	CIS	857508	03/2010	02/10/2010	100.08	100.11	100.16	1
LG&E	CIS	857509	03/2010	02/10/2010	100.10	100.01	100.00	1
LG&E	CIS	857510	03/2010	02/10/2010	100.10	99.92	100.01	1
LG&E	CIS	857511	03/2010	02/10/2010	100.09	100.08	100.25	1
LG&E	CIS	857512	03/2010	02/10/2010	100.09	99.93	100.06	1
LG&E	CIS	857513	03/2010	02/10/2010	100.09	99.89	100.07	1
LG&E	CIS	857514	03/2010	02/10/2010	100.06	99.82	99.97	1
LG&E	CIS	857515	03/2010	02/10/2010	100.10	99.94	100.12	1
LG&E	CIS	857516	03/2010	02/10/2010	100.10	100.02	100.09	1
LG&E	CIS	857517	03/2010	02/10/2010	100.09	99.98	99.97	1
LG&E	CIS	857518	03/2010	02/10/2010	100.05	100.02	100.15	1
LG&E	CIS	857519	03/2010	02/10/2010	100.09	100.04	100.14	1
LG&E	CIS	857520	03/2010	02/10/2010	100.06	99.93	100.01	1
LG&E	CIS	857521	03/2010	02/10/2010	100.09	100.07	100.05	1
LG&E	CIS	857522	03/2010	02/10/2010	100.08	100.05	100.14	1
LG&E	CIS	857523	03/2010	02/10/2010	100.08	100.07	100.01	1
LG&E	CIS	857524	03/2010	02/10/2010	100.09	99.93	100.06	1
LG&E	CIS	857525	03/2010	02/10/2010	100.06	99.93	100.03	1
LG&E	CIS	857526	03/2010	02/10/2010	100.10	99.92	100.01	1
LG&E	CIS	857527	03/2010	02/10/2010	100.09	100.11	100.17	1
LG&E	CIS	857528	03/2010	02/10/2010	100.10	99.93	100.19	1
LG&E	CIS	857529	03/2010	02/10/2010	100.08	100.12	100.17	1
LG&E	CIS	857530	03/2010	02/10/2010	100.08	100.00	100.08	1
LG&E	CIS	857531	03/2010	02/10/2010	100.07	99.90	100.10	1
LG&E	CIS	857532	03/2010	02/10/2010	100.09	100.02	100.14	1
LG&E	CIS	857533	03/2010	02/10/2010	100.09	99.87	100.06	1
LG&E	CIS	857534	03/2010	02/10/2010	100.10	99.96	99.97	1
LG&E	CIS	857535	03/2010	02/10/2010	100.06	100.00	100.19	1
LG&E	CIS	857536	03/2010	02/10/2010	100.10	100.07	100.16	1
LG&E	CIS	857537	03/2010	02/10/2010	100.09	100.13	100.13	1
LG&E	CIS	857538	03/2010	02/10/2010	100.06	100.02	100.16	1
LG&E	CIS	857539	03/2010	02/10/2010	100.06	100.12	100.13	1

LG&E	C1S	857540	03/2010	02/10/2010	100.09	99.93	100.11	1
LG&E	C1S	857541	03/2010	02/10/2010	100.10	100.11	100.22	1
LG&E	C1S	857542	03/2010	02/10/2010	100.06	99.93	100.10	1
LG&E	C1S	857543	03/2010	02/10/2010	100.07	99.92	99.85	1
LG&E	C1S	857544	03/2010	02/10/2010	100.07	99.95	100.04	1
LG&E	C1S	857545	03/2010	02/10/2010	100.07	99.91	100.02	1
LG&E	C1S	857546	03/2010	02/10/2010	100.07	99.96	99.94	1
LG&E	C1S	857547	03/2010	02/10/2010	100.10	99.99	100.01	1
LG&E	C1S	857548	03/2010	02/10/2010	100.09	100.01	100.09	1
LG&E	C1S	857549	03/2010	02/10/2010	100.09	99.91	100.08	1
LG&E	C1S	857550	03/2010	02/10/2010	100.06	99.84	99.92	1
LG&E	C1S	857551	03/2010	02/10/2010	100.09	100.05	99.99	1
LG&E	C1S	857552	03/2010	02/10/2010	100.08	100.03	100.20	1
LG&E	C1S	857553	03/2010	02/10/2010	100.09	100.08	100.12	1
LG&E	C1S	857554	03/2010	02/10/2010	100.08	100.01	100.09	1
LG&E	C1S	857555	03/2010	02/10/2010	100.06	99.94	100.14	1
LG&E	C1S	857556	03/2010	02/10/2010	100.07	99.99	100.09	1
LG&E	C1S	857557	03/2010	02/10/2010	100.09	100.08	100.16	1
LG&E	C1S	857558	03/2010	02/10/2010	100.06	99.91	100.00	1
LG&E	C1S	857559	03/2010	02/10/2010	100.07	99.94	99.96	1
LG&E	C1S	857560	03/2010	02/10/2010	100.08	99.95	100.00	1
LG&E	C1S	857561	03/2010	02/10/2010	100.06	99.88	99.93	1
LG&E	C1S	857562	03/2010	02/10/2010	100.06	99.87	100.03	1
LG&E	C1S	857563	03/2010	02/10/2010	100.08	99.98	100.04	1
LG&E	C1S	857564	03/2010	02/10/2010	100.07	100.06	100.14	1
LG&E	C1S	857565	03/2010	02/10/2010	100.05	99.92	100.11	1
LG&E	C1S	857566	03/2010	02/10/2010	100.08	100.08	100.11	1
LG&E	C1S	857567	03/2010	02/10/2010	100.06	99.93	100.03	1
LG&E	C1S	857568	03/2010	02/10/2010	100.10	99.99	100.06	1
LG&E	C1S	857569	03/2010	02/10/2010	100.06	100.06	100.15	1
LG&E	C1S	857570	03/2010	02/10/2010	100.10	99.98	100.09	1
LG&E	C1S	857571	03/2010	02/10/2010	100.06	100.10	100.09	1
LG&E	C1S	857572	03/2010	02/10/2010	100.08	99.95	100.02	1
LG&E	C1S	857573	03/2010	02/10/2010	100.06	100.04	100.11	1
LG&E	C1S	857574	03/2010	02/10/2010	100.07	99.96	100.09	1
LG&E	C1S	857575	03/2010	02/10/2010	100.08	99.97	100.06	1

LG&E	C1S	857576	03/2010	02/10/2010	100.05	99.89	99.88	1
LG&E	C1S	857577	03/2010	02/10/2010	100.08	99.91	100.06	1
LG&E	C1S	857578	03/2010	02/10/2010	100.08	100.03	100.18	1
LG&E	C1S	857579	03/2010	02/10/2010	100.06	99.88	99.98	1
LG&E	C1S	857580	03/2010	02/10/2010	100.06	99.98	100.15	1
LG&E	C1S	857581	03/2010	02/10/2010	100.06	100.03	100.12	1
LG&E	C1S	857582	03/2010	02/10/2010	100.10	99.90	100.10	1
LG&E	C1S	857583	03/2010	02/10/2010	100.05	100.03	100.10	1
LG&E	C1S	857584	03/2010	02/10/2010	100.08	100.09	100.10	1
LG&E	C1S	857585	03/2010	02/10/2010	100.08	100.05	100.13	1
LG&E	C1S	857586	03/2010	02/10/2010	100.10	100.05	100.19	1
LG&E	C1S	857587	03/2010	02/10/2010	100.07	100.03	100.22	1
LG&E	C1S	857588	03/2010	02/10/2010	100.07	100.02	100.16	1
LG&E	C1S	857589	03/2010	02/10/2010	100.07	100.04	100.14	1
LG&E	C1S	857590	03/2010	02/10/2010	100.09	100.07	100.15	1
LG&E	C1S	857591	03/2010	02/10/2010	100.08	100.04	100.09	1
LG&E	C1S	857592	03/2010	02/10/2010	100.06	100.02	100.13	1
LG&E	C1S	857593	03/2010	02/10/2010	100.07	100.07	100.14	1
LG&E	C1S	857594	03/2010	02/10/2010	100.09	99.97	100.02	1
LG&E	C1S	857595	03/2010	02/10/2010	100.08	100.03	100.19	1
LG&E	C1S	857596	03/2010	02/10/2010	100.09	100.05	100.16	1
LG&E	C1S	857597	03/2010	02/10/2010	100.10	99.91	100.05	1
LG&E	C1S	857598	03/2010	02/10/2010	100.05	100.03	100.08	1
LG&E	C1S	857599	03/2010	02/10/2010	100.10	100.13	100.20	1
LG&E	C1S	857600	03/2010	02/10/2010	100.09	99.98	100.05	1
LG&E	C1S	857601	03/2010	02/10/2010	100.10	100.03	100.04	1
LG&E	C1S	857602	03/2010	02/10/2010	100.07	100.05	100.20	1
LG&E	C1S	857603	03/2010	02/10/2010	100.10	100.10	100.20	1
LG&E	C1S	857604	03/2010	02/10/2010	100.08	99.90	100.09	1
LG&E	C1S	857605	03/2010	02/10/2010	100.09	100.07	100.22	1
LG&E	C1S	857606	03/2010	02/10/2010	100.10	99.96	100.05	1
LG&E	C1S	857607	03/2010	02/10/2010	100.07	99.95	100.00	1
LG&E	C1S	857608	03/2010	02/10/2010	100.10	100.04	100.04	1
LG&E	C1S	857609	03/2010	02/10/2010	100.05	99.93	99.98	1
LG&E	C1S	857610	03/2010	02/10/2010	100.10	99.92	100.07	1
LG&E	C1S	857611	03/2010	02/10/2010	100.06	99.93	100.06	1



LG&E	C1S	857612	03/2010	02/10/2010	100.08	100.03	100.15	1
LG&E	C1S	857613	03/2010	02/10/2010	100.06	99.92	99.99	1
LG&E	C1S	857614	03/2010	02/10/2010	100.06	99.91	99.99	1
LG&E	C1S	857615	03/2010	02/10/2010	100.08	100.09	100.07	1
LG&E	C1S	857616	03/2010	02/10/2010	100.07	100.01	100.03	1
LG&E	C1S	857617	03/2010	02/10/2010	100.10	100.07	100.16	1
LG&E	C1S	857618	03/2010	02/10/2010	100.10	99.97	100.05	1
LG&E	C1S	857619	03/2010	02/10/2010	100.06	100.02	100.09	1
LG&E	C1S	857620	03/2010	02/10/2010	100.10	100.05	100.08	1
LG&E	C1S	857621	03/2010	02/10/2010	100.06	99.97	99.92	1
LG&E	C1S	857622	03/2010	02/10/2010	100.08	99.97	100.12	1
LG&E	C1S	857623	03/2010	02/10/2010	100.07	99.94	100.06	1
LG&E	C1S	857624	03/2010	02/10/2010	100.06	99.93	100.03	1
LG&E	C1S	857625	03/2010	02/10/2010	100.07	99.83	100.00	1
LG&E	C1S	857626	03/2010	02/10/2010	100.06	100.09	100.20	1
LG&E	C1S	857627	03/2010	02/10/2010	100.09	99.89	100.07	1
LG&E	C1S	857628	03/2010	02/10/2010	100.06	99.93	100.07	1
LG&E	C1S	857629	03/2010	02/10/2010	100.09	100.19	100.19	1
LG&E	C1S	857630	03/2010	02/10/2010	100.08	99.84	100.05	1
LG&E	C1S	857631	03/2010	02/10/2010	100.10	99.98	100.06	1
LG&E	C1S	857632	03/2010	02/10/2010	100.07	100.05	100.12	1
LG&E	C1S	857633	03/2010	02/10/2010	100.08	100.07	100.15	1
LG&E	C1S	857634	03/2010	02/10/2010	100.06	100.03	100.02	1
LG&E	C1S	857635	03/2010	02/10/2010	100.06	100.03	100.17	1
LG&E	C1S	857636	03/2010	02/10/2010	100.09	99.86	100.05	1
LG&E	C1S	857637	03/2010	02/10/2010	100.05	99.98	100.13	1
LG&E	C1S	857638	03/2010	02/10/2010	100.05	99.96	100.06	1
LG&E	C1S	857639	03/2010	02/10/2010	100.10	99.99	100.04	1
LG&E	C1S	857640	03/2010	02/10/2010	100.06	99.84	100.02	1
LG&E	C1S	857641	03/2010	02/10/2010	100.08	99.99	100.00	1
LG&E	C1S	857642	03/2010	02/10/2010	100.07	99.98	100.02	1
LG&E	C1S	857643	03/2010	02/10/2010	100.08	99.96	100.05	1
LG&E	C1S	857644	03/2010	02/10/2010	100.08	99.89	100.00	1
LG&E	C1S	857645	03/2010	02/10/2010	100.08	99.92	100.08	1
LG&E	C1S	857646	03/2010	02/10/2010	100.08	99.84	100.06	1
LG&E	C1S	857647	03/2010	02/10/2010	100.06	99.84	100.02	1

LG&E	CIS	857648	03/2010	02/10/2010	100.08	99.94	100.04	1
LG&E	CIS	857649	03/2010	02/10/2010	100.07	99.95	100.06	1
LG&E	CIS	857650	03/2010	02/10/2010	100.06	99.95	99.98	1
LG&E	CIS	857651	03/2010	02/10/2010	100.09	99.93	100.02	1
LG&E	CIS	857652	03/2010	02/10/2010	100.08	100.08	100.20	1
LG&E	CIS	857653	03/2010	02/10/2010	100.08	100.13	100.20	1
LG&E	CIS	857654	03/2010	02/10/2010	100.08	100.02	100.00	1
LG&E	CIS	857655	03/2010	02/10/2010	100.07	99.85	99.99	1
LG&E	CIS	857656	03/2010	02/10/2010	100.10	99.97	99.97	1
LG&E	CIS	857657	03/2010	02/10/2010	100.08	100.06	100.00	1
LG&E	CIS	857658	03/2010	02/10/2010	100.10	99.90	99.99	1
LG&E	CIS	857659	03/2010	02/10/2010	100.06	99.86	100.03	1
LG&E	CIS	857660	03/2010	02/10/2010	100.10	100.02	100.04	1
LG&E	CIS	857661	03/2010	02/10/2010	100.07	99.98	100.04	1
LG&E	CIS	857662	03/2010	02/10/2010	100.09	99.91	100.07	1
LG&E	CIS	857663	03/2010	02/10/2010	100.09	99.97	100.02	1
LG&E	CIS	857664	03/2010	02/10/2010	100.10	100.01	100.12	1
LG&E	CIS	857665	03/2010	02/10/2010	100.07	99.99	99.96	1
LG&E	CIS	857666	03/2010	02/10/2010	100.07	100.01	100.01	1
LG&E	CIS	857667	03/2010	02/10/2010	100.09	100.03	100.12	1
LG&E	CIS	857668	03/2010	02/10/2010	100.06	99.91	100.00	1
LG&E	CIS	857669	03/2010	02/10/2010	100.08	100.11	100.16	1
LG&E	CIS	857670	03/2010	02/10/2010	100.06	100.03	99.97	1
LG&E	CIS	857671	03/2010	02/10/2010	100.08	99.90	100.08	1
LG&E	CIS	857672	03/2010	02/10/2010	100.09	100.09	100.13	1
LG&E	CIS	857673	03/2010	02/10/2010	100.08	99.95	100.05	1
LG&E	CIS	857674	03/2010	02/10/2010	100.06	99.99	100.17	1
LG&E	CIS	857675	03/2010	02/10/2010	100.07	100.02	100.17	1
LG&E	CIS	857676	03/2010	02/10/2010	100.05	99.86	100.03	1
LG&E	CIS	857677	03/2010	02/10/2010	100.08	100.04	100.12	1
LG&E	CIS	857678	03/2010	02/10/2010	100.08	100.07	100.12	1
LG&E	CIS	857679	03/2010	02/10/2010	100.10	100.11	100.16	1
LG&E	CIS	857680	03/2010	02/10/2010	100.07	100.09	100.10	1
LG&E	CIS	857681	03/2010	02/10/2010	100.06	100.07	100.15	1
LG&E	CIS	857682	03/2010	02/10/2010	100.10	99.95	100.03	1
LG&E	CIS	857683	03/2010	02/10/2010	100.06	100.05	100.16	1

LG&E	C1S	857684	03/2010	10/2010	100.09	100.01	100.08	1
LG&E	C1S	857685	03/2010	02/10/2010	100.09	99.88	100.12	1
LG&E	C1S	857686	03/2010	02/10/2010	100.09	99.91	99.99	1
LG&E	C1S	857687	03/2010	02/10/2010	100.10	100.09	100.23	1
LG&E	C1S	857688	03/2010	02/10/2010	100.10	100.05	100.15	1
LG&E	C1S	857689	03/2010	02/10/2010	100.07	99.96	99.93	1
LG&E	C1S	857690	03/2010	02/10/2010	100.09	99.97	100.00	1
LG&E	C1S	857691	03/2010	02/10/2010	100.06	99.92	100.03	1
LG&E	C1S	857692	03/2010	02/10/2010	100.09	100.03	100.15	1
LG&E	C1S	857693	03/2010	02/10/2010	100.08	99.96	100.04	1
LG&E	C1S	857694	03/2010	02/10/2010	100.10	100.12	100.18	1
LG&E	C1S	857695	03/2010	02/10/2010	100.08	99.98	99.98	1
LG&E	C1S	857696	03/2010	02/10/2010	100.09	99.89	100.06	1
LG&E	C1S	857697	03/2010	02/10/2010	100.05	99.83	100.05	1
LG&E	C1S	857698	03/2010	02/10/2010	100.10	99.88	100.06	1
LG&E	C1S	857699	03/2010	02/10/2010	100.08	100.06	100.13	1
LG&E	C1S	857700	03/2010	02/10/2010	100.07	100.05	100.10	1
LG&E	C1S	857701	03/2010	02/10/2010	100.10	99.91	100.01	1
LG&E	C1S	857702	03/2010	02/10/2010	100.10	100.05	100.17	1
LG&E	C1S	857703	03/2010	02/10/2010	100.09	99.88	100.01	1
LG&E	C1S	857704	03/2010	02/10/2010	100.09	99.85	100.05	1
LG&E	C1S	857705	03/2010	02/10/2010	100.06	99.93	99.99	1
LG&E	C1S	857706	03/2010	02/10/2010	100.06	100.10	100.15	1
LG&E	C1S	857707	03/2010	02/10/2010	100.06	100.03	100.12	1
LG&E	C1S	857708	03/2010	02/10/2010	100.06	99.96	100.00	1
LG&E	C1S	857709	03/2010	02/10/2010	100.07	99.91	100.07	1
LG&E	C1S	857710	03/2010	02/10/2010	100.07	99.92	100.00	1
LG&E	C1S	857711	03/2010	02/10/2010	100.08	99.94	100.07	1
LG&E	C1S	857712	03/2010	02/10/2010	100.05	99.85	100.03	1
LG&E	C1S	857713	03/2010	02/10/2010	100.08	100.07	100.19	1
LG&E	C1S	857714	03/2010	02/10/2010	100.10	100.02	100.17	1
LG&E	C1S	857715	03/2010	02/10/2010	100.08	99.91	100.01	1
LG&E	C1S	857716	03/2010	02/10/2010	100.06	99.90	100.00	1
LG&E	C1S	857717	03/2010	02/10/2010	100.06	99.89	100.02	1
LG&E	C1S	857718	03/2010	02/10/2010	100.08	100.06	100.20	1
LG&E	C1S	857719	03/2010	02/10/2010	100.05	99.99	100.02	1

LG&E	CIS	857720	03/2010	02/10/2010	100.09	99.97	100.03	1
LG&E	CIS	857721	03/2010	02/10/2010	100.09	100.02	100.15	1
LG&E	CIS	857722	03/2010	02/10/2010	100.08	100.01	100.11	1
LG&E	CIS	857723	03/2010	02/10/2010	100.08	99.91	100.06	1
LG&E	CIS	857724	03/2010	02/10/2010	100.08	100.09	100.14	1
LG&E	CIS	857725	03/2010	02/10/2010	100.10	100.03	100.10	1
LG&E	CIS	857726	03/2010	02/10/2010	100.06	100.00	99.96	1
LG&E	CIS	857727	03/2010	02/10/2010	100.08	99.97	100.04	1
LG&E	CIS	857728	03/2010	02/10/2010	100.08	99.86	100.01	1
LG&E	CIS	857729	03/2010	02/10/2010	100.07	99.99	100.09	1
LG&E	CIS	857730	03/2010	02/10/2010	100.10	100.11	100.19	1
LG&E	CIS	857731	03/2010	02/10/2010	100.07	99.93	100.02	1
LG&E	CIS	857732	03/2010	02/10/2010	100.08	99.97	100.04	1
LG&E	CIS	857733	03/2010	02/10/2010	100.05	99.93	99.94	1
LG&E	CIS	857734	03/2010	02/10/2010	100.07	99.99	100.02	1
LG&E	CIS	857735	03/2010	02/10/2010	100.07	99.84	100.06	1
LG&E	CIS	857736	03/2010	02/10/2010	100.09	99.92	100.00	1
LG&E	CIS	857737	03/2010	02/10/2010	100.09	99.91	100.01	1
LG&E	CIS	857738	03/2010	02/10/2010	100.07	100.02	100.15	1
LG&E	CIS	857739	03/2010	02/10/2010	100.09	99.91	100.08	1
LG&E	CIS	857740	03/2010	02/10/2010	100.10	100.04	100.20	1
LG&E	CIS	857741	03/2010	02/10/2010	100.07	100.04	100.00	1
LG&E	CIS	857742	03/2010	02/10/2010	100.07	99.92	100.01	1
LG&E	CIS	857743	03/2010	02/10/2010	100.09	99.86	100.01	1
LG&E	CIS	857744	03/2010	02/10/2010	100.08	99.91	100.00	1
LG&E	CIS	857745	03/2010	02/10/2010	100.08	99.96	100.06	1
LG&E	CIS	857746	03/2010	02/10/2010	100.05	99.92	100.01	1
LG&E	CIS	857747	03/2010	02/10/2010	100.06	99.97	100.07	1
LG&E	CIS	857748	03/2010	02/10/2010	100.07	99.93	100.03	1
LG&E	CIS	857749	03/2010	02/10/2010	100.08	99.85	100.05	1
LG&E	CIS	857750	03/2010	02/10/2010	100.06	100.08	100.16	1
LG&E	CIS	857751	03/2010	02/10/2010	100.06	99.96	99.98	1
LG&E	CIS	857752	03/2010	02/10/2010	100.05	99.94	100.05	1
LG&E	CIS	857753	03/2010	02/10/2010	100.08	100.07	100.11	1
LG&E	CIS	857754	03/2010	02/10/2010	100.06	100.04	99.98	1
LG&E	CIS	857755	03/2010	02/10/2010	100.09	99.93	100.10	1

LG&E	C1S	857756	03/2010	01/2010	100.06	100.08	100.09	1
LG&E	C1S	857757	03/2010	02/10/2010	100.06	99.99	100.12	1
LG&E	C1S	857758	03/2010	02/10/2010	100.05	99.87	100.01	1
LG&E	C1S	857759	03/2010	02/10/2010	100.07	100.10	100.19	1
LG&E	C1S	857760	03/2010	02/10/2010	100.10	99.94	100.04	1
LG&E	C1S	857761	03/2010	02/10/2010	100.08	99.87	99.95	1
LG&E	C1S	857762	03/2010	02/10/2010	100.09	99.94	100.04	1
LG&E	C1S	857763	03/2010	02/10/2010	100.08	99.92	100.00	1
LG&E	C1S	857764	03/2010	02/10/2010	100.07	99.94	100.02	1
LG&E	C1S	857765	03/2010	02/10/2010	100.08	99.97	100.09	1
LG&E	C1S	857766	03/2010	02/10/2010	100.09	100.00	100.01	1
LG&E	C1S	857767	03/2010	02/10/2010	100.07	99.98	99.97	1
LG&E	C1S	857768	03/2010	02/10/2010	100.10	99.96	100.11	1
LG&E	C1S	857769	03/2010	02/10/2010	100.09	99.99	100.19	1
LG&E	C1S	857770	03/2010	02/10/2010	100.10	99.94	100.09	1
LG&E	C1S	857771	03/2010	02/10/2010	100.07	99.94	99.99	1
LG&E	C1S	857772	03/2010	02/10/2010	100.08	99.95	100.08	1
LG&E	C1S	857773	03/2010	02/10/2010	100.09	99.85	100.01	1
LG&E	C1S	857774	03/2010	02/10/2010	100.06	100.03	100.15	1
LG&E	C1S	857775	03/2010	02/10/2010	100.08	99.94	100.07	1
LG&E	C1S	857776	03/2010	02/10/2010	100.09	99.87	100.05	1
LG&E	C1S	857777	03/2010	02/10/2010	100.10	99.94	100.08	1
LG&E	C1S	857778	03/2010	02/10/2010	100.08	99.94	99.97	1
LG&E	C1S	857779	03/2010	02/10/2010	100.08	99.94	100.11	1
LG&E	C1S	857780	03/2010	02/10/2010	100.08	99.88	100.07	1
LG&E	C1S	857781	03/2010	02/10/2010	100.07	99.96	100.09	1
LG&E	C1S	857782	03/2010	02/10/2010	100.08	100.07	100.18	1
LG&E	C1S	857783	03/2010	02/10/2010	100.06	100.07	100.17	1
LG&E	C1S	857784	03/2010	02/10/2010	100.09	99.97	100.06	1
LG&E	C1S	857785	03/2010	02/10/2010	100.09	100.06	100.16	1
LG&E	C1S	857786	03/2010	02/10/2010	100.09	99.93	100.06	1
LG&E	C1S	857787	03/2010	02/10/2010	100.07	99.89	100.01	1
LG&E	C1S	857788	03/2010	02/10/2010	100.07	99.92	100.09	1
LG&E	C1S	857789	03/2010	02/10/2010	100.09	99.97	100.09	1
LG&E	C1S	857790	03/2010	02/10/2010	100.07	100.08	100.16	1
LG&E	C1S	857791	03/2010	02/10/2010	100.09	100.10	100.18	1

LG&E	C1S	857792	03/2010	02/10/2010	100.09	100.05	100.17	1
LG&E	C1S	857793	03/2010	02/10/2010	100.09	99.97	100.07	1
LG&E	C1S	857794	03/2010	02/10/2010	100.06	99.85	100.01	1
LG&E	C1S	857795	03/2010	02/10/2010	100.09	99.93	99.98	1
LG&E	C1S	857796	03/2010	02/10/2010	100.08	99.95	100.09	1
LG&E	C1S	857797	03/2010	02/10/2010	100.08	99.93	100.09	1
LG&E	C1S	857798	03/2010	02/10/2010	100.09	100.03	100.18	1
LG&E	C1S	857799	03/2010	02/10/2010	100.06	100.09	100.19	1
LG&E	C1S	857800	03/2010	02/10/2010	100.08	99.98	99.99	1
LG&E	C1S	857801	03/2010	02/10/2010	100.09	99.99	100.07	1
LG&E	C1S	857802	03/2010	02/10/2010	100.07	99.91	100.08	1
LG&E	C1S	857803	03/2010	02/10/2010	100.08	100.01	100.11	1
LG&E	C1S	857804	03/2010	02/10/2010	100.06	99.85	100.02	1
LG&E	C1S	857805	03/2010	02/10/2010	100.09	100.06	100.19	1
LG&E	C1S	857806	03/2010	02/10/2010	100.06	99.91	100.01	1
LG&E	C1S	857807	03/2010	02/10/2010	100.09	100.12	100.17	1
LG&E	C1S	857808	03/2010	02/10/2010	100.07	99.90	100.07	1
LG&E	C1S	857809	03/2010	02/10/2010	100.05	99.86	100.03	1
LG&E	C1S	857810	03/2010	02/10/2010	100.08	100.01	100.14	1
LG&E	C1S	857811	03/2010	02/10/2010	100.08	100.00	100.04	1
LG&E	C1S	857812	03/2010	02/10/2010	100.06	100.04	100.16	1
LG&E	C1S	857813	03/2010	02/10/2010	100.06	99.87	99.98	1
LG&E	C1S	857814	03/2010	02/10/2010	100.08	100.00	99.98	1
LG&E	C1S	857815	03/2010	02/10/2010	100.06	99.87	100.01	1
LG&E	C1S	857816	03/2010	02/10/2010	100.09	100.06	100.10	1
LG&E	C1S	857817	03/2010	02/10/2010	100.07	99.86	99.94	1
LG&E	C1S	857818	03/2010	02/10/2010	100.06	100.01	100.14	1
LG&E	C1S	857819	03/2010	02/10/2010	100.08	100.06	100.17	1
LG&E	C1S	857820	03/2010	02/10/2010	100.06	100.03	100.06	1
LG&E	C1S	857821	03/2010	02/10/2010	100.09	99.97	100.04	1
LG&E	C1S	857822	03/2010	02/10/2010	100.09	99.98	100.03	1
LG&E	C1S	857823	03/2010	02/10/2010	100.08	99.91	99.98	1
LG&E	C1S	857824	03/2010	02/10/2010	100.10	100.05	100.20	1
LG&E	C1S	857825	03/2010	02/10/2010	100.09	99.97	100.01	1
LG&E	C1S	857826	03/2010	02/10/2010	100.06	100.01	100.14	1
LG&E	C1S	857827	03/2010	02/10/2010	100.07	99.89	100.13	1

LG&E	C1S	857828	03/2010	02/10/2010	100.10	100.09	100.14	1
LG&E	C1S	857829	03/2010	02/10/2010	100.07	99.94	100.02	1
LG&E	C1S	857830	03/2010	02/10/2010	100.06	99.87	100.01	1
LG&E	C1S	857831	03/2010	02/10/2010	100.05	99.86	100.06	1
LG&E	C1S	857832	03/2010	02/10/2010	100.06	100.00	100.04	1
LG&E	C1S	857833	03/2010	02/10/2010	100.07	99.82	100.03	1
LG&E	C1S	857834	03/2010	02/10/2010	100.08	99.91	100.12	1
LG&E	C1S	857835	03/2010	02/10/2010	100.08	99.92	100.02	1
LG&E	C1S	857836	03/2010	02/10/2010	100.07	99.85	100.06	1
LG&E	C1S	857837	03/2010	02/10/2010	100.06	100.01	100.15	1
LG&E	C1S	857838	03/2010	02/10/2010	100.08	99.91	100.03	1
LG&E	C1S	857839	03/2010	02/10/2010	100.08	99.89	99.92	1
LG&E	C1S	857840	03/2010	02/10/2010	100.10	99.98	100.11	1
LG&E	C1S	857841	03/2010	02/10/2010	100.07	100.04	99.99	1
LG&E	C1S	857842	03/2010	02/10/2010	100.06	99.90	100.00	1
LG&E	C1S	857843	03/2010	02/10/2010	100.09	100.12	100.21	1
LG&E	C1S	857844	03/2010	02/10/2010	100.08	99.88	99.97	1
LG&E	C1S	857845	03/2010	02/10/2010	100.10	99.85	100.03	1
LG&E	C1S	857846	03/2010	02/10/2010	100.06	99.92	100.03	1
LG&E	C1S	857847	03/2010	02/10/2010	100.08	99.83	100.02	1
LG&E	C1S	857848	03/2010	02/10/2010	100.08	100.02	100.09	1
LG&E	C1S	857849	03/2010	02/10/2010	100.10	100.07	100.08	1
LG&E	C1S	857850	03/2010	02/10/2010	100.06	99.92	99.95	1
LG&E	C1S	857851	03/2010	02/10/2010	100.09	100.00	99.92	1
LG&E	C1S	857852	03/2010	02/10/2010	100.05	99.99	100.01	1
LG&E	C1S	857853	03/2010	02/10/2010	100.07	100.07	100.17	1
LG&E	C1S	857854	03/2010	02/10/2010	100.08	99.80	100.03	1
LG&E	C1S	857855	03/2010	02/10/2010	100.10	100.08	100.19	1
LG&E	C1S	857856	03/2010	02/10/2010	100.08	100.07	100.11	1
LG&E	C1S	857857	03/2010	02/10/2010	100.09	100.05	100.22	1
LG&E	C1S	857858	03/2010	02/10/2010	100.06	99.83	100.04	1
LG&E	C1S	857859	03/2010	02/10/2010	100.10	100.07	100.23	1
LG&E	C1S	857860	03/2010	02/10/2010	100.10	99.92	100.08	1
LG&E	C1S	857861	03/2010	02/10/2010	100.07	99.91	100.02	1
LG&E	C1S	857862	03/2010	02/10/2010	100.06	100.01	100.18	1
LG&E	C1S	857863	03/2010	02/10/2010	100.10	99.82	100.09	1

LG&E	C1S	857864	03/2010	02/10/2010	100.10	100.15	100.26	1
LG&E	C1S	857865	03/2010	02/10/2010	100.07	100.07	100.17	1
LG&E	C1S	857866	03/2010	02/10/2010	100.07	100.00	100.11	1
LG&E	C1S	857867	03/2010	02/10/2010	100.08	100.06	100.17	1
LG&E	C1S	857868	03/2010	02/10/2010	100.08	99.92	100.04	1
LG&E	C1S	857869	03/2010	02/10/2010	100.07	99.97	100.02	1
LG&E	C1S	857870	03/2010	02/10/2010	100.06	99.92	100.03	1
LG&E	C1S	857871	03/2010	02/10/2010	100.08	100.02	100.00	1
LG&E	C1S	857872	03/2010	02/10/2010	100.08	99.93	100.07	1
LG&E	C1S	857873	03/2010	02/10/2010	100.06	100.10	100.19	1
LG&E	C1S	857874	03/2010	02/10/2010	100.06	99.89	100.04	1
LG&E	C1S	857875	03/2010	02/10/2010	100.08	100.01	100.17	1
LG&E	C1S	857876	03/2010	02/10/2010	100.07	100.10	100.22	1
LG&E	C1S	857877	03/2010	02/10/2010	100.09	99.96	100.06	1
LG&E	C1S	857878	03/2010	02/10/2010	100.07	100.07	100.19	1
LG&E	C1S	857879	03/2010	02/10/2010	100.10	99.85	100.10	1
LG&E	C1S	857880	03/2010	02/10/2010	100.08	99.95	100.07	1
LG&E	C1S	857881	03/2010	02/10/2010	100.05	100.02	100.12	1
LG&E	C1S	857882	03/2010	02/10/2010	100.10	100.10	100.16	1
LG&E	C1S	857883	03/2010	02/10/2010	100.08	100.15	100.18	1
LG&E	C1S	857884	03/2010	02/10/2010	100.09	99.93	100.08	1
LG&E	C1S	857885	03/2010	02/10/2010	100.09	99.94	100.07	1
LG&E	C1S	857886	03/2010	02/10/2010	100.06	100.05	100.18	1
LG&E	C1S	857887	03/2010	02/10/2010	100.08	100.06	100.18	1
LG&E	C1S	857888	03/2010	02/10/2010	100.08	99.98	100.01	1
LG&E	C1S	857889	03/2010	02/10/2010	100.07	99.97	99.99	1
LG&E	C1S	857890	03/2010	02/10/2010	100.09	99.92	100.09	1
LG&E	C1S	857891	03/2010	02/10/2010	100.07	100.10	100.19	1
LG&E	C1S	857892	03/2010	02/10/2010	100.09	99.97	100.07	1
LG&E	C1S	857893	03/2010	02/10/2010	100.08	99.89	100.05	1
LG&E	C1S	857894	03/2010	02/10/2010	100.06	100.00	100.14	1
LG&E	C1S	857895	03/2010	02/10/2010	100.06	99.97	100.19	1
LG&E	C1S	857896	03/2010	02/10/2010	100.06	99.88	100.03	1
LG&E	C1S	857897	03/2010	02/10/2010	100.10	100.08	100.04	1
LG&E	C1S	857898	03/2010	02/10/2010	100.06	99.88	100.06	1
LG&E	C1S	857899	03/2010	02/10/2010	100.06	99.98	100.00	1



LG&E	C1S	857900	03/2010	10/2010	100.08	100.08	100.20	1
LG&E	C1S	857901	03/2010	02/10/2010	100.07	99.96	100.08	1
LG&E	C1S	857902	03/2010	02/10/2010	100.09	99.95	100.04	1
LG&E	C1S	857903	03/2010	02/10/2010	100.07	99.96	100.04	1
LG&E	C1S	857904	03/2010	02/10/2010	100.06	100.00	100.05	1
LG&E	C1S	857905	03/2010	02/10/2010	100.10	99.95	100.03	1
LG&E	C1S	857906	03/2010	02/10/2010	100.10	100.00	100.01	1
LG&E	C1S	857907	03/2010	02/10/2010	100.08	99.97	100.03	1
LG&E	C1S	857908	03/2010	02/10/2010	100.05	99.87	100.07	1
LG&E	C1S	857909	03/2010	02/10/2010	100.10	99.95	100.10	1
LG&E	C1S	857910	03/2010	02/10/2010	100.06	99.95	99.99	1
LG&E	C1S	857911	03/2010	02/10/2010	100.08	99.89	99.97	1
LG&E	C1S	857912	03/2010	02/10/2010	100.09	99.98	99.98	1
LG&E	C1S	857913	03/2010	02/10/2010	100.06	99.90	99.98	1
LG&E	C1S	857914	03/2010	02/10/2010	100.09	100.08	100.11	1
LG&E	C1S	857915	03/2010	02/10/2010	100.07	99.97	100.04	1
LG&E	C1S	857916	03/2010	02/10/2010	100.08	100.04	100.13	1
LG&E	C1S	857917	03/2010	02/10/2010	100.07	99.91	100.01	1
LG&E	C1S	857918	03/2010	02/10/2010	100.06	99.89	100.11	1
LG&E	C1S	857919	03/2010	02/10/2010	100.09	99.92	100.06	1
LG&E	C1S	857920	03/2010	02/10/2010	100.08	99.92	100.02	1
LG&E	C1S	857921	03/2010	02/10/2010	100.05	99.92	100.11	1
LG&E	C1S	857922	03/2010	02/10/2010	100.05	99.90	99.99	1
LG&E	C1S	857923	03/2010	02/10/2010	100.10	99.95	100.06	1
LG&E	C1S	857924	03/2010	02/10/2010	100.11	99.92	100.07	1
LG&E	C1S	857925	03/2010	02/10/2010	100.06	99.91	100.02	1
LG&E	C1S	857926	03/2010	02/10/2010	100.05	99.99	100.13	1
LG&E	C1S	857927	03/2010	02/10/2010	100.09	100.04	100.14	1
LG&E	C1S	857928	03/2010	02/10/2010	100.07	100.03	100.16	1
LG&E	C1S	857929	03/2010	02/10/2010	100.07	99.88	100.11	1
LG&E	C1S	857930	03/2010	02/10/2010	100.07	99.86	100.05	1
LG&E	C1S	857931	03/2010	02/10/2010	100.08	100.12	100.14	1
LG&E	C1S	857932	03/2010	02/10/2010	100.05	99.91	99.98	1
LG&E	C1S	857933	03/2010	02/10/2010	100.06	99.95	100.03	1
LG&E	C1S	857934	03/2010	02/10/2010	100.09	99.96	100.08	1
LG&E	C1S	857935	03/2010	02/10/2010	100.05	99.87	100.06	1

LG&E	CIS	857936	03/2010	01/01/2010	100.06	99.86	99.98	1
LG&E	CIS	857937	03/2010	02/10/2010	100.05	99.87	99.97	1
LG&E	CIS	857938	03/2010	02/10/2010	100.08	99.95	99.91	1
LG&E	CIS	857939	03/2010	02/10/2010	100.06	100.07	100.16	1
LG&E	CIS	857940	03/2010	02/10/2010	100.07	99.97	99.93	1
LG&E	CIS	857941	03/2010	02/10/2010	100.08	99.88	100.06	1
LG&E	CIS	857942	03/2010	02/10/2010	100.07	100.06	100.13	1
LG&E	CIS	857943	03/2010	02/10/2010	100.09	100.13	100.17	1
LG&E	CIS	857944	03/2010	02/10/2010	100.08	100.00	100.01	1
LG&E	CIS	857945	03/2010	02/10/2010	100.05	100.02	100.16	1
LG&E	CIS	857946	03/2010	02/10/2010	100.09	100.09	100.21	1
LG&E	CIS	857947	03/2010	02/10/2010	100.06	100.04	100.14	1
LG&E	CIS	857948	03/2010	02/10/2010	100.06	100.12	100.17	1
LG&E	CIS	857949	03/2010	02/10/2010	100.10	99.95	99.98	1
LG&E	CIS	857950	03/2010	02/10/2010	100.05	100.01	100.16	1
LG&E	CIS	857951	03/2010	02/10/2010	100.10	100.00	100.19	1
LG&E	CIS	857952	03/2010	02/10/2010	100.08	99.94	100.03	1
LG&E	CIS	857953	03/2010	02/10/2010	100.05	99.91	99.94	1
LG&E	CIS	857954	03/2010	02/10/2010	100.08	99.96	99.98	1
LG&E	CIS	857955	03/2010	02/10/2010	100.08	99.92	100.09	1
LG&E	CIS	857956	03/2010	02/10/2010	100.09	100.00	100.07	1
LG&E	CIS	857957	03/2010	02/10/2010	100.09	99.96	100.05	1
LG&E	CIS	857958	03/2010	02/10/2010	100.08	99.97	99.96	1
LG&E	CIS	857959	03/2010	02/10/2010	100.07	99.86	100.04	1
LG&E	CIS	857960	03/2010	02/10/2010	100.08	99.97	99.97	1
LG&E	CIS	857961	03/2010	02/10/2010	100.08	100.06	100.13	1
LG&E	CIS	857962	03/2010	02/10/2010	100.08	100.06	100.10	1
LG&E	CIS	857963	03/2010	02/10/2010	100.09	100.14	100.17	1
LG&E	CIS	857964	03/2010	02/10/2010	100.09	99.93	100.12	1
LG&E	CIS	857965	03/2010	02/10/2010	100.09	99.87	100.06	1
LG&E	CIS	857966	03/2010	02/10/2010	100.09	99.89	100.05	1
LG&E	CIS	857967	03/2010	02/10/2010	100.09	99.94	99.99	1
LG&E	CIS	857968	03/2010	02/10/2010	100.07	99.99	99.98	1
LG&E	CIS	857969	03/2010	02/10/2010	100.07	100.03	100.17	1
LG&E	CIS	857970	03/2010	02/10/2010	100.06	99.84	100.09	1
LG&E	CIS	857971	03/2010	02/10/2010	100.07	99.88	100.06	1

LG&E		C1S	857972	03/2010	100.10	100.01	100.10	100.01	100.10	1
LG&E		C1S	857973	03/2010	100.06	99.84	100.06	99.84	100.01	1
LG&E		C1S	857974	03/2010	100.09	99.85	100.09	99.85	100.12	1
LG&E		C1S	857975	03/2010	100.08	100.04	100.08	100.04	100.16	1
LG&E		C1S	857976	03/2010	100.06	99.87	100.06	99.87	100.02	1
LG&E		C1S	857977	03/2010	100.08	99.93	100.08	99.93	100.10	1
LG&E		C1S	857978	03/2010	100.09	99.84	100.09	99.84	100.06	1
LG&E		C1S	857979	03/2010	100.06	99.88	100.06	99.88	100.08	1
LG&E		C1S	857980	03/2010	100.10	100.03	100.10	100.03	100.12	1
LG&E		C1S	857981	03/2010	100.06	100.05	100.06	100.05	100.13	1
LG&E		C1S	857982	03/2010	100.08	100.00	100.08	100.00	100.08	1
LG&E		C1S	857983	03/2010	100.07	99.95	100.07	99.95	99.98	1
LG&E		C1S	857984	03/2010	100.07	99.82	100.07	99.82	100.04	1
LG&E		C1S	857985	03/2010	100.07	99.88	100.07	99.88	100.05	1
LG&E		C1S	857986	03/2010	100.10	99.97	100.10	99.97	100.01	1
LG&E		C1S	857987	03/2010	100.10	100.00	100.10	100.00	100.02	1
LG&E		C1S	857988	03/2010	100.06	99.88	100.06	99.88	100.03	1
LG&E		C1S	857989	03/2010	100.06	99.89	100.06	99.89	100.05	1
LG&E		C1S	857990	03/2010	100.09	99.93	100.09	99.93	100.09	1
LG&E		C1S	857991	03/2010	100.08	99.89	100.08	99.89	100.03	1
LG&E		C1S	857992	03/2010	100.09	99.99	100.09	99.99	100.05	1
LG&E		C1S	857993	03/2010	100.08	99.88	100.08	99.88	100.00	1
LG&E		C1S	857994	03/2010	100.08	100.01	100.08	100.01	100.04	1
LG&E		C1S	857995	03/2010	100.08	99.97	100.08	99.97	100.08	1
LG&E		C1S	857996	03/2010	100.06	99.97	100.06	99.97	100.02	1
LG&E		C1S	857997	03/2010	100.08	99.94	100.08	99.94	99.97	1
LG&E		C1S	857998	03/2010	100.08	100.02	100.08	100.02	100.06	1
LG&E		C1S	857999	03/2010	100.07	100.11	100.07	100.11	100.14	1
LG&E		C1S	858000	03/2010	100.08	99.93	100.08	99.93	100.03	1
LG&E		C1S	858001	03/2010	100.06	100.05	100.06	100.05	100.12	1
LG&E		C1S	858002	03/2010	100.09	99.97	100.09	99.97	100.05	1
LG&E		C1S	858003	03/2010	100.10	100.07	100.10	100.07	100.14	1
LG&E		C1S	858004	03/2010	100.08	99.90	100.08	99.90	100.03	1
LG&E		C1S	858005	03/2010	100.06	100.11	100.06	100.11	100.17	1
LG&E		C1S	858006	03/2010	100.07	99.97	100.07	99.97	100.00	1
LG&E		C1S	858007	03/2010	100.06	99.94	100.06	99.94	99.97	1

LG&E	C1S	858008	03/2010	02/10/2010	100.05	99.84	99.96	1
LG&E	C1S	858009	03/2010	02/10/2010	100.09	100.03	100.09	1
LG&E	C1S	858010	03/2010	02/10/2010	100.10	100.06	100.04	1
LG&E	C1S	858011	03/2010	02/10/2010	100.08	99.87	100.00	1
LG&E	C1S	858012	03/2010	02/10/2010	100.09	100.09	100.23	1
LG&E	C1S	858013	03/2010	02/10/2010	100.05	99.82	99.96	1
LG&E	C1S	858014	03/2010	02/10/2010	100.06	100.03	100.12	1
LG&E	C1S	858015	03/2010	02/10/2010	100.05	99.92	100.02	1
LG&E	C1S	858016	03/2010	02/10/2010	100.05	100.03	100.10	1
LG&E	C1S	858017	03/2010	02/10/2010	100.05	100.02	100.10	1
LG&E	C1S	858018	03/2010	02/10/2010	100.08	100.01	100.03	1
LG&E	C1S	858019	03/2010	02/10/2010	100.08	99.99	100.09	1
LG&E	C1S	858020	03/2010	02/10/2010	100.08	99.88	100.03	1
LG&E	C1S	858021	03/2010	02/10/2010	100.06	99.95	99.93	1
LG&E	C1S	858022	03/2010	02/10/2010	100.07	100.07	100.21	1
LG&E	C1S	858023	03/2010	02/10/2010	100.10	100.05	100.16	1
LG&E	C1S	858024	03/2010	02/10/2010	100.09	100.08	100.08	1
LG&E	C1S	858025	03/2010	02/10/2010	100.05	99.88	100.03	1
LG&E	C1S	858026	03/2010	02/10/2010	100.05	100.08	100.16	1
LG&E	C1S	858027	03/2010	02/10/2010	100.09	100.11	100.16	1
LG&E	C1S	858028	03/2010	02/10/2010	100.09	99.93	100.04	1
LG&E	C1S	858029	03/2010	02/10/2010	100.06	99.90	100.04	1
LG&E	C1S	858030	03/2010	02/10/2010	100.05	99.97	99.91	1
LG&E	C1S	858031	03/2010	02/10/2010	100.09	99.84	100.08	1
LG&E	C1S	858032	03/2010	02/10/2010	100.07	100.02	100.03	1
LG&E	C1S	858033	03/2010	02/10/2010	100.08	99.90	100.01	1
LG&E	C1S	858034	03/2010	02/10/2010	100.09	100.09	100.02	1
LG&E	C1S	858035	03/2010	02/10/2010	100.07	99.89	100.08	1
LG&E	C1S	858036	03/2010	02/10/2010	100.07	99.82	100.00	1
LG&E	C1S	858037	03/2010	02/10/2010	100.10	99.94	100.02	1
LG&E	C1S	858038	03/2010	02/10/2010	100.09	100.03	100.00	1
LG&E	C1S	858039	03/2010	02/10/2010	100.07	99.96	99.97	1
LG&E	C1S	858040	03/2010	02/10/2010	100.06	100.03	100.16	1
LG&E	C1S	858041	03/2010	02/10/2010	100.07	99.93	100.00	1
LG&E	C1S	858042	03/2010	02/10/2010	100.09	99.98	99.99	1
LG&E	C1S	858043	03/2010	02/10/2010	100.07	100.02	99.98	1

LG&E	C1S	858044	03/2010	02/10/2010	100.07	100.01	100.07	1
LG&E	C1S	858045	03/2010	02/10/2010	100.06	100.00	99.93	1
LG&E	C1S	858046	03/2010	02/10/2010	100.05	100.08	100.07	1
LG&E	C1S	858047	03/2010	02/10/2010	100.08	100.00	100.15	1
LG&E	C1S	858048	03/2010	02/10/2010	100.06	100.08	100.11	1
LG&E	C1S	858049	03/2010	02/10/2010	100.06	100.04	100.12	1
LG&E	C1S	858050	03/2010	02/10/2010	100.06	99.99	100.00	1
LG&E	C1S	858051	03/2010	02/10/2010	100.08	100.16	100.12	1
LG&E	C1S	858052	03/2010	02/10/2010	100.06	99.98	100.13	1
LG&E	C1S	858053	03/2010	02/10/2010	100.08	99.97	100.09	1
LG&E	C1S	858054	03/2010	02/10/2010	100.07	99.92	100.02	1
LG&E	C1S	858055	03/2010	02/10/2010	100.10	99.92	100.04	1
LG&E	C1S	858056	03/2010	02/10/2010	100.07	99.94	100.03	1
LG&E	C1S	858057	03/2010	02/10/2010	100.09	100.02	100.08	1
LG&E	C1S	858058	03/2010	02/10/2010	100.08	99.88	99.98	1
LG&E	C1S	858059	03/2010	02/10/2010	100.06	99.86	100.04	1
LG&E	C1S	858060	03/2010	02/10/2010	100.08	99.94	99.99	1
LG&E	C1S	858061	03/2010	02/10/2010	100.08	99.98	100.07	1
LG&E	C1S	858062	03/2010	02/10/2010	100.08	99.98	99.95	1
LG&E	C1S	858063	03/2010	02/10/2010	100.10	99.97	99.99	1
LG&E	C1S	858064	03/2010	02/10/2010	100.08	100.06	100.17	1
LG&E	C1S	858065	03/2010	02/10/2010	100.09	99.90	100.03	1
LG&E	C1S	858066	03/2010	02/10/2010	100.08	100.00	100.03	1
LG&E	C1S	858067	03/2010	02/10/2010	100.08	100.02	100.05	1
LG&E	C1S	858068	03/2010	02/10/2010	100.09	99.98	100.04	1
LG&E	C1S	858069	03/2010	02/10/2010	100.09	99.91	100.02	1
LG&E	C1S	858070	03/2010	02/10/2010	100.09	100.03	100.19	1
LG&E	C1S	858071	03/2010	02/10/2010	100.08	100.01	100.05	1
LG&E	C1S	858072	03/2010	02/10/2010	100.06	99.87	100.01	1
LG&E	C1S	858073	03/2010	02/10/2010	100.06	99.97	99.98	1
LG&E	C1S	858074	03/2010	02/10/2010	100.08	99.96	99.98	1
LG&E	C1S	858075	03/2010	02/10/2010	100.07	99.88	99.94	1
LG&E	C1S	858076	03/2010	02/10/2010	100.08	99.98	99.98	1
LG&E	C1S	858077	03/2010	02/10/2010	100.07	100.04	100.04	1
LG&E	C1S	858078	03/2010	02/10/2010	100.10	100.12	100.17	1
LG&E	C1S	858079	03/2010	02/10/2010	100.06	100.05	100.12	1

LG&E	CIS	858080	03/2010	02/10/2010	100.07	100.07	100.12	1
LG&E	CIS	858081	03/2010	02/10/2010	100.08	100.03	100.13	1
LG&E	CIS	858082	03/2010	02/10/2010	100.10	99.99	100.04	1
LG&E	CIS	858083	03/2010	02/10/2010	100.08	99.95	100.07	1
LG&E	CIS	858084	03/2010	02/10/2010	100.09	100.13	100.19	1
LG&E	CIS	858085	03/2010	02/10/2010	100.10	99.87	100.08	1
LG&E	CIS	858086	03/2010	02/10/2010	100.07	99.91	100.06	1
LG&E	CIS	858087	03/2010	02/10/2010	100.08	100.02	100.03	1
LG&E	CIS	858088	03/2010	02/10/2010	100.07	99.96	99.96	1
LG&E	CIS	858089	03/2010	02/10/2010	100.06	99.88	99.99	1
LG&E	CIS	858090	03/2010	02/10/2010	100.07	99.95	100.01	1
LG&E	CIS	858091	03/2010	02/10/2010	100.06	99.96	99.99	1
LG&E	CIS	858092	03/2010	02/10/2010	100.06	99.97	100.00	1
LG&E	CIS	858093	03/2010	02/10/2010	100.07	99.90	100.05	1
LG&E	CIS	858094	03/2010	02/10/2010	100.08	100.10	100.14	1
LG&E	CIS	858095	03/2010	02/10/2010	100.08	99.88	100.08	1
LG&E	CIS	858096	03/2010	02/10/2010	100.09	99.88	100.07	1
LG&E	CIS	858097	03/2010	02/10/2010	100.06	99.96	99.97	1
LG&E	CIS	858098	03/2010	02/10/2010	100.08	99.99	100.06	1
LG&E	CIS	858099	03/2010	02/10/2010	100.08	99.88	100.05	1
LG&E	CIS	858100	03/2010	02/10/2010	100.09	100.10	100.22	1
LG&E	CIS	858101	03/2010	02/10/2010	100.05	99.92	100.00	1
LG&E	CIS	858102	03/2010	02/10/2010	100.09	99.95	100.13	1
LG&E	CIS	858103	03/2010	02/10/2010	100.06	99.87	100.02	1
LG&E	CIS	858104	03/2010	02/10/2010	100.09	99.99	100.02	1
LG&E	CIS	858105	03/2010	02/10/2010	100.06	100.09	100.18	1
LG&E	CIS	858106	03/2010	02/10/2010	100.05	100.03	100.12	1
LG&E	CIS	858107	03/2010	02/10/2010	100.06	99.82	100.02	1
LG&E	CIS	858108	03/2010	02/10/2010	100.09	100.05	100.07	1
LG&E	CIS	858109	03/2010	02/10/2010	100.08	100.06	100.10	1
LG&E	CIS	858110	03/2010	02/10/2010	100.06	99.99	100.17	1
LG&E	CIS	858111	03/2010	02/10/2010	100.08	100.04	100.14	1
LG&E	CIS	858112	03/2010	02/10/2010	100.08	100.09	100.12	1
LG&E	CIS	858113	03/2010	02/10/2010	100.08	100.04	100.17	1
LG&E	CIS	858114	03/2010	02/10/2010	100.05	99.93	100.06	1
LG&E	CIS	858115	03/2010	02/10/2010	100.05	100.02	100.03	1

LG&E		C1S	858116	03/2010	02/10/2010	100.07	99.89	99.98	1
LG&E		C1S	858117	03/2010	02/10/2010	100.08	100.03	100.17	1
LG&E		C1S	858118	03/2010	02/10/2010	100.08	99.94	99.95	1
LG&E		C1S	858119	03/2010	02/10/2010	100.06	99.80	99.96	1
LG&E		C1S	858120	03/2010	02/10/2010	100.09	100.06	100.10	1
LG&E		C1S	858121	03/2010	02/10/2010	100.08	99.98	99.92	1
LG&E		C1S	858122	03/2010	02/10/2010	100.07	100.08	100.16	1
LG&E		C1S	858123	03/2010	02/10/2010	100.10	99.94	100.10	1
LG&E		C1S	858124	03/2010	02/10/2010	100.05	99.93	100.08	1
LG&E		C1S	858125	03/2010	02/10/2010	100.06	99.96	100.17	1
LG&E		C1S	858126	03/2010	02/10/2010	100.06	99.86	100.01	1
LG&E		C1S	858127	03/2010	02/10/2010	100.08	100.01	100.19	1
LG&E		C1S	858128	03/2010	02/10/2010	100.06	99.99	100.17	1
LG&E		C1S	858129	03/2010	02/10/2010	100.09	99.97	99.96	1
LG&E		C1S	858130	03/2010	02/10/2010	100.06	99.94	100.01	1
LG&E		C1S	858131	03/2010	02/10/2010	100.06	99.91	99.98	1
LG&E		C1S	858132	03/2010	02/10/2010	100.08	100.02	100.17	1
LG&E		C1S	858133	03/2010	02/10/2010	100.10	100.06	100.11	1
LG&E		C1S	858134	03/2010	02/10/2010	100.08	100.08	100.19	1
LG&E		C1S	858135	03/2010	02/10/2010	100.06	99.94	100.03	1
LG&E		C1S	858136	03/2010	02/10/2010	100.05	99.99	100.03	1
LG&E		C1S	858137	03/2010	02/10/2010	100.08	99.89	100.00	1
LG&E		C1S	858138	03/2010	02/10/2010	100.09	99.91	100.04	1
LG&E		C1S	858139	03/2010	02/10/2010	100.10	99.95	100.06	1
LG&E		C1S	858140	03/2010	02/10/2010	100.08	100.04	100.20	1
LG&E		C1S	858141	03/2010	02/10/2010	100.10	99.93	99.99	1
LG&E		C1S	858142	03/2010	02/10/2010	100.07	99.86	100.02	1
LG&E		C1S	858143	03/2010	02/10/2010	100.06	99.95	100.04	1
LG&E		C1S	858144	03/2010	02/10/2010	100.09	100.07	100.22	1
LG&E		C1S	858145	03/2010	02/10/2010	100.08	100.04	100.12	1
LG&E		C1S	858146	03/2010	02/10/2010	100.10	99.98	100.04	1
LG&E		C1S	858147	03/2010	02/10/2010	100.09	100.00	100.11	1
LG&E		C1S	858148	03/2010	02/10/2010	100.08	100.09	100.21	1
LG&E		C1S	858149	03/2010	02/10/2010	100.10	100.01	100.26	1
LG&E		C1S	858150	03/2010	02/10/2010	100.09	99.93	100.03	1
LG&E		C1S	858151	03/2010	02/10/2010	100.10	100.06	99.98	1

LG&E	CIS	858152	03/2010	02/10/2010	100.08	100.05	100.18	1
LG&E	CIS	858153	03/2010	02/10/2010	100.08	99.92	100.12	1
LG&E	CIS	858154	03/2010	02/10/2010	100.08	99.90	100.04	1
LG&E	CIS	858155	03/2010	02/10/2010	100.06	99.98	99.94	1
LG&E	CIS	858156	03/2010	02/10/2010	100.10	99.83	100.02	1
LG&E	CIS	858157	03/2010	02/10/2010	100.10	100.04	100.15	1
LG&E	CIS	858158	03/2010	02/10/2010	100.07	99.96	100.00	1
LG&E	CIS	858159	03/2010	02/10/2010	100.08	99.97	99.99	1
LG&E	CIS	858160	03/2010	02/10/2010	100.07	100.07	100.20	1
LG&E	CIS	858161	03/2010	02/10/2010	100.08	99.90	100.08	1
LG&E	CIS	858162	03/2010	02/10/2010	100.08	99.89	100.00	1
LG&E	CIS	858163	03/2010	02/10/2010	100.08	100.03	99.95	1
LG&E	CIS	858164	03/2010	02/10/2010	100.09	99.98	100.03	1
LG&E	CIS	858165	03/2010	02/10/2010	100.08	99.97	100.03	1
LG&E	CIS	858166	03/2010	02/10/2010	100.07	100.10	100.12	1
LG&E	CIS	858167	03/2010	02/10/2010	100.06	99.92	100.03	1
LG&E	CIS	858168	03/2010	02/10/2010	100.08	100.01	100.05	1
LG&E	CIS	858169	03/2010	02/10/2010	100.09	99.93	100.03	1
LG&E	CIS	858170	03/2010	02/10/2010	100.07	100.11	100.17	1
LG&E	CIS	858171	03/2010	02/10/2010	100.06	99.85	100.01	1
LG&E	CIS	858172	03/2010	02/10/2010	100.05	100.13	100.08	1
LG&E	CIS	858173	03/2010	02/10/2010	100.07	99.89	100.08	1
LG&E	CIS	858174	03/2010	02/10/2010	100.08	99.86	100.10	1
LG&E	CIS	858175	03/2010	02/10/2010	100.07	100.00	100.16	1
LG&E	CIS	858176	03/2010	02/10/2010	100.06	100.03	100.03	1
LG&E	CIS	858177	03/2010	02/10/2010	100.06	99.90	100.02	1
LG&E	CIS	858178	03/2010	02/10/2010	100.05	99.86	100.00	1
LG&E	CIS	858179	03/2010	02/10/2010	100.06	99.99	99.98	1
LG&E	CIS	858180	03/2010	02/10/2010	100.08	99.95	99.94	1
LG&E	CIS	858181	03/2010	02/10/2010	100.10	99.97	100.05	1
LG&E	CIS	858182	03/2010	02/10/2010	100.06	99.93	99.96	1
LG&E	CIS	858183	03/2010	02/10/2010	100.05	100.13	100.16	1
LG&E	CIS	858184	03/2010	02/10/2010	100.08	99.87	100.08	1
LG&E	CIS	858185	03/2010	02/10/2010	100.06	100.01	100.14	1
LG&E	CIS	858186	03/2010	02/10/2010	100.07	99.90	100.03	1
LG&E	CIS	858187	03/2010	02/10/2010	100.08	99.92	100.03	1



LG&E	C1S	858188	03/2010	10/2010	100.09	100.12	100.09	100.22	1
LG&E	C1S	858189	03/2010	02/10/2010	100.09	100.05	100.09	100.09	1
LG&E	C1S	858190	03/2010	02/10/2010	100.09	99.92	100.09	100.09	1
LG&E	C1S	858191	03/2010	02/10/2010	100.09	99.95	100.03	100.03	1
LG&E	C1S	858192	03/2010	02/10/2010	100.06	99.94	99.99	99.99	1
LG&E	C1S	858193	03/2010	02/10/2010	100.06	99.89	100.09	100.09	1
LG&E	C1S	858194	03/2010	02/10/2010	100.09	99.95	100.06	100.06	1
LG&E	C1S	858195	03/2010	02/10/2010	100.09	100.08	100.19	100.19	1
LG&E	C1S	858196	03/2010	02/10/2010	100.06	99.95	100.08	100.08	1
LG&E	C1S	858197	03/2010	02/10/2010	100.06	99.98	100.05	100.05	1
LG&E	C1S	858198	03/2010	02/10/2010	100.05	100.03	100.11	100.11	1
LG&E	C1S	858199	03/2010	02/10/2010	100.07	99.93	100.02	100.02	1
LG&E	C1S	858200	03/2010	02/10/2010	100.07	99.89	100.04	100.04	1
LG&E	C1S	858201	03/2010	02/10/2010	100.11	100.10	100.19	100.19	1
LG&E	C1S	858202	03/2010	02/10/2010	100.06	100.00	100.10	100.10	1
LG&E	C1S	858203	03/2010	02/10/2010	100.07	99.96	99.98	99.98	1
LG&E	C1S	858204	03/2010	02/10/2010	100.08	100.08	100.23	100.23	1
LG&E	C1S	858205	03/2010	02/10/2010	100.08	99.90	100.02	100.02	1
LG&E	C1S	858206	03/2010	02/10/2010	100.06	99.82	100.03	100.03	1
LG&E	C1S	858207	03/2010	02/10/2010	100.08	99.96	100.07	100.07	1
LG&E	C1S	858208	03/2010	02/10/2010	100.10	99.92	100.05	100.05	1
LG&E	C1S	858209	03/2010	02/10/2010	100.06	99.87	100.08	100.08	1
LG&E	C1S	858210	03/2010	02/10/2010	100.09	99.96	100.06	100.06	1
LG&E	C1S	858211	03/2010	02/10/2010	100.08	100.00	100.07	100.07	1
LG&E	C1S	858212	03/2010	02/10/2010	100.05	100.03	100.11	100.11	1
LG&E	C1S	858213	03/2010	02/10/2010	100.06	99.93	99.98	99.98	1
LG&E	C1S	858214	03/2010	02/10/2010	100.06	100.00	100.19	100.19	1
LG&E	C1S	858215	03/2010	02/10/2010	100.08	100.04	100.09	100.09	1
LG&E	C1S	858216	03/2010	02/10/2010	100.06	99.91	99.96	99.96	1
LG&E	C1S	858217	03/2010	02/10/2010	100.09	100.08	100.16	100.16	1
LG&E	C1S	858218	03/2010	02/10/2010	100.09	99.98	99.97	99.97	1
LG&E	C1S	858219	03/2010	02/10/2010	100.09	99.94	100.06	100.06	1
LG&E	C1S	858220	03/2010	02/10/2010	100.09	99.86	100.00	100.00	1
LG&E	C1S	858221	03/2010	02/10/2010	100.08	99.91	100.08	100.08	1
LG&E	C1S	858222	03/2010	02/10/2010	100.07	100.05	100.12	100.12	1
LG&E	C1S	858223	03/2010	02/10/2010	100.06	99.91	100.05	100.05	1

LG&E	C1S	858224	03/2010	2/10/2010	100.08	100.00	100.04	1
LG&E	C1S	858225	03/2010	02/10/2010	100.08	100.06	100.19	1
LG&E	C1S	858226	03/2010	02/10/2010	100.09	99.90	100.02	1
LG&E	C1S	858227	03/2010	02/10/2010	100.09	99.87	100.03	1
LG&E	C1S	858228	03/2010	02/10/2010	100.06	99.92	100.06	1
LG&E	C1S	858229	03/2010	02/10/2010	100.10	100.05	100.09	1
LG&E	C1S	858230	03/2010	02/10/2010	100.08	99.85	100.05	1
LG&E	C1S	858231	03/2010	02/10/2010	100.09	100.10	100.19	1
LG&E	C1S	858232	03/2010	02/10/2010	100.09	100.06	100.22	1
LG&E	C1S	858233	03/2010	02/10/2010	100.06	99.95	99.92	1
LG&E	C1S	858234	03/2010	02/10/2010	100.09	100.11	100.17	1
LG&E	C1S	858235	03/2010	02/10/2010	100.08	99.88	100.09	1
LG&E	C1S	858236	03/2010	02/10/2010	100.09	99.89	100.12	1
LG&E	C1S	858237	03/2010	02/10/2010	100.09	99.97	100.07	1
LG&E	C1S	858238	03/2010	02/10/2010	100.06	99.89	100.05	1
LG&E	C1S	858239	03/2010	02/10/2010	100.07	100.05	100.20	1
LG&E	C1S	858240	03/2010	02/10/2010	100.08	99.99	100.11	1
LG&E	C1S	858241	03/2010	02/10/2010	100.08	99.86	100.09	1
LG&E	C1S	858242	03/2010	02/10/2010	100.10	100.02	100.11	1
LG&E	C1S	858243	03/2010	02/10/2010	100.05	100.01	100.08	1
LG&E	C1S	858244	03/2010	02/10/2010	100.08	99.94	100.01	1
LG&E	C1S	858245	03/2010	02/10/2010	100.06	100.02	100.06	1
LG&E	C1S	858246	03/2010	02/10/2010	100.07	99.92	100.03	1
LG&E	C1S	858247	03/2010	02/10/2010	100.09	99.90	100.00	1
LG&E	C1S	858248	03/2010	02/10/2010	100.09	99.95	100.00	1
LG&E	C1S	858249	03/2010	02/10/2010	100.06	99.82	100.03	1
LG&E	C1S	858250	03/2010	02/10/2010	100.08	99.88	99.99	1
LG&E	C1S	858251	03/2010	02/10/2010	100.07	99.99	100.06	1
LG&E	C1S	858252	03/2010	02/10/2010	100.10	99.95	100.08	1
LG&E	C1S	858253	03/2010	02/10/2010	100.05	99.92	100.06	1
LG&E	C1S	858254	03/2010	02/10/2010	100.07	99.95	100.01	1
LG&E	C1S	858255	03/2010	02/10/2010	100.09	99.93	99.99	1
LG&E	C1S	858256	03/2010	02/10/2010	100.10	99.98	100.07	1
LG&E	C1S	858257	03/2010	02/10/2010	100.07	99.94	99.98	1
LG&E	C1S	858258	03/2010	02/10/2010	100.07	99.94	100.08	1
LG&E	C1S	858259	03/2010	02/10/2010	100.07	99.95	100.06	1

LG&E		C1S	858260	03/2010	01/2010	100.08	100.00	100.07	1
LG&E		C1S	858261	03/2010	02/10/2010	100.06	100.12	100.13	1
LG&E		C1S	858262	03/2010	02/10/2010	100.08	99.99	100.00	1
LG&E		C1S	858263	03/2010	02/10/2010	100.06	99.84	99.99	1
LG&E		C1S	858264	03/2010	02/10/2010	100.08	99.88	100.06	1
LG&E		C1S	858265	03/2010	02/10/2010	100.09	100.00	100.14	1
LG&E		C1S	858266	03/2010	02/10/2010	100.07	99.97	100.06	1
LG&E		C1S	858267	03/2010	02/10/2010	100.09	100.05	100.12	1
LG&E		C1S	858268	03/2010	02/10/2010	100.10	100.06	100.17	1
LG&E		C1S	858269	03/2010	02/10/2010	100.08	99.96	100.04	1
LG&E		C1S	858270	03/2010	02/10/2010	100.10	100.06	100.14	1
LG&E		C1S	858271	03/2010	02/10/2010	100.06	99.94	99.96	1
LG&E		C1S	858272	03/2010	02/10/2010	100.08	100.10	100.12	1
LG&E		C1S	858273	03/2010	02/10/2010	100.08	100.03	100.19	1
LG&E		C1S	858274	03/2010	02/10/2010	100.09	99.95	100.04	1
LG&E		C1S	858275	03/2010	02/10/2010	100.06	100.03	100.20	1
LG&E		C1S	858276	03/2010	02/10/2010	100.10	100.14	100.15	1
LG&E		C1S	858277	03/2010	02/10/2010	100.08	99.92	100.08	1
LG&E		C1S	858278	03/2010	02/10/2010	100.10	100.09	100.23	1
LG&E		C1S	858279	03/2010	02/10/2010	100.08	100.03	99.98	1
LG&E		C1S	858280	03/2010	02/10/2010	100.10	99.89	100.16	1
LG&E		C1S	858281	03/2010	02/10/2010	100.08	99.97	100.00	1
LG&E		C1S	858282	03/2010	02/10/2010	100.07	99.85	100.01	1
LG&E		C1S	858283	03/2010	02/10/2010	100.05	100.02	100.10	1
LG&E		C1S	858284	03/2010	02/10/2010	100.08	99.94	100.03	1
LG&E		C1S	858285	03/2010	02/10/2010	100.08	100.03	99.98	1
LG&E		C1S	858286	03/2010	02/10/2010	100.05	100.07	100.15	1
LG&E		C1S	858287	03/2010	02/10/2010	100.06	100.03	100.12	1
LG&E		C1S	858288	03/2010	02/10/2010	100.07	100.11	100.18	1
LG&E		C1S	858289	03/2010	02/10/2010	100.06	99.81	100.00	1
LG&E		C1S	858290	03/2010	02/10/2010	100.06	100.00	100.13	1
LG&E		C1S	858291	03/2010	02/10/2010	100.07	99.99	100.10	1
LG&E		C1S	858292	03/2010	02/10/2010	100.08	100.08	100.11	1
LG&E		C1S	858293	03/2010	02/10/2010	100.09	100.00	100.09	1
LG&E		C1S	858294	03/2010	02/10/2010	100.05	99.93	100.07	1
LG&E		C1S	858295	03/2010	02/10/2010	100.09	99.97	99.99	1

LG&E	C1S	858296	03/2010	02/10/2010	100.09	99.95	100.09	1
LG&E	C1S	858297	03/2010	02/10/2010	100.08	99.97	99.95	1
LG&E	C1S	858298	03/2010	02/10/2010	100.08	99.89	100.04	1
LG&E	C1S	858299	03/2010	02/10/2010	100.08	100.05	100.17	1
LG&E	C1S	858300	03/2010	02/10/2010	100.09	100.09	100.25	1
LG&E	C1S	858301	03/2010	02/10/2010	100.05	99.96	100.05	1
LG&E	C1S	858302	03/2010	02/10/2010	100.05	99.85	99.95	1
LG&E	C1S	858303	03/2010	02/10/2010	100.09	100.02	99.96	1
LG&E	C1S	858304	03/2010	02/10/2010	100.08	99.91	99.92	1
LG&E	C1S	858305	03/2010	02/10/2010	100.06	99.90	99.95	1
LG&E	C1S	858306	03/2010	02/10/2010	100.10	99.86	100.10	1
LG&E	C1S	858307	03/2010	02/10/2010	100.06	100.05	100.18	1
LG&E	C1S	858308	03/2010	02/10/2010	100.05	100.03	100.13	1
LG&E	C1S	858309	03/2010	02/10/2010	100.08	100.05	100.21	1
LG&E	C1S	858310	03/2010	02/10/2010	100.05	99.93	100.09	1
LG&E	C1S	858311	03/2010	02/10/2010	100.06	100.06	100.19	1
LG&E	C1S	858312	03/2010	02/10/2010	100.05	99.94	100.02	1
LG&E	C1S	858313	03/2010	02/10/2010	100.06	100.04	100.06	1
LG&E	C1S	858314	03/2010	02/10/2010	100.08	99.92	99.99	1
LG&E	C1S	858315	03/2010	02/10/2010	100.09	99.94	100.00	1
LG&E	C1S	858316	03/2010	02/10/2010	100.08	99.95	100.09	1
LG&E	C1S	858317	03/2010	02/10/2010	100.06	100.09	100.17	1
LG&E	C1S	858318	03/2010	02/10/2010	100.09	99.97	100.07	1
LG&E	C1S	858319	03/2010	02/10/2010	100.08	99.91	99.97	1
LG&E	C1S	858320	03/2010	02/10/2010	100.06	99.90	100.05	1
LG&E	C1S	858321	03/2010	02/10/2010	100.10	100.00	100.03	1
LG&E	C1S	858322	03/2010	02/10/2010	100.07	99.96	100.16	1
LG&E	C1S	858323	03/2010	02/10/2010	100.06	99.99	99.99	1
LG&E	C1S	858324	03/2010	02/10/2010	100.08	100.03	100.00	1
LG&E	C1S	858325	03/2010	02/10/2010	100.08	99.83	100.04	1
LG&E	C1S	858326	03/2010	02/10/2010	100.07	99.87	99.99	1
LG&E	C1S	858327	03/2010	02/10/2010	100.08	100.10	100.08	1
LG&E	C1S	858328	03/2010	02/10/2010	100.06	99.89	100.02	1
LG&E	C1S	858329	03/2010	02/10/2010	100.07	100.03	100.15	1
LG&E	C1S	858330	03/2010	02/10/2010	100.07	99.89	100.01	1
LG&E	C1S	858331	03/2010	02/10/2010	100.10	100.01	100.07	1

LG&E	C1S	858332	03/2010	10/2010	100.10	99.89	100.06	1
LG&E	C1S	858333	03/2010	02/10/2010	100.08	100.07	99.99	1
LG&E	C1S	858334	03/2010	02/10/2010	100.08	100.06	100.18	1
LG&E	C1S	858335	03/2010	02/10/2010	100.07	99.97	99.95	1
LG&E	C1S	858336	03/2010	02/10/2010	100.09	99.90	100.11	1
LG&E	C1S	858337	03/2010	02/10/2010	100.07	99.96	100.03	1
LG&E	C1S	858338	03/2010	02/10/2010	100.09	99.89	100.09	1
LG&E	C1S	858339	03/2010	02/10/2010	100.08	99.95	100.08	1
LG&E	C1S	858340	03/2010	02/10/2010	100.09	100.00	100.04	1
LG&E	C1S	858341	03/2010	02/10/2010	100.09	100.00	100.13	1
LG&E	C1S	858342	03/2010	02/10/2010	100.10	100.01	100.05	1
LG&E	C1S	858343	03/2010	02/10/2010	100.08	100.06	100.14	1
LG&E	C1S	858344	03/2010	02/10/2010	100.11	99.91	100.05	1
LG&E	C1S	858345	03/2010	02/10/2010	100.08	100.02	100.06	1
LG&E	C1S	858346	03/2010	02/10/2010	100.07	99.89	99.99	1
LG&E	C1S	858347	03/2010	02/10/2010	100.06	99.92	99.98	1
LG&E	C1S	858348	03/2010	02/10/2010	100.05	99.98	100.15	1
LG&E	C1S	858349	03/2010	02/10/2010	100.07	100.11	100.18	1
LG&E	C1S	858350	03/2010	02/10/2010	100.08	99.97	100.01	1
LG&E	C1S	858351	03/2010	02/10/2010	100.07	99.98	100.03	1
LG&E	C1S	858352	03/2010	02/10/2010	100.06	99.97	100.16	1
LG&E	C1S	858353	03/2010	02/10/2010	100.07	100.02	100.19	1
LG&E	C1S	858354	03/2010	02/10/2010	100.10	100.08	100.08	1
LG&E	C1S	858355	03/2010	02/10/2010	100.06	99.94	99.91	1
LG&E	C1S	858356	03/2010	02/10/2010	100.09	99.97	99.99	1
LG&E	C1S	858357	03/2010	02/10/2010	100.06	99.99	100.14	1
LG&E	C1S	858358	03/2010	02/10/2010	100.06	99.86	100.04	1
LG&E	C1S	858359	03/2010	02/10/2010	100.07	100.02	100.07	1
LG&E	C1S	858360	03/2010	02/10/2010	100.08	99.90	100.05	1
LG&E	C1S	858361	03/2010	02/10/2010	100.05	99.94	100.00	1
LG&E	C1S	858362	03/2010	02/10/2010	100.09	99.94	100.14	1
LG&E	C1S	858363	03/2010	02/10/2010	100.07	99.93	100.04	1
LG&E	C1S	858364	03/2010	02/10/2010	100.07	100.07	100.20	1
LG&E	C1S	858365	03/2010	02/10/2010	100.10	100.06	100.16	1
LG&E	C1S	858366	03/2010	02/10/2010	100.07	99.89	100.02	1
LG&E	C1S	858367	03/2010	02/10/2010	100.06	99.84	100.08	1

LG&E	CIS	858368	03/2010	02/10/2010	100.08	100.06	100.13	1
LG&E	CIS	858369	03/2010	02/10/2010	100.07	99.89	100.05	1
LG&E	CIS	858370	03/2010	02/10/2010	100.06	99.85	99.89	1
LG&E	CIS	858371	03/2010	02/10/2010	100.10	100.08	100.20	1
LG&E	CIS	858372	03/2010	02/10/2010	100.05	99.81	100.01	1
LG&E	CIS	858373	03/2010	02/10/2010	100.11	100.02	99.97	1
LG&E	CIS	858374	03/2010	02/10/2010	100.06	99.95	100.08	1
LG&E	CIS	858375	03/2010	02/10/2010	100.06	99.89	100.02	1
LG&E	CIS	858376	03/2010	02/10/2010	100.07	99.90	100.08	1
LG&E	CIS	858377	03/2010	02/10/2010	100.07	100.11	100.14	1
LG&E	CIS	858378	03/2010	02/10/2010	100.07	100.05	100.14	1
LG&E	CIS	858379	03/2010	02/10/2010	100.06	99.95	100.05	1
LG&E	CIS	858380	03/2010	02/10/2010	100.06	99.99	99.94	1
LG&E	CIS	858381	03/2010	02/10/2010	100.10	100.05	100.18	1
LG&E	CIS	858382	03/2010	02/10/2010	100.07	100.04	100.13	1
LG&E	CIS	858383	03/2010	02/10/2010	100.08	99.86	100.06	1
LG&E	CIS	858384	03/2010	02/10/2010	100.08	99.96	100.03	1
LG&E	CIS	858385	03/2010	02/10/2010	100.10	99.97	100.04	1
LG&E	CIS	858386	03/2010	02/10/2010	100.08	99.97	100.08	1
LG&E	CIS	858387	03/2010	02/10/2010	100.07	99.83	100.02	1
LG&E	CIS	858388	03/2010	02/10/2010	100.08	99.98	100.03	1
LG&E	CIS	858389	03/2010	02/10/2010	100.08	100.00	100.21	1
LG&E	CIS	858390	03/2010	02/10/2010	100.06	100.00	100.14	1
LG&E	CIS	858391	03/2010	02/10/2010	100.08	99.94	100.05	1
LG&E	CIS	858392	03/2010	02/10/2010	100.08	99.94	100.06	1
LG&E	CIS	858393	03/2010	02/10/2010	100.08	99.97	99.95	1
LG&E	CIS	858394	03/2010	02/10/2010	100.05	100.07	100.17	1
LG&E	CIS	858395	03/2010	02/10/2010	100.08	99.95	100.04	1
LG&E	CIS	858396	03/2010	02/10/2010	100.06	99.95	100.01	1
LG&E	CIS	858397	03/2010	02/10/2010	100.09	99.96	100.03	1
LG&E	CIS	858398	03/2010	02/10/2010	100.08	99.93	100.02	1
LG&E	CIS	858399	03/2010	02/10/2010	100.07	100.03	100.08	1
LG&E	CIS	858400	03/2010	02/10/2010	100.06	100.09	100.18	1
LG&E	CIS	858401	03/2010	02/10/2010	100.10	100.08	100.23	1
LG&E	CIS	858402	03/2010	02/10/2010	100.08	99.84	100.00	1
LG&E	CIS	858403	03/2010	02/10/2010	100.09	100.07	100.02	1

LG&E	C1S	858404	03/2010	10/2010	100.06	99.89	99.97	1
LG&E	C1S	858405	03/2010	02/10/2010	100.07	99.99	100.07	1
LG&E	C1S	858406	03/2010	02/10/2010	100.08	100.00	100.01	1
LG&E	C1S	858407	03/2010	02/10/2010	100.09	99.96	100.01	1
LG&E	C1S	858408	03/2010	02/10/2010	100.07	99.91	100.03	1
LG&E	C1S	858409	03/2010	02/10/2010	100.06	100.04	100.19	1
LG&E	C1S	858410	03/2010	02/10/2010	100.06	99.90	99.89	1
LG&E	C1S	858411	03/2010	02/10/2010	100.10	100.07	100.21	1
LG&E	C1S	858412	03/2010	02/10/2010	100.08	100.07	100.17	1
LG&E	C1S	858413	03/2010	02/10/2010	100.07	100.04	100.00	1
LG&E	C1S	858414	03/2010	02/10/2010	100.09	99.94	100.16	1
LG&E	C1S	858415	03/2010	02/10/2010	100.06	99.87	99.94	1
LG&E	C1S	858416	03/2010	02/10/2010	100.07	100.10	100.23	1
LG&E	C1S	858417	03/2010	02/10/2010	100.08	99.82	100.09	1
LG&E	C1S	858418	03/2010	02/10/2010	100.07	100.04	100.15	1
LG&E	C1S	858419	03/2010	02/10/2010	100.08	99.87	100.01	1
LG&E	C1S	858420	03/2010	02/10/2010	100.07	99.86	100.00	1
LG&E	C1S	858421	03/2010	02/10/2010	100.08	99.88	100.09	1
LG&E	C1S	858422	03/2010	02/10/2010	100.10	100.06	100.17	1
LG&E	C1S	858423	03/2010	02/10/2010	100.08	99.80	100.03	1
LG&E	C1S	858424	03/2010	02/10/2010	100.06	99.87	99.92	1
LG&E	C1S	858425	03/2010	02/10/2010	100.10	100.05	100.19	1
LG&E	C1S	858426	03/2010	02/10/2010	100.06	100.06	100.19	1
LG&E	C1S	858427	03/2010	02/10/2010	100.09	100.07	100.22	1
LG&E	C1S	858428	03/2010	02/10/2010	100.08	100.03	100.03	1
LG&E	C1S	858429	03/2010	02/10/2010	100.05	99.87	100.08	1
LG&E	C1S	858430	03/2010	02/10/2010	100.07	99.99	100.09	1
LG&E	C1S	858431	03/2010	02/10/2010	100.05	100.00	100.10	1
LG&E	C1S	858432	03/2010	02/10/2010	100.05	100.03	100.10	1
LG&E	C1S	858433	03/2010	02/10/2010	100.09	100.01	100.18	1
LG&E	C1S	858434	03/2010	02/10/2010	100.09	99.96	99.98	1
LG&E	C1S	858435	03/2010	02/10/2010	100.06	99.87	99.92	1
LG&E	C1S	858436	03/2010	02/10/2010	100.10	99.91	100.06	1
LG&E	C1S	858437	03/2010	02/10/2010	100.08	100.03	100.14	1
LG&E	C1S	858438	03/2010	02/10/2010	100.07	99.89	99.95	1
LG&E	C1S	858439	03/2010	02/10/2010	100.09	99.94	100.10	1

LG&E	C1S	858440	03/2010	02/10/2010	100.08	99.97	100.06	1
LG&E	C1S	858441	03/2010	02/10/2010	100.10	99.93	100.07	1
LG&E	C1S	858442	03/2010	02/10/2010	100.07	100.07	100.11	1
LG&E	C1S	858443	03/2010	02/10/2010	100.10	99.97	100.06	1
LG&E	C1S	858444	03/2010	02/10/2010	100.11	99.97	100.00	1
LG&E	C1S	858445	03/2010	02/10/2010	100.06	99.89	100.00	1
LG&E	C1S	858446	03/2010	02/10/2010	100.09	100.09	100.12	1
LG&E	C1S	858447	03/2010	02/10/2010	100.06	100.07	100.10	1
LG&E	C1S	858448	03/2010	02/10/2010	100.10	100.07	100.16	1
LG&E	C1S	858449	03/2010	02/10/2010	100.08	100.10	100.21	1
LG&E	C1S	858450	03/2010	02/10/2010	100.07	99.92	100.04	1
LG&E	C1S	858451	03/2010	02/10/2010	100.06	99.97	100.04	1
LG&E	C1S	858452	03/2010	02/10/2010	100.08	99.94	99.94	1
LG&E	C1S	858453	03/2010	02/10/2010	100.06	100.12	100.08	1
LG&E	C1S	858454	03/2010	02/10/2010	100.06	100.03	100.13	1
LG&E	C1S	858455	03/2010	02/10/2010	100.07	99.91	99.96	1
LG&E	C1S	858456	03/2010	02/10/2010	100.09	99.96	99.96	1
LG&E	C1S	858457	03/2010	02/10/2010	100.09	99.97	100.10	1
LG&E	C1S	858458	03/2010	02/10/2010	100.08	100.00	100.14	1
LG&E	C1S	858459	03/2010	02/10/2010	100.06	99.98	100.12	1
LG&E	C1S	858460	03/2010	02/10/2010	100.08	99.92	99.97	1
LG&E	C1S	858461	03/2010	02/10/2010	100.06	99.99	100.09	1
LG&E	C1S	858462	03/2010	02/10/2010	100.09	100.01	100.07	1
LG&E	C1S	858463	03/2010	02/10/2010	100.05	99.95	100.00	1
LG&E	C1S	858464	03/2010	02/10/2010	100.08	99.99	100.10	1
LG&E	C1S	858465	03/2010	02/10/2010	100.08	99.91	100.02	1
LG&E	C1S	858466	03/2010	02/10/2010	100.06	100.01	100.14	1
LG&E	C1S	858467	03/2010	02/10/2010	100.05	99.90	100.06	1
LG&E	C1S	858468	03/2010	02/10/2010	100.08	99.94	99.95	1
LG&E	C1S	858469	03/2010	02/10/2010	100.07	99.89	100.00	1
LG&E	C1S	858470	03/2010	02/10/2010	100.09	100.07	100.19	1
LG&E	C1S	858471	03/2010	02/10/2010	100.09	99.98	100.02	1
LG&E	C1S	858472	03/2010	02/10/2010	100.07	100.11	100.13	1
LG&E	C1S	858473	03/2010	02/10/2010	100.07	99.94	100.05	1
LG&E	C1S	858474	03/2010	02/10/2010	100.08	99.95	100.05	1
LG&E	C1S	858475	03/2010	02/10/2010	100.06	99.99	100.05	1



LG&E	C1S	858476	03/2010	10/2010	100.07	99.86	100.02	1
LG&E	C1S	858477	03/2010	02/10/2010	100.10	100.03	100.11	1
LG&E	C1S	858478	03/2010	02/10/2010	100.07	100.03	100.17	1
LG&E	C1S	858479	03/2010	02/10/2010	100.05	99.99	100.07	1
LG&E	C1S	858480	03/2010	02/10/2010	100.06	100.04	100.17	1
LG&E	C1S	858481	03/2010	02/10/2010	100.06	99.96	100.02	1
LG&E	C1S	858482	03/2010	02/10/2010	100.10	100.02	100.17	1
LG&E	C1S	858483	03/2010	02/10/2010	100.06	99.93	99.90	1
LG&E	C1S	858484	03/2010	02/10/2010	100.07	100.01	99.98	1
LG&E	C1S	858485	03/2010	02/10/2010	100.10	99.86	100.05	1
LG&E	C1S	858486	03/2010	02/10/2010	100.09	99.99	99.99	1
LG&E	C1S	858487	03/2010	02/10/2010	100.07	99.92	99.91	1
LG&E	C1S	858488	03/2010	02/10/2010	100.06	100.02	100.11	1
LG&E	C1S	858489	03/2010	02/10/2010	100.07	99.98	100.17	1
LG&E	C1S	858490	03/2010	02/10/2010	100.07	100.06	100.16	1
LG&E	C1S	858491	03/2010	02/10/2010	100.09	99.98	100.01	1
LG&E	C1S	858492	03/2010	02/10/2010	100.08	100.07	100.14	1
LG&E	C1S	858493	03/2010	02/10/2010	100.09	99.98	100.08	1
LG&E	C1S	858494	03/2010	02/10/2010	100.07	99.94	100.09	1
LG&E	C1S	858495	03/2010	02/10/2010	100.09	99.83	100.09	1
LG&E	C1S	858496	03/2010	02/10/2010	100.06	99.99	100.12	1
LG&E	C1S	858497	03/2010	02/10/2010	100.06	99.97	100.03	1
LG&E	C1S	858498	03/2010	02/10/2010	100.07	100.08	100.06	1
LG&E	C1S	858499	03/2010	02/10/2010	100.10	100.08	100.21	1
LG&E	C1S	858500	03/2010	02/10/2010	100.07	100.06	100.14	1
LG&E	C1S	858501	03/2010	02/10/2010	100.05	99.89	100.05	1
LG&E	C1S	858502	03/2010	02/10/2010	100.08	99.97	100.14	1
LG&E	C1S	858503	03/2010	02/10/2010	100.06	99.96	100.04	1
LG&E	C1S	858504	03/2010	02/10/2010	100.08	99.81	100.05	1
LG&E	C1S	858505	03/2010	02/10/2010	100.09	99.90	100.08	1
LG&E	C1S	858506	03/2010	02/10/2010	100.08	100.06	100.18	1
LG&E	C1S	858507	03/2010	02/10/2010	100.07	99.88	100.11	1
LG&E	C1S	858508	03/2010	02/10/2010	100.07	99.89	100.11	1
LG&E	C1S	858509	03/2010	02/10/2010	100.06	100.08	100.06	1
LG&E	C1S	858510	03/2010	02/10/2010	100.10	100.04	100.16	1
LG&E	C1S	858511	03/2010	02/10/2010	100.06	99.91	100.03	1

LG&E	C1S	858512	03/2010	02/10/2010	100.08	99.94	100.09	1
LG&E	C1S	858513	03/2010	02/10/2010	100.09	99.86	100.01	1
LG&E	C1S	858514	03/2010	02/10/2010	100.08	99.91	100.04	1
LG&E	C1S	858515	03/2010	02/10/2010	100.07	99.92	100.01	1
LG&E	C1S	858516	03/2010	02/10/2010	100.06	99.94	100.02	1
LG&E	C1S	858517	03/2010	02/10/2010	100.08	100.08	100.12	1
LG&E	C1S	858518	03/2010	02/10/2010	100.06	100.09	100.11	1
LG&E	C1S	858519	03/2010	02/10/2010	100.07	99.95	99.99	1
LG&E	C1S	858520	03/2010	02/10/2010	100.08	99.91	100.05	1
LG&E	C1S	858521	03/2010	02/10/2010	100.08	100.10	100.10	1
LG&E	C1S	858522	03/2010	02/10/2010	100.07	99.85	100.07	1
LG&E	C1S	858523	03/2010	02/10/2010	100.08	99.97	100.05	1
LG&E	C1S	858524	03/2010	02/10/2010	100.09	99.95	100.02	1
LG&E	C1S	858525	03/2010	02/10/2010	100.08	100.09	100.12	1
LG&E	C1S	858526	03/2010	02/10/2010	100.07	99.81	100.01	1
LG&E	C1S	858527	03/2010	02/10/2010	100.08	99.85	100.06	1
LG&E	C1S	858528	03/2010	02/10/2010	100.06	99.98	100.06	1
LG&E	C1S	858529	03/2010	02/10/2010	100.07	99.98	100.04	1
LG&E	C1S	858530	03/2010	02/10/2010	100.09	99.81	100.06	1
LG&E	C1S	858531	03/2010	02/10/2010	100.08	100.10	100.17	1
LG&E	C1S	858532	03/2010	02/10/2010	100.07	99.94	100.05	1
LG&E	C1S	858533	03/2010	02/10/2010	100.09	100.03	100.11	1
LG&E	C1S	858534	03/2010	02/10/2010	100.09	100.05	100.15	1
LG&E	C1S	858535	03/2010	02/10/2010	100.10	100.02	100.24	1
LG&E	C1S	858536	03/2010	02/10/2010	100.09	99.93	100.09	1
LG&E	C1S	858537	03/2010	02/10/2010	100.06	100.04	100.16	1
LG&E	C1S	858538	03/2010	02/10/2010	100.06	100.04	100.18	1
LG&E	C1S	858539	03/2010	02/10/2010	100.06	99.93	100.00	1
LG&E	C1S	858540	03/2010	02/10/2010	100.08	100.07	100.14	1
LG&E	C1S	858541	03/2010	02/10/2010	100.10	99.97	100.09	1
LG&E	C1S	858542	03/2010	02/10/2010	100.06	99.94	100.00	1
LG&E	C1S	858543	03/2010	02/10/2010	100.07	100.06	100.06	1
LG&E	C1S	858544	03/2010	02/10/2010	100.08	100.05	100.05	1
LG&E	C1S	858545	03/2010	02/10/2010	100.10	99.89	100.11	1
LG&E	C1S	858546	03/2010	02/10/2010	100.06	99.87	100.04	1
LG&E	C1S	858547	03/2010	02/10/2010	100.09	100.07	100.19	1

LG&E	C1S	858548	03/2010	10/2010	100.07	100.10	100.09	1
LG&E	C1S	858549	03/2010	02/10/2010	100.07	99.88	100.01	1
LG&E	C1S	858550	03/2010	02/10/2010	100.09	100.05	100.19	1
LG&E	C1S	858551	03/2010	02/10/2010	100.10	100.04	100.07	1
LG&E	C1S	858552	03/2010	02/10/2010	100.08	99.94	100.04	1
LG&E	C1S	858553	03/2010	02/10/2010	100.09	99.94	100.08	1
LG&E	C1S	858554	03/2010	02/10/2010	100.10	100.09	100.20	1
LG&E	C1S	858555	03/2010	02/10/2010	100.07	99.93	99.96	1
LG&E	C1S	858556	03/2010	02/10/2010	100.07	99.88	99.95	1
LG&E	C1S	858557	03/2010	02/10/2010	100.06	99.93	100.03	1
LG&E	C1S	858558	03/2010	02/10/2010	100.05	99.91	100.04	1
LG&E	C1S	858559	03/2010	02/10/2010	100.07	99.87	99.92	1
LG&E	C1S	858560	03/2010	02/10/2010	100.10	99.97	100.04	1
LG&E	C1S	858561	03/2010	02/10/2010	100.09	99.97	99.97	1
LG&E	C1S	858562	03/2010	02/10/2010	100.08	100.07	100.11	1
LG&E	C1S	858563	03/2010	02/10/2010	100.09	100.01	99.98	1
LG&E	C1S	858564	03/2010	02/10/2010	100.08	100.02	100.14	1
LG&E	C1S	858565	03/2010	02/10/2010	100.09	100.10	100.12	1
LG&E	C1S	858566	03/2010	02/10/2010	100.08	100.04	100.16	1
LG&E	C1S	858567	03/2010	02/10/2010	100.07	100.00	100.14	1
LG&E	C1S	858568	03/2010	02/10/2010	100.07	100.08	100.15	1
LG&E	C1S	858569	03/2010	02/10/2010	100.08	99.93	100.00	1
LG&E	C1S	858570	03/2010	02/10/2010	100.08	99.99	100.00	1
LG&E	C1S	858571	03/2010	02/10/2010	100.07	99.91	100.06	1
LG&E	C1S	858572	03/2010	02/10/2010	100.06	99.88	100.04	1
LG&E	C1S	858573	03/2010	02/10/2010	100.07	99.85	100.02	1
LG&E	C1S	858574	03/2010	02/10/2010	100.10	99.97	99.99	1
LG&E	C1S	858575	03/2010	02/10/2010	100.10	99.85	100.03	1
LG&E	C1S	858576	03/2010	02/10/2010	100.10	99.85	100.05	1
LG&E	C1S	858577	03/2010	02/10/2010	100.10	99.96	100.10	1
LG&E	C1S	858578	03/2010	02/10/2010	100.06	99.81	100.05	1
LG&E	C1S	858579	03/2010	02/10/2010	100.06	100.04	100.14	1
LG&E	C1S	858580	03/2010	02/10/2010	100.06	99.87	99.99	1
LG&E	C1S	858581	03/2010	02/10/2010	100.08	99.97	100.00	1
LG&E	C1S	858582	03/2010	02/10/2010	100.09	100.03	100.07	1
LG&E	C1S	858583	03/2010	02/10/2010	100.09	99.98	100.09	1

LG&E	C1S	858584	03/2010	02/10/2010	100.06	99.89	100.04	1
LG&E	C1S	858585	03/2010	02/10/2010	100.06	99.92	100.01	1
LG&E	C1S	858586	03/2010	02/10/2010	100.06	99.97	100.06	1
LG&E	C1S	858587	03/2010	02/10/2010	100.10	99.96	100.02	1
LG&E	C1S	858588	03/2010	02/10/2010	100.10	100.01	100.04	1
LG&E	C1S	858589	03/2010	02/10/2010	100.06	100.00	100.16	1
LG&E	C1S	858590	03/2010	02/10/2010	100.08	100.03	100.14	1
LG&E	C1S	858591	03/2010	02/10/2010	100.08	99.90	100.06	1
LG&E	C1S	858592	03/2010	02/10/2010	100.08	100.00	100.09	1
LG&E	C1S	858593	03/2010	02/10/2010	100.06	99.96	99.96	1
LG&E	C1S	858594	03/2010	02/10/2010	100.10	99.94	100.16	1
LG&E	C1S	858595	03/2010	02/10/2010	100.08	99.93	100.10	1
LG&E	C1S	858596	03/2010	02/10/2010	100.10	100.08	100.19	1
LG&E	C1S	858597	03/2010	02/10/2010	100.06	99.90	100.03	1
LG&E	C1S	858598	03/2010	02/10/2010	100.06	99.85	100.10	1
LG&E	C1S	858599	03/2010	02/10/2010	100.05	99.98	100.00	1
LG&E	C1S	858600	03/2010	02/10/2010	100.06	100.00	100.16	1
LG&E	C1S	858601	03/2010	02/10/2010	100.09	100.11	100.20	1
LG&E	C1S	858602	03/2010	02/10/2010	100.09	100.09	100.09	1
LG&E	C1S	858603	03/2010	02/10/2010	100.11	99.92	100.17	1
LG&E	C1S	858604	03/2010	02/10/2010	100.08	100.03	100.10	1
LG&E	C1S	858605	03/2010	02/10/2010	100.07	99.83	100.03	1
LG&E	C1S	858606	03/2010	02/10/2010	100.05	100.04	100.19	1
LG&E	C1S	858607	03/2010	02/10/2010	100.08	99.94	100.04	1
LG&E	C1S	858608	03/2010	02/10/2010	100.05	99.94	100.01	1
LG&E	C1S	858609	03/2010	02/10/2010	100.08	100.09	100.17	1
LG&E	C1S	858610	03/2010	02/10/2010	100.09	99.99	100.12	1
LG&E	C1S	858611	03/2010	02/10/2010	100.07	99.98	100.02	1
LG&E	C1S	858612	03/2010	02/10/2010	100.08	100.09	100.11	1
LG&E	C1S	858613	03/2010	02/10/2010	100.06	99.96	99.96	1
LG&E	C1S	858614	03/2010	02/10/2010	100.06	99.98	99.91	1
LG&E	C1S	858615	03/2010	02/10/2010	100.10	100.03	100.20	1
LG&E	C1S	858616	03/2010	02/10/2010	100.10	99.97	100.13	1
LG&E	C1S	858617	03/2010	02/10/2010	100.09	100.11	100.16	1
LG&E	C1S	858618	03/2010	02/10/2010	100.10	100.03	100.11	1
LG&E	C1S	858619	03/2010	02/10/2010	100.09	100.06	100.15	1

LG&E	C1S	858620	03/2010	02/10/2010	100.09	99.98	100.08	1
LG&E	C1S	858621	03/2010	02/10/2010	100.07	100.06	100.17	1
LG&E	C1S	858622	03/2010	02/10/2010	100.06	99.99	100.09	1
LG&E	C1S	858623	03/2010	02/10/2010	100.08	100.11	100.19	1
LG&E	C1S	858624	03/2010	02/10/2010	100.08	100.05	100.21	1
LG&E	C1S	858625	03/2010	02/10/2010	100.09	100.05	100.17	1
LG&E	C1S	858626	03/2010	02/10/2010	100.08	100.06	100.12	1
LG&E	C1S	858627	03/2010	02/10/2010	100.09	99.96	100.08	1
LG&E	C1S	858628	03/2010	02/10/2010	100.10	99.94	100.06	1
LG&E	C1S	858629	03/2010	02/10/2010	100.07	99.99	100.01	1
LG&E	C1S	858630	03/2010	02/10/2010	100.10	100.02	100.16	1
LG&E	C1S	858631	03/2010	02/10/2010	100.09	100.00	100.09	1
LG&E	C1S	858632	03/2010	02/10/2010	100.06	100.12	100.11	1
LG&E	C1S	858633	03/2010	02/10/2010	100.10	99.96	100.06	1
LG&E	C1S	858634	03/2010	02/10/2010	100.07	100.09	100.13	1
LG&E	C1S	858635	03/2010	02/10/2010	100.06	99.93	100.04	1
LG&E	C1S	858636	03/2010	02/10/2010	100.06	100.03	100.18	1
LG&E	C1S	858637	03/2010	02/10/2010	100.07	99.96	100.09	1
LG&E	C1S	858638	03/2010	02/10/2010	100.08	99.92	100.06	1
LG&E	C1S	858639	03/2010	02/10/2010	100.05	99.88	100.04	1
LG&E	C1S	858640	03/2010	02/10/2010	100.07	99.92	100.03	1
LG&E	C1S	858641	03/2010	02/10/2010	100.09	99.89	100.08	1
LG&E	C1S	858642	03/2010	02/10/2010	100.06	99.90	100.02	1
LG&E	C1S	858643	03/2010	02/10/2010	100.06	100.09	100.15	1
LG&E	C1S	858644	03/2010	02/10/2010	100.07	99.92	99.96	1
LG&E	C1S	858645	03/2010	02/10/2010	100.06	99.95	99.96	1
LG&E	C1S	858646	03/2010	02/10/2010	100.06	99.96	100.05	1
LG&E	C1S	858647	03/2010	02/10/2010	100.08	99.87	100.06	1
LG&E	C1S	858648	03/2010	02/10/2010	100.07	99.94	100.01	1
LG&E	C1S	858649	03/2010	02/10/2010	100.08	99.93	100.01	1
LG&E	C1S	858650	03/2010	02/10/2010	100.07	99.89	99.99	1
LG&E	C1S	858651	03/2010	02/10/2010	100.06	99.98	100.03	1
LG&E	C1S	858652	03/2010	02/10/2010	100.10	100.00	100.03	1
LG&E	C1S	858653	03/2010	02/10/2010	100.06	100.06	100.15	1
LG&E	C1S	858654	03/2010	02/10/2010	100.09	99.95	100.11	1
LG&E	C1S	858655	03/2010	02/10/2010	100.09	100.10	100.17	1

LG&E	CIS	858656	03/2010	02/10/2010	100.09	100.10	100.24	1
LG&E	CIS	858657	03/2010	02/10/2010	100.09	100.09	100.14	1
LG&E	CIS	858658	03/2010	02/10/2010	100.08	100.06	100.14	1
LG&E	CIS	858659	03/2010	02/10/2010	100.09	99.96	100.02	1
LG&E	CIS	858660	03/2010	02/10/2010	100.08	100.03	100.17	1
LG&E	CIS	858661	03/2010	02/10/2010	100.10	100.01	100.03	1
LG&E	CIS	858662	03/2010	02/10/2010	100.06	99.89	100.05	1
LG&E	CIS	858663	03/2010	02/10/2010	100.09	100.10	100.20	1
LG&E	CIS	858664	03/2010	02/10/2010	100.06	100.04	100.20	1
LG&E	CIS	858665	03/2010	02/10/2010	100.10	100.12	100.13	1
LG&E	CIS	858666	03/2010	02/10/2010	100.08	100.08	100.25	1
LG&E	CIS	858667	03/2010	02/10/2010	100.05	100.10	100.04	1
LG&E	CIS	858668	03/2010	02/10/2010	100.10	100.15	100.19	1
LG&E	CIS	858669	03/2010	02/10/2010	100.08	100.12	100.12	1
LG&E	CIS	858670	03/2010	02/10/2010	100.09	100.10	100.17	1
LG&E	CIS	858671	03/2010	02/10/2010	100.06	100.01	99.97	1
LG&E	CIS	858672	03/2010	02/10/2010	100.09	99.94	100.08	1
LG&E	CIS	858673	03/2010	02/10/2010	100.06	99.97	100.09	1
LG&E	CIS	858674	03/2010	02/10/2010	100.09	100.01	100.13	1
LG&E	CIS	858675	03/2010	02/10/2010	100.06	100.05	100.07	1
LG&E	CIS	858676	03/2010	02/10/2010	100.08	100.06	100.21	1
LG&E	CIS	858677	03/2010	02/10/2010	100.06	100.04	100.16	1
LG&E	CIS	858678	03/2010	02/10/2010	100.05	100.06	100.15	1
LG&E	CIS	858679	03/2010	02/10/2010	100.08	100.12	100.17	1
LG&E	CIS	858680	03/2010	02/10/2010	100.09	100.06	100.15	1
LG&E	CIS	858681	03/2010	02/10/2010	100.05	100.03	100.19	1
LG&E	CIS	858682	03/2010	02/10/2010	100.08	100.04	100.19	1
LG&E	CIS	858683	03/2010	02/10/2010	100.08	100.06	100.18	1
LG&E	CIS	858684	03/2010	02/10/2010	100.09	100.06	100.20	1
LG&E	CIS	858685	03/2010	02/10/2010	100.08	99.89	100.05	1
LG&E	CIS	858687	03/2010	02/10/2010	100.09	100.02	100.05	1
LG&E	CIS	858688	03/2010	02/10/2010	100.09	99.92	100.08	1
LG&E	CIS	858689	03/2010	02/10/2010	100.05	99.94	99.99	1
LG&E	CIS	858690	03/2010	02/10/2010	100.10	99.98	100.10	1
LG&E	CIS	858691	03/2010	02/10/2010	100.06	100.00	100.23	1

LG&E	C1S	858692	03/2010	02/10/2010	100.07	99.90	100.03	1
LG&E	C1S	858693	03/2010	02/10/2010	100.06	99.90	99.98	1
LG&E	C1S	858694	03/2010	02/10/2010	100.09	100.00	100.06	1
LG&E	C1S	858695	03/2010	02/10/2010	100.06	99.92	99.96	1
LG&E	C1S	858696	03/2010	02/10/2010	100.09	100.03	100.03	1
LG&E	C1S	858697	03/2010	02/10/2010	100.09	99.93	100.07	1
LG&E	C1S	858698	03/2010	02/10/2010	100.07	100.04	100.14	1
LG&E	C1S	858699	03/2010	02/10/2010	100.06	99.84	100.05	1
LG&E	C1S	858700	03/2010	02/10/2010	100.10	99.92	100.08	1
LG&E	C1S	858701	03/2010	02/10/2010	100.09	99.99	100.14	1
LG&E	C1S	858702	03/2010	02/10/2010	100.05	99.97	99.92	1
LG&E	C1S	858703	03/2010	02/10/2010	100.07	99.92	99.98	1
LG&E	C1S	858704	03/2010	02/10/2010	100.09	100.10	100.14	1
LG&E	C1S	858705	03/2010	02/10/2010	100.07	99.88	100.07	1
LG&E	C1S	858706	03/2010	02/10/2010	100.08	100.04	100.21	1
LG&E	C1S	858707	03/2010	02/10/2010	100.09	100.05	100.01	1
LG&E	C1S	858708	03/2010	02/10/2010	100.06	99.89	100.03	1
LG&E	C1S	858709	03/2010	02/10/2010	100.08	99.93	100.00	1
LG&E	C1S	858710	03/2010	02/10/2010	100.10	99.92	100.06	1
LG&E	C1S	858711	03/2010	02/10/2010	100.06	99.97	99.95	1
LG&E	C1S	858712	03/2010	02/10/2010	100.07	99.97	100.03	1
LG&E	C1S	858713	03/2010	02/10/2010	100.06	100.01	100.11	1
LG&E	C1S	858714	03/2010	02/10/2010	100.06	99.89	100.10	1
LG&E	C1S	858715	03/2010	02/10/2010	100.06	100.02	100.12	1
LG&E	C1S	858716	03/2010	02/10/2010	100.08	99.91	99.94	1
LG&E	C1S	858717	03/2010	02/10/2010	100.06	99.89	100.00	1
LG&E	C1S	858718	03/2010	02/10/2010	100.07	99.94	100.12	1
LG&E	C1S	858719	03/2010	02/10/2010	100.09	99.96	100.13	1
LG&E	C1S	858720	03/2010	02/10/2010	100.09	99.92	99.98	1
LG&E	C1S	858721	03/2010	02/10/2010	100.06	99.95	100.06	1
LG&E	C1S	858722	03/2010	02/10/2010	100.07	99.98	100.12	1
LG&E	C1S	858723	03/2010	02/10/2010	100.09	100.12	100.19	1
LG&E	C1S	858724	03/2010	02/10/2010	100.07	100.05	100.15	1
LG&E	C1S	858725	03/2010	02/10/2010	100.06	100.03	100.14	1
LG&E	C1S	858726	03/2010	02/10/2010	100.08	100.03	100.04	1
LG&E	C1S	858727	03/2010	02/10/2010	100.08	99.96	99.94	1

LG&E	C1S	858728	03/2010	02/10/2010	100.06	99.87	100.08	1
LG&E	C1S	858729	03/2010	02/10/2010	100.05	99.89	100.01	1
LG&E	C1S	858730	03/2010	02/10/2010	100.08	99.94	100.01	1
LG&E	C1S	858731	03/2010	02/10/2010	100.06	100.03	100.15	1
LG&E	C1S	858732	03/2010	02/10/2010	100.09	100.02	100.03	1
LG&E	C1S	858733	03/2010	02/10/2010	100.10	100.03	100.09	1
LG&E	C1S	858734	03/2010	02/10/2010	100.09	99.93	100.00	1
LG&E	C1S	858735	03/2010	02/10/2010	100.08	100.03	100.00	1
LG&E	C1S	858736	03/2010	02/10/2010	100.05	99.96	100.04	1
LG&E	C1S	858737	03/2010	02/10/2010	100.08	99.95	100.15	1
LG&E	C1S	858738	03/2010	02/10/2010	100.07	99.94	100.07	1
LG&E	C1S	858739	03/2010	02/10/2010	100.06	99.90	100.02	1
LG&E	C1S	858740	03/2010	02/10/2010	100.06	100.02	100.01	1
LG&E	C1S	858741	03/2010	02/10/2010	100.06	100.06	100.14	1
LG&E	C1S	858742	03/2010	02/10/2010	100.06	99.93	100.02	1
LG&E	C1S	858743	03/2010	02/10/2010	100.06	99.93	100.07	1
LG&E	C1S	858744	03/2010	02/10/2010	100.07	100.02	100.11	1
LG&E	C1S	858745	03/2010	02/10/2010	100.09	100.03	100.14	1
LG&E	C1S	858746	03/2010	02/10/2010	100.07	99.95	100.03	1
LG&E	C1S	858747	03/2010	02/10/2010	100.08	99.84	100.04	1
LG&E	C1S	858748	03/2010	02/10/2010	100.07	99.94	100.04	1
LG&E	C1S	858749	03/2010	02/10/2010	100.10	99.89	100.02	1
LG&E	C1S	858750	03/2010	02/10/2010	100.09	99.90	100.03	1
LG&E	C1S	858751	03/2010	02/10/2010	100.09	99.97	100.00	1
LG&E	C1S	858752	03/2010	02/10/2010	100.07	99.90	100.01	1
LG&E	C1S	858753	03/2010	02/10/2010	100.09	100.06	100.19	1
LG&E	C1S	858754	03/2010	02/10/2010	100.09	100.01	100.13	1
LG&E	C1S	858755	03/2010	02/10/2010	100.08	100.02	100.03	1
LG&E	C1S	858756	03/2010	02/10/2010	100.09	100.07	100.25	1
LG&E	C1S	858757	03/2010	02/10/2010	100.08	99.98	100.02	1
LG&E	C1S	858758	03/2010	02/10/2010	100.09	100.10	100.18	1
LG&E	C1S	858759	03/2010	02/10/2010	100.05	100.07	100.13	1
LG&E	C1S	858760	03/2010	02/10/2010	100.06	99.90	100.03	1
LG&E	C1S	858761	03/2010	02/10/2010	100.06	99.91	100.03	1
LG&E	C1S	858762	03/2010	02/10/2010	100.06	100.04	100.12	1
LG&E	C1S	858763	03/2010	02/10/2010	100.06	100.10	100.17	1



LG&E	C1S	858764	03/2010	02/10/2010	100.08	100.08	100.19	1
LG&E	C1S	858765	03/2010	02/10/2010	100.08	100.12	100.20	1
LG&E	C1S	858766	03/2010	02/10/2010	100.07	99.88	100.02	1
LG&E	C1S	858767	03/2010	02/10/2010	100.10	100.06	100.18	1
LG&E	C1S	858768	03/2010	02/10/2010	100.08	100.12	100.16	1
LG&E	C1S	858769	03/2010	02/10/2010	100.05	99.91	99.90	1
LG&E	C1S	858770	03/2010	02/10/2010	100.06	99.92	100.06	1
LG&E	C1S	858771	03/2010	02/10/2010	100.06	100.01	100.06	1
LG&E	C1S	858772	03/2010	02/10/2010	100.08	99.88	100.01	1
LG&E	C1S	858773	03/2010	02/10/2010	100.09	100.00	100.02	1
LG&E	C1S	858774	03/2010	02/10/2010	100.07	99.99	100.02	1
LG&E	C1S	858775	03/2010	02/10/2010	100.07	99.86	99.96	1
LG&E	C1S	858776	03/2010	02/10/2010	100.06	99.99	100.07	1
LG&E	C1S	858777	03/2010	02/10/2010	100.09	99.89	100.08	1
LG&E	C1S	858778	03/2010	02/10/2010	100.06	100.05	100.21	1
LG&E	C1S	858779	03/2010	02/10/2010	100.07	99.86	100.01	1
LG&E	C1S	858780	03/2010	02/10/2010	100.07	100.01	100.12	1
LG&E	C1S	858781	03/2010	02/10/2010	100.07	99.98	99.96	1
LG&E	C1S	858782	03/2010	02/10/2010	100.08	99.95	100.04	1
LG&E	C1S	858783	03/2010	02/10/2010	100.09	99.95	100.05	1
LG&E	C1S	858784	03/2010	02/10/2010	100.06	100.02	100.00	1
LG&E	C1S	858785	03/2010	02/10/2010	100.08	99.97	100.07	1
LG&E	C1S	858786	03/2010	02/10/2010	100.08	99.95	100.11	1
LG&E	C1S	858787	03/2010	02/10/2010	100.08	100.03	100.13	1
LG&E	C1S	858788	03/2010	02/10/2010	100.08	99.94	100.05	1
LG&E	C1S	858789	03/2010	02/10/2010	100.08	100.06	100.09	1
LG&E	C1S	858790	03/2010	02/10/2010	100.07	100.04	100.19	1
LG&E	C1S	858791	03/2010	02/10/2010	100.10	99.99	100.16	1
LG&E	C1S	858792	03/2010	02/10/2010	100.10	99.85	100.06	1
LG&E	C1S	858793	03/2010	02/10/2010	100.06	100.10	100.20	1
LG&E	C1S	858794	03/2010	02/10/2010	100.06	100.00	100.13	1
LG&E	C1S	858795	03/2010	02/10/2010	100.06	99.97	99.97	1
LG&E	C1S	858796	03/2010	02/10/2010	100.10	99.92	100.06	1
LG&E	C1S	858797	03/2010	02/10/2010	100.08	99.93	99.95	1
LG&E	C1S	858798	03/2010	02/10/2010	100.07	100.05	100.07	1
LG&E	C1S	858799	03/2010	02/10/2010	100.05	99.94	100.01	1

LG&E	CIS	858800	03/2010	01/01/2010	100.08	100.03	99.93	1
LG&E	CIS	858801	03/2010	02/10/2010	100.09	99.97	99.92	1
LG&E	CIS	858802	03/2010	02/10/2010	100.08	99.89	100.06	1
LG&E	CIS	859584	07/2010	05/12/2010	100.08	99.98	99.92	1
LG&E	CIS	859585	07/2010	05/12/2010	100.06	100.09	99.97	1
LG&E	CIS	859586	07/2010	05/12/2010	100.09	100.00	99.99	1
LG&E	CIS	859587	07/2010	05/12/2010	100.07	99.89	100.05	1
LG&E	CIS	859588	07/2010	05/12/2010	100.08	99.98	100.11	1
LG&E	CIS	859589	07/2010	05/12/2010	100.08	99.98	100.20	1
LG&E	CIS	859590	07/2010	05/12/2010	100.10	100.04	99.93	1
LG&E	CIS	859591	07/2010	05/12/2010	100.07	100.04	100.11	1
LG&E	CIS	859592	07/2010	05/12/2010	100.08	99.97	100.00	1
LG&E	CIS	859593	07/2010	05/12/2010	100.08	99.92	100.00	1
LG&E	CIS	859594	07/2010	05/12/2010	100.09	100.07	100.15	1
LG&E	CIS	859595	07/2010	05/12/2010	100.08	99.96	100.02	1
LG&E	CIS	859596	07/2010	05/12/2010	100.10	100.00	100.07	1
LG&E	CIS	859597	07/2010	05/12/2010	100.06	100.03	100.14	1
LG&E	CIS	859598	07/2010	05/12/2010	100.10	99.89	100.09	1
LG&E	CIS	859599	07/2010	05/12/2010	100.05	99.98	99.93	1
LG&E	CIS	859600	07/2010	05/12/2010	100.06	99.98	100.06	1
LG&E	CIS	859601	07/2010	05/12/2010	100.10	100.01	100.20	1
LG&E	CIS	859602	07/2010	05/12/2010	100.06	99.96	99.97	1
LG&E	CIS	859603	07/2010	05/12/2010	100.09	100.06	100.14	1
LG&E	CIS	859604	07/2010	05/12/2010	100.07	100.06	100.17	1
LG&E	CIS	859605	07/2010	05/12/2010	100.10	99.95	100.05	1
LG&E	CIS	859606	07/2010	05/12/2010	100.10	100.03	99.99	1
LG&E	CIS	859607	07/2010	05/12/2010	100.08	99.91	100.18	1
LG&E	CIS	859608	07/2010	05/12/2010	100.08	100.11	100.20	1
LG&E	CIS	859609	07/2010	05/12/2010	100.07	100.03	100.19	1
LG&E	CIS	859610	07/2010	05/12/2010	100.09	100.00	100.10	1
LG&E	CIS	859611	07/2010	05/12/2010	100.07	99.90	99.96	1
LG&E	CIS	859612	07/2010	05/12/2010	100.07	99.98	99.98	1
LG&E	CIS	859613	07/2010	05/12/2010	100.10	100.00	100.18	1
LG&E	CIS	859614	07/2010	05/12/2010	100.05	100.07	99.91	1
LG&E	CIS	859615	07/2010	05/12/2010	100.06	99.99	100.18	1
LG&E	CIS	859616	07/2010	05/12/2010	100.06	100.00	100.01	1

LG&E	C1S	859617	07/2010	05/12/2010	100.06	99.94	99.97	1
LG&E	C1S	859618	07/2010	05/12/2010	100.09	100.06	100.18	1
LG&E	C1S	859619	07/2010	05/12/2010	100.10	99.97	99.97	1
LG&E	C1S	859620	07/2010	05/12/2010	100.10	100.10	100.12	1
LG&E	C1S	859621	07/2010	05/12/2010	100.06	99.91	100.11	1
LG&E	C1S	859622	07/2010	05/12/2010	100.06	100.00	99.96	1
LG&E	C1S	859623	07/2010	05/12/2010	100.09	99.96	99.96	1
LG&E	C1S	859624	07/2010	05/12/2010	100.10	100.08	100.20	1
LG&E	C1S	859625	07/2010	05/12/2010	100.06	100.09	100.17	1
LG&E	C1S	859626	07/2010	05/12/2010	100.07	99.88	100.04	1
LG&E	C1S	859627	07/2010	05/12/2010	100.08	100.04	100.18	1
LG&E	C1S	859628	07/2010	05/12/2010	100.06	100.03	100.14	1
LG&E	C1S	859629	07/2010	05/12/2010	100.06	99.97	100.06	1
LG&E	C1S	859630	07/2010	05/12/2010	100.09	100.00	100.13	1
LG&E	C1S	859631	07/2010	05/12/2010	100.10	99.95	100.17	1
LG&E	C1S	859632	07/2010	05/12/2010	100.08	99.99	100.05	1
LG&E	C1S	859633	07/2010	05/12/2010	100.06	100.00	99.96	1
LG&E	C1S	859634	07/2010	05/12/2010	100.05	99.87	100.03	1
LG&E	C1S	859635	07/2010	05/12/2010	100.06	99.89	100.11	1
LG&E	C1S	859636	07/2010	05/12/2010	100.08	100.07	100.20	1
LG&E	C1S	859637	07/2010	05/12/2010	100.08	100.13	100.14	1
LG&E	C1S	859638	07/2010	05/12/2010	100.06	100.01	100.08	1
LG&E	C1S	859639	07/2010	05/12/2010	100.05	100.02	100.13	1
LG&E	C1S	859640	07/2010	05/12/2010	100.09	99.99	99.97	1
LG&E	C1S	859641	07/2010	05/12/2010	100.08	99.88	100.15	1
LG&E	C1S	859642	07/2010	05/12/2010	100.10	100.04	100.12	1
LG&E	C1S	859643	07/2010	05/12/2010	100.07	100.00	100.08	1
LG&E	C1S	859644	07/2010	05/12/2010	100.09	100.04	99.97	1
LG&E	C1S	859645	07/2010	05/12/2010	100.10	100.07	100.24	1
LG&E	C1S	859646	07/2010	05/12/2010	100.08	99.87	100.02	1
LG&E	C1S	859647	07/2010	05/12/2010	100.08	100.03	100.11	1
LG&E	C1S	859648	07/2010	05/12/2010	100.07	99.92	100.02	1
LG&E	C1S	859649	07/2010	05/12/2010	100.10	100.11	99.99	1
LG&E	C1S	859650	07/2010	05/12/2010	100.07	99.92	99.97	1
LG&E	C1S	859651	07/2010	05/12/2010	100.06	99.99	100.13	1
LG&E	C1S	859652	07/2010	05/12/2010	100.09	100.05	100.19	1

LG&E	CIS	859653	07/2010	05/12/2010	100.08	100.07	100.17	1
LG&E	CIS	859654	07/2010	05/12/2010	100.08	100.11	100.16	1
LG&E	CIS	859655	07/2010	05/12/2010	100.06	99.94	99.98	1
LG&E	CIS	859656	07/2010	05/12/2010	100.09	100.09	100.23	1
LG&E	CIS	859657	07/2010	05/12/2010	100.08	99.96	100.07	1
LG&E	CIS	859658	07/2010	05/12/2010	100.10	99.93	99.89	1
LG&E	CIS	859659	07/2010	05/12/2010	100.07	99.97	100.08	1
LG&E	CIS	859660	07/2010	05/12/2010	100.07	99.86	100.03	1
LG&E	CIS	859661	07/2010	05/12/2010	100.08	99.94	100.11	1
LG&E	CIS	859662	07/2010	05/12/2010	100.08	100.01	100.13	1
LG&E	CIS	859663	07/2010	05/12/2010	100.10	99.88	100.04	1
LG&E	CIS	859664	07/2010	05/12/2010	100.09	100.03	100.14	1
LG&E	CIS	859665	07/2010	05/12/2010	100.09	100.04	100.23	1
LG&E	CIS	859666	07/2010	05/12/2010	100.09	99.97	100.07	1
LG&E	CIS	859667	07/2010	05/12/2010	100.07	99.90	99.97	1
LG&E	CIS	859668	07/2010	05/12/2010	100.09	99.98	100.02	1
LG&E	CIS	859669	07/2010	05/12/2010	100.07	100.03	100.09	1
LG&E	CIS	859670	07/2010	05/12/2010	100.06	99.91	100.08	1
LG&E	CIS	859671	07/2010	05/12/2010	100.08	100.01	100.02	1
LG&E	CIS	859672	07/2010	05/12/2010	100.06	99.93	100.08	1
LG&E	CIS	859673	07/2010	05/12/2010	100.07	100.00	100.15	1
LG&E	CIS	859674	07/2010	05/12/2010	100.08	99.90	100.06	1
LG&E	CIS	859675	07/2010	05/12/2010	100.07	99.85	100.03	1
LG&E	CIS	859676	07/2010	05/12/2010	100.09	100.09	100.19	1
LG&E	CIS	859677	07/2010	05/12/2010	100.10	100.10	100.02	1
LG&E	CIS	859678	07/2010	05/12/2010	100.09	99.93	100.11	1
LG&E	CIS	859679	07/2010	05/12/2010	100.09	99.96	99.95	1
LG&E	CIS	859680	07/2010	05/12/2010	100.08	100.04	100.16	1
LG&E	CIS	859681	07/2010	05/12/2010	100.06	99.89	100.04	1
LG&E	CIS	859682	07/2010	05/12/2010	100.06	100.02	100.03	1
LG&E	CIS	859683	07/2010	05/12/2010	100.06	100.14	100.13	1
LG&E	CIS	859684	07/2010	05/12/2010	100.07	99.94	100.10	1
LG&E	CIS	859685	07/2010	05/12/2010	100.07	99.97	99.95	1
LG&E	CIS	859686	07/2010	05/12/2010	100.09	100.09	100.14	1
LG&E	CIS	859687	07/2010	05/12/2010	100.09	100.06	100.16	1
LG&E	CIS	859688	07/2010	05/12/2010	100.08	100.06	100.12	1

LG&E	CIS	859689	07/2010	02/2010	100.06	100.02	99.94	1
LG&E	CIS	859690	07/2010	05/12/2010	100.10	99.96	100.14	1
LG&E	CIS	859691	07/2010	05/12/2010	100.10	99.91	100.10	1
LG&E	CIS	859692	07/2010	05/12/2010	100.09	100.09	100.20	1
LG&E	CIS	859693	07/2010	05/12/2010	100.09	100.04	100.12	1
LG&E	CIS	859694	07/2010	05/12/2010	100.07	100.09	99.96	1
LG&E	CIS	859695	07/2010	05/12/2010	100.09	99.96	99.96	1
LG&E	CIS	859696	07/2010	05/12/2010	100.08	100.07	100.15	1
LG&E	CIS	859697	07/2010	05/12/2010	100.08	99.93	100.08	1
LG&E	CIS	859698	07/2010	05/12/2010	100.07	99.97	99.99	1
LG&E	CIS	859699	07/2010	05/12/2010	100.09	99.97	100.07	1
LG&E	CIS	859700	07/2010	05/12/2010	100.06	99.91	100.02	1
LG&E	CIS	859701	07/2010	05/12/2010	100.09	100.02	99.93	1
LG&E	CIS	859702	07/2010	05/12/2010	100.09	100.12	100.16	1
LG&E	CIS	859703	07/2010	05/12/2010	100.09	100.01	100.17	1
LG&E	CIS	859704	07/2010	05/12/2010	100.05	99.94	100.03	1
LG&E	CIS	859705	07/2010	05/12/2010	100.06	99.90	100.00	1
LG&E	CIS	859706	07/2010	05/12/2010	100.07	99.84	100.11	1
LG&E	CIS	859707	07/2010	05/12/2010	100.08	100.07	100.17	1
LG&E	CIS	859708	07/2010	05/12/2010	100.08	99.86	100.01	1
LG&E	CIS	859709	07/2010	05/12/2010	100.06	99.98	100.15	1
LG&E	CIS	859710	07/2010	05/12/2010	100.08	99.97	100.05	1
LG&E	CIS	859711	07/2010	05/12/2010	100.05	100.05	100.00	1
LG&E	CIS	859712	07/2010	05/12/2010	100.05	99.86	99.97	1
LG&E	CIS	859713	07/2010	05/12/2010	100.10	100.06	100.20	1
LG&E	CIS	859714	07/2010	05/12/2010	100.08	100.03	100.03	1
LG&E	CIS	859715	07/2010	05/12/2010	100.07	99.80	100.10	1
LG&E	CIS	859716	07/2010	05/12/2010	100.07	100.09	100.14	1
LG&E	CIS	859717	07/2010	05/12/2010	100.08	100.01	99.93	1
LG&E	CIS	859718	07/2010	05/12/2010	100.09	99.98	100.09	1
LG&E	CIS	859719	07/2010	05/12/2010	100.09	99.98	100.09	1
LG&E	CIS	859720	07/2010	05/12/2010	100.08	99.91	100.11	1
LG&E	CIS	859721	07/2010	05/12/2010	100.08	100.05	100.17	1
LG&E	CIS	859722	07/2010	05/12/2010	100.08	100.01	100.03	1
LG&E	CIS	859723	07/2010	05/12/2010	100.09	99.96	100.11	1
LG&E	CIS	859724	07/2010	05/12/2010	100.09	99.95	100.04	1

LG&E	C1S	859725	07/2010	05/12/2010	100.07	99.91	100.08	1
LG&E	C1S	859726	07/2010	05/12/2010	100.06	100.04	100.13	1
LG&E	C1S	859727	07/2010	05/12/2010	100.06	99.92	99.90	1
LG&E	C1S	859728	07/2010	05/12/2010	100.07	100.05	100.24	1
LG&E	C1S	859729	07/2010	05/12/2010	100.05	100.07	100.16	1
LG&E	C1S	859730	07/2010	05/12/2010	100.08	99.89	100.03	1
LG&E	C1S	859731	07/2010	05/12/2010	100.08	99.93	100.09	1
LG&E	C1S	859732	07/2010	05/12/2010	100.06	100.05	100.14	1
LG&E	C1S	859733	07/2010	05/12/2010	100.09	99.95	99.95	1
LG&E	C1S	859734	07/2010	05/12/2010	100.07	100.04	100.00	1
LG&E	C1S	859735	07/2010	05/12/2010	100.09	99.96	100.02	1
LG&E	C1S	859736	07/2010	05/12/2010	100.08	100.00	100.00	1
LG&E	C1S	859737	07/2010	05/12/2010	100.06	99.98	100.04	1
LG&E	C1S	859738	07/2010	05/12/2010	100.07	100.03	100.19	1
LG&E	C1S	859739	07/2010	05/12/2010	100.10	100.03	100.07	1
LG&E	C1S	859740	07/2010	05/12/2010	100.06	99.93	100.00	1
LG&E	C1S	859741	07/2010	05/12/2010	100.06	99.94	100.00	1
LG&E	C1S	859742	07/2010	05/12/2010	100.09	100.11	100.19	1
LG&E	C1S	859743	07/2010	05/12/2010	100.05	100.10	100.15	1
LG&E	C1S	859744	07/2010	05/12/2010	100.06	100.00	100.02	1
LG&E	C1S	859745	07/2010	05/12/2010	100.08	99.95	100.10	1
LG&E	C1S	859746	07/2010	05/12/2010	100.06	99.95	100.06	1
LG&E	C1S	859747	07/2010	05/12/2010	100.08	100.05	100.22	1
LG&E	C1S	859748	07/2010	05/12/2010	100.06	99.94	100.01	1
LG&E	C1S	859749	07/2010	05/12/2010	100.07	100.06	100.14	1
LG&E	C1S	859750	07/2010	05/12/2010	100.06	100.02	100.14	1
LG&E	C1S	859751	07/2010	05/12/2010	100.07	100.00	100.12	1
LG&E	C1S	859752	07/2010	05/12/2010	100.05	100.02	100.09	1
LG&E	C1S	859753	07/2010	05/12/2010	100.06	99.96	100.11	1
LG&E	C1S	859754	07/2010	05/12/2010	100.09	99.93	99.89	1
LG&E	C1S	859755	07/2010	05/12/2010	100.05	100.06	100.16	1
LG&E	C1S	859756	07/2010	05/12/2010	100.07	99.93	99.97	1
LG&E	C1S	859757	07/2010	05/12/2010	100.08	100.09	100.21	1
LG&E	C1S	859758	07/2010	05/12/2010	100.08	99.97	100.05	1
LG&E	C1S	859759	07/2010	05/12/2010	100.10	100.07	100.17	1
LG&E	C1S	859760	07/2010	05/12/2010	100.09	100.07	100.20	1

LG&E	C1S	859761	07/2010	12/2010	100.10	99.92	100.07	1
LG&E	C1S	859762	07/2010	05/12/2010	100.08	99.92	99.92	1
LG&E	C1S	859763	07/2010	05/12/2010	100.08	99.93	100.01	1
LG&E	C1S	859764	07/2010	05/12/2010	100.08	100.12	100.20	1
LG&E	C1S	859765	07/2010	05/12/2010	100.06	100.06	100.11	1
LG&E	C1S	859766	07/2010	05/12/2010	100.09	100.03	100.15	1
LG&E	C1S	859767	07/2010	05/12/2010	100.08	99.94	100.12	1
LG&E	C1S	859768	07/2010	05/12/2010	100.07	99.89	100.12	1
LG&E	C1S	859769	07/2010	05/12/2010	100.06	100.00	100.01	1
LG&E	C1S	859770	07/2010	05/12/2010	100.07	100.12	100.12	1
LG&E	C1S	859771	07/2010	05/12/2010	100.05	99.90	100.02	1
LG&E	C1S	859772	07/2010	05/12/2010	100.08	99.93	100.03	1
LG&E	C1S	859773	07/2010	05/12/2010	100.08	100.03	100.02	1
LG&E	C1S	859774	07/2010	05/12/2010	100.08	100.02	100.01	1
LG&E	C1S	859775	07/2010	05/12/2010	100.09	100.01	100.04	1
LG&E	C1S	859776	07/2010	05/12/2010	100.08	100.04	100.17	1
LG&E	C1S	859777	07/2010	05/12/2010	100.09	100.07	100.17	1
LG&E	C1S	859778	07/2010	05/12/2010	100.10	100.13	100.25	1
LG&E	C1S	859779	07/2010	05/12/2010	100.08	99.94	99.98	1
LG&E	C1S	859780	07/2010	05/12/2010	100.06	99.93	99.97	1
LG&E	C1S	859781	07/2010	05/12/2010	100.07	99.99	100.03	1
LG&E	C1S	859782	07/2010	05/12/2010	100.07	99.88	100.07	1
LG&E	C1S	859783	07/2010	05/12/2010	100.09	100.01	99.98	1
LG&E	C1S	859784	07/2010	05/12/2010	100.06	99.99	100.13	1
LG&E	C1S	859785	07/2010	05/12/2010	100.10	100.02	99.96	1
LG&E	C1S	859786	07/2010	05/12/2010	100.08	100.02	100.01	1
LG&E	C1S	859787	07/2010	05/12/2010	100.08	100.03	100.20	1
LG&E	C1S	859788	07/2010	05/12/2010	100.07	99.94	100.06	1
LG&E	C1S	859789	07/2010	05/12/2010	100.09	99.92	100.15	1
LG&E	C1S	859790	07/2010	05/12/2010	100.09	100.09	100.15	1
LG&E	C1S	859791	07/2010	05/12/2010	100.09	100.08	100.17	1
LG&E	C1S	859792	07/2010	05/12/2010	100.09	100.06	100.16	1
LG&E	C1S	859793	07/2010	05/12/2010	100.08	100.01	99.99	1
LG&E	C1S	859794	07/2010	05/12/2010	100.08	100.08	100.12	1
LG&E	C1S	859795	07/2010	05/12/2010	100.06	99.99	99.96	1
LG&E	C1S	859796	07/2010	05/12/2010	100.06	99.87	100.14	1

LG&E	C1S	859797	07/2010	05/12/2010	100.07	99.95	100.09	1
LG&E	C1S	859798	07/2010	05/12/2010	100.09	100.03	100.11	1
LG&E	C1S	859799	07/2010	05/12/2010	100.08	99.88	100.08	1
LG&E	C1S	859800	07/2010	05/12/2010	100.08	100.02	100.12	1
LG&E	C1S	859801	07/2010	05/12/2010	100.10	99.95	100.07	1
LG&E	C1S	859802	07/2010	05/12/2010	100.09	99.94	100.07	1
LG&E	C1S	859803	07/2010	05/12/2010	100.06	100.02	100.12	1
LG&E	C1S	859804	07/2010	05/12/2010	100.08	100.09	100.19	1
LG&E	C1S	859805	07/2010	05/12/2010	100.09	100.00	100.11	1
LG&E	C1S	859806	07/2010	05/12/2010	100.10	99.97	100.08	1
LG&E	C1S	859807	07/2010	05/12/2010	100.09	100.02	100.02	1
LG&E	C1S	859808	07/2010	05/12/2010	100.08	99.93	100.19	1
LG&E	C1S	859809	07/2010	05/12/2010	100.08	100.01	100.00	1
LG&E	C1S	859810	07/2010	05/12/2010	100.09	99.84	100.08	1
LG&E	C1S	859811	07/2010	05/12/2010	100.08	100.07	100.09	1
LG&E	C1S	859812	07/2010	05/12/2010	100.09	99.97	100.10	1
LG&E	C1S	859813	07/2010	05/12/2010	100.06	99.91	100.04	1
LG&E	C1S	859814	07/2010	05/12/2010	100.08	99.98	100.06	1
LG&E	C1S	859815	07/2010	05/12/2010	100.09	100.01	99.95	1
LG&E	C1S	859816	07/2010	05/12/2010	100.09	99.98	100.15	1
LG&E	C1S	859817	07/2010	05/12/2010	100.07	99.91	100.06	1
LG&E	C1S	859818	07/2010	05/12/2010	100.06	99.92	99.98	1
LG&E	C1S	859819	07/2010	05/12/2010	100.09	100.01	100.21	1
LG&E	C1S	859820	07/2010	05/12/2010	100.07	100.06	100.12	1
LG&E	C1S	859821	07/2010	05/12/2010	100.06	99.87	100.09	1
LG&E	C1S	859822	07/2010	05/12/2010	100.08	100.09	100.13	1
LG&E	C1S	859823	07/2010	05/12/2010	100.10	99.99	99.97	1
LG&E	C1S	859824	07/2010	05/12/2010	100.06	100.06	100.10	1
LG&E	C1S	859825	07/2010	05/12/2010	100.08	100.06	100.16	1
LG&E	C1S	859826	07/2010	05/12/2010	100.08	99.99	100.04	1
LG&E	C1S	859827	07/2010	05/12/2010	100.06	100.06	100.16	1
LG&E	C1S	859828	07/2010	05/12/2010	100.08	100.08	100.15	1
LG&E	C1S	859829	07/2010	05/12/2010	100.06	100.07	100.13	1
LG&E	C1S	859830	07/2010	05/12/2010	100.08	100.01	100.19	1
LG&E	C1S	859831	07/2010	05/12/2010	100.07	100.00	99.98	1
LG&E	C1S	859832	07/2010	05/12/2010	100.06	99.90	100.16	1



LG&E	C1S	859833	07/2010	12/2010	100.10	99.98	100.09	1
LG&E	C1S	859834	07/2010	05/12/2010	100.07	100.02	100.18	1
LG&E	C1S	859835	07/2010	05/12/2010	100.06	100.05	100.16	1
LG&E	C1S	859836	07/2010	05/12/2010	100.07	100.04	100.07	1
LG&E	C1S	859837	07/2010	05/12/2010	100.08	99.95	100.08	1
LG&E	C1S	859838	07/2010	05/12/2010	100.08	100.08	100.16	1
LG&E	C1S	859839	07/2010	05/12/2010	100.07	100.06	100.17	1
LG&E	C1S	859840	07/2010	05/12/2010	100.10	99.92	100.15	1
LG&E	C1S	859841	07/2010	05/12/2010	100.09	99.89	100.02	1
LG&E	C1S	859842	07/2010	05/12/2010	100.07	99.96	100.08	1
LG&E	C1S	859843	07/2010	05/12/2010	100.07	99.93	99.94	1
LG&E	C1S	859844	07/2010	05/12/2010	100.06	100.00	100.11	1
LG&E	C1S	859845	07/2010	05/12/2010	100.06	100.01	99.96	1
LG&E	C1S	859846	07/2010	05/12/2010	100.06	100.06	100.16	1
LG&E	C1S	859847	07/2010	05/12/2010	100.10	99.94	100.16	1
LG&E	C1S	859848	07/2010	05/12/2010	100.08	99.95	99.99	1
LG&E	C1S	859849	07/2010	05/12/2010	100.06	99.91	100.08	1
LG&E	C1S	859850	07/2010	05/12/2010	100.09	100.07	100.17	1
LG&E	C1S	859851	07/2010	05/12/2010	100.09	99.95	99.92	1
LG&E	C1S	859852	07/2010	05/12/2010	100.10	99.97	100.16	1
LG&E	C1S	859853	07/2010	05/12/2010	100.10	99.93	99.94	1
LG&E	C1S	859854	07/2010	05/12/2010	100.07	99.98	100.20	1
LG&E	C1S	859855	07/2010	05/12/2010	100.09	99.96	100.03	1
LG&E	C1S	859856	07/2010	05/12/2010	100.09	99.97	99.98	1
LG&E	C1S	859857	07/2010	05/12/2010	100.09	100.02	99.99	1
LG&E	C1S	859858	07/2010	05/12/2010	100.09	99.98	100.08	1
LG&E	C1S	859859	07/2010	05/12/2010	100.09	99.97	100.12	1
LG&E	C1S	859860	07/2010	05/12/2010	100.10	100.06	100.00	1
LG&E	C1S	859861	07/2010	05/12/2010	100.09	99.81	100.11	1
LG&E	C1S	859862	07/2010	05/12/2010	100.10	100.16	100.11	1
LG&E	C1S	859863	07/2010	05/12/2010	100.09	100.06	99.91	1
LG&E	C1S	859864	07/2010	05/12/2010	100.08	99.87	100.03	1
LG&E	C1S	859865	07/2010	05/12/2010	100.05	100.01	100.05	1
LG&E	C1S	859866	07/2010	05/12/2010	100.08	100.03	100.04	1
LG&E	C1S	859867	07/2010	05/12/2010	100.06	99.94	99.93	1
LG&E	C1S	859868	07/2010	05/12/2010	100.09	99.95	99.96	1

LG&E	C1S	859869	07/2010	05/12/2010	100.09	99.97	100.00	1
LG&E	C1S	859870	07/2010	05/12/2010	100.07	99.91	100.13	1
LG&E	C1S	859871	07/2010	05/12/2010	100.10	99.96	99.97	1
LG&E	C1S	859872	07/2010	05/12/2010	100.10	100.09	100.19	1
LG&E	C1S	859873	07/2010	05/12/2010	100.05	99.95	100.08	1
LG&E	C1S	859874	07/2010	05/12/2010	100.09	100.10	100.18	1
LG&E	C1S	859875	07/2010	05/12/2010	100.07	100.11	100.15	1
LG&E	C1S	859876	07/2010	05/12/2010	100.09	100.03	100.13	1
LG&E	C1S	859877	07/2010	05/12/2010	100.08	99.97	99.92	1
LG&E	C1S	859878	07/2010	05/12/2010	100.09	100.10	100.11	1
LG&E	C1S	859879	07/2010	05/12/2010	100.09	100.05	100.15	1
LG&E	C1S	859880	07/2010	05/12/2010	100.06	99.95	100.12	1
LG&E	C1S	859881	07/2010	05/12/2010	100.09	99.89	100.08	1
LG&E	C1S	859882	07/2010	05/12/2010	100.07	100.00	100.08	1
LG&E	C1S	859883	07/2010	05/12/2010	100.08	99.91	100.06	1
LG&E	C1S	859884	07/2010	05/12/2010	100.09	100.03	100.22	1
LG&E	C1S	859885	07/2010	05/12/2010	100.09	99.90	100.12	1
LG&E	C1S	859886	07/2010	05/12/2010	100.09	100.09	100.19	1
LG&E	C1S	859887	07/2010	05/12/2010	100.06	100.01	100.13	1
LG&E	C1S	859888	07/2010	05/12/2010	100.10	100.11	100.26	1
LG&E	C1S	859889	07/2010	05/12/2010	100.08	100.06	100.16	1
LG&E	C1S	859890	07/2010	05/12/2010	100.06	100.06	100.15	1
LG&E	C1S	859891	07/2010	05/12/2010	100.08	100.02	100.12	1
LG&E	C1S	859892	07/2010	05/12/2010	100.06	99.91	99.95	1
LG&E	C1S	859893	07/2010	05/12/2010	100.06	100.04	100.10	1
LG&E	C1S	859894	07/2010	05/12/2010	100.09	100.03	100.05	1
LG&E	C1S	859895	07/2010	05/12/2010	100.08	99.96	100.04	1
LG&E	C1S	859896	07/2010	05/12/2010	100.08	99.89	100.08	1
LG&E	C1S	859897	07/2010	05/12/2010	100.08	100.05	100.17	1
LG&E	C1S	859898	07/2010	05/12/2010	100.08	100.02	100.22	1
LG&E	C1S	859899	07/2010	05/12/2010	100.06	100.06	100.15	1
LG&E	C1S	859900	07/2010	05/12/2010	100.10	99.92	100.05	1
LG&E	C1S	859901	07/2010	05/12/2010	100.09	99.92	100.07	1
LG&E	C1S	859902	07/2010	05/12/2010	100.07	100.07	100.06	1
LG&E	C1S	859903	07/2010	05/12/2010	100.06	99.87	100.03	1
LG&E	C1S	859904	07/2010	05/12/2010	100.10	100.03	100.03	1

LG&E	C1S	859905	07/2010	12/2010	100.06	100.05	100.08	1
LG&E	C1S	859906	07/2010	05/12/2010	100.06	100.00	100.13	1
LG&E	C1S	859907	07/2010	05/12/2010	100.09	99.96	100.01	1
LG&E	C1S	859908	07/2010	05/12/2010	100.08	100.05	100.19	1
LG&E	C1S	859909	07/2010	05/12/2010	100.06	99.93	100.08	1
LG&E	C1S	859910	07/2010	05/12/2010	100.08	99.93	99.93	1
LG&E	C1S	859911	07/2010	05/12/2010	100.06	99.95	99.98	1
LG&E	C1S	859912	07/2010	05/12/2010	100.07	99.85	100.06	1
LG&E	C1S	859913	07/2010	05/12/2010	100.07	99.91	100.04	1
LG&E	C1S	859914	07/2010	05/12/2010	100.06	99.94	100.04	1
LG&E	C1S	859915	07/2010	05/12/2010	100.07	100.01	100.17	1
LG&E	C1S	859916	07/2010	05/12/2010	100.10	100.14	100.11	1
LG&E	C1S	859917	07/2010	05/12/2010	100.07	100.01	100.15	1
LG&E	C1S	859918	07/2010	05/12/2010	100.10	100.05	100.22	1
LG&E	C1S	859919	07/2010	05/12/2010	100.08	100.11	100.11	1
LG&E	C1S	859920	07/2010	05/12/2010	100.08	99.98	100.03	1
LG&E	C1S	859921	07/2010	05/12/2010	100.09	99.96	99.98	1
LG&E	C1S	859922	07/2010	05/12/2010	100.08	99.94	100.12	1
LG&E	C1S	859923	07/2010	05/12/2010	100.08	100.04	100.17	1
LG&E	C1S	859924	07/2010	05/12/2010	100.08	100.07	100.08	1
LG&E	C1S	859925	07/2010	05/12/2010	100.07	99.96	100.03	1
LG&E	C1S	859926	07/2010	05/12/2010	100.10	99.98	100.13	1
LG&E	C1S	859927	07/2010	05/12/2010	100.05	99.99	100.12	1
LG&E	C1S	859928	07/2010	05/12/2010	100.10	100.06	100.07	1
LG&E	C1S	859929	07/2010	05/12/2010	100.09	99.98	100.00	1
LG&E	C1S	859930	07/2010	05/12/2010	100.06	100.07	100.10	1
LG&E	C1S	859931	07/2010	05/12/2010	100.10	99.97	100.01	1
LG&E	C1S	859932	07/2010	05/12/2010	100.10	99.91	100.07	1
LG&E	C1S	859933	07/2010	05/12/2010	100.09	99.94	99.98	1
LG&E	C1S	859934	07/2010	05/12/2010	100.07	100.02	100.15	1
LG&E	C1S	859935	07/2010	05/12/2010	100.09	99.96	100.06	1
LG&E	C1S	859936	07/2010	05/12/2010	100.10	99.95	99.96	1
LG&E	C1S	859937	07/2010	05/12/2010	100.07	99.92	100.08	1
LG&E	C1S	859938	07/2010	05/12/2010	100.08	100.01	100.01	1
LG&E	C1S	859939	07/2010	05/12/2010	100.08	99.98	100.01	1
LG&E	C1S	859940	07/2010	05/12/2010	100.09	99.97	100.03	1

LG&E	C1S	859941	07/2010	05/12/2010	100.05	99.88	100.11	1
LG&E	C1S	859942	07/2010	05/12/2010	100.09	100.05	99.97	1
LG&E	C1S	859943	07/2010	05/12/2010	100.07	99.96	100.02	1
LG&E	C1S	859944	07/2010	05/12/2010	100.08	100.00	100.11	1
LG&E	C1S	859945	07/2010	05/12/2010	100.10	99.92	99.99	1
LG&E	C1S	859946	07/2010	05/12/2010	100.08	100.06	100.13	1
LG&E	C1S	859947	07/2010	05/12/2010	100.09	99.82	100.08	1
LG&E	C1S	859948	07/2010	05/12/2010	100.10	100.06	100.16	1
LG&E	C1S	859949	07/2010	05/12/2010	100.06	99.90	100.11	1
LG&E	C1S	859950	07/2010	05/12/2010	100.06	100.09	100.20	1
LG&E	C1S	859951	07/2010	05/12/2010	100.08	99.92	100.04	1
LG&E	C1S	859952	07/2010	05/12/2010	100.06	99.94	100.00	1
LG&E	C1S	859953	07/2010	05/12/2010	100.10	100.06	100.15	1
LG&E	C1S	859954	07/2010	05/12/2010	100.09	100.02	99.97	1
LG&E	C1S	859955	07/2010	05/12/2010	100.06	99.85	100.06	1
LG&E	C1S	859956	07/2010	05/12/2010	100.10	99.98	100.02	1
LG&E	C1S	859957	07/2010	05/12/2010	100.08	99.93	99.99	1
LG&E	C1S	859958	07/2010	05/12/2010	100.08	99.87	99.92	1
LG&E	C1S	859959	07/2010	05/12/2010	100.06	99.96	100.07	1
LG&E	C1S	859960	07/2010	05/12/2010	100.06	100.00	100.17	1
LG&E	C1S	859961	07/2010	05/12/2010	100.10	100.15	100.16	1
LG&E	C1S	859962	07/2010	05/12/2010	100.08	99.97	100.00	1
LG&E	C1S	859963	07/2010	05/12/2010	100.06	99.99	100.17	1
LG&E	C1S	859964	07/2010	05/12/2010	100.07	99.94	100.10	1
LG&E	C1S	859965	07/2010	05/12/2010	100.07	100.02	100.12	1
LG&E	C1S	859966	07/2010	05/12/2010	100.06	99.96	100.13	1
LG&E	C1S	859967	07/2010	05/12/2010	100.08	100.08	100.17	1
LG&E	C1S	859968	07/2010	05/12/2010	100.05	99.97	99.87	1
LG&E	C1S	859969	07/2010	05/12/2010	100.09	99.94	100.03	1
LG&E	C1S	859970	07/2010	05/12/2010	100.09	100.11	100.19	1
LG&E	C1S	859971	07/2010	05/12/2010	100.07	99.96	100.17	1
LG&E	C1S	859972	07/2010	05/12/2010	100.08	100.07	100.23	1
LG&E	C1S	859973	07/2010	05/12/2010	100.06	99.97	99.94	1
LG&E	C1S	859974	07/2010	05/12/2010	100.07	100.05	100.13	1
LG&E	C1S	859975	07/2010	05/12/2010	100.06	100.02	99.99	1
LG&E	C1S	859976	07/2010	05/12/2010	100.08	99.98	100.00	1

LG&E	C1S	859977	07/2010	12/2010	100.09	100.01	100.02	1
LG&E	C1S	859978	07/2010	05/12/2010	100.08	99.98	100.17	1
LG&E	C1S	859979	07/2010	05/12/2010	100.06	99.92	99.99	1
LG&E	C1S	859980	07/2010	05/12/2010	100.09	99.97	99.95	1
LG&E	C1S	859981	07/2010	05/12/2010	100.09	100.08	100.19	1
LG&E	C1S	859982	07/2010	05/12/2010	100.08	100.13	100.00	1
LG&E	C1S	859983	07/2010	05/12/2010	100.10	100.15	100.27	1
LG&E	C1S	859984	07/2010	05/12/2010	100.09	99.89	100.16	1
LG&E	C1S	859985	07/2010	05/12/2010	100.06	100.00	100.07	1
LG&E	C1S	859986	07/2010	05/12/2010	100.07	100.08	100.13	1
LG&E	C1S	859987	07/2010	05/12/2010	100.08	100.02	99.97	1
LG&E	C1S	859988	07/2010	05/12/2010	100.06	100.00	100.21	1
LG&E	C1S	859989	07/2010	05/12/2010	100.09	100.08	100.14	1
LG&E	C1S	859990	07/2010	05/12/2010	100.06	100.00	99.88	1
LG&E	C1S	859991	07/2010	05/12/2010	100.06	100.04	100.22	1
LG&E	C1S	859992	07/2010	05/12/2010	100.07	99.92	99.92	1
LG&E	C1S	859993	07/2010	05/12/2010	100.09	100.03	100.11	1
LG&E	C1S	859994	07/2010	05/12/2010	100.07	99.87	100.09	1
LG&E	C1S	859995	07/2010	05/12/2010	100.09	99.90	100.12	1
LG&E	C1S	859996	07/2010	05/12/2010	100.06	99.89	99.98	1
LG&E	C1S	859997	07/2010	05/12/2010	100.08	100.08	100.11	1
LG&E	C1S	859998	07/2010	05/12/2010	100.06	100.12	100.16	1
LG&E	C1S	859999	07/2010	05/12/2010	100.06	100.02	100.06	1
LG&E	C1S	860000	07/2010	05/12/2010	100.07	99.97	100.03	1
LG&E	C1S	860001	07/2010	05/12/2010	100.08	100.01	100.14	1
LG&E	C1S	860002	07/2010	05/12/2010	100.07	99.88	100.13	1
LG&E	C1S	860003	07/2010	05/12/2010	100.06	100.09	100.18	1
LG&E	C1S	860004	07/2010	05/12/2010	100.09	100.00	100.09	1
LG&E	C1S	860005	07/2010	05/12/2010	100.09	99.92	100.21	1
LG&E	C1S	860006	07/2010	05/12/2010	100.09	100.05	100.10	1
LG&E	C1S	860007	07/2010	05/12/2010	100.07	99.93	100.00	1
LG&E	C1S	860008	07/2010	05/12/2010	100.06	100.04	100.11	1
LG&E	C1S	860009	07/2010	05/12/2010	100.06	100.11	100.12	1
LG&E	C1S	860010	07/2010	05/12/2010	100.07	99.95	100.03	1
LG&E	C1S	860011	07/2010	05/12/2010	100.10	99.95	100.05	1
LG&E	C1S	860012	07/2010	05/12/2010	100.06	100.05	100.17	1

LG&E	C1S	860013	07/2010	05/12/2010	100.08	99.98	100.07	1
LG&E	C1S	860014	07/2010	05/12/2010	100.10	99.91	100.00	1
LG&E	C1S	860015	07/2010	05/12/2010	100.06	99.94	100.03	1
LG&E	C1S	860016	07/2010	05/12/2010	100.08	99.93	99.98	1
LG&E	C1S	860017	07/2010	05/12/2010	100.10	100.05	99.97	1
LG&E	C1S	860018	07/2010	05/12/2010	100.09	99.88	100.00	1
LG&E	C1S	860019	07/2010	05/12/2010	100.10	100.14	100.24	1
LG&E	C1S	860020	07/2010	05/12/2010	100.08	99.91	100.12	1
LG&E	C1S	860021	07/2010	05/12/2010	100.07	99.94	100.06	1
LG&E	C1S	860022	07/2010	05/12/2010	100.08	100.01	100.22	1
LG&E	C1S	860023	07/2010	05/12/2010	100.06	99.98	99.98	1
LG&E	C1S	860024	07/2010	05/12/2010	100.09	99.89	100.00	1
LG&E	C1S	860025	07/2010	05/12/2010	100.08	99.91	99.97	1
LG&E	C1S	860026	07/2010	05/12/2010	100.07	100.02	100.17	1
LG&E	C1S	860027	07/2010	05/12/2010	100.06	100.02	99.98	1
LG&E	C1S	860028	07/2010	05/12/2010	100.09	99.93	100.02	1
LG&E	C1S	860029	07/2010	05/12/2010	100.08	100.03	100.20	1
LG&E	C1S	860030	07/2010	05/12/2010	100.06	100.04	100.18	1
LG&E	C1S	860031	07/2010	05/12/2010	100.06	99.95	100.09	1
LG&E	C1S	860032	07/2010	05/12/2010	100.08	100.01	100.21	1
LG&E	C1S	860033	07/2010	05/12/2010	100.09	100.09	100.20	1
LG&E	C1S	860034	07/2010	05/12/2010	100.09	99.95	100.15	1
LG&E	C1S	860035	07/2010	05/12/2010	100.10	99.93	99.99	1
LG&E	C1S	860036	07/2010	05/12/2010	100.10	99.91	99.95	1
LG&E	C1S	860037	07/2010	05/12/2010	100.07	100.04	99.92	1
LG&E	C1S	860038	07/2010	05/12/2010	100.08	100.07	100.17	1
LG&E	C1S	860039	07/2010	05/12/2010	100.08	99.97	100.11	1
LG&E	C1S	860040	07/2010	05/12/2010	100.10	99.97	100.26	1
LG&E	C1S	860041	07/2010	05/12/2010	100.06	99.81	99.89	1
LG&E	C1S	860042	07/2010	05/12/2010	100.09	100.06	99.98	1
LG&E	C1S	860043	07/2010	05/12/2010	100.10	100.14	100.14	1
LG&E	C1S	860044	07/2010	05/12/2010	100.08	99.93	100.07	1
LG&E	C1S	860045	07/2010	05/12/2010	100.09	99.84	100.05	1
LG&E	C1S	860046	07/2010	05/12/2010	100.06	100.00	100.02	1
LG&E	C1S	860047	07/2010	05/12/2010	100.08	99.96	99.86	1
LG&E	C1S	860048	07/2010	05/12/2010	100.06	100.10	100.15	1

LG&E	C1S	860049	07/2010	12/2010	100.08	99.96	100.09	1
LG&E	C1S	860050	07/2010	05/12/2010	100.10	99.95	100.01	1
LG&E	C1S	860051	07/2010	05/12/2010	100.08	99.95	100.20	1
LG&E	C1S	860052	07/2010	05/12/2010	100.08	100.13	100.24	1
LG&E	C1S	860053	07/2010	05/12/2010	100.10	100.06	100.15	1
LG&E	C1S	860054	07/2010	05/12/2010	100.08	100.11	100.14	1
LG&E	C1S	860055	07/2010	05/12/2010	100.08	100.06	100.11	1
LG&E	C1S	860056	07/2010	05/12/2010	100.09	99.90	100.05	1
LG&E	C1S	860057	07/2010	05/12/2010	100.09	99.94	100.01	1
LG&E	C1S	860058	07/2010	05/12/2010	100.09	100.04	100.02	1
LG&E	C1S	860059	07/2010	05/12/2010	100.06	100.10	100.12	1
LG&E	C1S	860060	07/2010	05/12/2010	100.08	100.11	100.17	1
LG&E	C1S	860061	07/2010	05/12/2010	100.08	99.89	100.01	1
LG&E	C1S	860062	07/2010	05/12/2010	100.07	99.93	100.06	1
LG&E	C1S	860063	07/2010	05/12/2010	100.05	99.99	100.09	1
LG&E	C1S	860064	07/2010	05/12/2010	100.06	100.01	100.11	1
LG&E	C1S	860065	07/2010	05/12/2010	100.08	99.92	100.04	1
LG&E	C1S	860066	07/2010	05/12/2010	100.08	100.09	100.18	1
LG&E	C1S	860067	07/2010	05/12/2010	100.05	99.96	100.09	1
LG&E	C1S	860068	07/2010	05/12/2010	100.10	99.94	100.04	1
LG&E	C1S	860069	07/2010	05/12/2010	100.09	100.02	100.04	1
LG&E	C1S	860070	07/2010	05/12/2010	100.07	99.96	99.90	1
LG&E	C1S	860071	07/2010	05/12/2010	100.08	100.03	100.14	1
LG&E	C1S	860072	07/2010	05/12/2010	100.09	100.00	99.94	1
LG&E	C1S	860073	07/2010	05/12/2010	100.08	99.85	100.05	1
LG&E	C1S	860074	07/2010	05/12/2010	100.10	99.99	100.10	1
LG&E	C1S	860075	07/2010	05/12/2010	100.06	100.03	99.93	1
LG&E	C1S	860076	07/2010	05/12/2010	100.09	100.12	100.26	1
LG&E	C1S	860077	07/2010	05/12/2010	100.10	100.07	100.16	1
LG&E	C1S	860078	07/2010	05/12/2010	100.10	99.94	100.21	1
LG&E	C1S	860079	07/2010	05/12/2010	100.07	99.92	99.93	1
LG&E	C1S	860080	07/2010	05/12/2010	100.06	99.98	99.91	1
LG&E	C1S	860081	07/2010	05/12/2010	100.06	100.08	100.18	1
LG&E	C1S	860082	07/2010	05/12/2010	100.10	99.94	100.09	1
LG&E	C1S	860083	07/2010	05/12/2010	100.10	100.10	99.91	1
LG&E	C1S	860084	07/2010	05/12/2010	100.07	100.12	100.14	1

LG&E	CIS	860085	07/2010	05/12/2010	100.07	100.05	100.10	1
LG&E	CIS	860086	07/2010	05/12/2010	100.08	100.09	100.15	1
LG&E	CIS	860087	07/2010	05/12/2010	100.07	100.07	100.16	1
LG&E	CIS	860088	07/2010	05/12/2010	100.10	99.99	99.99	1
LG&E	CIS	860089	07/2010	05/12/2010	100.08	100.10	100.19	1
LG&E	CIS	860090	07/2010	05/12/2010	100.08	99.92	100.07	1
LG&E	CIS	860091	07/2010	05/12/2010	100.09	100.09	100.17	1
LG&E	CIS	860092	07/2010	05/12/2010	100.07	100.09	100.16	1
LG&E	CIS	860093	07/2010	05/12/2010	100.08	99.93	100.00	1
LG&E	CIS	860094	07/2010	05/12/2010	100.08	99.98	99.98	1
LG&E	CIS	860095	07/2010	05/12/2010	100.10	99.96	100.12	1
LG&E	CIS	860096	07/2010	05/12/2010	100.06	99.97	99.86	1
LG&E	CIS	860097	07/2010	05/12/2010	100.10	99.92	100.04	1
LG&E	CIS	860098	07/2010	05/12/2010	100.05	100.02	100.05	1
LG&E	CIS	860099	07/2010	05/12/2010	100.09	100.13	100.20	1
LG&E	CIS	860100	07/2010	05/12/2010	100.08	99.99	100.08	1
LG&E	CIS	860101	07/2010	05/12/2010	100.08	99.98	100.20	1
LG&E	CIS	860102	07/2010	05/12/2010	100.10	100.00	100.20	1
LG&E	CIS	860103	07/2010	05/12/2010	100.07	100.08	100.19	1
LG&E	CIS	860104	07/2010	05/12/2010	100.10	100.09	100.21	1
LG&E	CIS	860105	07/2010	05/12/2010	100.06	99.94	99.99	1
LG&E	CIS	860106	07/2010	05/12/2010	100.07	100.12	100.18	1
LG&E	CIS	860107	07/2010	05/12/2010	100.06	99.91	99.99	1
LG&E	CIS	860108	07/2010	05/12/2010	100.07	99.94	100.04	1
LG&E	CIS	860109	07/2010	05/12/2010	100.07	100.06	100.13	1
LG&E	CIS	860110	07/2010	05/12/2010	100.08	100.00	100.07	1
LG&E	CIS	860111	07/2010	05/12/2010	100.07	100.00	100.11	1
LG&E	CIS	860112	07/2010	05/12/2010	100.08	99.97	100.11	1
LG&E	CIS	860113	07/2010	05/12/2010	100.08	100.06	100.14	1
LG&E	CIS	860114	07/2010	05/12/2010	100.10	99.98	100.05	1
LG&E	CIS	860115	07/2010	05/12/2010	100.07	99.96	100.11	1
LG&E	CIS	860116	07/2010	05/12/2010	100.08	99.91	100.12	1
LG&E	CIS	860117	07/2010	05/12/2010	100.06	99.90	100.08	1
LG&E	CIS	860118	07/2010	05/12/2010	100.08	99.99	99.99	1
LG&E	CIS	860119	07/2010	05/12/2010	100.10	100.05	100.26	1
LG&E	CIS	860120	07/2010	05/12/2010	100.07	100.00	99.98	1



LG&E	C1S	860121	07/2010	12/2010	100.08	99.90	100.19	1
LG&E	C1S	860122	07/2010	05/12/2010	100.09	100.06	100.19	1
LG&E	C1S	860123	07/2010	05/12/2010	100.08	99.94	100.10	1
LG&E	C1S	860124	07/2010	05/12/2010	100.10	100.08	100.14	1
LG&E	C1S	860125	07/2010	05/12/2010	100.08	100.09	100.11	1
LG&E	C1S	860126	07/2010	05/12/2010	100.08	100.05	100.12	1
LG&E	C1S	860127	07/2010	05/12/2010	100.05	99.93	100.22	1
LG&E	C1S	860128	07/2010	05/12/2010	100.07	100.08	100.18	1
LG&E	C1S	860129	07/2010	05/12/2010	100.05	99.96	100.13	1
LG&E	C1S	860130	07/2010	05/12/2010	100.08	100.14	100.11	1
LG&E	C1S	860131	07/2010	05/12/2010	100.06	100.01	99.98	1
LG&E	C1S	860132	07/2010	05/12/2010	100.06	99.98	100.21	1
LG&E	C1S	860133	07/2010	05/12/2010	100.06	99.86	99.88	1
LG&E	C1S	860134	07/2010	05/12/2010	100.07	99.95	100.19	1
LG&E	C1S	860135	07/2010	05/12/2010	100.09	99.95	100.05	1
LG&E	C1S	860136	07/2010	05/12/2010	100.09	99.95	100.03	1
LG&E	C1S	860137	07/2010	05/12/2010	100.06	99.94	100.16	1
LG&E	C1S	860138	07/2010	05/12/2010	100.09	100.07	100.13	1
LG&E	C1S	860139	07/2010	05/12/2010	100.09	100.06	100.17	1
LG&E	C1S	860140	07/2010	05/12/2010	100.06	99.91	100.20	1
LG&E	C1S	860141	07/2010	05/12/2010	100.08	99.98	100.13	1
LG&E	C1S	860142	07/2010	05/12/2010	100.06	100.01	99.97	1
LG&E	C1S	860143	07/2010	05/12/2010	100.08	100.03	100.16	1
LG&E	C1S	860144	07/2010	05/12/2010	100.06	99.97	99.96	1
LG&E	C1S	860145	07/2010	05/12/2010	100.09	99.94	100.05	1
LG&E	C1S	860146	07/2010	05/12/2010	100.07	99.89	100.04	1
LG&E	C1S	860147	07/2010	05/12/2010	100.05	99.93	100.01	1
LG&E	C1S	860148	07/2010	05/12/2010	100.08	99.99	100.03	1
LG&E	C1S	860149	07/2010	05/12/2010	100.09	100.14	100.19	1
LG&E	C1S	860150	07/2010	05/12/2010	100.07	99.99	100.02	1
LG&E	C1S	860151	07/2010	05/12/2010	100.07	100.04	100.11	1
LG&E	C1S	860152	07/2010	05/12/2010	100.09	99.99	100.12	1
LG&E	C1S	860153	07/2010	05/12/2010	100.06	100.02	100.14	1
LG&E	C1S	860154	07/2010	05/12/2010	100.06	99.87	100.00	1
LG&E	C1S	860155	07/2010	05/12/2010	100.06	99.86	100.07	1
LG&E	C1S	860156	07/2010	05/12/2010	100.08	99.89	99.96	1

LG&E	C1S	860157	07/2010	05/12/2010	100.09	100.14	100.19	1
LG&E	C1S	860158	07/2010	05/12/2010	100.08	100.08	100.13	1
LG&E	C1S	860159	07/2010	05/12/2010	100.09	99.92	100.09	1
LG&E	C1S	860160	07/2010	05/12/2010	100.10	100.02	100.06	1
LG&E	C1S	860161	07/2010	05/12/2010	100.09	99.96	99.98	1
LG&E	C1S	860162	07/2010	05/12/2010	100.08	99.91	100.07	1
LG&E	C1S	860163	07/2010	05/12/2010	100.08	99.97	100.02	1
LG&E	C1S	860164	07/2010	05/12/2010	100.06	99.99	100.05	1
LG&E	C1S	860165	07/2010	05/12/2010	100.06	100.09	100.15	1
LG&E	C1S	860166	07/2010	05/12/2010	100.07	100.05	100.17	1
LG&E	C1S	860167	07/2010	05/12/2010	100.08	99.96	100.15	1
LG&E	C1S	860168	07/2010	05/12/2010	100.06	99.97	99.91	1
LG&E	C1S	860169	07/2010	05/12/2010	100.10	99.92	100.10	1
LG&E	C1S	860170	07/2010	05/12/2010	100.09	100.09	100.13	1
LG&E	C1S	860171	07/2010	05/12/2010	100.09	100.00	100.14	1
LG&E	C1S	860172	07/2010	05/12/2010	100.09	100.02	99.97	1
LG&E	C1S	860173	07/2010	05/12/2010	100.09	99.93	100.01	1
LG&E	C1S	860174	07/2010	05/12/2010	100.07	99.90	100.01	1
LG&E	C1S	860175	07/2010	05/12/2010	100.09	100.04	99.99	1
LG&E	C1S	860176	07/2010	05/12/2010	100.08	100.01	99.98	1
LG&E	C1S	860177	07/2010	05/12/2010	100.06	99.93	99.96	1
LG&E	C1S	860178	07/2010	05/12/2010	100.08	100.01	99.99	1
LG&E	C1S	860179	07/2010	05/12/2010	100.09	99.99	99.98	1
LG&E	C1S	860180	07/2010	05/12/2010	100.05	99.89	99.96	1
LG&E	C1S	860181	07/2010	05/12/2010	100.07	99.88	100.02	1
LG&E	C1S	860182	07/2010	05/12/2010	100.06	99.95	100.03	1
LG&E	C1S	860183	07/2010	05/12/2010	100.09	100.10	100.17	1
LG&E	C1S	860184	07/2010	05/12/2010	100.09	100.01	99.98	1
LG&E	C1S	860185	07/2010	05/12/2010	100.06	99.99	99.98	1
LG&E	C1S	860186	07/2010	05/12/2010	100.09	100.07	100.15	1
LG&E	C1S	860187	07/2010	05/12/2010	100.08	100.02	99.98	1
LG&E	C1S	860188	07/2010	05/12/2010	100.06	99.93	99.95	1
LG&E	C1S	860189	07/2010	05/12/2010	100.08	100.07	100.15	1
LG&E	C1S	860190	07/2010	05/12/2010	100.06	99.86	100.04	1
LG&E	C1S	860191	07/2010	05/12/2010	100.06	100.02	100.17	1
LG&E	C1S	860192	07/2010	05/12/2010	100.10	99.95	100.08	1

LG&E	C1S	860193	07/2010	12/2010	100.07	99.94	99.92	1
LG&E	C1S	860194	07/2010	05/12/2010	100.09	99.95	100.04	1
LG&E	C1S	860195	07/2010	05/12/2010	100.08	99.97	99.97	1
LG&E	C1S	860196	07/2010	05/12/2010	100.10	100.02	100.14	1
LG&E	C1S	860197	07/2010	05/12/2010	100.08	100.02	100.17	1
LG&E	C1S	860198	07/2010	05/12/2010	100.06	99.86	99.99	1
LG&E	C1S	860199	07/2010	05/12/2010	100.07	99.99	100.01	1
LG&E	C1S	860200	07/2010	05/12/2010	100.10	100.02	100.03	1
LG&E	C1S	860201	07/2010	05/12/2010	100.06	99.96	100.03	1
LG&E	C1S	860202	07/2010	05/12/2010	100.08	100.09	100.19	1
LG&E	C1S	860203	07/2010	05/12/2010	100.09	100.11	100.14	1
LG&E	C1S	860204	07/2010	05/12/2010	100.09	99.88	100.01	1
LG&E	C1S	860205	07/2010	05/12/2010	100.10	99.93	100.19	1
LG&E	C1S	860206	07/2010	05/12/2010	100.11	100.01	100.15	1
LG&E	C1S	860207	07/2010	05/12/2010	100.09	100.03	100.06	1
LG&E	C1S	860208	07/2010	05/12/2010	100.06	100.05	100.05	1
LG&E	C1S	860209	07/2010	05/12/2010	100.06	99.91	100.07	1
LG&E	C1S	860210	07/2010	05/12/2010	100.06	100.09	100.09	1
LG&E	C1S	860211	07/2010	05/12/2010	100.08	99.95	100.01	1
LG&E	C1S	860212	07/2010	05/12/2010	100.10	100.08	100.20	1
LG&E	C1S	860213	07/2010	05/12/2010	100.09	100.16	100.19	1
LG&E	C1S	860214	07/2010	05/12/2010	100.10	100.00	99.97	1
LG&E	C1S	860215	07/2010	05/12/2010	100.09	100.03	100.14	1
LG&E	C1S	860216	07/2010	05/12/2010	100.05	99.99	100.07	1
LG&E	C1S	860217	07/2010	05/12/2010	100.10	99.97	100.11	1
LG&E	C1S	860218	07/2010	05/12/2010	100.08	100.00	100.03	1
LG&E	C1S	860219	07/2010	05/12/2010	100.06	99.90	100.14	1
LG&E	C1S	860220	07/2010	05/12/2010	100.09	100.05	100.12	1
LG&E	C1S	860221	07/2010	05/12/2010	100.05	99.85	100.08	1
LG&E	C1S	860222	07/2010	05/12/2010	100.06	99.99	99.97	1
LG&E	C1S	860223	07/2010	05/12/2010	100.06	99.86	100.09	1
LG&E	C1S	860224	07/2010	05/12/2010	100.10	99.96	100.08	1
LG&E	C1S	860225	07/2010	05/12/2010	100.09	99.93	99.98	1
LG&E	C1S	860226	07/2010	05/12/2010	100.08	100.02	99.96	1
LG&E	C1S	860227	07/2010	05/12/2010	100.06	99.86	100.07	1
LG&E	C1S	860228	07/2010	05/12/2010	100.08	100.08	100.09	1

LG&E	C1S	860229	07/2010	05/12/2010	100.07	99.95	100.08	1
LG&E	C1S	860230	07/2010	05/12/2010	100.08	99.95	99.92	1
LG&E	C1S	860231	07/2010	05/12/2010	100.06	100.00	100.07	1
LG&E	C1S	860232	07/2010	05/12/2010	100.05	99.97	99.86	1
LG&E	C1S	860233	07/2010	05/12/2010	100.10	99.96	100.05	1
LG&E	C1S	860234	07/2010	05/12/2010	100.07	99.97	99.93	1
LG&E	C1S	860235	07/2010	05/12/2010	100.09	99.97	100.01	1
LG&E	C1S	860236	07/2010	05/12/2010	100.06	99.91	100.05	1
LG&E	C1S	860237	07/2010	05/12/2010	100.06	99.92	99.99	1
LG&E	C1S	860238	07/2010	05/12/2010	100.09	99.94	100.07	1
LG&E	C1S	860239	07/2010	05/12/2010	100.06	99.93	100.03	1
LG&E	C1S	860240	07/2010	05/12/2010	100.07	100.03	100.12	1
LG&E	C1S	860241	07/2010	05/12/2010	100.09	99.98	100.10	1
LG&E	C1S	860242	07/2010	05/12/2010	100.09	100.05	99.94	1
LG&E	C1S	860243	07/2010	05/12/2010	100.08	99.84	100.03	1
LG&E	C1S	860244	07/2010	05/12/2010	100.06	100.00	100.00	1
LG&E	C1S	860245	07/2010	05/12/2010	100.09	100.03	100.21	1
LG&E	C1S	860246	07/2010	05/12/2010	100.07	99.89	100.04	1
LG&E	C1S	860247	07/2010	05/12/2010	100.08	100.03	100.08	1
LG&E	C1S	860248	07/2010	05/12/2010	100.08	99.98	100.00	1
LG&E	C1S	860249	07/2010	05/12/2010	100.08	100.07	100.13	1
LG&E	C1S	860250	07/2010	05/12/2010	100.09	100.09	100.14	1
LG&E	C1S	860251	07/2010	05/12/2010	100.07	100.12	100.15	1
LG&E	C1S	860252	07/2010	05/12/2010	100.06	100.01	100.14	1
LG&E	C1S	860253	07/2010	05/12/2010	100.09	99.93	100.09	1
LG&E	C1S	860254	07/2010	05/12/2010	100.10	100.09	100.17	1
LG&E	C1S	860255	07/2010	05/12/2010	100.10	99.89	100.03	1
LG&E	C1S	860256	07/2010	05/12/2010	100.06	100.03	99.97	1
LG&E	C1S	860257	07/2010	05/12/2010	100.06	99.87	99.99	1
LG&E	C1S	860258	07/2010	05/12/2010	100.08	100.06	100.04	1
LG&E	C1S	860259	07/2010	05/12/2010	100.08	100.01	99.86	1
LG&E	C1S	860260	07/2010	05/12/2010	100.07	99.90	100.05	1
LG&E	C1S	860261	07/2010	05/12/2010	100.06	99.80	100.01	1
LG&E	C1S	860262	07/2010	05/12/2010	100.07	99.92	99.93	1
LG&E	C1S	860263	07/2010	05/12/2010	100.06	100.03	100.11	1
LG&E	C1S	860264	07/2010	05/12/2010	100.07	100.04	100.11	1

LG&E	C1S	860265	07/2010	12/2010	100.09	100.02	100.15	1
LG&E	C1S	860266	07/2010	05/12/2010	100.06	100.07	99.97	1
LG&E	C1S	860267	07/2010	05/12/2010	100.05	99.91	99.92	1
LG&E	C1S	860268	07/2010	05/12/2010	100.05	100.00	100.13	1
LG&E	C1S	860269	07/2010	05/12/2010	100.08	99.92	100.08	1
LG&E	C1S	860270	07/2010	05/12/2010	100.07	100.02	100.08	1
LG&E	C1S	860271	07/2010	05/12/2010	100.08	99.94	99.97	1
LG&E	C1S	860272	07/2010	05/12/2010	100.10	99.93	100.18	1
LG&E	C1S	860273	07/2010	05/12/2010	100.08	99.88	99.96	1
LG&E	C1S	860274	07/2010	05/12/2010	100.06	99.96	100.14	1
LG&E	C1S	860275	07/2010	05/12/2010	100.08	99.96	100.15	1
LG&E	C1S	860276	07/2010	05/12/2010	100.08	99.95	100.09	1
LG&E	C1S	860277	07/2010	05/12/2010	100.08	100.07	100.08	1
LG&E	C1S	860278	07/2010	05/12/2010	100.08	100.08	100.16	1
LG&E	C1S	860279	07/2010	05/12/2010	100.06	99.98	99.96	1
LG&E	C1S	860280	07/2010	05/12/2010	100.05	99.93	100.02	1
LG&E	C1S	860281	07/2010	05/12/2010	100.08	99.98	100.13	1
LG&E	C1S	860282	07/2010	05/12/2010	100.08	99.97	100.06	1
LG&E	C1S	860283	07/2010	05/12/2010	100.07	100.03	100.22	1
LG&E	C1S	860284	07/2010	05/12/2010	100.06	99.88	100.08	1
LG&E	C1S	860285	07/2010	05/12/2010	100.07	99.99	100.13	1
LG&E	C1S	860286	07/2010	05/12/2010	100.07	99.98	100.11	1
LG&E	C1S	860287	07/2010	05/12/2010	100.09	99.91	100.08	1
LG&E	C1S	860288	07/2010	05/12/2010	100.09	99.93	100.07	1
LG&E	C1S	860289	07/2010	05/12/2010	100.07	99.86	100.10	1
LG&E	C1S	860290	07/2010	05/12/2010	100.05	99.84	100.06	1
LG&E	C1S	860291	07/2010	05/12/2010	100.09	100.10	100.12	1
LG&E	C1S	860292	07/2010	05/12/2010	100.09	100.02	100.01	1
LG&E	C1S	860293	07/2010	05/12/2010	100.08	99.98	100.07	1
LG&E	C1S	860294	07/2010	05/12/2010	100.07	100.06	100.02	1
LG&E	C1S	860295	07/2010	05/12/2010	100.06	100.01	99.91	1
LG&E	C1S	860296	07/2010	05/12/2010	100.06	99.95	100.04	1
LG&E	C1S	860297	07/2010	05/12/2010	100.08	99.87	100.02	1
LG&E	C1S	860298	07/2010	05/12/2010	100.06	99.91	100.04	1
LG&E	C1S	860299	07/2010	05/12/2010	100.08	99.90	100.01	1
LG&E	C1S	860300	07/2010	05/12/2010	100.07	99.98	100.06	1

LG&E	C1S	860301	07/2010	05/12/2010	100.09	99.86	100.06	1
LG&E	C1S	860302	07/2010	05/12/2010	100.08	100.09	100.11	1
LG&E	C1S	860303	07/2010	05/12/2010	100.08	99.99	100.05	1
LG&E	C1S	860304	07/2010	05/12/2010	100.07	99.99	100.11	1
LG&E	C1S	860305	07/2010	05/12/2010	100.08	99.92	100.11	1
LG&E	C1S	860306	07/2010	05/12/2010	100.11	100.02	100.03	1
LG&E	C1S	860307	07/2010	05/12/2010	100.09	100.08	100.17	1
LG&E	C1S	860308	07/2010	05/12/2010	100.07	100.09	100.15	1
LG&E	C1S	860309	07/2010	05/12/2010	100.06	100.03	100.14	1
LG&E	C1S	860310	07/2010	05/12/2010	100.10	99.98	100.18	1
LG&E	C1S	860311	07/2010	05/12/2010	100.10	100.02	100.13	1
LG&E	C1S	860312	07/2010	05/12/2010	100.08	99.94	100.13	1
LG&E	C1S	860313	07/2010	05/12/2010	100.08	99.91	100.11	1
LG&E	C1S	860314	07/2010	05/12/2010	100.07	99.96	100.03	1
LG&E	C1S	860315	07/2010	05/12/2010	100.06	100.04	99.99	1
LG&E	C1S	860316	07/2010	05/12/2010	100.08	100.10	100.19	1
LG&E	C1S	860317	07/2010	05/12/2010	100.05	100.04	100.11	1
LG&E	C1S	860318	07/2010	05/12/2010	100.08	99.96	100.14	1
LG&E	C1S	860319	07/2010	05/12/2010	100.06	99.95	100.09	1
LG&E	C1S	860320	07/2010	05/12/2010	100.08	99.99	100.02	1
LG&E	C1S	860321	07/2010	05/12/2010	100.07	100.02	100.16	1
LG&E	C1S	860322	07/2010	05/12/2010	100.09	99.94	100.13	1
LG&E	C1S	860323	07/2010	05/12/2010	100.06	99.92	99.81	1
LG&E	C1S	860324	07/2010	05/12/2010	100.06	100.09	100.12	1
LG&E	C1S	860325	07/2010	05/12/2010	100.08	99.96	100.11	1
LG&E	C1S	860326	07/2010	05/12/2010	100.07	99.97	100.14	1
LG&E	C1S	860327	07/2010	05/12/2010	100.10	99.96	100.15	1
LG&E	C1S	860328	07/2010	05/12/2010	100.10	99.92	100.02	1
LG&E	C1S	860329	07/2010	05/12/2010	100.09	99.98	100.15	1
LG&E	C1S	860330	07/2010	05/12/2010	100.05	100.06	100.11	1
LG&E	C1S	860331	07/2010	05/12/2010	100.08	99.86	99.94	1
LG&E	C1S	860332	07/2010	05/12/2010	100.08	99.91	100.16	1
LG&E	C1S	860333	07/2010	05/12/2010	100.08	99.92	100.09	1
LG&E	C1S	860334	07/2010	05/12/2010	100.07	100.05	100.09	1
LG&E	C1S	860335	07/2010	05/12/2010	100.09	99.95	100.09	1
LG&E	C1S	860336	07/2010	05/12/2010	100.06	99.91	100.04	1

LG&E	C1S	860337	07/2010	12/2010	100.07	99.96	100.15	1
LG&E	C1S	860338	07/2010	05/12/2010	100.06	100.00	100.10	1
LG&E	C1S	860339	07/2010	05/12/2010	100.06	99.91	100.00	1
LG&E	C1S	860340	07/2010	05/12/2010	100.06	99.90	99.95	1
LG&E	C1S	860341	07/2010	05/12/2010	100.06	99.89	100.10	1
LG&E	C1S	860342	07/2010	05/12/2010	100.09	99.89	100.10	1
LG&E	C1S	860343	07/2010	05/12/2010	100.09	99.99	100.08	1
LG&E	C1S	860344	07/2010	05/12/2010	100.10	99.94	100.09	1
LG&E	C1S	860345	07/2010	05/12/2010	100.10	99.90	100.11	1
LG&E	C1S	860346	07/2010	05/12/2010	100.05	99.88	100.13	1
LG&E	C1S	860347	07/2010	05/12/2010	100.09	99.93	99.98	1
LG&E	C1S	860348	07/2010	05/12/2010	100.10	99.97	100.11	1
LG&E	C1S	860349	07/2010	05/12/2010	100.09	99.89	100.04	1
LG&E	C1S	860350	07/2010	05/12/2010	100.08	99.92	99.96	1
LG&E	C1S	860351	07/2010	05/12/2010	100.10	99.94	100.10	1
LG&E	C1S	860352	07/2010	05/12/2010	100.06	99.85	100.07	1
LG&E	C1S	860353	07/2010	05/12/2010	100.09	99.95	100.07	1
LG&E	C1S	860354	07/2010	05/12/2010	100.06	100.06	100.10	1
LG&E	C1S	860355	07/2010	05/12/2010	100.08	99.96	99.93	1
LG&E	C1S	860356	07/2010	05/12/2010	100.10	100.03	100.14	1
LG&E	C1S	860357	07/2010	05/12/2010	100.10	99.97	100.02	1
LG&E	C1S	860358	07/2010	05/12/2010	100.06	99.91	99.94	1
LG&E	C1S	860359	07/2010	05/12/2010	100.08	99.99	99.99	1
LG&E	C1S	860360	07/2010	05/12/2010	100.08	100.10	100.17	1
LG&E	C1S	860361	07/2010	05/12/2010	100.10	99.94	100.05	1
LG&E	C1S	860362	07/2010	05/12/2010	100.08	99.99	100.06	1
LG&E	C1S	860363	07/2010	05/12/2010	100.06	99.91	100.04	1
LG&E	C1S	860364	07/2010	05/12/2010	100.06	99.84	100.04	1
LG&E	C1S	860365	07/2010	05/12/2010	100.09	99.91	99.97	1
LG&E	C1S	860366	07/2010	05/12/2010	100.06	100.02	100.11	1
LG&E	C1S	860367	07/2010	05/12/2010	100.09	99.89	100.04	1
LG&E	C1S	860368	07/2010	05/12/2010	100.08	99.99	100.13	1
LG&E	C1S	860369	07/2010	05/12/2010	100.07	99.90	99.91	1
LG&E	C1S	860370	07/2010	05/12/2010	100.06	99.89	99.95	1
LG&E	C1S	860371	07/2010	05/12/2010	100.06	99.89	100.07	1
LG&E	C1S	860372	07/2010	05/12/2010	100.08	100.10	100.21	1

LG&E	C1S	860373	07/2010	05/12/2010	100.08	100.12	100.13	1
LG&E	C1S	860374	07/2010	05/12/2010	100.09	100.07	100.12	1
LG&E	C1S	860375	07/2010	05/12/2010	100.06	99.97	100.05	1
LG&E	C1S	860376	07/2010	05/12/2010	100.10	99.92	99.98	1
LG&E	C1S	860377	07/2010	05/12/2010	100.07	99.96	100.09	1
LG&E	C1S	860378	07/2010	05/12/2010	100.09	99.90	100.11	1
LG&E	C1S	860379	07/2010	05/12/2010	100.09	100.01	100.08	1
LG&E	C1S	860380	07/2010	05/12/2010	100.05	99.99	100.13	1
LG&E	C1S	860381	07/2010	05/12/2010	100.09	100.06	99.90	1
LG&E	C1S	860382	07/2010	05/12/2010	100.10	99.92	99.96	1
LG&E	C1S	860383	07/2010	05/12/2010	100.07	100.09	100.17	1
LG&E	C1S	860384	07/2010	05/12/2010	100.05	100.03	100.16	1
LG&E	C1S	860385	07/2010	05/12/2010	100.09	100.01	100.14	1
LG&E	C1S	860386	07/2010	05/12/2010	100.10	100.13	100.17	1
LG&E	C1S	860387	07/2010	05/12/2010	100.08	100.00	100.08	1
LG&E	C1S	860388	07/2010	05/12/2010	100.06	100.06	100.11	1
LG&E	C1S	860389	07/2010	05/12/2010	100.09	99.92	100.07	1
LG&E	C1S	860390	07/2010	05/12/2010	100.05	99.96	100.09	1
LG&E	C1S	860391	07/2010	05/12/2010	100.07	100.03	100.16	1
LG&E	C1S	860392	07/2010	05/12/2010	100.08	100.02	100.18	1
LG&E	C1S	860393	07/2010	05/12/2010	100.06	99.89	99.96	1
LG&E	C1S	860394	07/2010	05/12/2010	100.09	99.94	99.98	1
LG&E	C1S	860395	07/2010	05/12/2010	100.07	100.05	100.18	1
LG&E	C1S	860396	07/2010	05/12/2010	100.08	100.04	100.17	1
LG&E	C1S	860397	07/2010	05/12/2010	100.10	100.09	100.14	1
LG&E	C1S	860398	07/2010	05/12/2010	100.09	100.01	100.13	1
LG&E	C1S	860399	07/2010	05/12/2010	100.06	100.05	100.11	1
LG&E	C1S	860400	07/2010	05/12/2010	100.06	100.05	100.07	1
LG&E	C1S	860401	07/2010	05/12/2010	100.09	100.07	100.15	1
LG&E	C1S	860402	07/2010	05/12/2010	100.09	100.08	100.16	1
LG&E	C1S	860403	07/2010	05/12/2010	100.08	100.04	100.11	1
LG&E	C1S	860404	07/2010	05/12/2010	100.06	100.01	100.09	1
LG&E	C1S	860405	07/2010	05/12/2010	100.07	100.00	100.09	1
LG&E	C1S	860406	07/2010	05/12/2010	100.09	99.97	100.13	1
LG&E	C1S	860407	07/2010	05/12/2010	100.06	100.02	100.12	1
LG&E	C1S	860408	07/2010	05/12/2010	100.06	100.04	100.06	1



LG&E	C1S	860409	07/2010	12/2010	100.10	99.99	99.95	1
LG&E	C1S	860410	07/2010	05/12/2010	100.07	99.97	100.13	1
LG&E	C1S	860411	07/2010	05/12/2010	100.06	99.83	100.05	1
LG&E	C1S	860412	07/2010	05/12/2010	100.09	100.02	100.18	1
LG&E	C1S	860413	07/2010	05/12/2010	100.10	99.94	100.11	1
LG&E	C1S	860414	07/2010	05/12/2010	100.06	99.90	100.03	1
LG&E	C1S	860415	07/2010	05/12/2010	100.08	100.01	100.01	1
LG&E	C1S	860416	07/2010	05/12/2010	100.09	100.02	99.90	1
LG&E	C1S	860417	07/2010	05/12/2010	100.08	100.01	100.02	1
LG&E	C1S	860418	07/2010	05/12/2010	100.08	100.02	100.06	1
LG&E	C1S	860419	07/2010	05/12/2010	100.06	99.95	100.17	1
LG&E	C1S	860420	07/2010	05/12/2010	100.10	100.06	100.08	1
LG&E	C1S	860421	07/2010	05/12/2010	100.07	99.99	99.89	1
LG&E	C1S	860422	07/2010	05/12/2010	100.07	99.91	100.08	1
LG&E	C1S	860423	07/2010	05/12/2010	100.10	100.00	100.12	1
LG&E	C1S	860424	07/2010	05/12/2010	100.06	99.91	100.17	1
LG&E	C1S	860425	07/2010	05/12/2010	100.06	99.94	99.80	1
LG&E	C1S	860426	07/2010	05/12/2010	100.06	99.84	99.94	1
LG&E	C1S	860427	07/2010	05/12/2010	100.05	99.83	100.12	1
LG&E	C1S	860428	07/2010	05/12/2010	100.06	99.88	99.90	1
LG&E	C1S	860429	07/2010	05/12/2010	100.10	100.00	100.13	1
LG&E	C1S	860430	07/2010	05/12/2010	100.08	100.00	99.95	1
LG&E	C1S	860431	07/2010	05/12/2010	100.06	99.92	100.05	1
LG&E	C1S	860432	07/2010	05/12/2010	100.06	99.92	99.82	1
LG&E	C1S	860433	07/2010	05/12/2010	100.08	99.94	99.89	1
LG&E	C1S	860434	07/2010	05/12/2010	100.07	99.94	99.92	1
LG&E	C1S	860435	07/2010	05/12/2010	100.09	99.97	100.16	1
LG&E	C1S	860436	07/2010	05/12/2010	100.09	100.00	99.99	1
LG&E	C1S	860437	07/2010	05/12/2010	100.06	99.96	100.04	1
LG&E	C1S	860438	07/2010	05/12/2010	100.09	99.91	99.97	1
LG&E	C1S	860439	07/2010	05/12/2010	100.09	99.96	100.00	1
LG&E	C1S	860440	07/2010	05/12/2010	100.10	100.04	99.95	1
LG&E	C1S	860441	07/2010	05/12/2010	100.07	99.90	100.07	1
LG&E	C1S	860442	07/2010	05/12/2010	100.07	99.89	99.97	1
LG&E	C1S	860443	07/2010	05/12/2010	100.09	99.91	99.98	1
LG&E	C1S	860444	07/2010	05/12/2010	100.07	99.94	100.10	1

LG&E	C1S	860445	07/2010	05/12/2010	100.09	100.03	100.03	1
LG&E	C1S	860446	07/2010	05/12/2010	100.05	99.90	99.97	1
LG&E	C1S	860447	07/2010	05/12/2010	100.09	99.90	100.09	1
LG&E	C1S	860448	07/2010	05/12/2010	100.06	99.88	100.07	1
LG&E	C1S	860449	07/2010	05/12/2010	100.08	100.07	99.90	1
LG&E	C1S	860450	07/2010	05/12/2010	100.08	99.89	99.98	1
LG&E	C1S	860451	07/2010	05/12/2010	100.07	99.89	100.09	1
LG&E	C1S	860452	07/2010	05/12/2010	100.09	99.89	100.04	1
LG&E	C1S	860453	07/2010	05/12/2010	100.06	100.00	100.05	1
LG&E	C1S	860454	07/2010	05/12/2010	100.07	99.92	100.05	1
LG&E	C1S	860455	07/2010	05/12/2010	100.08	100.04	99.94	1
LG&E	C1S	860456	07/2010	05/12/2010	100.06	100.09	100.09	1
LG&E	C1S	860457	07/2010	05/12/2010	100.07	99.91	99.95	1
LG&E	C1S	860458	07/2010	05/12/2010	100.06	100.08	100.16	1
LG&E	C1S	860459	07/2010	05/12/2010	100.09	99.98	99.97	1
LG&E	C1S	860460	07/2010	05/12/2010	100.10	100.04	100.17	1
LG&E	C1S	860461	07/2010	05/12/2010	100.10	99.97	100.14	1
LG&E	C1S	860462	07/2010	05/12/2010	100.10	99.95	100.07	1
LG&E	C1S	860463	07/2010	05/12/2010	100.09	100.08	100.13	1
LG&E	C1S	860464	07/2010	05/12/2010	100.07	99.90	100.04	1
LG&E	C1S	860465	07/2010	05/12/2010	100.08	99.95	100.07	1
LG&E	C1S	860466	07/2010	05/12/2010	100.06	99.95	100.01	1
LG&E	C1S	860467	07/2010	05/12/2010	100.07	99.93	99.99	1
LG&E	C1S	860468	07/2010	05/12/2010	100.08	99.93	100.11	1
LG&E	C1S	860469	07/2010	05/12/2010	100.08	100.04	100.19	1
LG&E	C1S	860470	07/2010	05/12/2010	100.06	100.01	100.11	1
LG&E	C1S	860471	07/2010	05/12/2010	100.06	100.00	100.03	1
LG&E	C1S	860472	07/2010	05/12/2010	100.06	99.95	100.03	1
LG&E	C1S	860473	07/2010	05/12/2010	100.10	99.95	100.09	1
LG&E	C1S	860474	07/2010	05/12/2010	100.10	100.08	100.00	1
LG&E	C1S	860475	07/2010	05/12/2010	100.08	99.95	100.05	1
LG&E	C1S	860476	07/2010	05/12/2010	100.06	99.99	99.97	1
LG&E	C1S	860477	07/2010	05/12/2010	100.10	99.95	100.09	1
LG&E	C1S	860478	07/2010	05/12/2010	100.07	99.98	100.12	1
LG&E	C1S	860479	07/2010	05/12/2010	100.09	99.95	100.08	1
LG&E	C1S	860480	07/2010	05/12/2010	100.07	99.91	100.14	1

LG&E	C1S	860481	07/2010	12/2010	100.08	99.96	100.08	100.08	1
LG&E	C1S	860482	07/2010	05/12/2010	100.06	99.98	100.06	100.01	1
LG&E	C1S	860483	07/2010	05/12/2010	100.10	99.96	100.10	100.10	1
LG&E	C1S	860484	07/2010	05/12/2010	100.08	99.87	100.08	100.17	1
LG&E	C1S	860485	07/2010	05/12/2010	100.06	99.88	100.06	100.04	1
LG&E	C1S	860486	07/2010	05/12/2010	100.08	100.01	100.08	100.03	1
LG&E	C1S	860487	07/2010	05/12/2010	100.09	99.97	100.09	99.95	1
LG&E	C1S	860488	07/2010	05/12/2010	100.05	99.95	100.05	100.04	1
LG&E	C1S	860489	07/2010	05/12/2010	100.10	100.01	100.10	100.13	1
LG&E	C1S	860490	07/2010	05/12/2010	100.07	99.97	100.07	100.05	1
LG&E	C1S	860491	07/2010	05/12/2010	100.08	99.96	100.08	100.04	1
LG&E	C1S	860492	07/2010	05/12/2010	100.09	99.95	100.09	100.17	1
LG&E	C1S	860493	07/2010	05/12/2010	100.06	99.94	100.06	99.87	1
LG&E	C1S	860494	07/2010	05/12/2010	100.10	100.02	100.10	99.97	1
LG&E	C1S	860495	07/2010	05/12/2010	100.08	99.90	100.08	100.18	1
LG&E	C1S	860496	07/2010	05/12/2010	100.06	100.02	100.06	100.03	1
LG&E	C1S	860497	07/2010	05/12/2010	100.06	99.84	100.06	99.91	1
LG&E	C1S	860498	07/2010	05/12/2010	100.06	99.89	100.06	99.98	1
LG&E	C1S	860499	07/2010	05/12/2010	100.10	100.05	100.10	100.08	1
LG&E	C1S	860500	07/2010	05/12/2010	100.08	99.92	100.08	99.99	1
LG&E	C1S	860501	07/2010	05/12/2010	100.08	99.92	100.08	99.82	1
LG&E	C1S	860502	07/2010	05/12/2010	100.06	99.94	100.06	99.86	1
LG&E	C1S	860503	07/2010	05/12/2010	100.10	99.94	100.10	99.94	1
LG&E	C1S	860504	07/2010	05/12/2010	100.09	99.86	100.09	100.17	1
LG&E	C1S	860505	07/2010	05/12/2010	100.07	99.95	100.07	99.86	1
LG&E	C1S	860506	07/2010	05/12/2010	100.06	99.96	100.06	99.99	1
LG&E	C1S	860507	07/2010	05/12/2010	100.08	99.95	100.08	100.09	1
LG&E	C1S	860508	07/2010	05/12/2010	100.09	100.02	100.09	99.99	1
LG&E	C1S	860509	07/2010	05/12/2010	100.08	99.97	100.08	100.02	1
LG&E	C1S	860510	07/2010	05/12/2010	100.10	100.01	100.10	100.01	1
LG&E	C1S	860511	07/2010	05/12/2010	100.07	99.98	100.07	100.02	1
LG&E	C1S	860512	07/2010	05/12/2010	100.07	99.95	100.07	100.09	1
LG&E	C1S	860513	07/2010	05/12/2010	100.06	99.93	100.06	100.01	1
LG&E	C1S	860514	07/2010	05/12/2010	100.08	100.04	100.08	100.16	1
LG&E	C1S	860515	07/2010	05/12/2010	100.09	100.03	100.09	100.21	1
LG&E	C1S	860516	07/2010	05/12/2010	100.06	100.00	100.06	100.10	1

LG&E	C1S	860517	07/2010	12/2010	100.10	99.99	100.13	1
LG&E	C1S	860518	07/2010	05/12/2010	100.06	99.86	100.10	1
LG&E	C1S	860519	07/2010	05/12/2010	100.09	99.96	99.92	1
LG&E	C1S	860520	07/2010	05/12/2010	100.08	99.97	99.91	1
LG&E	C1S	860521	07/2010	05/12/2010	100.09	99.94	100.10	1
LG&E	C1S	860522	07/2010	05/12/2010	100.08	100.02	100.09	1
LG&E	C1S	860523	07/2010	05/12/2010	100.06	99.97	100.09	1
LG&E	C1S	860524	07/2010	05/12/2010	100.09	99.92	100.00	1
LG&E	C1S	860525	07/2010	05/12/2010	100.06	100.06	100.20	1
LG&E	C1S	860526	07/2010	05/12/2010	100.06	99.91	100.09	1
LG&E	C1S	860527	07/2010	05/12/2010	100.10	100.11	100.14	1
LG&E	C1S	860528	07/2010	05/12/2010	100.09	100.00	100.02	1
LG&E	C1S	860529	07/2010	05/12/2010	100.09	100.08	100.14	1
LG&E	C1S	860530	07/2010	05/12/2010	100.09	99.97	99.99	1
LG&E	C1S	860531	07/2010	05/12/2010	100.07	99.95	99.97	1
LG&E	C1S	860532	07/2010	05/12/2010	100.06	100.00	99.85	1
LG&E	C1S	860533	07/2010	05/12/2010	100.09	99.88	100.15	1
LG&E	C1S	860534	07/2010	05/12/2010	100.07	100.05	100.10	1
LG&E	C1S	860535	07/2010	05/12/2010	100.09	99.98	99.90	1
LG&E	C1S	860536	07/2010	05/12/2010	100.08	100.02	100.20	1
LG&E	C1S	860537	07/2010	05/12/2010	100.07	99.83	100.10	1
LG&E	C1S	860538	07/2010	05/12/2010	100.07	100.04	100.16	1
LG&E	C1S	860539	07/2010	05/12/2010	100.09	99.99	100.00	1
LG&E	C1S	860540	07/2010	05/12/2010	100.06	99.93	100.07	1
LG&E	C1S	860541	07/2010	05/12/2010	100.08	99.93	100.12	1
LG&E	C1S	860542	07/2010	05/12/2010	100.08	99.87	100.07	1
LG&E	C1S	860543	07/2010	05/12/2010	100.09	100.00	100.03	1
LG&E	C1S	860544	07/2010	05/12/2010	100.06	99.93	99.98	1
LG&E	C1S	860545	07/2010	05/12/2010	100.09	100.01	100.03	1
LG&E	C1S	860546	07/2010	05/12/2010	100.09	100.04	100.14	1
LG&E	C1S	860547	07/2010	05/12/2010	100.09	99.91	100.08	1
LG&E	C1S	860548	07/2010	05/12/2010	100.09	100.08	100.11	1
LG&E	C1S	860549	07/2010	05/12/2010	100.06	99.94	99.88	1
LG&E	C1S	860550	07/2010	05/12/2010	100.06	100.05	100.11	1
LG&E	C1S	860551	07/2010	05/12/2010	100.09	99.94	100.09	1
LG&E	C1S	860552	07/2010	05/12/2010	100.05	99.91	99.96	1

LG&E	C1S	860553	07/2010	12/2010	100.09	99.92	99.95	1
LG&E	C1S	860554	07/2010	05/12/2010	100.07	99.97	100.13	1
LG&E	C1S	860555	07/2010	05/12/2010	100.10	99.95	100.07	1
LG&E	C1S	860556	07/2010	05/12/2010	100.08	100.06	100.13	1
LG&E	C1S	860557	07/2010	05/12/2010	100.05	99.88	100.06	1
LG&E	C1S	860558	07/2010	05/12/2010	100.09	99.95	100.12	1
LG&E	C1S	860559	07/2010	05/12/2010	100.06	99.92	99.96	1
LG&E	C1S	860560	07/2010	05/12/2010	100.08	100.00	100.11	1
LG&E	C1S	860561	07/2010	05/12/2010	100.06	100.05	100.14	1
LG&E	C1S	860562	07/2010	05/12/2010	100.06	99.97	99.97	1
LG&E	C1S	860563	07/2010	05/12/2010	100.07	99.89	100.11	1
LG&E	C1S	860564	07/2010	05/12/2010	100.09	100.03	99.86	1
LG&E	C1S	860565	07/2010	05/12/2010	100.06	100.08	100.12	1
LG&E	C1S	860566	07/2010	05/12/2010	100.10	99.96	100.00	1
LG&E	C1S	860567	07/2010	05/12/2010	100.08	99.88	100.11	1
LG&E	C1S	860568	07/2010	05/12/2010	100.09	99.93	100.10	1
LG&E	C1S	860569	07/2010	05/12/2010	100.07	100.01	100.21	1
LG&E	C1S	860570	07/2010	05/12/2010	100.10	99.96	100.02	1
LG&E	C1S	860571	07/2010	05/12/2010	100.08	100.00	100.09	1
LG&E	C1S	860572	07/2010	05/12/2010	100.08	99.87	100.07	1
LG&E	C1S	860573	07/2010	05/12/2010	100.09	99.94	100.01	1
LG&E	C1S	860574	07/2010	05/12/2010	100.09	99.92	100.08	1
LG&E	C1S	860575	07/2010	05/12/2010	100.06	99.97	99.94	1
LG&E	C1S	860576	07/2010	05/12/2010	100.10	99.94	100.06	1
LG&E	C1S	860577	07/2010	05/12/2010	100.10	99.95	100.08	1
LG&E	C1S	860578	07/2010	05/12/2010	100.07	99.90	100.06	1
LG&E	C1S	860579	07/2010	05/12/2010	100.09	99.92	100.15	1
LG&E	C1S	860580	07/2010	05/12/2010	100.09	99.93	100.05	1
LG&E	C1S	860581	07/2010	05/12/2010	100.08	99.96	99.99	1
LG&E	C1S	860582	07/2010	05/12/2010	100.09	100.06	100.01	1
LG&E	C1S	860583	07/2010	05/12/2010	100.05	100.02	100.13	1
LG&E	C1S	860584	07/2010	05/12/2010	100.06	100.04	100.13	1
LG&E	C1S	860585	07/2010	05/12/2010	100.06	100.09	100.09	1
LG&E	C1S	860586	07/2010	05/12/2010	100.08	100.02	100.17	1
LG&E	C1S	860587	07/2010	05/12/2010	100.08	100.02	100.01	1
LG&E	C1S	860588	07/2010	05/12/2010	100.06	100.07	99.93	1

LG&E	C1S	860589	07/2010	05/12/2010	100.06	99.97	100.11	1
LG&E	C1S	860590	07/2010	05/12/2010	100.08	99.94	100.03	1
LG&E	C1S	860591	07/2010	05/12/2010	100.06	99.93	99.96	1
LG&E	C1S	860592	07/2010	05/12/2010	100.06	99.92	100.08	1
LG&E	C1S	860593	07/2010	05/12/2010	100.08	100.01	100.16	1
LG&E	C1S	860594	07/2010	05/12/2010	100.06	99.96	100.00	1
LG&E	C1S	860595	07/2010	05/12/2010	100.05	99.99	100.21	1
LG&E	C1S	860596	07/2010	05/12/2010	100.09	100.07	100.20	1
LG&E	C1S	860597	07/2010	05/12/2010	100.09	100.12	100.19	1
LG&E	C1S	860598	07/2010	05/12/2010	100.06	99.86	100.11	1
LG&E	C1S	860599	07/2010	05/12/2010	100.08	100.07	100.25	1
LG&E	C1S	860600	07/2010	05/12/2010	100.07	100.03	100.22	1
LG&E	C1S	860601	07/2010	05/12/2010	100.05	99.84	99.99	1
LG&E	C1S	860602	07/2010	05/12/2010	100.10	100.03	100.11	1
LG&E	C1S	860603	07/2010	05/12/2010	100.09	100.02	100.14	1
LG&E	C1S	860604	07/2010	05/12/2010	100.08	99.91	100.00	1
LG&E	C1S	860605	07/2010	05/12/2010	100.06	99.86	100.06	1
LG&E	C1S	860606	07/2010	05/12/2010	100.09	100.08	100.13	1
LG&E	C1S	860607	07/2010	05/12/2010	100.06	100.03	100.11	1
LG&E	C1S	860608	07/2010	05/12/2010	100.08	100.06	100.11	1
LG&E	C1S	860609	07/2010	05/12/2010	100.07	100.02	100.13	1
LG&E	C1S	860610	07/2010	05/12/2010	100.10	100.09	100.18	1
LG&E	C1S	860611	07/2010	05/12/2010	100.09	100.09	100.23	1
LG&E	C1S	860612	07/2010	05/12/2010	100.10	99.99	100.16	1
LG&E	C1S	860613	07/2010	05/12/2010	100.08	99.94	100.08	1
LG&E	C1S	860614	07/2010	05/12/2010	100.06	99.94	99.92	1
LG&E	C1S	860615	07/2010	05/12/2010	100.05	100.02	100.00	1
LG&E	C1S	860616	07/2010	05/12/2010	100.08	99.89	100.02	1
LG&E	C1S	860617	07/2010	05/12/2010	100.07	100.02	100.10	1
LG&E	C1S	860618	07/2010	05/12/2010	100.09	99.95	100.14	1
LG&E	C1S	860619	07/2010	05/12/2010	100.08	99.98	100.06	1
LG&E	C1S	860620	07/2010	05/12/2010	100.07	99.90	100.09	1
LG&E	C1S	860621	07/2010	05/12/2010	100.10	100.05	100.18	1
LG&E	C1S	860622	07/2010	05/12/2010	100.07	99.93	100.05	1
LG&E	C1S	860623	07/2010	05/12/2010	100.06	99.90	100.06	1
LG&E	C1S	860624	07/2010	05/12/2010	100.06	99.98	99.98	1

LG&E	C1S	860625	07/2010	12/2010	100.08	100.09	100.19	1
LG&E	C1S	860626	07/2010	05/12/2010	100.08	100.11	100.17	1
LG&E	C1S	860627	07/2010	05/12/2010	100.08	99.84	100.11	1
LG&E	C1S	860628	07/2010	05/12/2010	100.08	99.92	100.07	1
LG&E	C1S	860629	07/2010	05/12/2010	100.07	99.94	99.98	1
LG&E	C1S	860630	07/2010	05/12/2010	100.09	100.04	100.24	1
LG&E	C1S	860631	07/2010	05/12/2010	100.10	99.96	100.19	1
LG&E	C1S	860632	07/2010	05/12/2010	100.09	100.12	100.14	1
LG&E	C1S	860633	07/2010	05/12/2010	100.09	99.86	100.09	1
LG&E	C1S	860634	07/2010	05/12/2010	100.05	100.03	100.17	1
LG&E	C1S	860635	07/2010	05/12/2010	100.09	99.95	100.02	1
LG&E	C1S	860636	07/2010	05/12/2010	100.06	99.94	100.07	1
LG&E	C1S	860637	07/2010	05/12/2010	100.06	100.05	100.06	1
LG&E	C1S	860638	07/2010	05/12/2010	100.10	99.97	100.12	1
LG&E	C1S	860639	07/2010	05/12/2010	100.10	99.88	100.08	1
LG&E	C1S	860640	07/2010	05/12/2010	100.08	99.92	100.10	1
LG&E	C1S	860641	07/2010	05/12/2010	100.07	99.94	100.04	1
LG&E	C1S	860642	07/2010	05/12/2010	100.08	100.05	100.17	1
LG&E	C1S	860643	07/2010	05/12/2010	100.09	99.91	100.22	1
LG&E	C1S	860644	07/2010	05/12/2010	100.06	99.92	100.07	1
LG&E	C1S	860645	07/2010	05/12/2010	100.09	99.98	100.10	1
LG&E	C1S	860646	07/2010	05/12/2010	100.07	99.96	100.01	1
LG&E	C1S	860647	07/2010	05/12/2010	100.07	99.95	99.88	1
LG&E	C1S	860648	07/2010	05/12/2010	100.10	100.03	100.24	1
LG&E	C1S	860649	07/2010	05/12/2010	100.06	100.01	100.16	1
LG&E	C1S	860650	07/2010	05/12/2010	100.08	99.88	100.07	1
LG&E	C1S	860651	07/2010	05/12/2010	100.08	100.05	100.14	1
LG&E	C1S	860652	07/2010	05/12/2010	100.07	99.91	99.94	1
LG&E	C1S	860653	07/2010	05/12/2010	100.08	100.01	99.91	1
LG&E	C1S	860654	07/2010	05/12/2010	100.08	99.91	100.07	1
LG&E	C1S	860655	07/2010	05/12/2010	100.10	99.97	100.07	1
LG&E	C1S	860656	07/2010	05/12/2010	100.09	100.00	100.02	1
LG&E	C1S	860657	07/2010	05/12/2010	100.09	99.95	100.13	1
LG&E	C1S	860658	07/2010	05/12/2010	100.08	99.92	100.02	1
LG&E	C1S	860659	07/2010	05/12/2010	100.06	100.07	100.11	1
LG&E	C1S	860660	07/2010	05/12/2010	100.05	100.07	100.14	1

LG&E	C1S	860661	07/2010	05/12/2010	100.10	100.03	99.96	1
LG&E	C1S	860662	07/2010	05/12/2010	100.08	100.01	100.12	1
LG&E	C1S	860663	07/2010	05/12/2010	100.10	99.97	99.94	1
LG&E	C1S	860664	07/2010	05/12/2010	100.09	100.02	100.22	1
LG&E	C1S	860665	07/2010	05/12/2010	100.06	100.07	100.14	1
LG&E	C1S	860666	07/2010	05/12/2010	100.10	100.06	100.16	1
LG&E	C1S	860667	07/2010	05/12/2010	100.09	99.95	99.97	1
LG&E	C1S	860668	07/2010	05/12/2010	100.07	100.01	100.10	1
LG&E	C1S	860669	07/2010	05/12/2010	100.07	99.99	100.06	1
LG&E	C1S	860670	07/2010	05/12/2010	100.06	99.83	100.06	1
LG&E	C1S	860671	07/2010	05/12/2010	100.09	100.13	100.16	1
LG&E	C1S	860672	07/2010	05/12/2010	100.08	99.86	100.09	1
LG&E	C1S	860673	07/2010	05/12/2010	100.07	99.89	99.98	1
LG&E	C1S	860674	07/2010	05/12/2010	100.05	100.03	99.97	1
LG&E	C1S	860675	07/2010	05/12/2010	100.09	99.97	100.00	1
LG&E	C1S	860676	07/2010	05/12/2010	100.10	100.06	100.04	1
LG&E	C1S	860677	07/2010	05/12/2010	100.07	100.06	100.20	1
LG&E	C1S	860678	07/2010	05/12/2010	100.07	100.05	100.11	1
LG&E	C1S	860679	07/2010	05/12/2010	100.09	100.10	100.19	1
LG&E	C1S	860680	07/2010	05/12/2010	100.07	100.05	100.14	1
LG&E	C1S	860681	07/2010	05/12/2010	100.08	100.11	100.22	1
LG&E	C1S	860682	07/2010	05/12/2010	100.10	100.08	100.23	1
LG&E	C1S	860683	07/2010	05/12/2010	100.09	100.12	100.18	1
LG&E	C1S	860684	07/2010	05/12/2010	100.07	99.88	99.95	1
LG&E	C1S	860685	07/2010	05/12/2010	100.06	100.03	100.08	1
LG&E	C1S	860686	07/2010	05/12/2010	100.05	99.99	99.96	1
LG&E	C1S	860687	07/2010	05/12/2010	100.06	100.01	99.99	1
LG&E	C1S	860688	07/2010	05/12/2010	100.07	99.95	100.17	1
LG&E	C1S	860689	07/2010	05/12/2010	100.09	99.97	100.09	1
LG&E	C1S	860690	07/2010	05/12/2010	100.08	100.04	100.13	1
LG&E	C1S	860691	07/2010	05/12/2010	100.07	100.05	100.09	1
LG&E	C1S	860692	07/2010	05/12/2010	100.06	100.07	100.16	1
LG&E	C1S	860693	07/2010	05/12/2010	100.06	99.97	100.00	1
LG&E	C1S	860694	07/2010	05/12/2010	100.06	100.03	100.05	1
LG&E	C1S	860695	07/2010	05/12/2010	100.06	100.11	100.09	1
LG&E	C1S	860696	07/2010	05/12/2010	100.08	100.09	100.16	1



LG&E	C1S	860697	07/2010	12/2010	100.07	99.96	100.09	1
LG&E	C1S	860698	07/2010	05/12/2010	100.09	100.07	100.12	1
LG&E	C1S	860699	07/2010	05/12/2010	100.06	100.05	100.12	1
LG&E	C1S	860700	07/2010	05/12/2010	100.06	100.02	100.22	1
LG&E	C1S	860701	07/2010	05/12/2010	100.07	100.07	100.10	1
LG&E	C1S	860702	07/2010	05/12/2010	100.10	100.13	100.11	1
LG&E	C1S	860703	07/2010	05/12/2010	100.10	100.06	100.12	1
LG&E	C1S	860704	07/2010	05/12/2010	100.08	100.08	100.04	1
LG&E	C1S	860705	07/2010	05/12/2010	100.08	100.07	100.23	1
LG&E	C1S	860706	07/2010	05/12/2010	100.09	100.01	99.99	1
LG&E	C1S	860707	07/2010	05/12/2010	100.09	100.08	100.21	1
LG&E	C1S	860708	07/2010	05/12/2010	100.09	100.09	100.24	1
LG&E	C1S	860709	07/2010	05/12/2010	100.08	100.03	100.19	1
LG&E	C1S	860710	07/2010	05/12/2010	100.08	99.99	99.90	1
LG&E	C1S	860711	07/2010	05/12/2010	100.08	99.86	100.03	1
LG&E	C1S	860712	07/2010	05/12/2010	100.08	100.03	100.19	1
LG&E	C1S	860713	07/2010	05/12/2010	100.09	100.01	100.23	1
LG&E	C1S	860714	07/2010	05/12/2010	100.07	100.06	100.05	1
LG&E	C1S	860715	07/2010	05/12/2010	100.07	99.90	100.07	1
LG&E	C1S	860716	07/2010	05/12/2010	100.06	99.88	100.06	1
LG&E	C1S	860717	07/2010	05/12/2010	100.08	99.89	100.04	1
LG&E	C1S	860718	07/2010	05/12/2010	100.08	100.00	100.25	1
LG&E	C1S	860719	07/2010	05/12/2010	100.10	99.93	100.08	1
LG&E	C1S	860720	07/2010	05/12/2010	100.07	100.04	100.14	1
LG&E	C1S	860721	07/2010	05/12/2010	100.07	100.11	100.19	1
LG&E	C1S	860722	07/2010	05/12/2010	100.08	100.03	100.16	1
LG&E	C1S	860723	07/2010	05/12/2010	100.07	99.99	100.15	1
LG&E	C1S	860724	07/2010	05/12/2010	100.10	100.01	100.15	1
LG&E	C1S	860725	07/2010	05/12/2010	100.08	100.05	100.13	1
LG&E	C1S	860726	07/2010	05/12/2010	100.10	99.98	100.08	1
LG&E	C1S	860727	07/2010	05/12/2010	100.06	99.95	99.99	1
LG&E	C1S	860728	07/2010	05/12/2010	100.06	100.08	100.10	1
LG&E	C1S	860729	07/2010	05/12/2010	100.06	100.02	100.04	1
LG&E	C1S	860730	07/2010	05/12/2010	100.09	100.10	100.19	1
LG&E	C1S	860731	07/2010	05/12/2010	100.08	100.07	100.19	1
LG&E	C1S	860732	07/2010	05/12/2010	100.06	100.04	100.09	1

LG&E	C1S	860733	07/2010	05/12/2010	100.07	100.03	100.17	1
LG&E	C1S	860734	07/2010	05/12/2010	100.10	100.12	100.16	1
LG&E	C1S	860735	07/2010	05/12/2010	100.05	99.91	99.97	1
LG&E	C1S	860736	07/2010	05/12/2010	100.08	100.03	100.02	1
LG&E	C1S	860737	07/2010	05/12/2010	100.10	100.00	100.05	1
LG&E	C1S	860738	07/2010	05/12/2010	100.10	99.92	99.92	1
LG&E	C1S	860739	07/2010	05/12/2010	100.06	99.93	100.14	1
LG&E	C1S	860740	07/2010	05/12/2010	100.08	99.98	99.97	1
LG&E	C1S	860741	07/2010	05/12/2010	100.09	100.08	100.10	1
LG&E	C1S	860742	07/2010	05/12/2010	100.05	99.92	100.06	1
LG&E	C1S	860743	07/2010	05/12/2010	100.09	100.01	100.23	1
LG&E	C1S	860744	07/2010	05/12/2010	100.10	100.09	100.11	1
LG&E	C1S	860745	07/2010	05/12/2010	100.05	99.96	100.07	1
LG&E	C1S	860746	07/2010	05/12/2010	100.09	99.99	100.07	1
LG&E	C1S	860747	07/2010	05/12/2010	100.07	100.05	99.98	1
LG&E	C1S	860748	07/2010	05/12/2010	100.08	99.94	100.00	1
LG&E	C1S	860749	07/2010	05/12/2010	100.10	99.95	100.06	1
LG&E	C1S	860750	07/2010	05/12/2010	100.06	99.92	100.02	1
LG&E	C1S	860751	07/2010	05/12/2010	100.10	99.88	100.06	1
LG&E	C1S	860752	07/2010	05/12/2010	100.06	100.06	100.18	1
LG&E	C1S	860753	07/2010	05/12/2010	100.08	100.00	100.00	1
LG&E	C1S	860754	07/2010	05/12/2010	100.07	100.06	100.17	1
LG&E	C1S	860755	07/2010	05/12/2010	100.09	100.07	100.13	1
LG&E	C1S	860756	07/2010	05/12/2010	100.07	99.96	100.03	1
LG&E	C1S	860757	07/2010	05/12/2010	100.10	100.01	100.02	1
LG&E	C1S	860758	07/2010	05/12/2010	100.08	100.00	99.97	1
LG&E	C1S	860759	07/2010	05/12/2010	100.07	100.04	100.14	1
LG&E	C1S	860760	07/2010	05/12/2010	100.07	99.87	100.04	1
LG&E	C1S	860761	07/2010	05/12/2010	100.07	100.04	100.24	1
LG&E	C1S	860762	07/2010	05/12/2010	100.06	99.87	100.08	1
LG&E	C1S	860763	07/2010	05/12/2010	100.08	100.10	100.17	1
LG&E	C1S	860764	07/2010	05/12/2010	100.08	99.96	100.05	1
LG&E	C1S	860765	07/2010	05/12/2010	100.08	100.06	100.11	1
LG&E	C1S	860766	07/2010	05/12/2010	100.06	99.88	100.06	1
LG&E	C1S	860767	07/2010	05/12/2010	100.09	99.99	100.06	1
LG&E	C1S	860768	07/2010	05/12/2010	100.09	100.04	99.95	1

LG&E	C1S	860769	07/2010	12/2010	100.09	99.90	99.97	1
LG&E	C1S	860770	07/2010	05/12/2010	100.07	100.06	100.11	1
LG&E	C1S	860771	07/2010	05/12/2010	100.06	99.97	100.11	1
LG&E	C1S	860772	07/2010	05/12/2010	100.07	99.89	99.99	1
LG&E	C1S	860773	07/2010	05/12/2010	100.09	100.03	100.15	1
LG&E	C1S	860774	07/2010	05/12/2010	100.10	99.94	100.07	1
LG&E	C1S	860775	07/2010	05/12/2010	100.09	99.89	100.03	1
LG&E	C1S	860776	07/2010	05/12/2010	100.09	99.98	100.15	1
LG&E	C1S	860777	07/2010	05/12/2010	100.07	99.82	99.97	1
LG&E	C1S	860778	07/2010	05/12/2010	100.09	99.95	99.91	1
LG&E	C1S	860779	07/2010	05/12/2010	100.08	99.93	99.87	1
LG&E	C1S	860780	07/2010	05/12/2010	100.08	99.90	99.84	1
LG&E	C1S	860781	07/2010	05/12/2010	100.09	99.97	99.87	1
LG&E	C1S	860782	07/2010	05/12/2010	100.07	99.88	100.07	1
LG&E	C1S	860783	07/2010	05/12/2010	100.06	100.05	100.12	1
LG&E	C1S	860784	07/2010	05/12/2010	100.05	100.10	100.09	1
LG&E	C1S	860785	07/2010	05/12/2010	100.10	100.10	100.17	1
LG&E	C1S	860786	07/2010	05/12/2010	100.09	99.98	99.96	1
LG&E	C1S	860787	07/2010	05/12/2010	100.07	100.03	100.18	1
LG&E	C1S	860788	07/2010	05/12/2010	100.06	99.90	100.06	1
LG&E	C1S	860789	07/2010	05/12/2010	100.06	99.93	99.92	1
LG&E	C1S	860790	07/2010	05/12/2010	100.08	100.11	100.22	1
LG&E	C1S	860791	07/2010	05/12/2010	100.08	100.09	100.22	1
LG&E	C1S	860792	07/2010	05/12/2010	100.09	99.99	100.12	1
LG&E	C1S	860793	07/2010	05/12/2010	100.11	99.96	100.05	1
LG&E	C1S	860794	07/2010	05/12/2010	100.09	100.05	100.14	1
LG&E	C1S	860795	07/2010	05/12/2010	100.10	99.96	100.03	1
LG&E	C1S	860796	07/2010	05/12/2010	100.09	99.98	99.99	1
LG&E	C1S	860797	07/2010	05/12/2010	100.08	100.11	100.12	1
LG&E	C1S	860798	07/2010	05/12/2010	100.08	99.91	99.98	1
LG&E	C1S	860799	07/2010	05/12/2010	100.05	99.99	100.07	1
LG&E	C1S	860800	07/2010	05/12/2010	100.06	99.92	100.04	1
LG&E	C1S	860801	07/2010	05/12/2010	100.06	99.99	100.16	1
LG&E	C1S	860802	07/2010	05/12/2010	100.08	99.89	100.05	1
LG&E	C1S	860803	07/2010	05/12/2010	100.09	100.07	100.09	1
LG&E	C1S	860804	07/2010	05/12/2010	100.07	99.86	100.07	1

LG&E	C1S	860805	07/2010	05/12/2010	100.10	100.10	100.10	100.15	1
LG&E	C1S	860806	07/2010	05/12/2010	100.10	99.86	100.12	100.12	1
LG&E	C1S	860807	07/2010	05/12/2010	100.05	99.93	100.12	100.12	1
LG&E	C1S	860808	07/2010	05/12/2010	100.08	100.06	100.18	100.18	1
LG&E	C1S	860809	07/2010	05/12/2010	100.08	100.08	100.19	100.19	1
LG&E	C1S	860810	07/2010	05/12/2010	100.06	100.00	100.11	100.11	1
LG&E	C1S	860811	07/2010	05/12/2010	100.07	100.06	100.15	100.15	1
LG&E	C1S	860812	07/2010	05/12/2010	100.08	100.08	100.17	100.17	1
LG&E	C1S	860813	07/2010	05/12/2010	100.07	99.97	100.13	100.13	1
LG&E	C1S	860814	07/2010	05/12/2010	100.07	100.02	100.09	100.09	1
LG&E	C1S	860815	07/2010	05/12/2010	100.06	99.96	100.15	100.15	1
LG&E	C1S	860816	07/2010	05/12/2010	100.06	100.01	100.06	100.06	1
LG&E	C1S	860817	07/2010	05/12/2010	100.06	99.95	99.95	99.95	1
LG&E	C1S	860818	07/2010	05/12/2010	100.08	100.06	100.12	100.12	1
LG&E	C1S	860819	07/2010	05/12/2010	100.08	99.92	99.94	99.94	1
LG&E	C1S	860820	07/2010	05/12/2010	100.06	99.94	99.96	99.96	1
LG&E	C1S	860821	07/2010	05/12/2010	100.10	99.98	100.05	100.05	1
LG&E	C1S	860822	07/2010	05/12/2010	100.09	100.06	99.95	99.95	1
LG&E	C1S	860823	07/2010	05/12/2010	100.09	100.06	100.00	100.00	1
LG&E	C1S	860824	07/2010	05/12/2010	100.06	99.88	99.94	99.94	1
LG&E	C1S	860825	07/2010	05/12/2010	100.08	99.90	100.03	100.03	1
LG&E	C1S	860826	07/2010	05/12/2010	100.06	99.88	100.03	100.03	1
LG&E	C1S	860827	07/2010	05/12/2010	100.10	100.05	100.06	100.06	1
LG&E	C1S	860828	07/2010	05/12/2010	100.06	99.83	100.04	100.04	1
LG&E	C1S	860829	07/2010	05/12/2010	100.06	100.02	100.15	100.15	1
LG&E	C1S	860830	07/2010	05/12/2010	100.08	100.09	100.13	100.13	1
LG&E	C1S	860831	07/2010	05/12/2010	100.10	99.97	100.05	100.05	1
LG&E	C1S	860832	07/2010	05/12/2010	100.08	99.90	99.95	99.95	1
LG&E	C1S	860833	07/2010	05/12/2010	100.10	99.94	99.98	99.98	1
LG&E	C1S	860834	07/2010	05/12/2010	100.10	100.01	100.04	100.04	1
LG&E	C1S	860835	07/2010	05/12/2010	100.09	99.86	100.08	100.08	1
LG&E	C1S	860836	07/2010	05/12/2010	100.10	100.08	100.14	100.14	1
LG&E	C1S	860837	07/2010	05/12/2010	100.08	99.97	99.99	99.99	1
LG&E	C1S	860838	07/2010	05/12/2010	100.10	99.92	100.07	100.07	1
LG&E	C1S	860839	07/2010	05/12/2010	100.07	99.95	99.99	99.99	1
LG&E	C1S	860840	07/2010	05/12/2010	100.07	99.91	99.99	99.99	1

LG&E	C1S	860841	07/2010	12/2010	100.08	100.01	100.18	1
LG&E	C1S	860842	07/2010	05/12/2010	100.06	99.92	100.04	1
LG&E	C1S	860843	07/2010	05/12/2010	100.06	99.89	100.02	1
LG&E	C1S	860844	07/2010	05/12/2010	100.08	99.95	99.98	1
LG&E	C1S	860845	07/2010	05/12/2010	100.07	99.85	100.06	1
LG&E	C1S	860846	07/2010	05/12/2010	100.08	99.89	99.97	1
LG&E	C1S	860847	07/2010	05/12/2010	100.09	99.92	100.02	1
LG&E	C1S	860848	07/2010	05/12/2010	100.08	99.90	100.07	1
LG&E	C1S	860849	07/2010	05/12/2010	100.06	99.91	100.08	1
LG&E	C1S	860850	07/2010	05/12/2010	100.06	99.88	99.98	1
LG&E	C1S	860851	07/2010	05/12/2010	100.06	99.92	100.01	1
LG&E	C1S	860852	07/2010	05/12/2010	100.09	99.86	100.10	1
LG&E	C1S	860853	07/2010	05/12/2010	100.10	99.91	100.11	1
LG&E	C1S	860854	07/2010	05/12/2010	100.10	99.99	99.97	1
LG&E	C1S	860855	07/2010	05/12/2010	100.06	99.92	99.98	1
LG&E	C1S	860856	07/2010	05/12/2010	100.10	100.09	100.15	1
LG&E	C1S	860857	07/2010	05/12/2010	100.08	99.94	99.97	1
LG&E	C1S	860858	07/2010	05/12/2010	100.06	99.97	99.97	1
LG&E	C1S	860859	07/2010	05/12/2010	100.06	100.03	100.11	1
LG&E	C1S	860860	07/2010	05/12/2010	100.09	99.82	100.07	1
LG&E	C1S	860861	07/2010	05/12/2010	100.06	99.84	99.98	1
LG&E	C1S	860862	07/2010	05/12/2010	100.09	100.06	100.12	1
LG&E	C1S	860863	07/2010	05/12/2010	100.05	99.92	100.13	1
LG&E	C1S	860864	07/2010	05/12/2010	100.09	100.00	100.09	1
LG&E	C1S	860865	07/2010	05/12/2010	100.06	99.96	99.99	1
LG&E	C1S	860866	07/2010	05/12/2010	100.06	99.88	100.06	1
LG&E	C1S	860867	07/2010	05/12/2010	100.09	100.00	100.22	1
LG&E	C1S	860868	07/2010	05/12/2010	100.08	100.01	99.98	1
LG&E	C1S	860869	07/2010	05/12/2010	100.08	99.99	100.10	1
LG&E	C1S	860870	07/2010	05/12/2010	100.08	100.12	100.17	1
LG&E	C1S	860871	07/2010	05/12/2010	100.10	100.04	100.14	1
LG&E	C1S	860872	07/2010	05/12/2010	100.07	100.02	99.94	1
LG&E	C1S	860873	07/2010	05/12/2010	100.09	99.89	99.99	1
LG&E	C1S	860874	07/2010	05/12/2010	100.07	100.03	100.12	1
LG&E	C1S	860875	07/2010	05/12/2010	100.06	99.98	100.17	1
LG&E	C1S	860876	07/2010	05/12/2010	100.05	99.91	100.01	1

LG&E	C1S	860877	07/2010	05/12/2010	100.08	100.08	100.14	1
LG&E	C1S	860878	07/2010	05/12/2010	100.10	100.02	100.19	1
LG&E	C1S	860879	07/2010	05/12/2010	100.06	100.06	100.08	1
LG&E	C1S	860880	07/2010	05/12/2010	100.08	100.02	100.15	1
LG&E	C1S	860881	07/2010	05/12/2010	100.08	100.06	100.14	1
LG&E	C1S	860882	07/2010	05/12/2010	100.08	100.06	100.12	1
LG&E	C1S	860883	07/2010	05/12/2010	100.07	100.08	100.09	1
LG&E	C1S	860884	07/2010	05/12/2010	100.09	99.99	100.10	1
LG&E	C1S	860885	07/2010	05/12/2010	100.06	99.94	100.06	1
LG&E	C1S	860886	07/2010	05/12/2010	100.07	100.00	100.14	1
LG&E	C1S	860887	07/2010	05/12/2010	100.08	99.91	100.09	1
LG&E	C1S	860888	07/2010	05/12/2010	100.07	99.87	100.09	1
LG&E	C1S	860889	07/2010	05/12/2010	100.08	99.91	99.89	1
LG&E	C1S	860890	07/2010	05/12/2010	100.06	100.02	100.11	1
LG&E	C1S	860891	07/2010	05/12/2010	100.07	99.89	100.09	1
LG&E	C1S	860892	07/2010	05/12/2010	100.08	99.94	100.11	1
LG&E	C1S	860893	07/2010	05/12/2010	100.08	99.97	99.96	1
LG&E	C1S	860894	07/2010	05/12/2010	100.09	99.90	100.05	1
LG&E	C1S	860895	07/2010	05/12/2010	100.08	99.89	100.13	1
LG&E	C1S	860896	07/2010	05/12/2010	100.09	99.99	99.97	1
LG&E	C1S	860897	07/2010	05/12/2010	100.05	99.91	99.99	1
LG&E	C1S	860898	07/2010	05/12/2010	100.09	100.03	100.09	1
LG&E	C1S	860899	07/2010	05/12/2010	100.06	100.03	100.17	1
LG&E	C1S	860900	07/2010	05/12/2010	100.06	100.07	100.06	1
LG&E	C1S	860901	07/2010	05/12/2010	100.07	100.05	100.13	1
LG&E	C1S	860902	07/2010	05/12/2010	100.08	99.99	100.13	1
LG&E	C1S	860903	07/2010	05/12/2010	100.08	99.88	100.06	1
LG&E	C1S	860904	07/2010	05/12/2010	100.07	99.95	100.01	1
LG&E	C1S	860905	07/2010	05/12/2010	100.07	99.97	100.02	1
LG&E	C1S	860906	07/2010	05/12/2010	100.08	99.98	100.05	1
LG&E	C1S	860907	07/2010	05/12/2010	100.10	100.11	100.14	1
LG&E	C1S	860908	07/2010	05/12/2010	100.06	99.92	100.06	1
LG&E	C1S	860909	07/2010	05/12/2010	100.09	99.95	100.07	1
LG&E	C1S	860910	07/2010	05/12/2010	100.07	100.03	100.16	1
LG&E	C1S	860911	07/2010	05/12/2010	100.08	99.97	99.94	1
LG&E	C1S	860912	07/2010	05/12/2010	100.06	99.95	100.02	1

LG&E		C1S	860913	07/2010	12/2010	100.06	99.97	99.98	1
LG&E		C1S	860914	07/2010	05/12/2010	100.09	99.95	100.04	1
LG&E		C1S	860915	07/2010	05/12/2010	100.09	99.94	100.10	1
LG&E		C1S	860916	07/2010	05/12/2010	100.09	99.97	100.04	1
LG&E		C1S	860917	07/2010	05/12/2010	100.06	99.98	100.06	1
LG&E		C1S	860918	07/2010	05/12/2010	100.09	99.88	100.14	1
LG&E		C1S	860919	07/2010	05/12/2010	100.06	99.85	100.00	1
LG&E		C1S	860920	07/2010	05/12/2010	100.07	99.97	99.95	1
LG&E		C1S	860921	07/2010	05/12/2010	100.08	99.96	100.01	1
LG&E		C1S	860922	07/2010	05/12/2010	100.09	99.96	100.00	1
LG&E		C1S	860923	07/2010	05/12/2010	100.09	100.04	100.10	1
LG&E		C1S	860924	07/2010	05/12/2010	100.06	100.02	99.88	1
LG&E		C1S	860925	07/2010	05/12/2010	100.05	99.92	99.96	1
LG&E		C1S	860926	07/2010	05/12/2010	100.10	99.98	100.02	1
LG&E		C1S	860927	07/2010	05/12/2010	100.09	99.99	100.03	1
LG&E		C1S	860928	07/2010	05/12/2010	100.09	99.99	100.14	1
LG&E		C1S	860929	07/2010	05/12/2010	100.06	99.92	100.04	1
LG&E		C1S	860930	07/2010	05/12/2010	100.08	100.05	100.18	1
LG&E		C1S	860931	07/2010	05/12/2010	100.09	100.05	100.12	1
LG&E		C1S	860932	07/2010	05/12/2010	100.06	100.03	100.15	1
LG&E		C1S	860933	07/2010	05/12/2010	100.08	100.06	100.17	1
LG&E		C1S	860934	07/2010	05/12/2010	100.09	100.05	100.22	1
LG&E		C1S	860935	07/2010	05/12/2010	100.08	99.97	100.16	1
LG&E		C1S	860936	07/2010	05/12/2010	100.06	99.97	100.13	1
LG&E		C1S	860937	07/2010	05/12/2010	100.07	99.91	100.10	1
LG&E		C1S	860938	07/2010	05/12/2010	100.08	99.83	100.10	1
LG&E		C1S	860939	07/2010	05/12/2010	100.07	100.07	100.16	1
LG&E		C1S	860940	07/2010	05/12/2010	100.05	100.04	100.06	1
LG&E		C1S	860941	07/2010	05/12/2010	100.06	100.00	100.18	1
LG&E		C1S	860942	07/2010	05/12/2010	100.06	99.98	100.03	1
LG&E		C1S	860943	07/2010	05/12/2010	100.09	99.86	100.03	1
LG&E		C1S	860944	07/2010	05/12/2010	100.09	100.07	100.19	1
LG&E		C1S	860945	07/2010	05/12/2010	100.09	99.98	100.10	1
LG&E		C1S	860946	07/2010	05/12/2010	100.09	100.10	100.19	1
LG&E		C1S	860947	07/2010	05/12/2010	100.10	100.03	100.14	1
LG&E		C1S	860948	07/2010	05/12/2010	100.09	99.96	99.83	1

LG&E	C1S	860949	07/2010	05/12/2010	100.10	99.89	100.08	1
LG&E	C1S	860950	07/2010	05/12/2010	100.09	100.08	100.08	1
LG&E	C1S	860951	07/2010	05/12/2010	100.06	99.96	99.83	1
LG&E	C1S	860952	07/2010	05/12/2010	100.06	100.08	99.95	1
LG&E	C1S	860953	07/2010	05/12/2010	100.06	99.86	100.10	1
LG&E	C1S	860954	07/2010	05/12/2010	100.09	99.96	100.03	1
LG&E	C1S	860955	07/2010	05/12/2010	100.06	99.95	100.00	1
LG&E	C1S	860956	07/2010	05/12/2010	100.07	99.96	100.03	1
LG&E	C1S	860957	07/2010	05/12/2010	100.06	99.83	100.04	1
LG&E	C1S	860958	07/2010	05/12/2010	100.08	99.91	99.97	1
LG&E	C1S	860959	07/2010	05/12/2010	100.05	99.94	99.91	1
LG&E	C1S	860960	07/2010	05/12/2010	100.06	99.95	100.01	1
LG&E	C1S	860961	07/2010	05/12/2010	100.07	99.91	100.08	1
LG&E	C1S	860962	07/2010	05/12/2010	100.05	99.93	100.00	1
LG&E	C1S	860963	07/2010	05/12/2010	100.06	99.84	100.08	1
LG&E	C1S	860964	07/2010	05/12/2010	100.06	99.95	100.06	1
LG&E	C1S	860965	07/2010	05/12/2010	100.06	100.02	100.14	1
LG&E	C1S	860966	07/2010	05/12/2010	100.07	99.92	100.06	1
LG&E	C1S	860967	07/2010	05/12/2010	100.07	99.93	100.09	1
LG&E	C1S	860968	07/2010	05/12/2010	100.09	100.02	99.92	1
LG&E	C1S	860969	07/2010	05/12/2010	100.08	99.87	99.95	1
LG&E	C1S	860970	07/2010	05/12/2010	100.06	99.89	100.05	1
LG&E	C1S	860971	07/2010	05/12/2010	100.07	99.81	100.05	1
LG&E	C1S	860972	07/2010	05/12/2010	100.06	99.91	100.04	1
LG&E	C1S	860973	07/2010	05/12/2010	100.09	99.94	100.00	1
LG&E	C1S	860974	07/2010	05/12/2010	100.09	99.90	99.94	1
LG&E	C1S	860975	07/2010	05/12/2010	100.06	99.99	99.93	1
LG&E	C1S	860976	07/2010	05/12/2010	100.07	99.89	99.97	1
LG&E	C1S	860977	07/2010	05/12/2010	100.10	99.97	100.16	1
LG&E	C1S	860978	07/2010	05/12/2010	100.05	99.82	100.03	1
LG&E	C1S	860979	07/2010	05/12/2010	100.08	99.92	100.04	1
LG&E	C1S	860980	07/2010	05/12/2010	100.08	99.99	100.03	1
LG&E	C1S	860981	07/2010	05/12/2010	100.07	99.99	99.94	1
LG&E	C1S	860982	07/2010	05/12/2010	100.06	100.01	100.11	1
LG&E	C1S	860983	07/2010	05/12/2010	100.06	99.92	100.00	1
LG&E	C1S	860984	07/2010	05/12/2010	100.10	99.85	100.05	1



LG&E	C1S	860985	07/2010	12/2010	100.06	99.90	99.84	1
LG&E	C1S	860986	07/2010	05/12/2010	100.09	99.97	100.03	1
LG&E	C1S	860987	07/2010	05/12/2010	100.08	99.94	100.10	1
LG&E	C1S	860988	07/2010	05/12/2010	100.09	100.02	100.06	1
LG&E	C1S	860989	07/2010	05/12/2010	100.08	99.92	100.10	1
LG&E	C1S	860990	07/2010	05/12/2010	100.07	99.98	99.92	1
LG&E	C1S	860991	07/2010	05/12/2010	100.09	99.92	100.14	1
LG&E	C1S	860992	07/2010	05/12/2010	100.07	99.92	100.10	1
LG&E	C1S	860993	07/2010	05/12/2010	100.06	99.91	99.98	1
LG&E	C1S	860994	07/2010	05/12/2010	100.05	99.90	100.01	1
LG&E	C1S	860995	07/2010	05/12/2010	100.05	99.89	99.82	1
LG&E	C1S	860996	07/2010	05/12/2010	100.07	99.95	100.06	1
LG&E	C1S	860997	07/2010	05/12/2010	100.08	100.03	100.00	1
LG&E	C1S	860998	07/2010	05/12/2010	100.06	99.91	100.08	1
LG&E	C1S	860999	07/2010	05/12/2010	100.05	100.06	100.09	1
LG&E	C1S	861000	07/2010	05/12/2010	100.09	100.00	100.05	1
LG&E	C1S	861001	07/2010	05/12/2010	100.08	100.03	100.02	1
LG&E	C1S	861002	07/2010	05/12/2010	100.10	100.09	100.12	1
LG&E	C1S	861003	07/2010	05/12/2010	100.07	99.93	100.08	1
LG&E	C1S	861004	07/2010	05/12/2010	100.09	99.91	100.06	1
LG&E	C1S	861005	07/2010	05/12/2010	100.07	100.10	100.13	1
LG&E	C1S	861006	07/2010	05/12/2010	100.10	100.06	100.18	1
LG&E	C1S	861007	07/2010	05/12/2010	100.07	100.00	100.10	1
LG&E	C1S	861008	07/2010	05/12/2010	100.07	99.89	100.06	1
LG&E	C1S	861009	07/2010	05/12/2010	100.08	99.92	99.92	1
LG&E	C1S	861010	07/2010	05/12/2010	100.10	99.89	100.15	1
LG&E	C1S	861011	07/2010	05/12/2010	100.08	99.91	100.08	1
LG&E	C1S	861012	07/2010	05/12/2010	100.08	99.92	100.11	1
LG&E	C1S	861013	07/2010	05/12/2010	100.07	99.97	100.05	1
LG&E	C1S	861014	07/2010	05/12/2010	100.05	100.00	100.08	1
LG&E	C1S	861015	07/2010	05/12/2010	100.10	100.05	100.15	1
LG&E	C1S	861016	07/2010	05/12/2010	100.06	99.83	100.10	1
LG&E	C1S	861017	07/2010	05/12/2010	100.07	100.01	100.15	1
LG&E	C1S	861018	07/2010	05/12/2010	100.07	100.08	100.19	1
LG&E	C1S	861019	07/2010	05/12/2010	100.06	99.92	100.05	1
LG&E	C1S	861020	07/2010	05/12/2010	100.08	99.93	100.08	1

LG&E	C1S	861021	07/2010	12/2010	100.06	99.97	100.11	1
LG&E	C1S	861022	07/2010	05/12/2010	100.10	100.08	100.19	1
LG&E	C1S	861023	07/2010	05/12/2010	100.09	100.08	100.18	1
LG&E	C1S	861024	07/2010	05/12/2010	100.05	100.06	100.08	1
LG&E	C1S	861025	07/2010	05/12/2010	100.08	100.02	100.17	1
LG&E	C1S	861026	07/2010	05/12/2010	100.09	100.05	100.16	1
LG&E	C1S	861027	07/2010	05/12/2010	100.07	99.96	100.04	1
LG&E	C1S	861028	07/2010	05/12/2010	100.08	100.08	100.19	1
LG&E	C1S	861029	07/2010	05/12/2010	100.08	100.04	100.13	1
LG&E	C1S	861030	07/2010	05/12/2010	100.07	99.97	100.11	1
LG&E	C1S	861031	07/2010	05/12/2010	100.07	100.00	100.14	1
LG&E	C1S	861032	07/2010	05/12/2010	100.08	100.00	100.17	1
LG&E	C1S	861033	07/2010	05/12/2010	100.08	100.05	100.12	1
LG&E	C1S	861034	07/2010	05/12/2010	100.08	99.98	100.09	1
LG&E	C1S	861035	07/2010	05/12/2010	100.08	99.97	99.88	1
LG&E	C1S	861036	07/2010	05/12/2010	100.09	100.00	100.06	1
LG&E	C1S	861037	07/2010	05/12/2010	100.06	100.03	100.17	1
LG&E	C1S	861038	07/2010	05/12/2010	100.09	100.09	100.16	1
LG&E	C1S	861039	07/2010	05/12/2010	100.09	99.94	100.08	1
LG&E	C1S	861040	07/2010	05/12/2010	100.07	99.89	99.99	1
LG&E	C1S	861041	07/2010	05/12/2010	100.05	100.17	100.11	1
LG&E	C1S	861042	07/2010	05/12/2010	100.09	99.97	100.16	1
LG&E	C1S	861043	07/2010	05/12/2010	100.10	99.97	100.01	1
LG&E	C1S	861044	07/2010	05/12/2010	100.08	99.95	99.98	1
LG&E	C1S	861045	07/2010	05/12/2010	100.10	100.07	100.06	1
LG&E	C1S	861046	07/2010	05/12/2010	100.05	99.92	99.97	1
LG&E	C1S	861047	07/2010	05/12/2010	100.07	99.89	100.08	1
LG&E	C1S	861048	07/2010	05/12/2010	100.08	99.95	99.92	1
LG&E	C1S	861049	07/2010	05/12/2010	100.08	99.99	100.15	1
LG&E	C1S	861050	07/2010	05/12/2010	100.09	99.92	100.08	1
LG&E	C1S	861051	07/2010	05/12/2010	100.09	100.05	100.18	1
LG&E	C1S	861052	07/2010	05/12/2010	100.07	99.93	100.01	1
LG&E	C1S	861053	07/2010	05/12/2010	100.07	99.96	99.99	1
LG&E	C1S	861054	07/2010	05/12/2010	100.08	99.93	99.98	1
LG&E	C1S	861055	07/2010	05/12/2010	100.09	100.06	100.11	1
LG&E	C1S	861056	07/2010	05/12/2010	100.07	100.06	100.14	1

LG&E	C1S	861057	07/2010	12/2010	100.06	99.85	100.02	1
LG&E	C1S	861058	07/2010	05/12/2010	100.07	99.98	100.17	1
LG&E	C1S	861059	07/2010	05/12/2010	100.06	100.03	100.11	1
LG&E	C1S	861060	07/2010	05/12/2010	100.06	100.00	100.20	1
LG&E	C1S	861061	07/2010	05/12/2010	100.09	100.05	100.12	1
LG&E	C1S	861062	07/2010	05/12/2010	100.07	100.09	100.18	1
LG&E	C1S	861063	07/2010	05/12/2010	100.06	99.85	100.02	1
LG&E	C1S	861064	07/2010	05/12/2010	100.09	99.97	99.97	1
LG&E	C1S	861065	07/2010	05/12/2010	100.09	100.03	100.17	1
LG&E	C1S	861066	07/2010	05/12/2010	100.09	100.06	100.19	1
LG&E	C1S	861067	07/2010	05/12/2010	100.06	100.03	99.99	1
LG&E	C1S	861068	07/2010	05/12/2010	100.10	100.17	100.14	1
LG&E	C1S	861069	07/2010	05/12/2010	100.08	99.94	100.01	1
LG&E	C1S	861070	07/2010	05/12/2010	100.06	99.97	100.00	1
LG&E	C1S	861071	07/2010	05/12/2010	100.06	100.02	100.13	1
LG&E	C1S	861072	07/2010	05/12/2010	100.07	100.06	100.18	1
LG&E	C1S	861073	07/2010	05/12/2010	100.09	100.08	100.19	1
LG&E	C1S	861074	07/2010	05/12/2010	100.11	100.05	100.02	1
LG&E	C1S	861075	07/2010	05/12/2010	100.10	100.12	100.15	1
LG&E	C1S	861076	07/2010	05/12/2010	100.06	99.93	99.94	1
LG&E	C1S	861077	07/2010	05/12/2010	100.10	100.00	100.16	1
LG&E	C1S	861078	07/2010	05/12/2010	100.05	99.87	100.04	1
LG&E	C1S	861079	07/2010	05/12/2010	100.10	100.13	100.15	1
LG&E	C1S	861080	07/2010	05/12/2010	100.06	99.87	100.08	1
LG&E	C1S	861081	07/2010	05/12/2010	100.08	99.98	100.14	1
LG&E	C1S	861082	07/2010	05/12/2010	100.06	100.06	100.15	1
LG&E	C1S	861083	07/2010	05/12/2010	100.05	99.91	99.97	1
LG&E	C1S	861084	07/2010	05/12/2010	100.05	99.90	99.94	1
LG&E	C1S	861085	07/2010	05/12/2010	100.08	99.93	99.99	1
LG&E	C1S	861086	07/2010	05/12/2010	100.06	100.00	100.14	1
LG&E	C1S	861087	07/2010	05/12/2010	100.10	99.95	100.14	1
LG&E	C1S	861088	07/2010	05/12/2010	100.06	99.90	99.98	1
LG&E	C1S	861089	07/2010	05/12/2010	100.10	99.94	100.03	1
LG&E	C1S	861090	07/2010	05/12/2010	100.09	100.05	100.14	1
LG&E	C1S	861091	07/2010	05/12/2010	100.06	100.07	100.09	1
LG&E	C1S	861092	07/2010	05/12/2010	100.06	100.01	100.14	1

LG&E	C1S	861093	07/2010	05/12/2010	100.08	100.00	100.17	1
LG&E	C1S	861094	07/2010	05/12/2010	100.07	99.99	100.14	1
LG&E	C1S	861095	07/2010	05/12/2010	100.07	99.89	99.95	1
LG&E	C1S	861096	07/2010	05/12/2010	100.06	99.99	100.17	1
LG&E	C1S	861097	07/2010	05/12/2010	100.08	100.07	100.21	1
LG&E	C1S	861098	07/2010	05/12/2010	100.09	100.08	100.11	1
LG&E	C1S	861099	07/2010	05/12/2010	100.07	100.11	100.08	1
LG&E	C1S	861100	07/2010	05/12/2010	100.09	99.99	99.97	1
LG&E	C1S	861101	07/2010	05/12/2010	100.09	99.93	100.01	1
LG&E	C1S	861102	07/2010	05/12/2010	100.09	99.98	100.13	1
LG&E	C1S	861103	07/2010	05/12/2010	100.07	99.97	100.09	1
LG&E	C1S	861104	07/2010	05/12/2010	100.08	100.02	100.19	1
LG&E	C1S	861105	07/2010	05/12/2010	100.06	100.05	99.97	1
LG&E	C1S	861106	07/2010	05/12/2010	100.09	99.92	100.09	1
LG&E	C1S	861107	07/2010	05/12/2010	100.07	100.04	100.01	1
LG&E	C1S	861108	07/2010	05/12/2010	100.08	99.93	100.03	1
LG&E	C1S	861109	07/2010	05/12/2010	100.06	100.02	100.01	1
LG&E	C1S	861110	07/2010	05/12/2010	100.08	100.02	100.10	1
LG&E	C1S	861111	07/2010	05/12/2010	100.07	99.93	100.06	1
LG&E	C1S	861112	07/2010	05/12/2010	100.10	99.97	100.04	1
LG&E	C1S	861113	07/2010	05/12/2010	100.07	100.03	100.07	1
LG&E	C1S	861114	07/2010	05/12/2010	100.09	99.98	99.98	1
LG&E	C1S	861115	07/2010	05/12/2010	100.10	99.99	100.14	1
LG&E	C1S	861116	07/2010	05/12/2010	100.09	99.96	99.91	1
LG&E	C1S	861117	07/2010	05/12/2010	100.06	99.90	100.08	1
LG&E	C1S	861118	07/2010	05/12/2010	100.09	100.01	100.04	1
LG&E	C1S	861119	07/2010	05/12/2010	100.06	99.95	99.95	1
LG&E	C1S	861120	07/2010	05/12/2010	100.07	99.91	100.09	1
LG&E	C1S	861121	07/2010	05/12/2010	100.09	100.05	100.14	1
LG&E	C1S	861122	07/2010	05/12/2010	100.06	99.86	100.04	1
LG&E	C1S	861123	07/2010	05/12/2010	100.07	99.90	100.04	1
LG&E	C1S	861124	07/2010	05/12/2010	100.08	100.03	100.14	1
LG&E	C1S	861125	07/2010	05/12/2010	100.07	100.06	100.02	1
LG&E	C1S	861126	07/2010	05/12/2010	100.06	100.00	100.04	1
LG&E	C1S	861127	07/2010	05/12/2010	100.06	100.08	100.08	1
LG&E	C1S	861128	07/2010	05/12/2010	100.07	99.88	100.05	1

LG&E	C1S	861129	07/2010	07/2010	100.10	100.06	100.12	1
LG&E	C1S	861130	07/2010	05/12/2010	100.07	100.04	99.98	1
LG&E	C1S	861131	07/2010	05/12/2010	100.10	99.95	100.10	1
LG&E	C1S	861132	07/2010	05/12/2010	100.09	100.03	100.18	1
LG&E	C1S	861133	07/2010	05/12/2010	100.08	99.88	99.82	1
LG&E	C1S	861134	07/2010	05/12/2010	100.10	100.12	100.14	1
LG&E	C1S	861135	07/2010	05/12/2010	100.08	100.02	100.11	1
LG&E	C1S	861136	07/2010	05/12/2010	100.09	100.03	100.22	1
LG&E	C1S	861137	07/2010	05/12/2010	100.05	99.97	99.96	1
LG&E	C1S	861138	07/2010	05/12/2010	100.08	100.08	100.09	1
LG&E	C1S	861139	07/2010	05/12/2010	100.10	100.08	100.21	1
LG&E	C1S	861140	07/2010	05/12/2010	100.09	100.00	100.06	1
LG&E	C1S	861141	07/2010	05/12/2010	100.06	100.00	100.15	1
LG&E	C1S	861142	07/2010	05/12/2010	100.05	99.99	100.10	1
LG&E	C1S	861143	07/2010	05/12/2010	100.06	99.91	100.00	1
LG&E	C1S	861144	07/2010	05/12/2010	100.08	99.89	100.15	1
LG&E	C1S	861145	07/2010	05/12/2010	100.10	100.06	100.13	1
LG&E	C1S	861146	07/2010	05/12/2010	100.08	99.98	100.03	1
LG&E	C1S	861147	07/2010	05/12/2010	100.08	99.98	100.11	1
LG&E	C1S	861148	07/2010	05/12/2010	100.07	100.07	99.95	1
LG&E	C1S	861149	07/2010	05/12/2010	100.06	99.92	100.02	1
LG&E	C1S	861150	07/2010	05/12/2010	100.08	99.91	100.08	1
LG&E	C1S	861151	07/2010	05/12/2010	100.09	100.03	100.16	1
LG&E	C1S	861152	07/2010	05/12/2010	100.07	100.00	99.88	1
LG&E	C1S	861153	07/2010	05/12/2010	100.05	99.97	100.00	1
LG&E	C1S	861154	07/2010	05/12/2010	100.09	99.96	100.11	1
LG&E	C1S	861155	07/2010	05/12/2010	100.05	99.99	100.06	1
LG&E	C1S	861156	07/2010	05/12/2010	100.07	100.05	100.16	1
LG&E	C1S	861157	07/2010	05/12/2010	100.06	100.13	100.16	1
LG&E	C1S	861158	07/2010	05/12/2010	100.07	100.10	100.16	1
LG&E	C1S	861159	07/2010	05/12/2010	100.08	100.00	99.97	1
LG&E	C1S	861160	07/2010	05/12/2010	100.07	99.97	100.07	1
LG&E	C1S	861161	07/2010	05/12/2010	100.06	99.91	100.13	1
LG&E	C1S	861162	07/2010	05/12/2010	100.09	99.88	100.04	1
LG&E	C1S	861163	07/2010	05/12/2010	100.10	100.06	100.15	1
LG&E	C1S	861164	07/2010	05/12/2010	100.05	99.92	100.16	1

LG&E	CIS	861165	07/2010	05/12/2010	100.08	100.09	100.04	1
LG&E	CIS	861166	07/2010	05/12/2010	100.06	100.05	100.12	1
LG&E	CIS	861167	07/2010	05/12/2010	100.09	100.04	100.13	1
LG&E	CIS	861168	07/2010	05/12/2010	100.05	99.92	100.11	1
LG&E	CIS	861169	07/2010	05/12/2010	100.06	99.87	100.18	1
LG&E	CIS	861170	07/2010	05/12/2010	100.07	99.98	100.06	1
LG&E	CIS	861171	07/2010	05/12/2010	100.06	100.00	100.11	1
LG&E	CIS	861172	07/2010	05/12/2010	100.05	100.04	100.06	1
LG&E	CIS	861173	07/2010	05/12/2010	100.06	100.00	100.10	1
LG&E	CIS	861174	07/2010	05/12/2010	100.06	99.92	100.06	1
LG&E	CIS	861175	07/2010	05/12/2010	100.07	99.98	100.02	1
LG&E	CIS	861176	07/2010	05/12/2010	100.08	99.92	100.04	1
LG&E	CIS	861177	07/2010	05/12/2010	100.08	99.92	99.88	1
LG&E	CIS	861178	07/2010	05/12/2010	100.08	100.02	100.13	1
LG&E	CIS	861179	07/2010	05/12/2010	100.10	99.99	100.15	1
LG&E	CIS	861180	07/2010	05/12/2010	100.07	100.00	99.93	1
LG&E	CIS	861181	07/2010	05/12/2010	100.10	99.84	100.11	1
LG&E	CIS	861182	07/2010	05/12/2010	100.10	99.94	100.03	1
LG&E	CIS	861183	07/2010	05/12/2010	100.10	100.01	99.90	1
LG&E	CIS	861184	07/2010	05/12/2010	100.10	100.05	100.14	1
LG&E	CIS	861185	07/2010	05/12/2010	100.06	99.98	100.12	1
LG&E	CIS	861186	07/2010	05/12/2010	100.09	99.94	100.05	1
LG&E	CIS	861187	07/2010	05/12/2010	100.09	99.91	100.02	1
LG&E	CIS	861188	07/2010	05/12/2010	100.07	99.83	100.06	1
LG&E	CIS	861189	07/2010	05/12/2010	100.07	99.88	100.07	1
LG&E	CIS	861190	07/2010	05/12/2010	100.09	100.03	100.10	1
LG&E	CIS	861191	07/2010	05/12/2010	100.08	99.95	100.06	1
LG&E	CIS	861192	07/2010	05/12/2010	100.08	99.98	99.96	1
LG&E	CIS	861193	07/2010	05/12/2010	100.06	100.00	100.16	1
LG&E	CIS	861194	07/2010	05/12/2010	100.07	100.02	100.14	1
LG&E	CIS	861195	07/2010	05/12/2010	100.08	99.98	100.01	1
LG&E	CIS	861196	07/2010	05/12/2010	100.06	100.05	100.10	1
LG&E	CIS	861197	07/2010	05/12/2010	100.10	100.02	99.97	1
LG&E	CIS	861198	07/2010	05/12/2010	100.10	100.05	100.14	1
LG&E	CIS	861199	07/2010	05/12/2010	100.06	99.90	100.20	1
LG&E	CIS	861200	07/2010	05/12/2010	100.10	99.96	99.95	1

LG&E	C1S	861201	07/2010	2/2010	100.10	100.09	100.19	1
LG&E	C1S	861202	07/2010	05/12/2010	100.08	99.91	100.07	1
LG&E	C1S	861203	07/2010	05/12/2010	100.06	100.02	100.14	1
LG&E	C1S	861204	07/2010	05/12/2010	100.09	100.06	100.12	1
LG&E	C1S	861205	07/2010	05/12/2010	100.08	99.98	100.06	1
LG&E	C1S	861206	07/2010	05/12/2010	100.07	100.10	100.14	1
LG&E	C1S	861207	07/2010	05/12/2010	100.07	100.04	100.12	1
LG&E	C1S	861208	07/2010	05/12/2010	100.06	99.90	100.07	1
LG&E	C1S	861209	07/2010	05/12/2010	100.07	99.97	100.14	1
LG&E	C1S	861210	07/2010	05/12/2010	100.05	100.02	100.12	1
LG&E	C1S	861211	07/2010	05/12/2010	100.07	100.01	99.87	1
LG&E	C1S	861212	07/2010	05/12/2010	100.10	99.89	100.06	1
LG&E	C1S	861213	07/2010	05/12/2010	100.09	99.94	100.02	1
LG&E	C1S	861214	07/2010	05/12/2010	100.07	100.03	100.13	1
LG&E	C1S	861215	07/2010	05/12/2010	100.08	100.00	100.11	1
LG&E	C1S	861216	07/2010	05/12/2010	100.07	100.08	100.17	1
LG&E	C1S	861217	07/2010	05/12/2010	100.07	99.91	100.08	1
LG&E	C1S	861218	07/2010	05/12/2010	100.06	99.92	100.01	1
LG&E	C1S	861219	07/2010	05/12/2010	100.05	100.02	100.19	1
LG&E	C1S	861220	07/2010	05/12/2010	100.09	100.06	100.14	1
LG&E	C1S	861221	07/2010	05/12/2010	100.09	100.08	100.12	1
LG&E	C1S	861222	07/2010	05/12/2010	100.09	99.94	100.01	1
LG&E	C1S	861223	07/2010	05/12/2010	100.09	100.01	100.15	1
LG&E	C1S	861224	07/2010	05/12/2010	100.09	99.92	100.09	1
LG&E	C1S	861225	07/2010	05/12/2010	100.09	100.11	100.21	1
LG&E	C1S	861226	07/2010	05/12/2010	100.07	99.91	100.14	1
LG&E	C1S	861227	07/2010	05/12/2010	100.08	99.93	100.06	1
LG&E	C1S	861228	07/2010	05/12/2010	100.09	100.01	100.11	1
LG&E	C1S	861229	07/2010	05/12/2010	100.07	99.91	100.15	1
LG&E	C1S	861230	07/2010	05/12/2010	100.10	100.11	100.27	1
LG&E	C1S	861231	07/2010	05/12/2010	100.07	99.97	100.06	1
LG&E	C1S	861232	07/2010	05/12/2010	100.05	100.01	100.12	1
LG&E	C1S	861233	07/2010	05/12/2010	100.10	100.05	100.15	1
LG&E	C1S	861234	07/2010	05/12/2010	100.05	100.06	100.09	1
LG&E	C1S	861235	07/2010	05/12/2010	100.07	100.03	100.22	1
LG&E	C1S	861236	07/2010	05/12/2010	100.10	99.93	100.20	1

LG&E	C1S	861237	07/2010	05/12/2010	100.09	99.96	100.04	1
LG&E	C1S	861238	07/2010	05/12/2010	100.08	100.00	100.17	1
LG&E	C1S	861239	07/2010	05/12/2010	100.10	100.04	100.12	1
LG&E	C1S	861240	07/2010	05/12/2010	100.09	100.05	100.16	1
LG&E	C1S	861241	07/2010	05/12/2010	100.06	100.03	100.12	1
LG&E	C1S	861242	07/2010	05/12/2010	100.08	99.81	99.98	1
LG&E	C1S	861243	07/2010	05/12/2010	100.07	99.90	100.00	1
LG&E	C1S	861244	07/2010	05/12/2010	100.08	99.95	100.11	1
LG&E	C1S	861245	07/2010	05/12/2010	100.06	99.89	100.10	1
LG&E	C1S	861246	07/2010	05/12/2010	100.08	99.96	100.01	1
LG&E	C1S	861247	07/2010	05/12/2010	100.07	100.05	100.13	1
LG&E	C1S	861248	07/2010	05/12/2010	100.07	100.03	100.11	1
LG&E	C1S	861249	07/2010	05/12/2010	100.07	100.02	100.15	1
LG&E	C1S	861250	07/2010	05/12/2010	100.09	99.99	100.00	1
LG&E	C1S	861251	07/2010	05/12/2010	100.06	99.93	100.10	1
LG&E	C1S	861252	07/2010	05/12/2010	100.07	100.06	100.10	1
LG&E	C1S	861253	07/2010	05/12/2010	100.08	100.09	100.12	1
LG&E	C1S	861254	07/2010	05/12/2010	100.07	99.82	100.01	1
LG&E	C1S	861255	07/2010	05/12/2010	100.09	99.94	100.05	1
LG&E	C1S	861256	07/2010	05/12/2010	100.09	99.92	100.07	1
LG&E	C1S	861257	07/2010	05/12/2010	100.06	100.06	100.11	1
LG&E	C1S	861258	07/2010	05/12/2010	100.07	100.04	100.15	1
LG&E	C1S	861259	07/2010	05/12/2010	100.06	99.97	100.10	1
LG&E	C1S	861260	07/2010	05/12/2010	100.06	99.95	100.03	1
LG&E	C1S	861261	07/2010	05/12/2010	100.07	99.96	100.00	1
LG&E	C1S	861262	07/2010	05/12/2010	100.06	100.00	99.99	1
LG&E	C1S	861263	07/2010	05/12/2010	100.09	100.05	100.01	1
LG&E	C1S	861264	07/2010	05/12/2010	100.09	99.90	99.91	1
LG&E	C1S	861265	07/2010	05/12/2010	100.06	99.86	100.00	1
LG&E	C1S	861266	07/2010	05/12/2010	100.06	99.92	100.08	1
LG&E	C1S	861267	07/2010	05/12/2010	100.09	100.06	100.05	1
LG&E	C1S	861268	07/2010	05/12/2010	100.07	100.00	100.07	1
LG&E	C1S	861269	07/2010	05/12/2010	100.06	99.97	100.14	1
LG&E	C1S	861270	07/2010	05/12/2010	100.08	99.97	99.84	1
LG&E	C1S	861271	07/2010	05/12/2010	100.09	99.93	100.10	1
LG&E	C1S	861272	07/2010	05/12/2010	100.07	99.92	100.01	1



LG&E	C1S	861273	07/2010	12/2010	100.06	99.93	99.88	1
LG&E	C1S	861274	07/2010	05/12/2010	100.10	100.02	100.08	1
LG&E	C1S	861275	07/2010	05/12/2010	100.09	99.98	100.18	1
LG&E	C1S	861276	07/2010	05/12/2010	100.07	99.97	100.18	1
LG&E	C1S	861277	07/2010	05/12/2010	100.07	99.87	99.84	1
LG&E	C1S	861278	07/2010	05/12/2010	100.07	99.95	99.95	1
LG&E	C1S	861279	07/2010	05/12/2010	100.07	99.95	100.16	1
LG&E	C1S	861280	07/2010	05/12/2010	100.09	100.05	100.16	1
LG&E	C1S	861281	07/2010	05/12/2010	100.09	99.95	100.13	1
LG&E	C1S	861282	07/2010	05/12/2010	100.07	100.05	100.13	1
LG&E	C1S	861283	07/2010	05/12/2010	100.08	99.83	100.01	1
LG&E	C1S	861284	07/2010	05/12/2010	100.07	99.82	100.05	1
LG&E	C1S	861285	07/2010	05/12/2010	100.07	100.00	100.13	1
LG&E	C1S	861286	07/2010	05/12/2010	100.10	99.95	99.84	1
LG&E	C1S	861287	07/2010	05/12/2010	100.06	99.93	99.97	1
LG&E	C1S	861288	07/2010	05/12/2010	100.05	99.89	100.01	1
LG&E	C1S	861289	07/2010	05/12/2010	100.08	99.83	100.14	1
LG&E	C1S	861290	07/2010	05/12/2010	100.08	100.06	100.07	1
LG&E	C1S	861291	07/2010	05/12/2010	100.06	99.96	100.00	1
LG&E	C1S	861292	07/2010	05/12/2010	100.09	99.95	100.15	1
LG&E	C1S	861293	07/2010	05/12/2010	100.08	99.98	99.95	1
LG&E	C1S	861294	07/2010	05/12/2010	100.07	99.98	99.94	1
LG&E	C1S	861295	07/2010	05/12/2010	100.08	100.01	99.92	1
LG&E	C1S	861296	07/2010	05/12/2010	100.09	99.97	99.98	1
LG&E	C1S	861297	07/2010	05/12/2010	100.07	100.00	100.15	1
LG&E	C1S	861298	07/2010	05/12/2010	100.07	99.99	100.13	1
LG&E	C1S	861299	07/2010	05/12/2010	100.07	100.00	99.98	1
LG&E	C1S	861300	07/2010	05/12/2010	100.07	99.91	100.16	1
LG&E	C1S	861301	07/2010	05/12/2010	100.09	99.97	99.98	1
LG&E	C1S	861302	07/2010	05/12/2010	100.08	100.05	100.08	1
LG&E	C1S	861303	07/2010	05/12/2010	100.10	99.98	100.01	1
LG&E	C1S	861304	07/2010	05/12/2010	100.07	99.97	100.20	1
LG&E	C1S	861305	07/2010	05/12/2010	100.10	100.06	100.16	1
LG&E	C1S	861306	07/2010	05/12/2010	100.07	99.92	99.98	1
LG&E	C1S	861307	07/2010	05/12/2010	100.09	100.05	100.15	1
LG&E	C1S	861308	07/2010	05/12/2010	100.07	99.99	100.08	1

LG&E	C1S	861309	07/2010	05/12/2010	100.10	100.03	100.11	1
LG&E	C1S	861310	07/2010	05/12/2010	100.06	99.98	100.11	1
LG&E	C1S	861311	07/2010	05/12/2010	100.06	99.91	100.08	1
LG&E	C1S	861312	07/2010	05/12/2010	100.08	99.95	100.18	1
LG&E	C1S	861313	07/2010	05/12/2010	100.06	99.97	99.98	1
LG&E	C1S	861314	07/2010	05/12/2010	100.09	100.07	100.15	1
LG&E	C1S	861315	07/2010	05/12/2010	100.08	100.05	100.00	1
LG&E	C1S	861316	07/2010	05/12/2010	100.09	99.89	100.03	1
LG&E	C1S	861317	07/2010	05/12/2010	100.08	99.84	100.12	1
LG&E	C1S	861318	07/2010	05/12/2010	100.07	100.09	100.14	1
LG&E	C1S	861319	07/2010	05/12/2010	100.09	100.03	99.93	1
LG&E	C1S	861320	07/2010	05/12/2010	100.09	100.08	100.14	1
LG&E	C1S	861321	07/2010	05/12/2010	100.06	99.91	100.11	1
LG&E	C1S	861322	07/2010	05/12/2010	100.08	99.95	100.06	1
LG&E	C1S	861323	07/2010	05/12/2010	100.08	99.94	100.03	1
LG&E	C1S	861324	07/2010	05/12/2010	100.10	100.01	100.14	1
LG&E	C1S	861325	07/2010	05/12/2010	100.06	99.87	100.06	1
LG&E	C1S	861326	07/2010	05/12/2010	100.08	100.04	100.09	1
LG&E	C1S	861327	07/2010	05/12/2010	100.09	100.04	100.18	1
LG&E	C1S	861328	07/2010	05/12/2010	100.05	99.87	100.07	1
LG&E	C1S	861329	07/2010	05/12/2010	100.08	100.06	100.19	1
LG&E	C1S	861330	07/2010	05/12/2010	100.05	99.99	100.11	1
LG&E	C1S	861331	07/2010	05/12/2010	100.07	99.95	99.94	1
LG&E	C1S	861332	07/2010	05/12/2010	100.08	99.99	100.00	1
LG&E	C1S	861333	07/2010	05/12/2010	100.08	99.97	100.12	1
LG&E	C1S	861334	07/2010	05/12/2010	100.10	100.07	100.14	1
LG&E	C1S	861335	07/2010	05/12/2010	100.09	100.05	100.17	1
LG&E	C1S	861336	07/2010	05/12/2010	100.10	99.96	100.13	1
LG&E	C1S	861337	07/2010	05/12/2010	100.08	100.00	100.06	1
LG&E	C1S	861338	07/2010	05/12/2010	100.07	99.97	99.91	1
LG&E	C1S	861339	07/2010	05/12/2010	100.05	100.02	100.05	1
LG&E	C1S	861340	07/2010	05/12/2010	100.09	100.04	100.09	1
LG&E	C1S	861341	07/2010	05/12/2010	100.10	100.11	100.19	1
LG&E	C1S	861342	07/2010	05/12/2010	100.10	100.07	100.20	1
LG&E	C1S	861343	07/2010	05/12/2010	100.08	99.96	99.92	1
LG&E	C1S	861344	07/2010	05/12/2010	100.06	99.90	100.05	1

LG&E	C1S	861345	07/2010	12/2010	100.08	100.10	100.14	1
LG&E	C1S	861346	07/2010	05/12/2010	100.08	99.94	99.93	1
LG&E	C1S	861347	07/2010	05/12/2010	100.08	99.93	99.91	1
LG&E	C1S	861348	07/2010	05/12/2010	100.06	99.97	100.10	1
LG&E	C1S	861349	07/2010	05/12/2010	100.06	100.01	100.07	1
LG&E	C1S	861350	07/2010	05/12/2010	100.09	100.07	100.16	1
LG&E	C1S	861351	07/2010	05/12/2010	100.07	99.95	100.03	1
LG&E	C1S	861352	07/2010	05/12/2010	100.09	100.09	100.13	1
LG&E	C1S	861353	07/2010	05/12/2010	100.08	99.90	99.95	1
LG&E	C1S	861354	07/2010	05/12/2010	100.09	99.94	100.15	1
LG&E	C1S	861355	07/2010	05/12/2010	100.08	100.13	100.16	1
LG&E	C1S	861356	07/2010	05/12/2010	100.08	100.00	100.05	1
LG&E	C1S	861357	07/2010	05/12/2010	100.06	100.01	99.92	1
LG&E	C1S	861358	07/2010	05/12/2010	100.06	99.95	99.91	1
LG&E	C1S	861359	07/2010	05/12/2010	100.09	100.13	100.18	1
LG&E	C1S	861360	07/2010	05/12/2010	100.09	99.91	100.07	1
LG&E	C1S	861361	07/2010	05/12/2010	100.06	100.03	100.20	1
LG&E	C1S	861362	07/2010	05/12/2010	100.10	99.99	100.08	1
LG&E	C1S	861363	07/2010	05/12/2010	100.06	100.01	100.04	1
LG&E	C1S	861364	07/2010	05/12/2010	100.07	100.07	100.07	1
LG&E	C1S	861365	07/2010	05/12/2010	100.09	99.92	100.00	1
LG&E	C1S	861366	07/2010	05/12/2010	100.08	99.91	99.97	1
LG&E	C1S	861367	07/2010	05/12/2010	100.10	99.92	99.95	1
LG&E	C1S	861368	07/2010	05/12/2010	100.10	99.99	99.99	1
LG&E	C1S	861369	07/2010	05/12/2010	100.08	99.92	100.05	1
LG&E	C1S	861370	07/2010	05/12/2010	100.06	100.01	100.06	1
LG&E	C1S	861371	07/2010	05/12/2010	100.06	100.07	100.13	1
LG&E	C1S	861372	07/2010	05/12/2010	100.10	99.98	99.93	1
LG&E	C1S	861373	07/2010	05/12/2010	100.10	100.03	100.04	1
LG&E	C1S	861374	07/2010	05/12/2010	100.10	99.94	99.99	1
LG&E	C1S	861375	07/2010	05/12/2010	100.06	99.89	100.04	1
LG&E	C1S	861376	07/2010	05/12/2010	100.09	99.93	100.02	1
LG&E	C1S	861377	07/2010	05/12/2010	100.08	100.02	99.98	1
LG&E	C1S	861378	07/2010	05/12/2010	100.09	100.03	100.11	1
LG&E	C1S	861379	07/2010	05/12/2010	100.09	99.95	99.98	1
LG&E	C1S	861380	07/2010	05/12/2010	100.07	99.88	100.03	1

LG&E	CIS	861381	07/2010	05/12/2010	100.08	99.94	99.90	1
LG&E	CIS	861382	07/2010	05/12/2010	100.08	100.04	100.13	1
LG&E	CIS	861383	07/2010	05/12/2010	100.08	99.86	100.04	1
LG&E	CIS	861384	07/2010	05/12/2010	100.06	99.86	100.04	1
LG&E	CIS	861385	07/2010	05/12/2010	100.08	100.02	100.12	1
LG&E	CIS	861386	07/2010	05/12/2010	100.07	99.92	100.06	1
LG&E	CIS	861387	07/2010	05/12/2010	100.07	100.07	100.07	1
LG&E	CIS	861388	07/2010	05/12/2010	100.10	99.92	100.07	1
LG&E	CIS	861389	07/2010	05/12/2010	100.08	100.01	100.22	1
LG&E	CIS	861390	07/2010	05/12/2010	100.08	100.06	100.24	1
LG&E	CIS	861391	07/2010	05/12/2010	100.05	99.91	100.10	1
LG&E	CIS	861392	07/2010	05/12/2010	100.09	100.05	100.00	1
LG&E	CIS	861393	07/2010	05/12/2010	100.09	100.00	100.00	1
LG&E	CIS	861394	07/2010	05/12/2010	100.08	100.00	100.20	1
LG&E	CIS	861395	07/2010	05/12/2010	100.09	100.11	100.17	1
LG&E	CIS	861396	07/2010	05/12/2010	100.07	100.03	100.10	1
LG&E	CIS	861397	07/2010	05/12/2010	100.07	99.91	100.16	1
LG&E	CIS	861398	07/2010	05/12/2010	100.06	100.12	100.10	1
LG&E	CIS	861399	07/2010	05/12/2010	100.06	99.97	100.10	1
LG&E	CIS	861400	07/2010	05/12/2010	100.06	100.05	100.14	1
LG&E	CIS	861401	07/2010	05/12/2010	100.07	100.07	100.17	1
LG&E	CIS	861402	07/2010	05/12/2010	100.06	99.98	100.09	1
LG&E	CIS	861403	07/2010	05/12/2010	100.09	99.87	99.96	1
LG&E	CIS	861404	07/2010	05/12/2010	100.09	99.87	99.90	1
LG&E	CIS	861405	07/2010	05/12/2010	100.09	99.98	100.08	1
LG&E	CIS	861406	07/2010	05/12/2010	100.08	99.80	99.99	1
LG&E	CIS	861407	07/2010	05/12/2010	100.07	99.98	99.98	1
LG&E	CIS	861408	07/2010	05/12/2010	100.08	99.95	100.03	1
LG&E	CIS	861409	07/2010	05/12/2010	100.09	100.03	100.21	1
LG&E	CIS	861410	07/2010	05/12/2010	100.05	99.97	99.89	1
LG&E	CIS	861411	07/2010	05/12/2010	100.09	100.06	100.20	1
LG&E	CIS	861412	07/2010	05/12/2010	100.07	99.96	100.05	1
LG&E	CIS	861413	07/2010	05/12/2010	100.08	100.12	100.21	1
LG&E	CIS	861414	07/2010	05/12/2010	100.06	100.04	100.11	1
LG&E	CIS	861415	07/2010	05/12/2010	100.08	100.04	100.12	1
LG&E	CIS	861416	07/2010	05/12/2010	100.08	99.91	100.06	1

LG&E	C1S	861417	07/2010	12/2010	100.06	100.00	100.18	1
LG&E	C1S	861418	07/2010	05/12/2010	100.07	100.03	100.10	1
LG&E	C1S	861419	07/2010	05/12/2010	100.06	100.05	100.14	1
LG&E	C1S	861420	07/2010	05/12/2010	100.10	100.07	99.97	1
LG&E	C1S	861421	07/2010	05/12/2010	100.08	100.03	100.11	1
LG&E	C1S	861422	07/2010	05/12/2010	100.09	100.00	100.02	1
LG&E	C1S	861423	07/2010	05/12/2010	100.07	100.08	100.15	1
LG&E	C1S	861424	07/2010	05/12/2010	100.08	99.98	100.09	1
LG&E	C1S	861425	07/2010	05/12/2010	100.08	99.94	100.09	1
LG&E	C1S	861426	07/2010	05/12/2010	100.09	100.08	100.18	1
LG&E	C1S	861427	07/2010	05/12/2010	100.09	99.90	100.12	1
LG&E	C1S	861428	07/2010	05/12/2010	100.06	100.12	100.14	1
LG&E	C1S	861429	07/2010	05/12/2010	100.10	99.97	100.11	1
LG&E	C1S	861430	07/2010	05/12/2010	100.06	99.81	100.12	1
LG&E	C1S	861431	07/2010	05/12/2010	100.08	100.08	100.14	1
LG&E	C1S	861432	07/2010	05/12/2010	100.07	100.02	100.13	1
LG&E	C1S	861433	07/2010	05/12/2010	100.08	100.03	100.17	1
LG&E	C1S	861434	07/2010	05/12/2010	100.06	100.03	100.06	1
LG&E	C1S	861435	07/2010	05/12/2010	100.09	100.06	100.08	1
LG&E	C1S	861436	07/2010	05/12/2010	100.09	99.93	99.84	1
LG&E	C1S	861437	07/2010	05/12/2010	100.09	100.08	100.21	1
LG&E	C1S	861438	07/2010	05/12/2010	100.07	100.03	100.03	1
LG&E	C1S	861439	07/2010	05/12/2010	100.06	99.93	100.05	1
LG&E	C1S	861440	07/2010	05/12/2010	100.10	100.01	100.20	1
LG&E	C1S	861441	07/2010	05/12/2010	100.09	100.09	100.19	1
LG&E	C1S	861442	07/2010	05/12/2010	100.09	99.96	99.98	1
LG&E	C1S	861443	07/2010	05/12/2010	100.09	99.91	100.03	1
LG&E	C1S	861444	07/2010	05/12/2010	100.08	100.11	100.02	1
LG&E	C1S	861445	07/2010	05/12/2010	100.05	100.02	100.14	1
LG&E	C1S	861446	07/2010	05/12/2010	100.07	99.98	100.04	1
LG&E	C1S	861447	07/2010	05/12/2010	100.08	100.03	100.15	1
LG&E	C1S	861448	07/2010	05/12/2010	100.09	100.11	100.16	1
LG&E	C1S	861449	07/2010	05/12/2010	100.09	99.91	100.03	1
LG&E	C1S	861450	07/2010	05/12/2010	100.07	100.06	100.12	1
LG&E	C1S	861451	07/2010	05/12/2010	100.09	100.08	100.12	1
LG&E	C1S	861452	07/2010	05/12/2010	100.05	100.08	100.19	1

LG&E	CIS	861453	07/2010	05/12/2010	100.05	99.86	100.07	1
LG&E	CIS	861454	07/2010	05/12/2010	100.06	100.01	100.03	1
LG&E	CIS	861455	07/2010	05/12/2010	100.08	99.96	100.00	1
LG&E	CIS	861456	07/2010	05/12/2010	100.06	100.00	100.19	1
LG&E	CIS	861457	07/2010	05/12/2010	100.09	100.11	100.14	1
LG&E	CIS	861458	07/2010	05/12/2010	100.05	99.81	99.92	1
LG&E	CIS	861459	07/2010	05/12/2010	100.09	100.00	100.13	1
LG&E	CIS	861460	07/2010	05/12/2010	100.10	100.01	100.05	1
LG&E	CIS	861461	07/2010	05/12/2010	100.08	99.92	100.00	1
LG&E	CIS	861462	07/2010	05/12/2010	100.07	99.94	100.00	1
LG&E	CIS	861463	07/2010	05/12/2010	100.10	100.04	100.19	1
LG&E	CIS	861464	07/2010	05/12/2010	100.09	99.96	100.08	1
LG&E	CIS	861465	07/2010	05/12/2010	100.08	100.03	100.15	1
LG&E	CIS	861466	07/2010	05/12/2010	100.09	100.08	100.19	1
LG&E	CIS	861467	07/2010	05/12/2010	100.05	99.94	100.03	1
LG&E	CIS	861468	07/2010	05/12/2010	100.08	100.00	100.00	1
LG&E	CIS	861469	07/2010	05/12/2010	100.06	99.97	99.88	1
LG&E	CIS	861470	07/2010	05/12/2010	100.09	100.08	100.16	1
LG&E	CIS	861471	07/2010	05/12/2010	100.10	99.96	100.12	1
LG&E	CIS	861472	07/2010	05/12/2010	100.06	99.96	100.05	1
LG&E	CIS	861473	07/2010	05/12/2010	100.09	99.94	100.04	1
LG&E	CIS	861474	07/2010	05/12/2010	100.05	99.90	99.83	1
LG&E	CIS	861475	07/2010	05/12/2010	100.09	99.94	100.02	1
LG&E	CIS	861476	07/2010	05/12/2010	100.05	99.97	100.07	1
LG&E	CIS	861477	07/2010	05/12/2010	100.10	99.91	99.99	1
LG&E	CIS	861478	07/2010	05/12/2010	100.06	100.01	100.10	1
LG&E	CIS	861479	07/2010	05/12/2010	100.06	99.94	100.10	1
LG&E	CIS	861480	07/2010	05/12/2010	100.08	99.81	100.10	1
LG&E	CIS	861481	07/2010	05/12/2010	100.06	99.80	100.10	1
LG&E	CIS	861482	07/2010	05/12/2010	100.08	99.94	100.00	1
LG&E	CIS	861483	07/2010	05/12/2010	100.06	100.03	100.13	1
LG&E	CIS	861484	07/2010	05/12/2010	100.06	99.97	99.89	1
LG&E	CIS	861485	07/2010	05/12/2010	100.06	100.07	100.16	1
LG&E	CIS	861486	07/2010	05/12/2010	100.07	99.91	100.02	1
LG&E	CIS	861487	07/2010	05/12/2010	100.08	100.05	100.09	1
LG&E	CIS	861488	07/2010	05/12/2010	100.08	99.89	100.01	1

LG&E		C1S	861489	07/2010	12/2010	100.08	100.05	100.17	1
LG&E		C1S	861490	07/2010	05/12/2010	100.09	100.06	100.13	1
LG&E		C1S	861491	07/2010	05/12/2010	100.07	100.04	100.07	1
LG&E		C1S	861492	07/2010	05/12/2010	100.09	100.07	100.14	1
LG&E		C1S	861493	07/2010	05/12/2010	100.06	100.02	100.19	1
LG&E		C1S	861494	07/2010	05/12/2010	100.05	100.03	100.15	1
LG&E		C1S	861495	07/2010	05/12/2010	100.06	99.99	99.96	1
LG&E		C1S	861496	07/2010	05/12/2010	100.08	100.03	100.15	1
LG&E		C1S	861497	07/2010	05/12/2010	100.06	100.03	100.13	1
LG&E		C1S	861498	07/2010	05/12/2010	100.10	100.05	100.19	1
LG&E		C1S	861499	07/2010	05/12/2010	100.08	100.02	100.11	1
LG&E		C1S	861500	07/2010	05/12/2010	100.08	100.01	100.13	1
LG&E		C1S	861501	07/2010	05/12/2010	100.09	100.04	100.17	1
LG&E		C1S	861502	07/2010	05/12/2010	100.08	100.05	100.16	1
LG&E		C1S	861503	07/2010	05/12/2010	100.07	100.05	100.20	1
LG&E		C1S	863428	11/2010	09/23/2010	100.08	100.07	100.13	1
LG&E		C1S	863429	11/2010	09/23/2010	100.09	100.00	100.18	1
LG&E		C1S	863430	11/2010	09/23/2010	100.09	99.92	100.09	1
LG&E		C1S	863431	11/2010	09/23/2010	100.06	99.83	99.89	1
LG&E		C1S	863432	11/2010	09/23/2010	100.08	99.95	100.01	1
LG&E		C1S	863433	11/2010	09/23/2010	100.07	100.00	100.10	1
LG&E		C1S	863434	11/2010	09/23/2010	100.08	99.92	100.02	1
LG&E		C1S	863435	11/2010	09/23/2010	100.09	99.95	100.00	1
LG&E		C1S	863436	11/2010	09/23/2010	100.06	100.06	100.11	1
LG&E		C1S	863437	11/2010	09/23/2010	100.09	99.97	100.13	1
LG&E		C1S	863438	11/2010	09/23/2010	100.07	99.94	100.05	1
LG&E		C1S	863439	11/2010	09/23/2010	100.10	99.94	100.11	1
LG&E		C1S	863440	11/2010	09/23/2010	100.09	100.03	100.18	1
LG&E		C1S	863441	11/2010	09/23/2010	100.08	100.02	100.22	1
LG&E		C1S	863442	11/2010	09/23/2010	100.06	99.99	100.12	1
LG&E		C1S	863443	11/2010	09/23/2010	100.06	99.95	100.02	1
LG&E		C1S	863444	11/2010	09/23/2010	100.09	99.94	100.15	1
LG&E		C1S	863445	11/2010	09/23/2010	100.09	100.02	100.14	1
LG&E		C1S	863446	11/2010	09/23/2010	100.07	100.06	100.14	1
LG&E		C1S	863447	11/2010	09/23/2010	100.07	100.01	100.14	1
LG&E		C1S	863448	11/2010	09/23/2010	100.06	100.02	100.14	1

LG&E	CIS	863449	11/2010	09/23/2010	100.08	100.07	100.22	1
LG&E	CIS	863450	11/2010	09/23/2010	100.07	100.02	100.16	1
LG&E	CIS	863451	11/2010	09/23/2010	100.08	99.93	100.01	1
LG&E	CIS	863452	11/2010	09/23/2010	100.10	100.02	100.08	1
LG&E	CIS	863453	11/2010	09/23/2010	100.10	100.00	100.09	1
LG&E	CIS	863454	11/2010	09/23/2010	100.06	99.96	100.06	1
LG&E	CIS	863455	11/2010	09/23/2010	100.09	100.05	100.12	1
LG&E	CIS	863456	11/2010	09/23/2010	100.05	99.91	100.13	1
LG&E	CIS	863457	11/2010	09/23/2010	100.07	100.11	100.14	1
LG&E	CIS	863458	11/2010	09/23/2010	100.09	100.06	100.10	1
LG&E	CIS	863459	11/2010	09/23/2010	100.05	100.03	100.19	1
LG&E	CIS	863460	11/2010	09/23/2010	100.05	99.84	100.11	1
LG&E	CIS	863461	11/2010	09/23/2010	100.09	100.13	100.23	1
LG&E	CIS	863462	11/2010	09/23/2010	100.10	100.06	100.20	1
LG&E	CIS	863463	11/2010	09/23/2010	100.07	100.02	100.12	1
LG&E	CIS	863464	11/2010	09/23/2010	100.10	100.01	100.22	1
LG&E	CIS	863465	11/2010	09/23/2010	100.09	99.99	100.10	1
LG&E	CIS	863466	11/2010	09/23/2010	100.08	99.98	100.04	1
LG&E	CIS	863467	11/2010	09/23/2010	100.09	99.93	99.98	1
LG&E	CIS	863468	11/2010	09/23/2010	100.09	99.90	100.02	1
LG&E	CIS	863469	11/2010	09/23/2010	100.06	99.95	100.00	1
LG&E	CIS	863470	11/2010	09/23/2010	100.10	99.97	100.08	1
LG&E	CIS	863471	11/2010	09/23/2010	100.08	100.03	100.19	1
LG&E	CIS	863472	11/2010	09/23/2010	100.09	99.96	100.02	1
LG&E	CIS	863473	11/2010	09/23/2010	100.07	99.95	100.11	1
LG&E	CIS	863474	11/2010	09/23/2010	100.09	99.97	100.08	1
LG&E	CIS	863475	11/2010	09/23/2010	100.05	99.94	100.07	1
LG&E	CIS	863476	11/2010	09/23/2010	100.08	99.99	100.08	1
LG&E	CIS	863477	11/2010	09/23/2010	100.09	99.95	100.14	1
LG&E	CIS	863478	11/2010	09/23/2010	100.09	99.99	100.08	1
LG&E	CIS	863479	11/2010	09/23/2010	100.08	100.01	100.08	1
LG&E	CIS	863480	11/2010	09/23/2010	100.10	100.03	100.24	1
LG&E	CIS	863481	11/2010	09/23/2010	100.07	99.83	100.03	1
LG&E	CIS	863482	11/2010	09/23/2010	100.06	100.06	100.13	1
LG&E	CIS	863483	11/2010	09/23/2010	100.10	99.99	100.01	1
LG&E	CIS	863484	11/2010	09/23/2010	100.08	99.97	100.05	1



LG&E		C1S	863485	11/2010	23/2010	100.08	100.00	100.05	1
LG&E		C1S	863486	11/2010	09/23/2010	100.10	99.98	100.14	1
LG&E		C1S	863487	11/2010	09/23/2010	100.08	99.93	100.06	1
LG&E		C1S	863488	11/2010	09/23/2010	100.07	99.99	100.02	1
LG&E		C1S	863489	11/2010	09/23/2010	100.09	99.99	100.17	1
LG&E		C1S	863490	11/2010	09/23/2010	100.06	99.97	100.11	1
LG&E		C1S	863491	11/2010	09/23/2010	100.06	99.95	100.09	1
LG&E		C1S	863492	11/2010	09/23/2010	100.09	99.99	100.09	1
LG&E		C1S	863493	11/2010	09/23/2010	100.09	99.94	100.14	1
LG&E		C1S	863494	11/2010	09/23/2010	100.07	99.98	99.99	1
LG&E		C1S	863495	11/2010	09/23/2010	100.07	99.86	100.05	1
LG&E		C1S	863496	11/2010	09/23/2010	100.06	99.98	100.03	1
LG&E		C1S	863497	11/2010	09/23/2010	100.09	99.93	100.06	1
LG&E		C1S	863498	11/2010	09/23/2010	100.10	100.01	100.05	1
LG&E		C1S	863499	11/2010	09/23/2010	100.08	100.03	100.17	1
LG&E		C1S	863500	11/2010	09/23/2010	100.09	100.05	100.04	1
LG&E		C1S	863501	11/2010	09/23/2010	100.06	99.94	100.07	1
LG&E		C1S	863502	11/2010	09/23/2010	100.06	100.04	100.03	1
LG&E		C1S	863503	11/2010	09/23/2010	100.05	99.97	100.20	1
LG&E		C1S	863504	11/2010	09/23/2010	100.10	100.11	100.11	1
LG&E		C1S	863505	11/2010	09/23/2010	100.09	100.06	100.15	1
LG&E		C1S	863506	11/2010	09/23/2010	100.08	99.98	100.02	1
LG&E		C1S	863507	11/2010	09/23/2010	100.09	100.08	100.24	1
LG&E		C1S	863508	11/2010	09/23/2010	100.08	99.89	99.99	1
LG&E		C1S	863509	11/2010	09/23/2010	100.06	100.00	100.14	1
LG&E		C1S	863510	11/2010	09/23/2010	100.08	99.92	100.02	1
LG&E		C1S	863511	11/2010	09/23/2010	100.06	99.96	100.13	1
LG&E		C1S	863512	11/2010	09/23/2010	100.10	100.02	100.09	1
LG&E		C1S	863513	11/2010	09/23/2010	100.06	100.00	100.10	1
LG&E		C1S	863514	11/2010	09/23/2010	100.08	100.03	100.18	1
LG&E		C1S	863515	11/2010	09/23/2010	100.06	99.97	100.15	1
LG&E		C1S	863516	11/2010	09/23/2010	100.06	100.16	100.14	1
LG&E		C1S	863517	11/2010	09/23/2010	100.05	100.08	100.18	1
LG&E		C1S	863518	11/2010	09/23/2010	100.07	100.04	100.22	1
LG&E		C1S	863519	11/2010	09/23/2010	100.06	99.97	100.12	1
LG&E		C1S	863520	11/2010	09/23/2010	100.07	100.00	100.08	1

LG&E	CIS	863521	11/2010	09/23/2010	100.08	100.08	100.08	100.16	1
LG&E	CIS	863522	11/2010	09/23/2010	100.08	100.07	100.07	100.21	1
LG&E	CIS	863523	11/2010	09/23/2010	100.09	100.03	100.03	100.25	1
LG&E	CIS	863524	11/2010	09/23/2010	100.06	100.06	100.06	100.16	1
LG&E	CIS	863525	11/2010	09/23/2010	100.06	99.97	100.13		1
LG&E	CIS	863526	11/2010	09/23/2010	100.06	100.01	100.18		1
LG&E	CIS	863527	11/2010	09/23/2010	100.09	100.05	100.14		1
LG&E	CIS	863528	11/2010	09/23/2010	100.06	100.04	99.95		1
LG&E	CIS	863529	11/2010	09/23/2010	100.08	99.91	100.03		1
LG&E	CIS	863530	11/2010	09/23/2010	100.10	100.17	100.19		1
LG&E	CIS	863531	11/2010	09/23/2010	100.09	99.96	100.08		1
LG&E	CIS	863532	11/2010	09/23/2010	100.10	100.08	100.18		1
LG&E	CIS	863533	11/2010	09/23/2010	100.08	99.85	100.06		1
LG&E	CIS	863534	11/2010	09/23/2010	100.08	100.04	100.09		1
LG&E	CIS	863535	11/2010	09/23/2010	100.09	99.98	100.14		1
LG&E	CIS	863536	11/2010	09/23/2010	100.05	100.04	100.11		1
LG&E	CIS	863537	11/2010	09/23/2010	100.08	100.00	100.19		1
LG&E	CIS	863538	11/2010	09/23/2010	100.08	99.92	100.09		1
LG&E	CIS	863539	11/2010	09/23/2010	100.07	99.92	100.03		1
LG&E	CIS	863540	11/2010	09/23/2010	100.09	99.97	100.14		1
LG&E	CIS	863541	11/2010	09/23/2010	100.10	99.97	100.09		1
LG&E	CIS	863542	11/2010	09/23/2010	100.09	99.97	100.12		1
LG&E	CIS	863543	11/2010	09/23/2010	100.10	100.00	100.01		1
LG&E	CIS	863544	11/2010	09/23/2010	100.06	99.96	100.00		1
LG&E	CIS	863545	11/2010	09/23/2010	100.09	99.95	100.08		1
LG&E	CIS	863546	11/2010	09/23/2010	100.09	99.95	100.10		1
LG&E	CIS	863547	11/2010	09/23/2010	100.07	99.90	100.13		1
LG&E	CIS	863548	11/2010	09/23/2010	100.09	100.00	100.08		1
LG&E	CIS	863549	11/2010	09/23/2010	100.09	99.99	100.08		1
LG&E	CIS	863550	11/2010	09/23/2010	100.10	100.03	100.13		1
LG&E	CIS	863551	11/2010	09/23/2010	100.09	100.06	100.24		1
LG&E	CIS	863552	11/2010	09/23/2010	100.09	99.98	100.00		1
LG&E	CIS	863553	11/2010	09/23/2010	100.07	99.97	100.07		1
LG&E	CIS	863554	11/2010	09/23/2010	100.07	100.04	100.03		1
LG&E	CIS	863555	11/2010	09/23/2010	100.08	99.91	99.99		1
LG&E	CIS	863556	11/2010	09/23/2010	100.06	100.05	100.01		1

LG&E	C1S	863557	11/2010	23/2010	100.05	100.01	100.19	1
LG&E	C1S	863558	11/2010	09/23/2010	100.08	100.09	100.15	1
LG&E	C1S	863559	11/2010	09/23/2010	100.08	100.08	100.23	1
LG&E	C1S	863560	11/2010	09/23/2010	100.08	100.07	100.19	1
LG&E	C1S	863561	11/2010	09/23/2010	100.06	99.99	100.27	1
LG&E	C1S	863562	11/2010	09/23/2010	100.09	99.91	100.05	1
LG&E	C1S	863563	11/2010	09/23/2010	100.07	99.98	100.27	1
LG&E	C1S	863564	11/2010	09/23/2010	100.10	100.07	100.26	1
LG&E	C1S	863565	11/2010	09/23/2010	100.08	100.04	100.12	1
LG&E	C1S	863566	11/2010	09/23/2010	100.08	100.01	100.19	1
LG&E	C1S	863567	11/2010	09/23/2010	100.06	99.95	100.02	1
LG&E	C1S	863568	11/2010	09/23/2010	100.07	100.03	100.10	1
LG&E	C1S	863569	11/2010	09/23/2010	100.09	100.10	100.17	1
LG&E	C1S	863570	11/2010	09/23/2010	100.08	99.97	99.97	1
LG&E	C1S	863571	11/2010	09/23/2010	100.07	100.06	100.23	1
LG&E	C1S	863572	11/2010	09/23/2010	100.05	99.98	99.96	1
LG&E	C1S	863573	11/2010	09/23/2010	100.09	99.95	99.99	1
LG&E	C1S	863574	11/2010	09/23/2010	100.10	100.02	100.12	1
LG&E	C1S	863575	11/2010	09/23/2010	100.07	99.94	100.00	1
LG&E	C1S	863576	11/2010	09/23/2010	100.07	99.91	99.93	1
LG&E	C1S	863577	11/2010	09/23/2010	100.09	100.01	100.27	1
LG&E	C1S	863578	11/2010	09/23/2010	100.10	99.92	100.08	1
LG&E	C1S	863579	11/2010	09/23/2010	100.10	100.03	100.05	1
LG&E	C1S	863580	11/2010	09/23/2010	100.10	100.04	100.11	1
LG&E	C1S	863581	11/2010	09/23/2010	100.09	99.97	100.10	1
LG&E	C1S	863582	11/2010	09/23/2010	100.06	100.07	100.10	1
LG&E	C1S	863583	11/2010	09/23/2010	100.06	99.95	99.98	1
LG&E	C1S	863584	11/2010	09/23/2010	100.09	100.09	100.18	1
LG&E	C1S	863585	11/2010	09/23/2010	100.08	100.06	100.18	1
LG&E	C1S	863586	11/2010	09/23/2010	100.06	100.03	100.21	1
LG&E	C1S	863587	11/2010	09/23/2010	100.08	100.02	100.17	1
LG&E	C1S	863588	11/2010	09/23/2010	100.07	100.07	100.19	1
LG&E	C1S	863589	11/2010	09/23/2010	100.06	99.94	100.01	1
LG&E	C1S	863590	11/2010	09/23/2010	100.09	99.92	100.16	1
LG&E	C1S	863591	11/2010	09/23/2010	100.06	100.05	100.19	1
LG&E	C1S	863592	11/2010	09/23/2010	100.06	99.99	100.12	1

LG&E	CIS	863593	11/2010	09/23/2010	100.10	99.99	100.01	1
LG&E	CIS	863594	11/2010	09/23/2010	100.07	99.97	100.25	1
LG&E	CIS	863595	11/2010	09/23/2010	100.07	100.08	100.20	1
LG&E	CIS	863596	11/2010	09/23/2010	100.08	100.07	100.12	1
LG&E	CIS	863597	11/2010	09/23/2010	100.10	100.11	100.24	1
LG&E	CIS	863598	11/2010	09/23/2010	100.09	100.07	100.12	1
LG&E	CIS	863599	11/2010	09/23/2010	100.10	100.15	100.27	1
LG&E	CIS	863600	11/2010	09/23/2010	100.06	100.02	100.11	1
LG&E	CIS	863601	11/2010	09/23/2010	100.06	100.05	99.99	1
LG&E	CIS	863602	11/2010	09/23/2010	100.05	100.03	100.24	1
LG&E	CIS	863603	11/2010	09/23/2010	100.05	99.97	100.17	1
LG&E	CIS	863604	11/2010	09/23/2010	100.09	100.03	100.26	1
LG&E	CIS	863605	11/2010	09/23/2010	100.06	99.95	100.07	1
LG&E	CIS	863606	11/2010	09/23/2010	100.09	100.08	100.23	1
LG&E	CIS	863607	11/2010	09/23/2010	100.07	100.01	100.17	1
LG&E	CIS	863608	11/2010	09/23/2010	100.08	100.03	100.18	1
LG&E	CIS	863609	11/2010	09/23/2010	100.07	100.01	100.19	1
LG&E	CIS	863610	11/2010	09/23/2010	100.10	100.00	100.19	1
LG&E	CIS	863611	11/2010	09/23/2010	100.07	100.06	100.27	1
LG&E	CIS	863612	11/2010	09/23/2010	100.09	100.01	100.18	1
LG&E	CIS	863613	11/2010	09/23/2010	100.10	100.01	100.10	1
LG&E	CIS	863614	11/2010	09/23/2010	100.06	100.01	100.16	1
LG&E	CIS	863615	11/2010	09/23/2010	100.08	100.14	100.20	1
LG&E	CIS	863616	11/2010	09/23/2010	100.06	99.90	100.06	1
LG&E	CIS	863617	11/2010	09/23/2010	100.08	100.03	100.18	1
LG&E	CIS	863618	11/2010	09/23/2010	100.06	100.03	100.11	1
LG&E	CIS	863619	11/2010	09/23/2010	100.10	100.01	100.16	1
LG&E	CIS	863620	11/2010	09/23/2010	100.06	100.05	100.27	1
LG&E	CIS	863621	11/2010	09/23/2010	100.06	100.01	100.13	1
LG&E	CIS	863622	11/2010	09/23/2010	100.06	100.05	100.21	1
LG&E	CIS	863623	11/2010	09/23/2010	100.06	100.02	100.10	1
LG&E	CIS	863624	11/2010	09/23/2010	100.07	100.00	100.02	1
LG&E	CIS	863625	11/2010	09/23/2010	100.06	100.06	100.14	1
LG&E	CIS	863626	11/2010	09/23/2010	100.09	100.01	100.13	1
LG&E	CIS	863627	11/2010	09/23/2010	100.06	100.04	100.25	1
LG&E	CIS	863628	11/2010	09/23/2010	100.08	99.96	100.06	1

LG&E	C1S	863629	11/2010	09/23/2010	100.09	100.03	99.99	1
LG&E	C1S	863630	11/2010	09/23/2010	100.08	99.95	100.06	1
LG&E	C1S	863631	11/2010	09/23/2010	100.09	99.97	100.06	1
LG&E	C1S	863632	11/2010	09/23/2010	100.07	100.05	100.08	1
LG&E	C1S	863633	11/2010	09/23/2010	100.06	99.93	100.06	1
LG&E	C1S	863634	11/2010	09/23/2010	100.07	99.97	100.07	1
LG&E	C1S	863635	11/2010	09/23/2010	100.10	99.90	100.11	1
LG&E	C1S	863636	11/2010	09/23/2010	100.09	100.07	100.04	1
LG&E	C1S	863637	11/2010	09/23/2010	100.09	100.06	100.16	1
LG&E	C1S	863638	11/2010	09/23/2010	100.10	100.01	100.09	1
LG&E	C1S	863639	11/2010	09/23/2010	100.07	99.89	100.03	1
LG&E	C1S	863640	11/2010	09/23/2010	100.06	99.92	100.05	1
LG&E	C1S	863641	11/2010	09/23/2010	100.07	99.95	100.03	1
LG&E	C1S	863642	11/2010	09/23/2010	100.06	99.91	100.01	1
LG&E	C1S	863643	11/2010	09/23/2010	100.06	99.89	100.03	1
LG&E	C1S	863644	11/2010	09/23/2010	100.09	100.07	100.13	1
LG&E	C1S	863645	11/2010	09/23/2010	100.09	100.08	100.11	1
LG&E	C1S	863646	11/2010	09/23/2010	100.07	99.89	99.97	1
LG&E	C1S	863647	11/2010	09/23/2010	100.09	99.89	99.98	1
LG&E	C1S	863648	11/2010	09/23/2010	100.06	99.97	100.08	1
LG&E	C1S	863649	11/2010	09/23/2010	100.05	99.97	100.03	1
LG&E	C1S	863650	11/2010	09/23/2010	100.08	100.05	100.14	1
LG&E	C1S	863651	11/2010	09/23/2010	100.06	99.94	100.09	1
LG&E	C1S	863652	11/2010	09/23/2010	100.06	99.88	100.16	1
LG&E	C1S	863653	11/2010	09/23/2010	100.10	100.04	100.26	1
LG&E	C1S	863654	11/2010	09/23/2010	100.09	100.09	100.12	1
LG&E	C1S	863655	11/2010	09/23/2010	100.05	99.98	100.08	1
LG&E	C1S	863656	11/2010	09/23/2010	100.08	100.06	100.04	1
LG&E	C1S	863657	11/2010	09/23/2010	100.06	100.03	100.17	1
LG&E	C1S	863658	11/2010	09/23/2010	100.06	99.92	100.04	1
LG&E	C1S	863659	11/2010	09/23/2010	100.10	99.94	100.08	1
LG&E	C1S	863660	11/2010	09/23/2010	100.06	99.98	100.01	1
LG&E	C1S	863661	11/2010	09/23/2010	100.06	100.11	100.19	1
LG&E	C1S	863662	11/2010	09/23/2010	100.10	99.99	100.07	1
LG&E	C1S	863663	11/2010	09/23/2010	100.08	100.04	100.24	1
LG&E	C1S	863664	11/2010	09/23/2010	100.05	99.89	99.97	1

LG&E	C1S	863665	11/2010	09/23/2010	100.08	100.11	100.21	1
LG&E	C1S	863666	11/2010	09/23/2010	100.07	100.06	100.19	1
LG&E	C1S	863667	11/2010	09/23/2010	100.10	100.04	100.19	1
LG&E	C1S	863668	11/2010	09/23/2010	100.10	100.05	100.20	1
LG&E	C1S	863669	11/2010	09/23/2010	100.09	100.04	100.14	1
LG&E	C1S	863670	11/2010	09/23/2010	100.07	100.09	100.10	1
LG&E	C1S	863671	11/2010	09/23/2010	100.06	99.90	100.03	1
LG&E	C1S	863672	11/2010	09/23/2010	100.07	100.01	100.06	1
LG&E	C1S	863673	11/2010	09/23/2010	100.07	99.93	100.00	1
LG&E	C1S	863674	11/2010	09/23/2010	100.08	99.86	100.11	1
LG&E	C1S	863675	11/2010	09/23/2010	100.06	100.03	100.14	1
LG&E	C1S	863676	11/2010	09/23/2010	100.10	100.09	100.20	1
LG&E	C1S	863677	11/2010	09/23/2010	100.06	99.91	100.08	1
LG&E	C1S	863678	11/2010	09/23/2010	100.10	99.95	100.06	1
LG&E	C1S	863679	11/2010	09/23/2010	100.06	99.94	100.02	1
LG&E	C1S	863680	11/2010	09/23/2010	100.07	99.93	100.17	1
LG&E	C1S	863681	11/2010	09/23/2010	100.10	100.06	100.22	1
LG&E	C1S	863682	11/2010	09/23/2010	100.06	100.03	100.04	1
LG&E	C1S	863683	11/2010	09/23/2010	100.06	99.91	100.04	1
LG&E	C1S	863684	11/2010	09/23/2010	100.09	100.09	100.20	1
LG&E	C1S	863685	11/2010	09/23/2010	100.09	100.02	100.14	1
LG&E	C1S	863686	11/2010	09/23/2010	100.08	100.03	100.08	1
LG&E	C1S	863687	11/2010	09/23/2010	100.06	100.03	100.11	1
LG&E	C1S	863688	11/2010	09/23/2010	100.07	99.90	100.05	1
LG&E	C1S	863689	11/2010	09/23/2010	100.10	99.98	100.08	1
LG&E	C1S	863690	11/2010	09/23/2010	100.09	99.99	100.09	1
LG&E	C1S	863691	11/2010	09/23/2010	100.10	99.96	100.05	1
LG&E	C1S	863692	11/2010	09/23/2010	100.07	100.06	100.15	1
LG&E	C1S	863693	11/2010	09/23/2010	100.06	99.98	100.06	1
LG&E	C1S	863694	11/2010	09/23/2010	100.06	99.89	100.01	1
LG&E	C1S	863695	11/2010	09/23/2010	100.07	100.05	100.15	1
LG&E	C1S	863696	11/2010	09/23/2010	100.10	100.01	100.02	1
LG&E	C1S	863697	11/2010	09/23/2010	100.07	100.07	100.13	1
LG&E	C1S	863698	11/2010	09/23/2010	100.07	99.94	100.09	1
LG&E	C1S	863699	11/2010	09/23/2010	100.06	100.02	100.21	1
LG&E	C1S	863700	11/2010	09/23/2010	100.08	99.99	100.01	1

LG&E	C1S	863701	11/2010	09/23/2010	100.07	99.92	100.01	1
LG&E	C1S	863702	11/2010	09/23/2010	100.06	100.07	100.14	1
LG&E	C1S	863703	11/2010	09/23/2010	100.06	99.94	100.06	1
LG&E	C1S	863704	11/2010	09/23/2010	100.09	99.90	100.08	1
LG&E	C1S	863705	11/2010	09/23/2010	100.07	99.98	100.03	1
LG&E	C1S	863706	11/2010	09/23/2010	100.06	100.00	100.16	1
LG&E	C1S	863707	11/2010	09/23/2010	100.10	100.01	100.05	1
LG&E	C1S	863708	11/2010	09/23/2010	100.06	100.03	100.10	1
LG&E	C1S	863709	11/2010	09/23/2010	100.06	100.04	100.12	1
LG&E	C1S	863710	11/2010	09/23/2010	100.07	100.08	100.14	1
LG&E	C1S	863711	11/2010	09/23/2010	100.09	99.99	100.00	1
LG&E	C1S	863712	11/2010	09/23/2010	100.09	99.91	100.06	1
LG&E	C1S	863713	11/2010	09/23/2010	100.10	100.08	100.07	1
LG&E	C1S	863714	11/2010	09/23/2010	100.06	99.90	100.01	1
LG&E	C1S	863715	11/2010	09/23/2010	100.08	99.93	100.07	1
LG&E	C1S	863716	11/2010	09/23/2010	100.09	100.02	100.12	1
LG&E	C1S	863717	11/2010	09/23/2010	100.07	99.91	100.08	1
LG&E	C1S	863718	11/2010	09/23/2010	100.10	99.94	100.13	1
LG&E	C1S	863719	11/2010	09/23/2010	100.08	99.98	100.09	1
LG&E	C1S	863720	11/2010	09/23/2010	100.08	100.03	100.06	1
LG&E	C1S	863721	11/2010	09/23/2010	100.07	99.93	100.11	1
LG&E	C1S	863722	11/2010	09/23/2010	100.10	99.98	100.02	1
LG&E	C1S	863723	11/2010	09/23/2010	100.09	99.97	100.07	1
LG&E	C1S	863724	11/2010	09/23/2010	100.06	99.90	100.06	1
LG&E	C1S	863725	11/2010	09/23/2010	100.07	100.05	99.96	1
LG&E	C1S	863726	11/2010	09/23/2010	100.08	100.02	99.96	1
LG&E	C1S	863727	11/2010	09/23/2010	100.07	99.98	100.23	1
LG&E	C1S	863728	11/2010	09/23/2010	100.05	99.98	100.02	1
LG&E	C1S	863729	11/2010	09/23/2010	100.08	100.06	100.16	1
LG&E	C1S	863730	11/2010	09/23/2010	100.06	99.87	99.97	1
LG&E	C1S	863731	11/2010	09/23/2010	100.09	99.87	100.00	1
LG&E	C1S	863732	11/2010	09/23/2010	100.06	99.92	100.01	1
LG&E	C1S	863733	11/2010	09/23/2010	100.09	100.04	100.00	1
LG&E	C1S	863734	11/2010	09/23/2010	100.09	99.99	100.00	1
LG&E	C1S	863735	11/2010	09/23/2010	100.10	100.13	100.19	1
LG&E	C1S	863736	11/2010	09/23/2010	100.06	100.04	100.09	1

LG&E	CIS	863737	11/2010	23/2010	100.06	100.01	100.14	1
LG&E	CIS	863738	11/2010	09/23/2010	100.10	99.97	100.09	1
LG&E	CIS	863739	11/2010	09/23/2010	100.10	100.04	100.19	1
LG&E	CIS	863740	11/2010	09/23/2010	100.10	100.03	100.10	1
LG&E	CIS	863741	11/2010	09/23/2010	100.07	100.02	100.00	1
LG&E	CIS	863742	11/2010	09/23/2010	100.10	99.93	99.98	1
LG&E	CIS	863743	11/2010	09/23/2010	100.07	99.91	100.02	1
LG&E	CIS	863744	11/2010	09/23/2010	100.07	100.00	100.15	1
LG&E	CIS	863745	11/2010	09/23/2010	100.10	99.95	100.09	1
LG&E	CIS	863746	11/2010	09/23/2010	100.08	100.05	100.18	1
LG&E	CIS	863747	11/2010	09/23/2010	100.08	99.97	100.00	1
LG&E	CIS	863748	11/2010	09/23/2010	100.09	99.99	100.05	1
LG&E	CIS	863749	11/2010	09/23/2010	100.07	99.96	100.08	1
LG&E	CIS	863750	11/2010	09/23/2010	100.06	100.00	100.14	1
LG&E	CIS	863751	11/2010	09/23/2010	100.09	100.00	100.03	1
LG&E	CIS	863752	11/2010	09/23/2010	100.06	100.05	100.10	1
LG&E	CIS	863753	11/2010	09/23/2010	100.07	100.05	100.11	1
LG&E	CIS	863754	11/2010	09/23/2010	100.08	99.89	100.04	1
LG&E	CIS	863755	11/2010	09/23/2010	100.06	99.89	99.96	1
LG&E	CIS	863756	11/2010	09/23/2010	100.09	100.04	100.07	1
LG&E	CIS	863757	11/2010	09/23/2010	100.09	100.04	100.05	1
LG&E	CIS	863758	11/2010	09/23/2010	100.06	100.02	100.11	1
LG&E	CIS	863759	11/2010	09/23/2010	100.08	99.96	100.03	1
LG&E	CIS	863760	11/2010	09/23/2010	100.06	99.95	100.03	1
LG&E	CIS	863761	11/2010	09/23/2010	100.09	99.98	100.08	1
LG&E	CIS	863762	11/2010	09/23/2010	100.10	100.07	100.19	1
LG&E	CIS	863763	11/2010	09/23/2010	100.08	99.91	100.12	1
LG&E	CIS	863764	11/2010	09/23/2010	100.08	99.91	100.09	1
LG&E	CIS	863765	11/2010	09/23/2010	100.09	99.96	100.06	1
LG&E	CIS	863766	11/2010	09/23/2010	100.08	100.05	100.12	1
LG&E	CIS	863767	11/2010	09/23/2010	100.08	99.93	100.06	1
LG&E	CIS	863768	11/2010	09/23/2010	100.10	100.02	100.17	1
LG&E	CIS	863769	11/2010	09/23/2010	100.09	100.12	100.23	1
LG&E	CIS	863770	11/2010	09/23/2010	100.08	100.02	100.18	1
LG&E	CIS	863771	11/2010	09/23/2010	100.10	99.81	100.03	1
LG&E	CIS	863772	11/2010	09/23/2010	100.08	100.09	100.12	1



LG&E	C1S	863773	11/2010	09/23/2010	100.09	99.92	100.14	1
LG&E	C1S	863774	11/2010	09/23/2010	100.06	100.02	100.12	1
LG&E	C1S	863775	11/2010	09/23/2010	100.08	99.97	100.10	1
LG&E	C1S	863776	11/2010	09/23/2010	100.11	99.99	100.12	1
LG&E	C1S	863777	11/2010	09/23/2010	100.06	100.13	100.15	1
LG&E	C1S	863778	11/2010	09/23/2010	100.08	99.89	100.07	1
LG&E	C1S	863779	11/2010	09/23/2010	100.10	99.93	100.11	1
LG&E	C1S	863780	11/2010	09/23/2010	100.08	99.89	100.08	1
LG&E	C1S	863781	11/2010	09/23/2010	100.11	100.08	100.14	1
LG&E	C1S	863782	11/2010	09/23/2010	100.10	100.00	100.20	1
LG&E	C1S	863783	11/2010	09/23/2010	100.09	99.97	100.07	1
LG&E	C1S	863784	11/2010	09/23/2010	100.10	100.08	100.11	1
LG&E	C1S	863785	11/2010	09/23/2010	100.10	100.05	99.99	1
LG&E	C1S	863786	11/2010	09/23/2010	100.06	100.04	100.09	1
LG&E	C1S	863787	11/2010	09/23/2010	100.09	100.02	100.03	1
LG&E	C1S	863788	11/2010	09/23/2010	100.06	99.99	100.05	1
LG&E	C1S	863789	11/2010	09/23/2010	100.07	99.97	99.99	1
LG&E	C1S	863790	11/2010	09/23/2010	100.05	100.04	100.20	1
LG&E	C1S	863791	11/2010	09/23/2010	100.08	100.01	100.05	1
LG&E	C1S	863792	11/2010	09/23/2010	100.06	99.97	99.95	1
LG&E	C1S	863793	11/2010	09/23/2010	100.07	100.00	100.16	1
LG&E	C1S	863794	11/2010	09/23/2010	100.09	100.01	100.18	1
LG&E	C1S	863795	11/2010	09/23/2010	100.07	99.99	99.97	1
LG&E	C1S	863796	11/2010	09/23/2010	100.09	100.07	100.23	1
LG&E	C1S	863797	11/2010	09/23/2010	100.09	100.09	100.16	1
LG&E	C1S	863798	11/2010	09/23/2010	100.06	100.03	100.13	1
LG&E	C1S	863799	11/2010	09/23/2010	100.06	100.02	100.13	1
LG&E	C1S	863800	11/2010	09/23/2010	100.09	100.08	100.20	1
LG&E	C1S	863801	11/2010	09/23/2010	100.06	100.03	100.16	1
LG&E	C1S	863802	11/2010	09/23/2010	100.09	99.92	100.15	1
LG&E	C1S	863803	11/2010	09/23/2010	100.08	99.98	99.91	1
LG&E	C1S	863804	11/2010	09/23/2010	100.09	99.92	100.00	1
LG&E	C1S	863805	11/2010	09/23/2010	100.05	99.99	100.14	1
LG&E	C1S	863806	11/2010	09/23/2010	100.08	99.85	100.06	1
LG&E	C1S	863807	11/2010	09/23/2010	100.06	100.06	100.24	1
LG&E	C1S	863808	11/2010	09/23/2010	100.10	100.01	100.18	1

LG&E	CIS	863809	11/2010	09/23/2010	100.08	100.06	100.08	1
LG&E	CIS	863810	11/2010	09/23/2010	100.08	99.99	99.98	1
LG&E	CIS	863811	11/2010	09/23/2010	100.08	100.03	100.19	1
LG&E	CIS	863812	11/2010	09/23/2010	100.09	100.04	99.94	1
LG&E	CIS	863813	11/2010	09/23/2010	100.08	100.00	100.07	1
LG&E	CIS	863814	11/2010	09/23/2010	100.11	100.04	100.17	1
LG&E	CIS	863815	11/2010	09/23/2010	100.05	99.95	100.04	1
LG&E	CIS	863816	11/2010	09/23/2010	100.06	100.00	100.18	1
LG&E	CIS	863817	11/2010	09/23/2010	100.09	99.97	100.10	1
LG&E	CIS	863818	11/2010	09/23/2010	100.06	100.04	100.18	1
LG&E	CIS	863819	11/2010	09/23/2010	100.09	100.06	100.21	1
LG&E	CIS	863820	11/2010	09/23/2010	100.07	100.03	100.02	1
LG&E	CIS	863821	11/2010	09/23/2010	100.06	100.03	100.02	1
LG&E	CIS	863822	11/2010	09/23/2010	100.10	99.94	100.06	1
LG&E	CIS	863823	11/2010	09/23/2010	100.06	100.06	100.14	1
LG&E	CIS	863824	11/2010	09/23/2010	100.06	99.90	100.11	1
LG&E	CIS	863825	11/2010	09/23/2010	100.08	100.03	99.97	1
LG&E	CIS	863826	11/2010	09/23/2010	100.09	100.08	100.27	1
LG&E	CIS	863827	11/2010	09/23/2010	100.09	99.98	100.11	1
LG&E	CIS	863828	11/2010	09/23/2010	100.06	99.96	100.01	1
LG&E	CIS	863829	11/2010	09/23/2010	100.09	100.04	100.08	1
LG&E	CIS	863830	11/2010	09/23/2010	100.06	99.92	100.06	1
LG&E	CIS	863831	11/2010	09/23/2010	100.09	99.86	100.03	1
LG&E	CIS	863832	11/2010	09/23/2010	100.10	99.99	100.08	1
LG&E	CIS	863833	11/2010	09/23/2010	100.07	99.97	99.98	1
LG&E	CIS	863834	11/2010	09/23/2010	100.08	99.90	99.97	1
LG&E	CIS	863835	11/2010	09/23/2010	100.08	100.06	100.18	1
LG&E	CIS	863836	11/2010	09/23/2010	100.08	99.93	100.04	1
LG&E	CIS	863837	11/2010	09/23/2010	100.10	100.02	99.97	1
LG&E	CIS	863838	11/2010	09/23/2010	100.08	100.01	100.12	1
LG&E	CIS	863839	11/2010	09/23/2010	100.08	99.92	100.14	1
LG&E	CIS	863840	11/2010	09/23/2010	100.08	99.87	100.00	1
LG&E	CIS	863841	11/2010	09/23/2010	100.06	99.96	99.97	1
LG&E	CIS	863842	11/2010	09/23/2010	100.06	99.96	100.02	1
LG&E	CIS	863843	11/2010	09/23/2010	100.05	100.04	100.09	1
LG&E	CIS	863844	11/2010	09/23/2010	100.09	99.99	100.19	1

LG&E	C1S	863845	11/2010	03/2010	100.09	99.95	100.14	1
LG&E	C1S	863846	11/2010	09/23/2010	100.08	100.06	100.16	1
LG&E	C1S	863847	11/2010	09/23/2010	100.09	100.12	100.20	1
LG&E	C1S	863848	11/2010	09/23/2010	100.08	99.96	100.03	1
LG&E	C1S	863849	11/2010	09/23/2010	100.06	100.07	100.03	1
LG&E	C1S	863850	11/2010	09/23/2010	100.10	99.95	100.11	1
LG&E	C1S	863851	11/2010	09/23/2010	100.10	100.06	100.21	1
LG&E	C1S	863852	11/2010	09/23/2010	100.08	99.87	100.04	1
LG&E	C1S	863853	11/2010	09/23/2010	100.06	99.87	99.94	1
LG&E	C1S	863854	11/2010	09/23/2010	100.06	100.01	100.14	1
LG&E	C1S	863855	11/2010	09/23/2010	100.08	100.08	100.19	1
LG&E	C1S	863856	11/2010	09/23/2010	100.09	100.12	100.18	1
LG&E	C1S	863857	11/2010	09/23/2010	100.06	100.00	100.05	1
LG&E	C1S	863858	11/2010	09/23/2010	100.09	99.92	100.12	1
LG&E	C1S	863859	11/2010	09/23/2010	100.06	99.83	99.96	1
LG&E	C1S	863860	11/2010	09/23/2010	100.07	99.97	100.06	1
LG&E	C1S	863861	11/2010	09/23/2010	100.09	100.17	100.22	1
LG&E	C1S	863862	11/2010	09/23/2010	100.06	99.99	100.12	1
LG&E	C1S	863863	11/2010	09/23/2010	100.08	100.02	99.97	1
LG&E	C1S	863864	11/2010	09/23/2010	100.09	100.09	100.16	1
LG&E	C1S	863865	11/2010	09/23/2010	100.07	100.03	100.14	1
LG&E	C1S	863866	11/2010	09/23/2010	100.09	99.97	100.05	1
LG&E	C1S	863867	11/2010	09/23/2010	100.06	99.85	100.05	1
LG&E	C1S	863868	11/2010	09/23/2010	100.08	100.03	100.16	1
LG&E	C1S	863869	11/2010	09/23/2010	100.06	99.89	100.01	1
LG&E	C1S	863870	11/2010	09/23/2010	100.09	99.97	100.04	1
LG&E	C1S	863871	11/2010	09/23/2010	100.07	100.02	100.09	1
LG&E	C1S	863872	11/2010	09/23/2010	100.09	100.00	100.03	1
LG&E	C1S	863873	11/2010	09/23/2010	100.05	99.97	100.25	1
LG&E	C1S	863874	11/2010	09/23/2010	100.08	100.02	100.08	1
LG&E	C1S	863875	11/2010	09/23/2010	100.09	99.95	100.17	1
LG&E	C1S	863876	11/2010	09/23/2010	100.06	99.93	100.05	1
LG&E	C1S	863877	11/2010	09/23/2010	100.09	99.98	100.18	1
LG&E	C1S	863878	11/2010	09/23/2010	100.07	100.05	100.17	1
LG&E	C1S	863879	11/2010	09/23/2010	100.10	100.04	100.16	1
LG&E	C1S	863880	11/2010	09/23/2010	100.09	99.97	100.06	1

LG&E	CIS	863881	11/2010	09/23/2010	100.07	100.00	99.97	1
LG&E	CIS	863882	11/2010	09/23/2010	100.07	100.07	100.10	1
LG&E	CIS	863883	11/2010	09/23/2010	100.08	100.01	100.16	1
LG&E	CIS	863884	11/2010	09/23/2010	100.09	99.95	100.09	1
LG&E	CIS	863885	11/2010	09/23/2010	100.08	99.99	100.14	1
LG&E	CIS	863886	11/2010	09/23/2010	100.09	100.08	100.19	1
LG&E	CIS	863887	11/2010	09/23/2010	100.09	100.05	100.18	1
LG&E	CIS	863888	11/2010	09/23/2010	100.07	99.96	99.96	1
LG&E	CIS	863889	11/2010	09/23/2010	100.08	99.98	100.14	1
LG&E	CIS	863890	11/2010	09/23/2010	100.07	99.90	100.14	1
LG&E	CIS	863891	11/2010	09/23/2010	100.06	99.86	100.02	1
LG&E	CIS	863892	11/2010	09/23/2010	100.08	99.92	100.10	1
LG&E	CIS	863893	11/2010	09/23/2010	100.09	99.96	99.99	1
LG&E	CIS	863894	11/2010	09/23/2010	100.10	100.00	100.04	1
LG&E	CIS	863895	11/2010	09/23/2010	100.09	100.03	100.11	1
LG&E	CIS	863896	11/2010	09/23/2010	100.05	99.94	99.97	1
LG&E	CIS	863897	11/2010	09/23/2010	100.08	100.05	99.97	1
LG&E	CIS	863898	11/2010	09/23/2010	100.09	100.01	100.05	1
LG&E	CIS	863899	11/2010	09/23/2010	100.09	99.94	100.10	1
LG&E	CIS	863900	11/2010	09/23/2010	100.07	99.95	100.08	1
LG&E	CIS	863901	11/2010	09/23/2010	100.06	100.01	100.08	1
LG&E	CIS	863902	11/2010	09/23/2010	100.08	99.88	99.96	1
LG&E	CIS	863903	11/2010	09/23/2010	100.07	99.94	100.02	1
LG&E	CIS	863904	11/2010	09/23/2010	100.05	100.03	100.20	1
LG&E	CIS	863905	11/2010	09/23/2010	100.11	100.05	100.06	1
LG&E	CIS	863906	11/2010	09/23/2010	100.07	100.02	100.00	1
LG&E	CIS	863907	11/2010	09/23/2010	100.06	99.92	100.10	1
LG&E	CIS	863908	11/2010	09/23/2010	100.06	99.91	100.02	1
LG&E	CIS	863909	11/2010	09/23/2010	100.06	100.11	100.14	1
LG&E	CIS	863910	11/2010	09/23/2010	100.08	100.01	100.15	1
LG&E	CIS	863911	11/2010	09/23/2010	100.09	100.00	100.08	1
LG&E	CIS	863912	11/2010	09/23/2010	100.08	100.09	100.14	1
LG&E	CIS	863913	11/2010	09/23/2010	100.08	100.06	100.21	1
LG&E	CIS	863914	11/2010	09/23/2010	100.08	100.01	100.19	1
LG&E	CIS	863915	11/2010	09/23/2010	100.06	99.93	100.01	1
LG&E	CIS	863916	11/2010	09/23/2010	100.07	100.02	100.13	1

LG&E	C1S	863917	11/2010	03/2010	100.06	99.95	100.17	1
LG&E	C1S	863918	11/2010	09/23/2010	100.10	99.97	100.09	1
LG&E	C1S	863919	11/2010	09/23/2010	100.06	99.97	100.11	1
LG&E	C1S	863920	11/2010	09/23/2010	100.08	99.92	100.09	1
LG&E	C1S	863921	11/2010	09/23/2010	100.08	100.06	100.00	1
LG&E	C1S	863922	11/2010	09/23/2010	100.07	100.03	100.06	1
LG&E	C1S	863923	11/2010	09/23/2010	100.08	99.99	100.00	1
LG&E	C1S	863924	11/2010	09/23/2010	100.07	100.07	100.20	1
LG&E	C1S	863925	11/2010	09/23/2010	100.08	100.05	100.05	1
LG&E	C1S	863926	11/2010	09/23/2010	100.06	99.98	100.02	1
LG&E	C1S	863927	11/2010	09/23/2010	100.06	99.92	100.00	1
LG&E	C1S	863928	11/2010	09/23/2010	100.08	99.91	100.06	1
LG&E	C1S	863929	11/2010	09/23/2010	100.07	99.94	100.19	1
LG&E	C1S	863930	11/2010	09/23/2010	100.09	100.07	100.20	1
LG&E	C1S	863931	11/2010	09/23/2010	100.07	100.00	100.10	1
LG&E	C1S	863932	11/2010	09/23/2010	100.08	100.04	100.18	1
LG&E	C1S	863933	11/2010	09/23/2010	100.09	100.00	99.99	1
LG&E	C1S	863934	11/2010	09/23/2010	100.09	100.02	100.08	1
LG&E	C1S	863935	11/2010	09/23/2010	100.07	100.05	100.09	1
LG&E	C1S	863936	11/2010	09/23/2010	100.08	99.92	100.08	1
LG&E	C1S	863937	11/2010	09/23/2010	100.08	100.02	100.17	1
LG&E	C1S	863938	11/2010	09/23/2010	100.07	100.09	100.18	1
LG&E	C1S	863939	11/2010	09/23/2010	100.09	99.98	100.02	1
LG&E	C1S	863940	11/2010	09/23/2010	100.08	100.10	100.17	1
LG&E	C1S	863941	11/2010	09/23/2010	100.08	99.95	100.05	1
LG&E	C1S	863942	11/2010	09/23/2010	100.08	100.04	100.03	1
LG&E	C1S	863943	11/2010	09/23/2010	100.06	100.03	100.20	1
LG&E	C1S	863944	11/2010	09/23/2010	100.07	99.94	100.02	1
LG&E	C1S	863945	11/2010	09/23/2010	100.07	99.98	100.09	1
LG&E	C1S	863946	11/2010	09/23/2010	100.06	100.00	100.11	1
LG&E	C1S	863947	11/2010	09/23/2010	100.08	99.96	100.07	1
LG&E	C1S	863948	11/2010	09/23/2010	100.09	100.04	100.00	1
LG&E	C1S	863949	11/2010	09/23/2010	100.07	99.94	100.00	1
LG&E	C1S	863950	11/2010	09/23/2010	100.09	100.01	100.13	1
LG&E	C1S	863951	11/2010	09/23/2010	100.09	99.94	100.05	1
LG&E	C1S	863952	11/2010	09/23/2010	100.09	99.88	100.10	1

LG&E	CIS	863953	11/2010	09/23/2010	100.06	99.97	100.05	1
LG&E	CIS	863954	11/2010	09/23/2010	100.06	99.98	100.13	1
LG&E	CIS	863955	11/2010	09/23/2010	100.07	100.07	100.17	1
LG&E	CIS	863956	11/2010	09/23/2010	100.09	99.94	100.04	1
LG&E	CIS	863957	11/2010	09/23/2010	100.07	99.98	100.09	1
LG&E	CIS	863958	11/2010	09/23/2010	100.06	99.94	99.96	1
LG&E	CIS	863959	11/2010	09/23/2010	100.07	100.11	100.15	1
LG&E	CIS	863960	11/2010	09/23/2010	100.08	99.89	100.15	1
LG&E	CIS	863961	11/2010	09/23/2010	100.08	99.98	100.11	1
LG&E	CIS	863962	11/2010	09/23/2010	100.06	99.91	100.00	1
LG&E	CIS	863963	11/2010	09/23/2010	100.10	100.07	100.00	1
LG&E	CIS	863964	11/2010	09/23/2010	100.07	100.07	100.20	1
LG&E	CIS	863965	11/2010	09/23/2010	100.10	99.97	100.05	1
LG&E	CIS	863966	11/2010	09/23/2010	100.08	99.91	100.10	1
LG&E	CIS	863967	11/2010	09/23/2010	100.08	99.98	100.07	1
LG&E	CIS	863968	11/2010	09/23/2010	100.06	100.02	100.14	1
LG&E	CIS	863969	11/2010	09/23/2010	100.10	99.92	100.05	1
LG&E	CIS	863970	11/2010	09/23/2010	100.07	99.98	99.93	1
LG&E	CIS	863971	11/2010	09/23/2010	100.05	99.92	100.01	1
LG&E	CIS	863972	11/2010	09/23/2010	100.06	99.83	99.95	1
LG&E	CIS	863973	11/2010	09/23/2010	100.10	100.04	100.06	1
LG&E	CIS	863974	11/2010	09/23/2010	100.06	100.03	100.13	1
LG&E	CIS	863975	11/2010	09/23/2010	100.07	100.01	100.05	1
LG&E	CIS	863976	11/2010	09/23/2010	100.10	99.87	100.13	1
LG&E	CIS	863977	11/2010	09/23/2010	100.09	99.86	100.11	1
LG&E	CIS	863978	11/2010	09/23/2010	100.10	100.02	100.03	1
LG&E	CIS	863979	11/2010	09/23/2010	100.06	99.96	100.08	1
LG&E	CIS	863980	11/2010	09/23/2010	100.09	100.06	100.06	1
LG&E	CIS	863981	11/2010	09/23/2010	100.08	100.05	100.27	1
LG&E	CIS	863982	11/2010	09/23/2010	100.07	99.91	100.03	1
LG&E	CIS	863983	11/2010	09/23/2010	100.08	100.07	100.14	1
LG&E	CIS	863984	11/2010	09/23/2010	100.07	99.91	100.02	1
LG&E	CIS	863985	11/2010	09/23/2010	100.05	100.03	100.14	1
LG&E	CIS	863986	11/2010	09/23/2010	100.06	99.88	100.06	1
LG&E	CIS	863987	11/2010	09/23/2010	100.08	100.06	100.23	1
LG&E	CIS	863988	11/2010	09/23/2010	100.10	100.02	100.19	1

LG&E	C1S	863989	11/2010	23/2010	100.07	100.00	100.19	1
LG&E	C1S	863990	11/2010	09/23/2010	100.09	100.08	100.18	1
LG&E	C1S	863991	11/2010	09/23/2010	100.05	100.04	100.15	1
LG&E	C1S	863992	11/2010	09/23/2010	100.10	99.95	100.04	1
LG&E	C1S	863993	11/2010	09/23/2010	100.06	99.98	100.23	1
LG&E	C1S	863994	11/2010	09/23/2010	100.10	100.11	100.15	1
LG&E	C1S	863995	11/2010	09/23/2010	100.10	100.02	100.11	1
LG&E	C1S	863996	11/2010	09/23/2010	100.07	99.99	100.22	1
LG&E	C1S	863997	11/2010	09/23/2010	100.08	99.94	100.13	1
LG&E	C1S	863998	11/2010	09/23/2010	100.08	100.02	100.15	1
LG&E	C1S	863999	11/2010	09/23/2010	100.06	99.97	100.05	1
LG&E	C1S	864000	11/2010	09/23/2010	100.06	99.91	100.01	1
LG&E	C1S	864001	11/2010	09/23/2010	100.06	100.02	99.96	1
LG&E	C1S	864002	11/2010	09/23/2010	100.05	99.90	100.03	1
LG&E	C1S	864003	11/2010	09/23/2010	100.06	99.99	100.19	1
LG&E	C1S	864004	11/2010	09/23/2010	100.08	100.00	100.05	1
LG&E	C1S	864005	11/2010	09/23/2010	100.10	99.92	100.15	1
LG&E	C1S	864006	11/2010	09/23/2010	100.09	100.13	100.09	1
LG&E	C1S	864007	11/2010	09/23/2010	100.05	99.99	99.93	1
LG&E	C1S	864008	11/2010	09/23/2010	100.09	100.07	100.16	1
LG&E	C1S	864009	11/2010	09/23/2010	100.08	99.93	100.16	1
LG&E	C1S	864010	11/2010	09/23/2010	100.06	99.91	100.08	1
LG&E	C1S	864011	11/2010	09/23/2010	100.10	99.92	100.06	1
LG&E	C1S	864012	11/2010	09/23/2010	100.09	100.04	100.14	1
LG&E	C1S	864013	11/2010	09/23/2010	100.07	99.91	100.08	1
LG&E	C1S	864014	11/2010	09/23/2010	100.09	99.94	100.09	1
LG&E	C1S	864015	11/2010	09/23/2010	100.06	99.87	100.03	1
LG&E	C1S	864016	11/2010	09/23/2010	100.10	99.97	100.06	1
LG&E	C1S	864017	11/2010	09/23/2010	100.09	100.10	100.17	1
LG&E	C1S	864018	11/2010	09/23/2010	100.07	99.88	100.00	1
LG&E	C1S	864019	11/2010	09/23/2010	100.08	99.96	100.10	1
LG&E	C1S	864020	11/2010	09/23/2010	100.06	99.92	100.06	1
LG&E	C1S	864021	11/2010	09/23/2010	100.09	100.05	100.15	1
LG&E	C1S	864022	11/2010	09/23/2010	100.10	100.04	100.18	1
LG&E	C1S	864023	11/2010	09/23/2010	100.09	99.90	100.06	1
LG&E	C1S	864024	11/2010	09/23/2010	100.05	100.09	100.18	1

LG&E	C1S	864025	11/2010	09/23/2010	100.06	100.03	100.13	1
LG&E	C1S	864026	11/2010	09/23/2010	100.07	100.06	100.12	1
LG&E	C1S	864027	11/2010	09/23/2010	100.09	99.97	100.09	1
LG&E	C1S	864028	11/2010	09/23/2010	100.07	99.95	99.98	1
LG&E	C1S	864029	11/2010	09/23/2010	100.06	99.96	100.02	1
LG&E	C1S	864030	11/2010	09/23/2010	100.08	99.89	99.98	1
LG&E	C1S	864031	11/2010	09/23/2010	100.07	100.06	100.20	1
LG&E	C1S	864032	11/2010	09/23/2010	100.07	99.93	100.10	1
LG&E	C1S	864033	11/2010	09/23/2010	100.07	100.07	100.16	1
LG&E	C1S	864034	11/2010	09/23/2010	100.08	100.05	100.15	1
LG&E	C1S	864035	11/2010	09/23/2010	100.08	100.03	100.09	1
LG&E	C1S	864036	11/2010	09/23/2010	100.08	100.08	100.24	1
LG&E	C1S	864037	11/2010	09/23/2010	100.07	99.83	100.01	1
LG&E	C1S	864038	11/2010	09/23/2010	100.09	99.86	100.02	1
LG&E	C1S	864039	11/2010	09/23/2010	100.09	100.00	100.13	1
LG&E	C1S	864040	11/2010	09/23/2010	100.09	100.09	100.20	1
LG&E	C1S	864041	11/2010	09/23/2010	100.08	99.99	100.19	1
LG&E	C1S	864042	11/2010	09/23/2010	100.09	99.95	100.08	1
LG&E	C1S	864043	11/2010	09/23/2010	100.06	100.05	100.22	1
LG&E	C1S	864044	11/2010	09/23/2010	100.06	100.00	100.06	1
LG&E	C1S	864045	11/2010	09/23/2010	100.09	100.00	100.07	1
LG&E	C1S	864046	11/2010	09/23/2010	100.10	100.04	100.08	1
LG&E	C1S	864047	11/2010	09/23/2010	100.07	100.04	100.15	1
LG&E	C1S	864048	11/2010	09/23/2010	100.08	99.90	99.95	1
LG&E	C1S	864049	11/2010	09/23/2010	100.08	100.06	100.18	1
LG&E	C1S	864050	11/2010	09/23/2010	100.06	99.88	100.11	1
LG&E	C1S	864051	11/2010	09/23/2010	100.08	100.04	100.07	1
LG&E	C1S	864052	11/2010	09/23/2010	100.06	100.04	100.14	1
LG&E	C1S	864053	11/2010	09/23/2010	100.10	100.06	100.09	1
LG&E	C1S	864054	11/2010	09/23/2010	100.08	99.97	100.21	1
LG&E	C1S	864055	11/2010	09/23/2010	100.09	99.97	100.19	1
LG&E	C1S	864056	11/2010	09/23/2010	100.05	100.03	100.07	1
LG&E	C1S	864057	11/2010	09/23/2010	100.05	99.92	100.03	1
LG&E	C1S	864058	11/2010	09/23/2010	100.07	99.96	100.12	1
LG&E	C1S	864059	11/2010	09/23/2010	100.05	100.02	100.12	1
LG&E	C1S	864060	11/2010	09/23/2010	100.07	100.00	100.10	1



LG&E	C1S	864061	11/2010	23/2010	100.10	100.04	100.10	100.10	1
LG&E	C1S	864062	11/2010	09/23/2010	100.08	99.98	100.08	100.04	1
LG&E	C1S	864063	11/2010	09/23/2010	100.08	99.98	100.08	100.14	1
LG&E	C1S	864064	11/2010	09/23/2010	100.06	99.97	100.06	100.02	1
LG&E	C1S	864065	11/2010	09/23/2010	100.06	99.92	100.06	100.05	1
LG&E	C1S	864066	11/2010	09/23/2010	100.06	99.95	100.06	100.14	1
LG&E	C1S	864067	11/2010	09/23/2010	100.08	99.96	100.08	100.14	1
LG&E	C1S	864068	11/2010	09/23/2010	100.08	99.94	100.08	100.13	1
LG&E	C1S	864069	11/2010	09/23/2010	100.08	100.05	100.08	100.15	1
LG&E	C1S	864070	11/2010	09/23/2010	100.09	100.06	100.09	100.04	1
LG&E	C1S	864071	11/2010	09/23/2010	100.06	99.97	100.06	100.00	1
LG&E	C1S	864072	11/2010	09/23/2010	100.06	99.92	100.06	100.07	1
LG&E	C1S	864073	11/2010	09/23/2010	100.08	99.91	100.08	100.08	1
LG&E	C1S	864074	11/2010	09/23/2010	100.08	99.82	100.08	99.98	1
LG&E	C1S	864075	11/2010	09/23/2010	100.08	100.00	100.08	100.18	1
LG&E	C1S	864076	11/2010	09/23/2010	100.07	100.05	100.07	100.13	1
LG&E	C1S	864077	11/2010	09/23/2010	100.10	100.00	100.10	100.14	1
LG&E	C1S	864078	11/2010	09/23/2010	100.06	99.87	100.06	100.08	1
LG&E	C1S	864079	11/2010	09/23/2010	100.07	100.05	100.07	100.16	1
LG&E	C1S	864080	11/2010	09/23/2010	100.09	99.92	100.09	100.03	1
LG&E	C1S	864081	11/2010	09/23/2010	100.08	100.02	100.08	100.03	1
LG&E	C1S	864082	11/2010	09/23/2010	100.10	99.96	100.10	100.09	1
LG&E	C1S	864083	11/2010	09/23/2010	100.06	100.07	100.06	100.17	1
LG&E	C1S	864084	11/2010	09/23/2010	100.08	99.97	100.08	100.01	1
LG&E	C1S	864085	11/2010	09/23/2010	100.07	99.90	100.07	100.05	1
LG&E	C1S	864086	11/2010	09/23/2010	100.05	100.00	100.05	100.12	1
LG&E	C1S	864087	11/2010	09/23/2010	100.09	100.05	100.09	100.13	1
LG&E	C1S	864088	11/2010	09/23/2010	100.09	99.84	100.09	100.08	1
LG&E	C1S	864089	11/2010	09/23/2010	100.09	100.02	100.09	100.07	1
LG&E	C1S	864090	11/2010	09/23/2010	100.06	100.08	100.06	100.13	1
LG&E	C1S	864091	11/2010	09/23/2010	100.08	100.00	100.08	100.14	1
LG&E	C1S	864092	11/2010	09/23/2010	100.06	99.90	100.06	100.02	1
LG&E	C1S	864093	11/2010	09/23/2010	100.08	100.01	100.08	100.10	1
LG&E	C1S	864094	11/2010	09/23/2010	100.07	99.93	100.07	100.09	1
LG&E	C1S	864095	11/2010	09/23/2010	100.07	99.95	100.07	100.04	1
LG&E	C1S	864096	11/2010	09/23/2010	100.09	100.12	100.09	100.25	1

LG&E	CIS	864097	11/2010	09/23/2010	100.07	99.86	100.00	1
LG&E	CIS	864098	11/2010	09/23/2010	100.08	99.88	99.97	1
LG&E	CIS	864099	11/2010	09/23/2010	100.07	99.97	100.03	1
LG&E	CIS	864100	11/2010	09/23/2010	100.05	99.85	99.99	1
LG&E	CIS	864101	11/2010	09/23/2010	100.09	99.89	100.05	1
LG&E	CIS	864102	11/2010	09/23/2010	100.09	100.05	100.23	1
LG&E	CIS	864103	11/2010	09/23/2010	100.08	100.09	100.18	1
LG&E	CIS	864104	11/2010	09/23/2010	100.07	99.88	99.99	1
LG&E	CIS	864105	11/2010	09/23/2010	100.10	99.86	100.06	1
LG&E	CIS	864106	11/2010	09/23/2010	100.07	100.09	100.14	1
LG&E	CIS	864107	11/2010	09/23/2010	100.09	99.91	100.07	1
LG&E	CIS	864108	11/2010	09/23/2010	100.08	99.92	100.08	1
LG&E	CIS	864109	11/2010	09/23/2010	100.06	100.07	100.03	1
LG&E	CIS	864110	11/2010	09/23/2010	100.09	99.98	100.05	1
LG&E	CIS	864111	11/2010	09/23/2010	100.08	99.93	100.11	1
LG&E	CIS	864112	11/2010	09/23/2010	100.05	99.94	100.12	1
LG&E	CIS	864113	11/2010	09/23/2010	100.06	100.04	100.11	1
LG&E	CIS	864114	11/2010	09/23/2010	100.08	100.05	100.13	1
LG&E	CIS	864115	11/2010	09/23/2010	100.10	99.92	100.17	1
LG&E	CIS	864116	11/2010	09/23/2010	100.10	99.94	100.06	1
LG&E	CIS	864117	11/2010	09/23/2010	100.06	99.94	100.16	1
LG&E	CIS	864118	11/2010	09/23/2010	100.07	100.04	100.15	1
LG&E	CIS	864119	11/2010	09/23/2010	100.05	99.93	100.04	1
LG&E	CIS	864120	11/2010	09/23/2010	100.09	100.05	100.08	1
LG&E	CIS	864121	11/2010	09/23/2010	100.08	100.02	100.19	1
LG&E	CIS	864122	11/2010	09/23/2010	100.06	100.04	100.23	1
LG&E	CIS	864123	11/2010	09/23/2010	100.06	99.91	100.03	1
LG&E	CIS	864124	11/2010	09/23/2010	100.06	100.02	100.12	1
LG&E	CIS	864125	11/2010	09/23/2010	100.06	99.91	99.94	1
LG&E	CIS	864126	11/2010	09/23/2010	100.10	100.10	100.27	1
LG&E	CIS	864127	11/2010	09/23/2010	100.07	100.09	100.24	1
LG&E	CIS	864128	11/2010	09/23/2010	100.06	99.97	99.99	1
LG&E	CIS	864129	11/2010	09/23/2010	100.06	99.93	100.11	1
LG&E	CIS	864130	11/2010	09/23/2010	100.10	100.02	100.18	1
LG&E	CIS	864131	11/2010	09/23/2010	100.07	99.96	100.02	1
LG&E	CIS	864132	11/2010	09/23/2010	100.10	99.99	100.11	1

LG&E	C1S	864133	11/2010	3/2010	100.09	99.95	99.99	1
LG&E	C1S	864134	11/2010	09/23/2010	100.06	100.03	100.12	1
LG&E	C1S	864135	11/2010	09/23/2010	100.10	100.13	100.25	1
LG&E	C1S	864136	11/2010	09/23/2010	100.09	99.96	100.08	1
LG&E	C1S	864137	11/2010	09/23/2010	100.10	99.97	100.11	1
LG&E	C1S	864138	11/2010	09/23/2010	100.09	99.98	100.11	1
LG&E	C1S	864139	11/2010	09/23/2010	100.08	100.00	100.11	1
LG&E	C1S	864140	11/2010	09/23/2010	100.08	99.89	100.03	1
LG&E	C1S	864141	11/2010	09/23/2010	100.08	100.01	100.16	1
LG&E	C1S	864142	11/2010	09/23/2010	100.08	99.94	100.05	1
LG&E	C1S	864143	11/2010	09/23/2010	100.08	99.99	99.92	1
LG&E	C1S	864144	11/2010	09/23/2010	100.06	99.96	100.03	1
LG&E	C1S	864145	11/2010	09/23/2010	100.08	99.88	100.06	1
LG&E	C1S	864146	11/2010	09/23/2010	100.05	99.96	100.20	1
LG&E	C1S	864147	11/2010	09/23/2010	100.06	99.98	100.08	1
LG&E	C1S	864148	11/2010	09/23/2010	100.06	99.89	100.07	1
LG&E	C1S	864149	11/2010	09/23/2010	100.07	99.95	100.10	1
LG&E	C1S	864150	11/2010	09/23/2010	100.06	99.89	100.09	1
LG&E	C1S	864151	11/2010	09/23/2010	100.06	99.84	99.95	1
LG&E	C1S	864152	11/2010	09/23/2010	100.10	100.01	100.07	1
LG&E	C1S	864153	11/2010	09/23/2010	100.09	100.13	100.18	1
LG&E	C1S	864154	11/2010	09/23/2010	100.09	100.08	100.17	1
LG&E	C1S	864155	11/2010	09/23/2010	100.09	100.06	100.19	1
LG&E	C1S	864156	11/2010	09/23/2010	100.08	100.05	100.26	1
LG&E	C1S	864157	11/2010	09/23/2010	100.10	100.03	100.17	1
LG&E	C1S	864158	11/2010	09/23/2010	100.07	100.01	100.02	1
LG&E	C1S	864159	11/2010	09/23/2010	100.08	99.97	100.14	1
LG&E	C1S	864160	11/2010	09/23/2010	100.07	100.04	100.20	1
LG&E	C1S	864161	11/2010	09/23/2010	100.08	99.92	100.03	1
LG&E	C1S	864162	11/2010	09/23/2010	100.06	99.88	100.01	1
LG&E	C1S	864163	11/2010	09/23/2010	100.07	99.94	100.08	1
LG&E	C1S	864164	11/2010	09/23/2010	100.07	99.95	100.11	1
LG&E	C1S	864165	11/2010	09/23/2010	100.07	100.10	100.19	1
LG&E	C1S	864166	11/2010	09/23/2010	100.08	99.99	100.03	1
LG&E	C1S	864167	11/2010	09/23/2010	100.06	99.99	100.00	1
LG&E	C1S	864168	11/2010	09/23/2010	100.07	100.00	100.09	1

LG&E	CIS	864169	11/2010	09/23/2010	100.09	99.90	99.98	1
LG&E	CIS	864170	11/2010	09/23/2010	100.07	99.94	100.00	1
LG&E	CIS	864171	11/2010	09/23/2010	100.09	100.04	100.23	1
LG&E	CIS	864172	11/2010	09/23/2010	100.06	100.02	100.24	1
LG&E	CIS	864173	11/2010	09/23/2010	100.08	99.97	100.20	1
LG&E	CIS	864174	11/2010	09/23/2010	100.06	99.97	100.23	1
LG&E	CIS	864175	11/2010	09/23/2010	100.08	100.03	100.05	1
LG&E	CIS	864176	11/2010	09/23/2010	100.07	99.89	100.08	1
LG&E	CIS	864177	11/2010	09/23/2010	100.08	99.93	100.08	1
LG&E	CIS	864178	11/2010	09/23/2010	100.09	99.93	100.08	1
LG&E	CIS	864179	11/2010	09/23/2010	100.06	99.93	100.07	1
LG&E	CIS	864180	11/2010	09/23/2010	100.07	100.00	100.13	1
LG&E	CIS	864181	11/2010	09/23/2010	100.10	100.06	100.15	1
LG&E	CIS	864182	11/2010	09/23/2010	100.07	100.04	99.99	1
LG&E	CIS	864183	11/2010	09/23/2010	100.08	100.00	100.03	1
LG&E	CIS	864184	11/2010	09/23/2010	100.08	99.89	100.06	1
LG&E	CIS	864185	11/2010	09/23/2010	100.06	99.97	99.95	1
LG&E	CIS	864186	11/2010	09/23/2010	100.07	100.00	99.99	1
LG&E	CIS	864187	11/2010	09/23/2010	100.07	100.04	100.13	1
LG&E	CIS	864188	11/2010	09/23/2010	100.09	99.92	100.05	1
LG&E	CIS	864189	11/2010	09/23/2010	100.08	99.99	100.11	1
LG&E	CIS	864190	11/2010	09/23/2010	100.09	99.95	100.07	1
LG&E	CIS	864191	11/2010	09/23/2010	100.07	99.86	100.03	1
LG&E	CIS	864192	11/2010	09/23/2010	100.09	99.97	100.12	1
LG&E	CIS	864193	11/2010	09/23/2010	100.07	100.03	100.12	1
LG&E	CIS	864194	11/2010	09/23/2010	100.10	100.08	100.06	1
LG&E	CIS	864195	11/2010	09/23/2010	100.09	100.01	100.12	1
LG&E	CIS	864196	11/2010	09/23/2010	100.05	100.08	100.11	1
LG&E	CIS	864197	11/2010	09/23/2010	100.07	100.11	100.18	1
LG&E	CIS	864198	11/2010	09/23/2010	100.06	100.00	100.15	1
LG&E	CIS	864199	11/2010	09/23/2010	100.06	100.00	100.16	1
LG&E	CIS	864200	11/2010	09/23/2010	100.07	100.05	100.16	1
LG&E	CIS	864201	11/2010	09/23/2010	100.09	100.06	100.12	1
LG&E	CIS	864202	11/2010	09/23/2010	100.09	99.88	100.00	1
LG&E	CIS	864203	11/2010	09/23/2010	100.09	100.00	100.08	1
LG&E	CIS	864204	11/2010	09/23/2010	100.05	99.97	99.97	1

LG&E	C1S	864205	11/2010	03/2010	100.06	99.99	100.25	1
LG&E	C1S	864206	11/2010	09/23/2010	100.09	99.99	100.14	1
LG&E	C1S	864207	11/2010	09/23/2010	100.08	99.94	100.10	1
LG&E	C1S	864208	11/2010	09/23/2010	100.07	99.96	100.07	1
LG&E	C1S	864209	11/2010	09/23/2010	100.08	99.96	100.13	1
LG&E	C1S	864210	11/2010	09/23/2010	100.06	99.95	99.99	1
LG&E	C1S	864211	11/2010	09/23/2010	100.09	100.07	100.15	1
LG&E	C1S	864212	11/2010	09/23/2010	100.06	100.03	100.14	1
LG&E	C1S	864213	11/2010	09/23/2010	100.09	99.97	100.04	1
LG&E	C1S	864214	11/2010	09/23/2010	100.07	100.01	100.19	1
LG&E	C1S	864215	11/2010	09/23/2010	100.05	99.96	100.14	1
LG&E	C1S	864216	11/2010	09/23/2010	100.07	100.00	100.17	1
LG&E	C1S	864217	11/2010	09/23/2010	100.07	99.94	100.02	1
LG&E	C1S	864218	11/2010	09/23/2010	100.08	100.02	100.15	1
LG&E	C1S	864219	11/2010	09/23/2010	100.08	99.97	100.07	1
LG&E	C1S	864220	11/2010	09/23/2010	100.08	100.05	100.18	1
LG&E	C1S	864221	11/2010	09/23/2010	100.05	99.85	100.02	1
LG&E	C1S	864222	11/2010	09/23/2010	100.06	99.91	99.95	1
LG&E	C1S	864223	11/2010	09/23/2010	100.08	99.87	100.08	1
LG&E	C1S	864224	11/2010	09/23/2010	100.06	100.07	100.17	1
LG&E	C1S	864225	11/2010	09/23/2010	100.08	100.06	100.21	1
LG&E	C1S	864226	11/2010	09/23/2010	100.09	100.03	100.08	1
LG&E	C1S	864227	11/2010	09/23/2010	100.06	100.05	100.18	1
LG&E	C1S	864228	11/2010	09/23/2010	100.10	100.02	100.08	1
LG&E	C1S	864229	11/2010	09/23/2010	100.08	99.90	100.05	1
LG&E	C1S	864230	11/2010	09/23/2010	100.07	100.02	100.14	1
LG&E	C1S	864231	11/2010	09/23/2010	100.10	100.11	100.18	1
LG&E	C1S	864232	11/2010	09/23/2010	100.07	100.08	100.17	1
LG&E	C1S	864233	11/2010	09/23/2010	100.10	100.05	100.09	1
LG&E	C1S	864234	11/2010	09/23/2010	100.09	100.07	100.18	1
LG&E	C1S	864235	11/2010	09/23/2010	100.06	99.90	100.00	1
LG&E	C1S	864236	11/2010	09/23/2010	100.07	99.97	99.97	1
LG&E	C1S	864237	11/2010	09/23/2010	100.07	99.95	100.01	1
LG&E	C1S	864238	11/2010	09/23/2010	100.08	99.91	100.06	1
LG&E	C1S	864239	11/2010	09/23/2010	100.10	100.04	100.25	1
LG&E	C1S	864240	11/2010	09/23/2010	100.06	100.03	100.16	1

LG&E	CIS	864241	11/2010	09/23/2010	100.08	99.97	100.05	1
LG&E	CIS	864242	11/2010	09/23/2010	100.06	100.04	100.17	1
LG&E	CIS	864243	11/2010	09/23/2010	100.08	99.91	99.99	1
LG&E	CIS	864244	11/2010	09/23/2010	100.06	100.03	100.14	1
LG&E	CIS	864245	11/2010	09/23/2010	100.09	100.00	100.03	1
LG&E	CIS	864246	11/2010	09/23/2010	100.08	100.02	100.12	1
LG&E	CIS	864247	11/2010	09/23/2010	100.09	99.95	100.11	1
LG&E	CIS	864248	11/2010	09/23/2010	100.09	99.95	100.09	1
LG&E	CIS	864249	11/2010	09/23/2010	100.06	99.97	100.11	1
LG&E	CIS	864250	11/2010	09/23/2010	100.06	99.91	100.12	1
LG&E	CIS	864251	11/2010	09/23/2010	100.06	99.98	100.22	1
LG&E	CIS	864252	11/2010	09/23/2010	100.09	99.99	100.06	1
LG&E	CIS	864253	11/2010	09/23/2010	100.06	99.92	100.05	1
LG&E	CIS	864254	11/2010	09/23/2010	100.09	99.90	100.05	1
LG&E	CIS	864255	11/2010	09/23/2010	100.07	100.02	100.08	1
LG&E	CIS	864256	11/2010	09/23/2010	100.09	100.07	100.26	1
LG&E	CIS	864257	11/2010	09/23/2010	100.07	100.07	100.07	1
LG&E	CIS	864258	11/2010	09/23/2010	100.10	100.07	100.18	1
LG&E	CIS	864259	11/2010	09/23/2010	100.10	99.95	100.03	1
LG&E	CIS	864260	11/2010	09/23/2010	100.08	99.95	100.09	1
LG&E	CIS	864261	11/2010	09/23/2010	100.05	99.92	100.02	1
LG&E	CIS	864262	11/2010	09/23/2010	100.06	99.81	99.98	1
LG&E	CIS	864263	11/2010	09/23/2010	100.08	99.89	100.05	1
LG&E	CIS	864264	11/2010	09/23/2010	100.09	100.08	100.24	1
LG&E	CIS	864265	11/2010	09/23/2010	100.06	99.92	100.07	1
LG&E	CIS	864266	11/2010	09/23/2010	100.06	99.95	100.01	1
LG&E	CIS	864267	11/2010	09/23/2010	100.08	100.00	100.03	1
LG&E	CIS	864268	11/2010	09/23/2010	100.08	99.97	100.01	1
LG&E	CIS	864269	11/2010	09/23/2010	100.07	99.91	100.14	1
LG&E	CIS	864270	11/2010	09/23/2010	100.09	99.99	99.95	1
LG&E	CIS	864271	11/2010	09/23/2010	100.09	99.97	100.17	1
LG&E	CIS	864272	11/2010	09/23/2010	100.08	100.06	100.11	1
LG&E	CIS	864273	11/2010	09/23/2010	100.08	99.95	100.02	1
LG&E	CIS	864274	11/2010	09/23/2010	100.09	99.96	100.02	1
LG&E	CIS	864275	11/2010	09/23/2010	100.09	99.96	100.05	1
LG&E	CIS	864276	11/2010	09/23/2010	100.09	100.01	100.03	1

LG&E	C1S	864277	11/2010	03/2010	100.09	100.06	100.09	1
LG&E	C1S	864278	11/2010	09/23/2010	100.09	100.03	100.23	1
LG&E	C1S	864279	11/2010	09/23/2010	100.10	100.14	100.21	1
LG&E	C1S	864280	11/2010	09/23/2010	100.08	99.89	100.08	1
LG&E	C1S	864281	11/2010	09/23/2010	100.08	100.08	100.22	1
LG&E	C1S	864282	11/2010	09/23/2010	100.10	100.07	100.08	1
LG&E	C1S	864283	11/2010	09/23/2010	100.10	100.11	100.18	1
LG&E	C1S	864284	11/2010	09/23/2010	100.08	99.92	100.06	1
LG&E	C1S	864285	11/2010	09/23/2010	100.08	100.09	100.20	1
LG&E	C1S	864286	11/2010	09/23/2010	100.09	100.00	100.08	1
LG&E	C1S	864287	11/2010	09/23/2010	100.05	99.90	100.04	1
LG&E	C1S	864288	11/2010	09/23/2010	100.09	99.97	100.08	1
LG&E	C1S	864289	11/2010	09/23/2010	100.08	99.98	100.10	1
LG&E	C1S	864290	11/2010	09/23/2010	100.10	100.06	100.19	1
LG&E	C1S	864291	11/2010	09/23/2010	100.06	99.98	100.14	1
LG&E	C1S	864292	11/2010	09/23/2010	100.05	100.03	100.07	1
LG&E	C1S	864293	11/2010	09/23/2010	100.06	100.12	100.18	1
LG&E	C1S	864294	11/2010	09/23/2010	100.10	100.04	100.23	1
LG&E	C1S	864295	11/2010	09/23/2010	100.09	100.09	100.21	1
LG&E	C1S	864296	11/2010	09/23/2010	100.06	99.87	100.11	1
LG&E	C1S	864297	11/2010	09/23/2010	100.10	99.93	100.05	1
LG&E	C1S	864298	11/2010	09/23/2010	100.06	99.99	100.15	1
LG&E	C1S	864299	11/2010	09/23/2010	100.08	99.92	100.08	1
LG&E	C1S	864300	11/2010	09/23/2010	100.08	99.87	100.07	1
LG&E	C1S	864301	11/2010	09/23/2010	100.05	99.97	100.10	1
LG&E	C1S	864302	11/2010	09/23/2010	100.07	100.07	100.13	1
LG&E	C1S	864303	11/2010	09/23/2010	100.10	100.10	100.20	1
LG&E	C1S	864304	11/2010	09/23/2010	100.09	99.94	100.09	1
LG&E	C1S	864305	11/2010	09/23/2010	100.08	100.02	100.04	1
LG&E	C1S	864306	11/2010	09/23/2010	100.09	99.90	100.08	1
LG&E	C1S	864307	11/2010	09/23/2010	100.06	99.87	100.01	1
LG&E	C1S	864308	11/2010	09/23/2010	100.07	99.94	100.04	1
LG&E	C1S	864309	11/2010	09/23/2010	100.06	99.88	100.07	1
LG&E	C1S	864310	11/2010	09/23/2010	100.06	99.92	100.09	1
LG&E	C1S	864311	11/2010	09/23/2010	100.09	100.13	100.16	1
LG&E	C1S	864312	11/2010	09/23/2010	100.09	100.00	100.02	1

LG&E	C1S	864313	11/2010	09/23/2010	100.07	100.03	100.04	1
LG&E	C1S	864314	11/2010	09/23/2010	100.06	100.00	100.03	1
LG&E	C1S	864315	11/2010	09/23/2010	100.05	99.90	99.97	1
LG&E	C1S	864316	11/2010	09/23/2010	100.08	100.08	100.18	1
LG&E	C1S	864317	11/2010	09/23/2010	100.09	99.91	99.98	1
LG&E	C1S	864318	11/2010	09/23/2010	100.08	99.90	100.02	1
LG&E	C1S	864319	11/2010	09/23/2010	100.08	100.11	100.12	1
LG&E	C1S	864320	11/2010	09/23/2010	100.09	100.10	100.17	1
LG&E	C1S	864321	11/2010	09/23/2010	100.08	100.00	100.18	1
LG&E	C1S	864322	11/2010	09/23/2010	100.06	100.07	100.03	1
LG&E	C1S	864323	11/2010	09/23/2010	100.10	100.03	100.09	1
LG&E	C1S	864324	11/2010	09/23/2010	100.07	99.99	100.01	1
LG&E	C1S	864325	11/2010	09/23/2010	100.08	100.04	100.11	1
LG&E	C1S	864326	11/2010	09/23/2010	100.06	100.05	100.12	1
LG&E	C1S	864327	11/2010	09/23/2010	100.10	99.92	100.05	1
LG&E	C1S	864328	11/2010	09/23/2010	100.07	100.06	100.23	1
LG&E	C1S	864329	11/2010	09/23/2010	100.08	100.08	100.18	1
LG&E	C1S	864330	11/2010	09/23/2010	100.06	100.07	100.15	1
LG&E	C1S	864331	11/2010	09/23/2010	100.10	99.90	100.13	1
LG&E	C1S	864332	11/2010	09/23/2010	100.06	99.93	100.06	1
LG&E	C1S	864333	11/2010	09/23/2010	100.08	100.08	100.17	1
LG&E	C1S	864334	11/2010	09/23/2010	100.05	100.00	100.09	1
LG&E	C1S	864335	11/2010	09/23/2010	100.08	100.00	100.07	1
LG&E	C1S	864336	11/2010	09/23/2010	100.06	100.00	100.22	1
LG&E	C1S	864337	11/2010	09/23/2010	100.08	99.90	100.05	1
LG&E	C1S	864338	11/2010	09/23/2010	100.07	99.97	100.12	1
LG&E	C1S	864339	11/2010	09/23/2010	100.07	99.90	100.00	1
LG&E	C1S	864340	11/2010	09/23/2010	100.06	100.05	100.20	1
LG&E	C1S	864341	11/2010	09/23/2010	100.09	99.94	100.03	1
LG&E	C1S	864342	11/2010	09/23/2010	100.08	99.98	100.09	1
LG&E	C1S	864343	11/2010	09/23/2010	100.09	99.94	100.07	1
LG&E	C1S	864344	11/2010	09/23/2010	100.06	100.00	100.13	1
LG&E	C1S	864345	11/2010	09/23/2010	100.10	99.97	100.16	1
LG&E	C1S	864346	11/2010	09/23/2010	100.07	99.89	100.05	1
LG&E	C1S	864347	11/2010	09/23/2010	100.08	100.01	100.16	1
LG&E	C1S	864348	11/2010	09/23/2010	100.07	99.92	99.99	1



LG&E		C1S	864349	11/2010	3/2010	100.05	100.03	100.09	1
LG&E		C1S	864350	11/2010	09/23/2010	100.06	99.98	100.09	1
LG&E		C1S	864351	11/2010	09/23/2010	100.09	100.02	100.00	1
LG&E		C1S	864352	11/2010	09/23/2010	100.06	100.07	100.14	1
LG&E		C1S	864353	11/2010	09/23/2010	100.09	100.01	100.03	1
LG&E		C1S	864354	11/2010	09/23/2010	100.09	99.96	100.08	1
LG&E		C1S	864355	11/2010	09/23/2010	100.08	100.00	100.13	1
LG&E		C1S	864356	11/2010	09/23/2010	100.06	99.92	99.98	1
LG&E		C1S	864357	11/2010	09/23/2010	100.08	99.92	100.12	1
LG&E		C1S	864358	11/2010	09/23/2010	100.07	99.99	100.00	1
LG&E		C1S	864359	11/2010	09/23/2010	100.10	100.03	100.03	1
LG&E		C1S	864360	11/2010	09/23/2010	100.07	100.06	100.20	1
LG&E		C1S	864361	11/2010	09/23/2010	100.06	100.06	100.17	1
LG&E		C1S	864362	11/2010	09/23/2010	100.08	100.02	100.11	1
LG&E		C1S	864363	11/2010	09/23/2010	100.10	100.12	100.14	1
LG&E		C1S	864364	11/2010	09/23/2010	100.07	99.93	99.91	1
LG&E		C1S	864365	11/2010	09/23/2010	100.08	100.05	100.17	1
LG&E		C1S	864366	11/2010	09/23/2010	100.06	99.93	100.04	1
LG&E		C1S	864367	11/2010	09/23/2010	100.09	99.96	99.95	1
LG&E		C1S	864368	11/2010	09/23/2010	100.09	100.08	100.17	1
LG&E		C1S	864369	11/2010	09/23/2010	100.08	100.05	100.12	1
LG&E		C1S	864370	11/2010	09/23/2010	100.05	99.94	100.15	1
LG&E		C1S	864371	11/2010	09/23/2010	100.06	100.01	100.15	1
LG&E		C1S	864372	11/2010	09/23/2010	100.09	100.03	100.06	1
LG&E		C1S	864373	11/2010	09/23/2010	100.08	100.04	100.13	1
LG&E		C1S	864374	11/2010	09/23/2010	100.06	100.03	100.21	1
LG&E		C1S	864375	11/2010	09/23/2010	100.06	100.04	100.09	1
LG&E		C1S	864376	11/2010	09/23/2010	100.08	100.03	100.13	1
LG&E		C1S	864377	11/2010	09/23/2010	100.07	100.02	100.16	1
LG&E		C1S	864378	11/2010	09/23/2010	100.09	99.91	100.12	1
LG&E		C1S	864379	11/2010	09/23/2010	100.09	100.03	100.09	1
LG&E		C1S	864380	11/2010	09/23/2010	100.06	99.95	100.16	1
LG&E		C1S	864381	11/2010	09/23/2010	100.09	100.01	100.06	1
LG&E		C1S	864382	11/2010	09/23/2010	100.09	99.93	100.07	1
LG&E		C1S	864383	11/2010	09/23/2010	100.05	99.90	99.98	1
LG&E		C1S	864384	11/2010	09/23/2010	100.10	99.90	100.18	1

LG&E	CIS	864385	11/2010	09/23/2010	100.06	99.88	100.03	1
LG&E	CIS	864386	11/2010	09/23/2010	100.07	100.04	100.09	1
LG&E	CIS	864387	11/2010	09/23/2010	100.08	99.94	100.06	1
LG&E	CISR	853355	01/2010	06/18/2009	100.10	99.97	100.10	1
LG&E	CISR	853356	01/2010	06/18/2009	100.07	100.02	99.93	1
LG&E	CISR	853357	01/2010	06/18/2009	100.05	99.99	100.04	1
LG&E	CISR	853358	01/2010	06/18/2009	100.07	99.87	100.07	1
LG&E	CISR	853359	01/2010	06/18/2009	100.09	100.03	100.18	1
LG&E	CISR	853360	01/2010	06/18/2009	100.07	100.12	100.18	1
LG&E	CISR	853361	01/2010	06/18/2009	100.07	99.94	100.12	1
LG&E	CISR	853362	01/2010	06/18/2009	100.08	100.03	100.02	1
LG&E	CISR	853363	01/2010	06/18/2009	100.05	100.06	99.94	1
LG&E	CISR	853364	01/2010	06/18/2009	100.08	100.03	100.08	1
LG&E	CISR	853365	01/2010	06/18/2009	100.09	100.03	100.20	1
LG&E	CISR	853366	01/2010	06/18/2009	100.08	100.12	100.11	1
LG&E	CISR	853367	01/2010	06/18/2009	100.07	99.96	100.12	1
LG&E	CISR	853368	01/2010	06/18/2009	100.05	99.90	100.16	1
LG&E	CISR	853369	01/2010	06/18/2009	100.06	99.95	99.92	1
LG&E	CISR	853370	01/2010	06/18/2009	100.10	99.92	100.18	1
LG&E	CISR	853371	01/2010	06/18/2009	100.08	100.02	100.01	1
LG&E	CISR	853372	01/2010	06/18/2009	100.08	100.09	100.15	1
LG&E	CISR	853373	01/2010	06/18/2009	100.08	100.03	100.24	1
LG&E	CISR	853374	01/2010	06/18/2009	100.08	100.04	100.14	1
LG&E	CISR	853375	01/2010	06/18/2009	100.06	100.08	100.17	1
LG&E	CISR	853376	01/2010	06/18/2009	100.10	100.10	100.18	1
LG&E	CISR	853377	01/2010	06/18/2009	100.09	99.97	99.95	1
LG&E	CISR	853378	01/2010	06/18/2009	100.07	99.96	100.17	1
LG&E	CISR	853379	01/2010	06/18/2009	100.06	100.01	99.95	1
LG&E	CISR	853380	01/2010	06/18/2009	100.09	99.95	99.94	1
LG&E	CISR	853381	01/2010	06/18/2009	100.08	99.92	100.09	1
LG&E	CISR	853382	01/2010	06/18/2009	100.06	99.94	100.14	1
LG&E	CISR	853383	01/2010	06/18/2009	100.10	99.97	100.18	1
LG&E	CISR	853384	01/2010	06/18/2009	100.09	100.14	100.20	1
LG&E	CISR	853385	01/2010	06/18/2009	100.06	99.95	100.04	1
LG&E	CISR	853386	01/2010	06/18/2009	100.09	100.01	99.98	1
LG&E	CISR	853387	01/2010	06/18/2009	100.06	99.95	100.15	1

LG&E	C1SR	853388	01/2010	8/2009	100.08	100.07	100.17	1
LG&E	C1SR	853389	01/2010	06/18/2009	100.08	99.88	100.06	1
LG&E	C1SR	853390	01/2010	06/18/2009	100.08	99.94	99.97	1
LG&E	C1SR	853391	01/2010	06/18/2009	100.06	99.98	100.14	1
LG&E	C1SR	853392	01/2010	06/18/2009	100.06	99.91	99.98	1
LG&E	C1SR	853393	01/2010	06/18/2009	100.06	99.84	99.93	1
LG&E	C1SR	853394	01/2010	06/18/2009	100.07	100.05	100.09	1
LG&E	C1SR	853395	01/2010	06/18/2009	100.07	99.97	100.00	1
LG&E	C1SR	853396	01/2010	06/18/2009	100.08	100.00	99.92	1
LG&E	C1SR	853397	01/2010	06/18/2009	100.06	100.03	100.14	1
LG&E	C1SR	853398	01/2010	06/18/2009	100.09	99.94	100.01	1
LG&E	C1SR	853399	01/2010	06/18/2009	100.09	99.99	100.04	1
LG&E	C1SR	853400	01/2010	06/18/2009	100.08	99.98	100.04	1
LG&E	C1SR	853401	01/2010	06/18/2009	100.07	100.09	100.16	1
LG&E	C1SR	853402	01/2010	06/18/2009	100.06	99.91	100.00	1
LG&E	C1SR	853403	01/2010	06/18/2009	100.09	99.91	100.18	1
LG&E	C1SR	853404	01/2010	06/18/2009	100.10	100.04	100.06	1
LG&E	C1SR	853405	01/2010	06/18/2009	100.10	100.02	100.12	1
LG&E	C1SR	853406	01/2010	06/18/2009	100.07	100.03	99.95	1
LG&E	C1SR	853407	01/2010	06/18/2009	100.10	100.00	100.03	1
LG&E	C1SR	853408	01/2010	06/18/2009	100.06	99.87	100.08	1
LG&E	C1SR	853409	01/2010	06/18/2009	100.05	99.89	100.05	1
LG&E	C1SR	853410	01/2010	06/18/2009	100.09	100.01	100.02	1
LG&E	C1SR	853411	01/2010	06/18/2009	100.09	99.90	100.13	1
LG&E	C1SR	853412	01/2010	06/18/2009	100.07	99.93	100.00	1
LG&E	C1SR	853413	01/2010	06/18/2009	100.06	100.02	99.87	1
LG&E	C1SR	853414	01/2010	06/18/2009	100.09	100.09	100.19	1
LG&E	C1SR	853415	01/2010	06/18/2009	100.06	99.91	100.11	1
LG&E	C1SR	853416	01/2010	06/18/2009	100.06	99.96	99.98	1
LG&E	C1SR	853417	01/2010	06/18/2009	100.08	99.99	100.06	1
LG&E	C1SR	853418	01/2010	06/18/2009	100.07	99.97	100.06	1
LG&E	C1SR	853419	01/2010	06/18/2009	100.08	100.00	100.03	1
LG&E	C1SR	853420	01/2010	06/18/2009	100.05	99.98	100.09	1
LG&E	C1SR	853421	01/2010	06/18/2009	100.09	100.03	100.02	1
LG&E	C1SR	853422	01/2010	06/18/2009	100.10	99.99	100.13	1
LG&E	C1SR	853423	01/2010	06/18/2009	100.07	99.96	99.92	1

LG&E	C1SR	853424	01/2010	06/18/2009	100.06	100.06	100.06	100.17	1
LG&E	C1SR	853425	01/2010	06/18/2009	100.08	100.06	100.06	100.02	1
LG&E	C1SR	853426	01/2010	06/18/2009	100.07	100.03	100.01	100.01	1
LG&E	C1SR	853427	01/2010	06/18/2009	100.06	99.93	100.00	100.00	1
LG&E	C1SR	853428	01/2010	06/18/2009	100.09	100.12	100.20	100.20	1
LG&E	C1SR	853429	01/2010	06/18/2009	100.09	100.08	100.13	100.13	1
LG&E	C1SR	853430	01/2010	06/18/2009	100.09	100.09	100.18	100.18	1
LG&E	C1SR	853431	01/2010	06/18/2009	100.09	100.04	100.13	100.13	1
LG&E	C1SR	853432	01/2010	06/18/2009	100.05	99.90	100.13	100.13	1
LG&E	C1SR	853433	01/2010	06/18/2009	100.07	99.97	99.97	99.97	1
LG&E	C1SR	853434	01/2010	06/18/2009	100.06	99.97	100.04	100.04	1
LG&E	C1SR	853435	01/2010	06/18/2009	100.08	99.97	100.10	100.10	1
LG&E	C1SR	853436	01/2010	06/18/2009	100.09	99.98	100.13	100.13	1
LG&E	C1SR	853437	01/2010	06/18/2009	100.06	99.97	100.00	100.00	1
LG&E	C1SR	853438	01/2010	06/18/2009	100.07	100.02	100.00	100.00	1
LG&E	C1SR	853439	01/2010	06/18/2009	100.06	100.06	100.15	100.15	1
LG&E	C1SR	853440	01/2010	06/18/2009	100.08	99.92	100.03	100.03	1
LG&E	C1SR	853441	01/2010	06/18/2009	100.09	100.00	100.08	100.08	1
LG&E	C1SR	853442	01/2010	06/18/2009	100.06	100.03	100.15	100.15	1
LG&E	C1SR	853443	01/2010	06/18/2009	100.09	100.04	100.16	100.16	1
LG&E	C1SR	853444	01/2010	06/18/2009	100.07	99.87	100.00	100.00	1
LG&E	C1SR	853445	01/2010	06/18/2009	100.08	99.91	100.12	100.12	1
LG&E	C1SR	853446	01/2010	06/18/2009	100.06	99.96	100.06	100.06	1
LG&E	C1SR	853447	01/2010	06/18/2009	100.06	99.90	100.04	100.04	1
LG&E	C1SR	853448	01/2010	06/18/2009	100.10	99.96	100.00	100.00	1
LG&E	C1SR	853449	01/2010	06/18/2009	100.07	99.90	100.08	100.08	1
LG&E	C1SR	853450	01/2010	06/18/2009	100.05	99.92	100.04	100.04	1
LG&E	C1SR	853451	01/2010	06/18/2009	100.08	100.00	100.15	100.15	1
LG&E	C1SR	853452	01/2010	06/18/2009	100.08	99.96	100.03	100.03	1
LG&E	C1SR	853453	01/2010	06/18/2009	100.06	100.00	100.17	100.17	1
LG&E	C1SR	853454	01/2010	06/18/2009	100.07	99.88	100.02	100.02	1
LG&E	C1SR	853455	01/2010	06/18/2009	100.07	100.03	100.14	100.14	1
LG&E	C1SR	853456	01/2010	06/18/2009	100.06	100.04	100.14	100.14	1
LG&E	C1SR	853457	01/2010	06/18/2009	100.06	99.87	100.03	100.03	1
LG&E	C1SR	853458	01/2010	06/18/2009	100.07	100.07	100.13	100.13	1
LG&E	C1SR	853459	01/2010	06/18/2009	100.09	99.95	100.06	100.06	1

LG&E	C1SR	853460	01/2010	18/2009	100.07	100.03	100.09	1
LG&E	C1SR	853461	01/2010	06/18/2009	100.08	100.02	100.00	1
LG&E	C1SR	853462	01/2010	06/18/2009	100.09	99.99	100.10	1
LG&E	C1SR	853463	01/2010	06/18/2009	100.07	99.93	100.14	1
LG&E	C1SR	853464	01/2010	06/18/2009	100.09	99.95	99.97	1
LG&E	C1SR	853465	01/2010	06/18/2009	100.08	99.94	99.94	1
LG&E	C1SR	853466	01/2010	06/18/2009	100.07	100.06	100.13	1
LG&E	C1SR	853467	01/2010	06/18/2009	100.08	99.99	100.14	1
LG&E	C1SR	853468	01/2010	06/18/2009	100.08	100.07	100.04	1
LG&E	C1SR	853469	01/2010	06/18/2009	100.07	99.93	99.96	1
LG&E	C1SR	853470	01/2010	06/18/2009	100.10	99.99	100.00	1
LG&E	C1SR	853471	01/2010	06/18/2009	100.09	99.96	100.19	1
LG&E	C1SR	853472	01/2010	06/18/2009	100.07	99.92	100.06	1
LG&E	C1SR	853473	01/2010	06/18/2009	100.09	99.88	99.98	1
LG&E	C1SR	853474	01/2010	06/18/2009	100.07	99.99	99.91	1
LG&E	C1SR	853475	01/2010	06/18/2009	100.08	99.92	100.04	1
LG&E	C1SR	853476	01/2010	06/18/2009	100.09	99.90	100.02	1
LG&E	C1SR	853477	01/2010	06/18/2009	100.07	100.00	99.98	1
LG&E	C1SR	853478	01/2010	06/18/2009	100.10	99.96	100.11	1
LG&E	C1SR	853479	01/2010	06/18/2009	100.08	99.91	100.09	1
LG&E	C1SR	853480	01/2010	06/18/2009	100.07	99.98	100.05	1
LG&E	C1SR	853481	01/2010	06/18/2009	100.09	99.94	100.00	1
LG&E	C1SR	853482	01/2010	06/18/2009	100.08	99.98	100.09	1
LG&E	C1SR	853483	01/2010	06/18/2009	100.10	99.94	100.01	1
LG&E	C1SR	853484	01/2010	06/18/2009	100.08	99.94	100.08	1
LG&E	C1SR	853485	01/2010	06/18/2009	100.06	100.02	99.99	1
LG&E	C1SR	853486	01/2010	06/18/2009	100.07	99.87	100.08	1
LG&E	C1SR	853487	01/2010	06/18/2009	100.09	99.96	100.08	1
LG&E	C1SR	853488	01/2010	06/18/2009	100.07	99.98	99.98	1
LG&E	C1SR	853489	01/2010	06/18/2009	100.07	99.83	100.04	1
LG&E	C1SR	853490	01/2010	06/18/2009	100.08	100.03	100.02	1
LG&E	C1SR	853491	01/2010	06/18/2009	100.09	100.07	100.15	1
LG&E	C1SR	853492	01/2010	06/18/2009	100.08	99.92	100.13	1
LG&E	C1SR	853493	01/2010	06/18/2009	100.08	100.00	100.18	1
LG&E	C1SR	853494	01/2010	06/18/2009	100.07	99.98	100.06	1
LG&E	C1SR	853495	01/2010	06/18/2009	100.06	99.82	100.10	1

LG&E	CISR	853496	01/2010	06/18/2009	100.08	99.91	100.09	1
LG&E	CISR	853497	01/2010	06/18/2009	100.08	100.01	100.15	1
LG&E	CISR	853498	01/2010	06/18/2009	100.08	100.11	100.18	1
LG&E	CISR	853499	01/2010	06/18/2009	100.06	100.07	100.11	1
LG&E	CISR	853500	01/2010	06/18/2009	100.08	99.87	99.91	1
LG&E	CISR	853501	01/2010	06/18/2009	100.06	100.05	100.02	1
LG&E	CISR	853502	01/2010	06/18/2009	100.05	99.90	100.10	1
LG&E	CISR	853503	01/2010	06/18/2009	100.07	99.97	100.22	1
LG&E	CISR	853504	01/2010	06/18/2009	100.07	100.02	100.07	1
LG&E	CISR	853505	01/2010	06/18/2009	100.10	99.99	100.14	1
LG&E	CISR	853506	01/2010	06/18/2009	100.07	99.96	100.13	1
LG&E	CISR	853507	01/2010	06/18/2009	100.09	99.99	99.98	1
LG&E	CISR	853508	01/2010	06/18/2009	100.09	99.97	100.05	1
LG&E	CISR	853509	01/2010	06/18/2009	100.06	99.96	100.12	1
LG&E	CISR	853510	01/2010	06/18/2009	100.08	100.00	100.14	1
LG&E	CISR	853511	01/2010	06/18/2009	100.09	100.06	100.14	1
LG&E	CISR	853512	01/2010	06/18/2009	100.09	99.99	100.05	1
LG&E	CISR	853513	01/2010	06/18/2009	100.06	99.97	100.16	1
LG&E	CISR	853514	01/2010	06/18/2009	100.10	100.15	100.22	1
LG&E	CISR	853515	01/2010	06/18/2009	100.09	99.99	100.01	1
LG&E	CISR	853516	01/2010	06/18/2009	100.10	100.06	100.19	1
LG&E	CISR	853517	01/2010	06/18/2009	100.07	99.95	99.96	1
LG&E	CISR	853518	01/2010	06/18/2009	100.09	99.97	100.10	1
LG&E	CISR	853519	01/2010	06/18/2009	100.07	99.85	100.07	1
LG&E	CISR	853520	01/2010	06/18/2009	100.07	99.98	100.24	1
LG&E	CISR	853521	01/2010	06/18/2009	100.07	100.05	100.02	1
LG&E	CISR	853522	01/2010	06/18/2009	100.06	100.06	100.15	1
LG&E	CISR	853523	01/2010	06/18/2009	100.09	100.11	100.15	1
LG&E	CISR	853524	01/2010	06/18/2009	100.08	99.99	100.08	1
LG&E	CISR	853525	01/2010	06/18/2009	100.06	99.92	100.08	1
LG&E	CISR	853526	01/2010	06/18/2009	100.06	99.92	100.12	1
LG&E	CISR	853527	01/2010	06/18/2009	100.07	99.92	100.10	1
LG&E	CISR	853528	01/2010	06/18/2009	100.06	99.94	100.04	1
LG&E	CISR	853529	01/2010	06/18/2009	100.06	100.01	100.13	1
LG&E	CISR	853530	01/2010	06/18/2009	100.09	99.95	100.00	1
LG&E	CISR	853531	01/2010	06/18/2009	100.10	100.09	100.24	1

LG&E	C1SR	853532	01/2010	18/2009	100.06	99.92	100.09	1
LG&E	C1SR	853533	01/2010	06/18/2009	100.09	99.92	100.06	1
LG&E	C1SR	853534	01/2010	06/18/2009	100.06	99.92	100.06	1
LG&E	C1SR	853535	01/2010	06/18/2009	100.06	99.89	100.09	1
LG&E	C1SR	853536	01/2010	06/18/2009	100.06	100.01	99.92	1
LG&E	C1SR	853537	01/2010	06/18/2009	100.09	100.10	100.14	1
LG&E	C1SR	853538	01/2010	06/18/2009	100.09	100.05	100.13	1
LG&E	C1SR	853539	01/2010	06/18/2009	100.06	100.04	100.15	1
LG&E	C1SR	853540	01/2010	06/18/2009	100.08	100.10	100.21	1
LG&E	C1SR	853541	01/2010	06/18/2009	100.06	100.09	100.13	1
LG&E	C1SR	853542	01/2010	06/18/2009	100.06	99.92	99.95	1
LG&E	C1SR	853543	01/2010	06/18/2009	100.06	99.94	99.99	1
LG&E	C1SR	853544	01/2010	06/18/2009	100.07	100.06	100.07	1
LG&E	C1SR	853545	01/2010	06/18/2009	100.08	100.09	100.15	1
LG&E	C1SR	853546	01/2010	06/18/2009	100.10	100.04	100.20	1
LG&E	C1SR	856691	01/2010	12/04/2009	100.06	99.92	100.13	1
LG&E	C1SR	856692	01/2010	12/04/2009	100.06	100.02	100.13	1
LG&E	C1SR	856693	01/2010	12/04/2009	100.08	99.97	100.01	1
LG&E	C1SR	856694	01/2010	12/04/2009	100.09	100.00	100.06	1
LG&E	C1SR	856695	01/2010	12/04/2009	100.08	99.90	100.09	1
LG&E	C1SR	856696	01/2010	12/04/2009	100.10	100.10	100.19	1
LG&E	C1SR	856697	01/2010	12/04/2009	100.08	99.82	100.02	1
LG&E	C1SR	856698	01/2010	12/04/2009	100.09	99.98	100.07	1
LG&E	C1SR	856699	01/2010	12/04/2009	100.08	99.96	99.93	1
LG&E	C1SR	856700	01/2010	12/04/2009	100.07	100.09	100.18	1
LG&E	C1SR	856701	01/2010	12/04/2009	100.07	100.02	100.07	1
LG&E	C1SR	856702	01/2010	12/04/2009	100.07	99.93	100.04	1
LG&E	C1SR	856703	01/2010	12/04/2009	100.06	99.94	99.95	1
LG&E	C1SR	856704	01/2010	12/04/2009	100.09	99.89	100.03	1
LG&E	C1SR	856705	01/2010	12/04/2009	100.07	100.01	100.04	1
LG&E	C1SR	856706	01/2010	12/04/2009	100.06	100.10	100.03	1
LG&E	C1SR	856707	01/2010	12/04/2009	100.09	100.07	100.08	1
LG&E	C1SR	856708	01/2010	12/04/2009	100.10	100.03	99.97	1
LG&E	C1SR	856709	01/2010	12/04/2009	100.10	100.05	100.16	1
LG&E	C1SR	856710	01/2010	12/04/2009	100.09	99.93	100.02	1
LG&E	C1SR	856711	01/2010	12/04/2009	100.07	99.98	99.92	1

LG&E	C1SR	856712	01/2010	12/04/2009	100.08	99.97	100.05	1
LG&E	C1SR	856713	01/2010	12/04/2009	100.09	100.03	99.96	1
LG&E	C1SR	856714	01/2010	12/04/2009	100.10	100.05	100.01	1
LG&E	C1SR	856715	01/2010	12/04/2009	100.08	99.95	100.07	1
LG&E	C1SR	856716	01/2010	12/04/2009	100.08	99.85	100.04	1
LG&E	C1SR	856717	01/2010	12/04/2009	100.07	99.92	100.02	1
LG&E	C1SR	856718	01/2010	12/04/2009	100.10	99.97	100.00	1
LG&E	C1SR	856719	01/2010	12/04/2009	100.06	99.94	100.06	1
LG&E	C1SR	856720	01/2010	12/04/2009	100.10	99.90	100.04	1
LG&E	C1SR	856721	01/2010	12/04/2009	100.09	99.90	100.11	1
LG&E	C1SR	856722	01/2010	12/04/2009	100.06	100.00	100.01	1
LG&E	C1SR	856723	01/2010	12/04/2009	100.06	99.92	100.09	1
LG&E	C1SR	856724	01/2010	12/04/2009	100.08	99.95	100.04	1
LG&E	C1SR	856725	01/2010	12/04/2009	100.09	100.02	99.99	1
LG&E	C1SR	856726	01/2010	12/04/2009	100.07	99.99	100.05	1
LG&E	C1SR	856727	01/2010	12/04/2009	100.08	99.92	99.95	1
LG&E	C1SR	856728	01/2010	12/04/2009	100.07	99.99	100.06	1
LG&E	C1SR	856729	01/2010	12/04/2009	100.09	100.05	100.19	1
LG&E	C1SR	856730	01/2010	12/04/2009	100.10	99.92	100.05	1
LG&E	C1SR	856731	01/2010	12/04/2009	100.09	99.97	100.11	1
LG&E	C1SR	856732	01/2010	12/04/2009	100.06	99.91	100.04	1
LG&E	C1SR	856733	01/2010	12/04/2009	100.09	99.85	100.11	1
LG&E	C1SR	856734	01/2010	12/04/2009	100.08	99.92	100.08	1
LG&E	C1SR	856735	01/2010	12/04/2009	100.06	99.92	100.05	1
LG&E	C1SR	856736	01/2010	12/04/2009	100.08	99.98	100.09	1
LG&E	C1SR	856737	01/2010	12/04/2009	100.08	99.98	100.07	1
LG&E	C1SR	856738	01/2010	12/04/2009	100.08	99.86	100.08	1
LG&E	C1SR	856739	01/2010	12/04/2009	100.08	100.08	100.11	1
LG&E	C1SR	856740	01/2010	12/04/2009	100.08	99.81	100.08	1
LG&E	C1SR	856741	01/2010	12/04/2009	100.08	100.01	100.02	1
LG&E	C1SR	856742	01/2010	12/04/2009	100.08	100.00	100.13	1
LG&E	C1SR	856743	01/2010	12/04/2009	100.06	99.99	99.96	1
LG&E	C1SR	856744	01/2010	12/04/2009	100.06	99.95	99.91	1
LG&E	C1SR	856745	01/2010	12/04/2009	100.09	99.92	100.18	1
LG&E	C1SR	856746	01/2010	12/04/2009	100.08	100.09	100.17	1
LG&E	C1SR	856747	01/2010	12/04/2009	100.10	100.10	100.19	1



LG&E	C1SR	856748	01/2010	04/2009	100.08	100.10	100.11	1
LG&E	C1SR	856749	01/2010	12/04/2009	100.10	99.81	100.05	1
LG&E	C1SR	856750	01/2010	12/04/2009	100.09	100.11	100.20	1
LG&E	C1SR	856751	01/2010	12/04/2009	100.07	100.01	100.13	1
LG&E	C1SR	856752	01/2010	12/04/2009	100.09	100.07	100.20	1
LG&E	C1SR	856753	01/2010	12/04/2009	100.09	100.05	100.12	1
LG&E	C1SR	856754	01/2010	12/04/2009	100.05	100.00	100.11	1
LG&E	C1SR	856755	01/2010	12/04/2009	100.09	100.13	100.20	1
LG&E	C1SR	856756	01/2010	12/04/2009	100.09	99.92	100.03	1
LG&E	C1SR	856757	01/2010	12/04/2009	100.06	99.99	100.13	1
LG&E	C1SR	856758	01/2010	12/04/2009	100.05	99.99	100.11	1
LG&E	C1SR	856759	01/2010	12/04/2009	100.06	99.89	99.96	1
LG&E	C1SR	856760	01/2010	12/04/2009	100.09	99.94	100.16	1
LG&E	C1SR	856761	01/2010	12/04/2009	100.07	100.05	99.98	1
LG&E	C1SR	856762	01/2010	12/04/2009	100.06	99.95	99.97	1
LG&E	C1SR	856763	01/2010	12/04/2009	100.09	99.98	99.99	1
LG&E	C1SR	856764	01/2010	12/04/2009	100.08	100.06	100.07	1
LG&E	C1SR	856765	01/2010	12/04/2009	100.08	100.04	100.14	1
LG&E	C1SR	856766	01/2010	12/04/2009	100.07	99.98	100.05	1
LG&E	C1SR	856767	01/2010	12/04/2009	100.08	100.05	100.11	1
LG&E	C1SR	856768	01/2010	12/04/2009	100.06	100.00	100.15	1
LG&E	C1SR	856769	01/2010	12/04/2009	100.10	99.97	100.02	1
LG&E	C1SR	856770	01/2010	12/04/2009	100.06	99.95	99.94	1
LG&E	C1SR	856771	01/2010	12/04/2009	100.05	99.96	99.96	1
LG&E	C1SR	856772	01/2010	12/04/2009	100.09	99.94	100.03	1
LG&E	C1SR	856773	01/2010	12/04/2009	100.10	100.00	100.13	1
LG&E	C1SR	856774	01/2010	12/04/2009	100.10	99.95	99.98	1
LG&E	C1SR	856775	01/2010	12/04/2009	100.06	99.93	100.07	1
LG&E	C1SR	856776	01/2010	12/04/2009	100.05	99.99	99.98	1
LG&E	C1SR	856777	01/2010	12/04/2009	100.08	99.89	100.10	1
LG&E	C1SR	856778	01/2010	12/04/2009	100.09	99.97	100.17	1
LG&E	C1SR	856779	01/2010	12/04/2009	100.07	99.93	100.06	1
LG&E	C1SR	856780	01/2010	12/04/2009	100.06	99.89	100.04	1
LG&E	C1SR	856781	01/2010	12/04/2009	100.06	99.82	100.02	1
LG&E	C1SR	856782	01/2010	12/04/2009	100.09	100.03	100.08	1
LG&E	C1SR	856783	01/2010	12/04/2009	100.07	99.82	100.08	1

LG&E	C1SR	856784	01/2010	12/04/2009	100.09	99.88	100.06	1
LG&E	C1SR	856785	01/2010	12/04/2009	100.08	99.87	100.04	1
LG&E	C1SR	856786	01/2010	12/04/2009	100.08	100.02	99.97	1
LG&E	C1SR	856787	01/2010	12/04/2009	100.11	100.05	100.03	1
LG&E	C1SR	856788	01/2010	12/04/2009	100.07	99.90	100.06	1
LG&E	C1SR	856789	01/2010	12/04/2009	100.10	100.02	100.12	1
LG&E	C1SR	856790	01/2010	12/04/2009	100.09	100.01	99.98	1
LG&E	C1SR	856791	01/2010	12/04/2009	100.07	100.02	100.17	1
LG&E	C1SR	856792	01/2010	12/04/2009	100.10	100.04	100.20	1
LG&E	C1SR	856793	01/2010	12/04/2009	100.09	99.90	100.02	1
LG&E	C1SR	856794	01/2010	12/04/2009	100.08	99.94	99.97	1
LG&E	C1SR	856795	01/2010	12/04/2009	100.09	100.11	100.03	1
LG&E	C1SR	856796	01/2010	12/04/2009	100.08	99.98	100.14	1
LG&E	C1SR	856797	01/2010	12/04/2009	100.09	100.01	100.02	1
LG&E	C1SR	856798	01/2010	12/04/2009	100.06	99.87	100.12	1
LG&E	C1SR	856799	01/2010	12/04/2009	100.06	100.02	100.13	1
LG&E	C1SR	856800	01/2010	12/04/2009	100.08	100.14	100.19	1
LG&E	C1SR	856801	01/2010	12/04/2009	100.08	100.07	100.09	1
LG&E	C1SR	856802	01/2010	12/04/2009	100.06	99.97	99.97	1
LG&E	C1SR	856803	01/2010	12/04/2009	100.06	99.99	100.00	1
LG&E	C1SR	856804	01/2010	12/04/2009	100.10	100.03	100.14	1
LG&E	C1SR	856805	01/2010	12/04/2009	100.06	99.95	100.00	1
LG&E	C1SR	856806	01/2010	12/04/2009	100.09	99.91	100.06	1
LG&E	C1SR	856807	01/2010	12/04/2009	100.08	99.94	100.08	1
LG&E	C1SR	856808	01/2010	12/04/2009	100.10	99.89	100.05	1
LG&E	C1SR	856809	01/2010	12/04/2009	100.08	100.02	99.98	1
LG&E	C1SR	856810	01/2010	12/04/2009	100.06	100.02	100.01	1
LG&E	C1SR	856811	01/2010	12/04/2009	100.07	100.10	100.12	1
LG&E	C1SR	856812	01/2010	12/04/2009	100.06	99.88	100.02	1
LG&E	C1SR	856813	01/2010	12/04/2009	100.08	99.91	100.04	1
LG&E	C1SR	856814	01/2010	12/04/2009	100.08	100.00	100.03	1
LG&E	C1SR	856815	01/2010	12/04/2009	100.08	99.98	100.11	1
LG&E	C1SR	856816	01/2010	12/04/2009	100.10	99.85	100.01	1
LG&E	C1SR	856817	01/2010	12/04/2009	100.08	100.00	100.12	1
LG&E	C1SR	856818	01/2010	12/04/2009	100.10	99.98	100.06	1
LG&E	C1SR	856819	01/2010	12/04/2009	100.09	100.10	100.16	1

LG&E	C1SR	856820	01/2010	04/2009	100.11	100.09	100.08	1
LG&E	C1SR	856821	01/2010	12/04/2009	100.07	99.96	100.09	1
LG&E	C1SR	856822	01/2010	12/04/2009	100.06	100.07	100.17	1
LG&E	C1SR	856823	01/2010	12/04/2009	100.09	99.90	100.12	1
LG&E	C1SR	856824	01/2010	12/04/2009	100.08	99.89	100.01	1
LG&E	C1SR	856825	01/2010	12/04/2009	100.08	100.06	100.15	1
LG&E	C1SR	856826	01/2010	12/04/2009	100.07	99.98	100.01	1
LG&E	C1SR	856827	01/2010	12/04/2009	100.09	99.91	100.15	1
LG&E	C1SR	856828	01/2010	12/04/2009	100.08	99.99	100.05	1
LG&E	C1SR	856829	01/2010	12/04/2009	100.07	99.99	100.11	1
LG&E	C1SR	856830	01/2010	12/04/2009	100.10	99.97	100.08	1
LG&E	C1SR	856831	01/2010	12/04/2009	100.10	100.05	100.19	1
LG&E	C1SR	856832	01/2010	12/04/2009	100.05	100.03	100.14	1
LG&E	C1SR	856833	01/2010	12/04/2009	100.07	100.11	100.16	1
LG&E	C1SR	856834	01/2010	12/04/2009	100.10	99.97	100.14	1
LG&E	C1SR	856835	01/2010	12/04/2009	100.09	100.06	100.19	1
LG&E	C1SR	856836	01/2010	12/04/2009	100.08	100.04	100.15	1
LG&E	C1SR	856837	01/2010	12/04/2009	100.09	99.93	100.03	1
LG&E	C1SR	856838	01/2010	12/04/2009	100.06	99.93	100.04	1
LG&E	C1SR	856839	01/2010	12/04/2009	100.09	100.03	100.08	1
LG&E	C1SR	856840	01/2010	12/04/2009	100.07	99.97	99.99	1
LG&E	C1SR	856841	01/2010	12/04/2009	100.07	99.90	100.04	1
LG&E	C1SR	856842	01/2010	12/04/2009	100.08	99.90	100.01	1
LG&E	C1SR	856843	01/2010	12/04/2009	100.09	99.95	100.03	1
LG&E	C1SR	856844	01/2010	12/04/2009	100.09	99.93	100.21	1
LG&E	C1SR	856845	01/2010	12/04/2009	100.08	99.86	100.08	1
LG&E	C1SR	856846	01/2010	12/04/2009	100.09	99.95	100.07	1
LG&E	C1SR	856847	01/2010	12/04/2009	100.06	99.86	100.11	1
LG&E	C1SR	856848	01/2010	12/04/2009	100.05	100.07	100.19	1
LG&E	C1SR	856849	01/2010	12/04/2009	100.10	100.09	100.10	1
LG&E	C1SR	856850	01/2010	12/04/2009	100.08	99.93	100.10	1
LG&E	C1SR	856851	01/2010	12/04/2009	100.09	100.03	100.05	1
LG&E	C1SR	856852	01/2010	12/04/2009	100.06	100.04	100.08	1
LG&E	C1SR	856853	01/2010	12/04/2009	100.05	100.05	100.16	1
LG&E	C1SR	856854	01/2010	12/04/2009	100.06	99.86	100.11	1
LG&E	C1SR	856855	01/2010	12/04/2009	100.08	100.09	100.20	1

LG&E	CISR	856856	01/2010	04/2009	100.08	99.97	100.13	1
LG&E	CISR	856857	01/2010	12/04/2009	100.09	100.14	100.19	1
LG&E	CISR	856858	01/2010	12/04/2009	100.10	100.09	100.17	1
LG&E	CISR	856859	01/2010	12/04/2009	100.06	99.82	99.96	1
LG&E	CISR	856860	01/2010	12/04/2009	100.08	99.91	100.03	1
LG&E	CISR	856861	01/2010	12/04/2009	100.09	100.04	100.16	1
LG&E	CISR	856862	01/2010	12/04/2009	100.06	99.97	100.05	1
LG&E	CISR	856863	01/2010	12/04/2009	100.05	99.91	100.05	1
LG&E	CISR	856864	01/2010	12/04/2009	100.08	99.98	100.15	1
LG&E	CISR	856865	01/2010	12/04/2009	100.08	99.96	100.08	1
LG&E	CISR	856866	01/2010	12/04/2009	100.07	100.05	100.16	1
LG&E	CISR	856867	01/2010	12/04/2009	100.08	100.08	100.18	1
LG&E	CISR	856868	01/2010	12/04/2009	100.09	100.01	100.04	1
LG&E	CISR	856869	01/2010	12/04/2009	100.07	100.03	100.09	1
LG&E	CISR	856870	01/2010	12/04/2009	100.05	99.85	100.03	1
LG&E	CISR	856871	01/2010	12/04/2009	100.08	100.09	100.16	1
LG&E	CISR	856872	01/2010	12/04/2009	100.09	99.97	100.05	1
LG&E	CISR	856873	01/2010	12/04/2009	100.07	99.93	100.12	1
LG&E	CISR	856874	01/2010	12/04/2009	100.10	100.10	100.21	1
LG&E	CISR	856875	01/2010	12/04/2009	100.09	99.98	99.98	1
LG&E	CISR	856876	01/2010	12/04/2009	100.06	100.00	99.97	1
LG&E	CISR	856877	01/2010	12/04/2009	100.06	99.99	100.10	1
LG&E	CISR	856878	01/2010	12/04/2009	100.08	99.84	100.08	1
LG&E	CISR	856879	01/2010	12/04/2009	100.08	100.04	99.97	1
LG&E	CISR	856880	01/2010	12/04/2009	100.05	99.93	100.02	1
LG&E	CISR	856881	01/2010	12/04/2009	100.08	100.05	100.22	1
LG&E	CISR	856882	01/2010	12/04/2009	100.07	100.00	100.11	1
LG&E	CISR	861840	08/2010	06/23/2010	100.08	99.99	100.15	1
LG&E	CISR	861841	08/2010	06/23/2010	100.08	100.12	100.22	1
LG&E	CISR	861842	08/2010	06/23/2010	100.10	99.89	100.18	1
LG&E	CISR	861843	08/2010	06/23/2010	100.09	100.03	100.07	1
LG&E	CISR	861844	08/2010	06/23/2010	100.05	100.01	100.22	1
LG&E	CISR	861845	08/2010	06/23/2010	100.06	100.00	100.13	1
LG&E	CISR	861846	08/2010	06/23/2010	100.09	100.04	100.03	1
LG&E	CISR	861847	08/2010	06/23/2010	100.08	100.09	100.15	1
LG&E	CISR	861848	08/2010	06/23/2010	100.10	100.07	100.14	1

LG&E	C1SR	861849	08/2010	03/2010	100.10	100.08	100.19	1
LG&E	C1SR	861850	08/2010	06/23/2010	100.05	100.08	100.15	1
LG&E	C1SR	861851	08/2010	06/23/2010	100.06	99.96	100.11	1
LG&E	C1SR	861852	08/2010	06/23/2010	100.10	100.04	100.14	1
LG&E	C1SR	861853	08/2010	06/23/2010	100.07	100.08	100.05	1
LG&E	C1SR	861854	08/2010	06/23/2010	100.10	100.02	100.16	1
LG&E	C1SR	861855	08/2010	06/23/2010	100.06	99.98	100.00	1
LG&E	C1SR	861856	08/2010	06/23/2010	100.08	99.94	100.00	1
LG&E	C1SR	861857	08/2010	06/23/2010	100.06	99.98	100.10	1
LG&E	C1SR	861858	08/2010	06/23/2010	100.08	99.92	100.15	1
LG&E	C1SR	861859	08/2010	06/23/2010	100.06	99.91	100.07	1
LG&E	C1SR	861860	08/2010	06/23/2010	100.10	100.13	100.21	1
LG&E	C1SR	861861	08/2010	06/23/2010	100.09	100.11	100.17	1
LG&E	C1SR	861862	08/2010	06/23/2010	100.06	100.00	100.08	1
LG&E	C1SR	861863	08/2010	06/23/2010	100.06	99.92	100.04	1
LG&E	C1SR	861864	08/2010	06/23/2010	100.08	100.05	100.15	1
LG&E	C1SR	861865	08/2010	06/23/2010	100.10	100.06	100.17	1
LG&E	C1SR	861866	08/2010	06/23/2010	100.10	99.99	100.06	1
LG&E	C1SR	861867	08/2010	06/23/2010	100.10	100.09	100.23	1
LG&E	C1SR	861868	08/2010	06/23/2010	100.10	99.95	100.12	1
LG&E	C1SR	861869	08/2010	06/23/2010	100.08	99.92	100.12	1
LG&E	C1SR	861870	08/2010	06/23/2010	100.09	100.09	100.17	1
LG&E	C1SR	861871	08/2010	06/23/2010	100.09	99.98	100.09	1
LG&E	C1SR	861872	08/2010	06/23/2010	100.05	100.02	100.06	1
LG&E	C1SR	861873	08/2010	06/23/2010	100.05	100.03	100.17	1
LG&E	C1SR	861874	08/2010	06/23/2010	100.10	100.07	100.25	1
LG&E	C1SR	861875	08/2010	06/23/2010	100.08	100.07	100.13	1
LG&E	C1SR	861876	08/2010	06/23/2010	100.08	100.08	100.00	1
LG&E	C1SR	861877	08/2010	06/23/2010	100.08	100.04	100.10	1
LG&E	C1SR	861878	08/2010	06/23/2010	100.06	100.05	100.13	1
LG&E	C1SR	861879	08/2010	06/23/2010	100.07	99.94	100.01	1
LG&E	C1SR	861880	08/2010	06/23/2010	100.10	99.96	100.12	1
LG&E	C1SR	861881	08/2010	06/23/2010	100.08	100.02	100.14	1
LG&E	C1SR	861882	08/2010	06/23/2010	100.10	99.99	100.06	1
LG&E	C1SR	861883	08/2010	06/23/2010	100.06	99.98	99.87	1
LG&E	C1SR	861884	08/2010	06/23/2010	100.06	99.84	100.00	1

LG&E	C1SR	861885	08/2010	06/23/2010	100.10	99.97	100.06	1
LG&E	C1SR	861886	08/2010	06/23/2010	100.09	100.13	100.12	1
LG&E	C1SR	861887	08/2010	06/23/2010	100.11	100.02	100.14	1
LG&E	C1SR	861888	08/2010	06/23/2010	100.10	99.98	100.00	1
LG&E	C1SR	861889	08/2010	06/23/2010	100.07	100.08	100.13	1
LG&E	C1SR	861890	08/2010	06/23/2010	100.07	99.89	100.13	1
LG&E	C1SR	861891	08/2010	06/23/2010	100.09	100.00	100.15	1
LG&E	C1SR	861892	08/2010	06/23/2010	100.09	100.05	100.20	1
LG&E	C1SR	861893	08/2010	06/23/2010	100.07	99.93	100.06	1
LG&E	C1SR	861894	08/2010	06/23/2010	100.10	100.07	100.20	1
LG&E	C1SR	861895	08/2010	06/23/2010	100.08	100.00	100.00	1
LG&E	C1SR	861896	08/2010	06/23/2010	100.07	99.97	100.10	1
LG&E	C1SR	861897	08/2010	06/23/2010	100.08	99.93	100.05	1
LG&E	C1SR	861898	08/2010	06/23/2010	100.10	99.94	100.04	1
LG&E	C1SR	861899	08/2010	06/23/2010	100.06	99.96	99.97	1
LG&E	C1SR	861900	08/2010	06/23/2010	100.09	100.03	100.17	1
LG&E	C1SR	861901	08/2010	06/23/2010	100.08	99.91	99.97	1
LG&E	C1SR	861902	08/2010	06/23/2010	100.09	100.01	100.20	1
LG&E	C1SR	861903	08/2010	06/23/2010	100.07	100.03	100.09	1
LG&E	C1SR	861904	08/2010	06/23/2010	100.07	99.91	100.09	1
LG&E	C1SR	861905	08/2010	06/23/2010	100.09	99.99	100.03	1
LG&E	C1SR	861906	08/2010	06/23/2010	100.10	100.08	100.20	1
LG&E	C1SR	861907	08/2010	06/23/2010	100.08	100.05	100.12	1
LG&E	C1SR	861908	08/2010	06/23/2010	100.08	99.97	99.97	1
LG&E	C1SR	861909	08/2010	06/23/2010	100.06	100.00	100.17	1
LG&E	C1SR	861910	08/2010	06/23/2010	100.05	99.96	100.01	1
LG&E	C1SR	861911	08/2010	06/23/2010	100.10	99.98	100.04	1
LG&E	C1SR	861912	08/2010	06/23/2010	100.10	100.06	100.21	1
LG&E	C1SR	861913	08/2010	06/23/2010	100.06	99.97	100.08	1
LG&E	C1SR	861914	08/2010	06/23/2010	100.06	99.95	100.01	1
LG&E	C1SR	861915	08/2010	06/23/2010	100.10	100.05	100.14	1
LG&E	C1SR	861916	08/2010	06/23/2010	100.07	99.93	99.95	1
LG&E	C1SR	861917	08/2010	06/23/2010	100.07	100.07	100.11	1
LG&E	C1SR	861918	08/2010	06/23/2010	100.06	99.98	100.12	1
LG&E	C1SR	861919	08/2010	06/23/2010	100.09	100.09	100.17	1
LG&E	C1SR	861920	08/2010	06/23/2010	100.06	99.97	100.13	1

LG&E		C1SR	861921	08/2010	03/2010	100.06	100.06	100.06	100.12	1
LG&E		C1SR	861922	08/2010	06/23/2010	100.08	100.08	99.87	100.04	1
LG&E		C1SR	861923	08/2010	06/23/2010	100.08	100.08	100.12	100.18	1
LG&E		C1SR	861924	08/2010	06/23/2010	100.08	100.08	100.08	100.15	1
LG&E		C1SR	861925	08/2010	06/23/2010	100.06	100.06	99.89	99.96	1
LG&E		C1SR	861926	08/2010	06/23/2010	100.06	100.06	100.00	99.95	1
LG&E		C1SR	861927	08/2010	06/23/2010	100.08	100.08	99.99	100.19	1
LG&E		C1SR	861928	08/2010	06/23/2010	100.07	100.07	99.90	100.03	1
LG&E		C1SR	861929	08/2010	06/23/2010	100.06	100.06	100.05	100.09	1
LG&E		C1SR	861930	08/2010	06/23/2010	100.08	100.08	100.05	100.11	1
LG&E		C1SR	861931	08/2010	06/23/2010	100.09	100.09	99.94	100.01	1
LG&E		C1SR	861932	08/2010	06/23/2010	100.08	100.08	99.91	100.09	1
LG&E		C1SR	861933	08/2010	06/23/2010	100.08	100.08	99.90	100.00	1
LG&E		C1SR	861934	08/2010	06/23/2010	100.07	100.07	99.91	100.06	1
LG&E		C1SR	861935	08/2010	06/23/2010	100.06	100.06	100.05	100.14	1
LG&E		C1SR	861936	08/2010	06/23/2010	100.06	100.06	100.01	100.11	1
LG&E		C1SR	861937	08/2010	06/23/2010	100.06	100.06	99.94	99.97	1
LG&E		C1SR	861938	08/2010	06/23/2010	100.05	100.05	99.93	99.94	1
LG&E		C1SR	861939	08/2010	06/23/2010	100.09	100.09	100.02	100.18	1
LG&E		C1SR	861940	08/2010	06/23/2010	100.10	100.10	100.05	100.17	1
LG&E		C1SR	861941	08/2010	06/23/2010	100.06	100.06	100.05	100.15	1
LG&E		C1SR	861942	08/2010	06/23/2010	100.09	100.09	99.97	100.07	1
LG&E		C1SR	861943	08/2010	06/23/2010	100.05	100.05	100.00	100.15	1
LG&E		C1SR	861944	08/2010	06/23/2010	100.07	100.07	99.93	99.97	1
LG&E		C1SR	861945	08/2010	06/23/2010	100.06	100.06	100.03	100.11	1
LG&E		C1SR	861946	08/2010	06/23/2010	100.07	100.07	99.89	99.94	1
LG&E		C1SR	861947	08/2010	06/23/2010	100.08	100.08	99.95	100.10	1
LG&E		C1SR	861948	08/2010	06/23/2010	100.09	100.09	99.93	100.05	1
LG&E		C1SR	861949	08/2010	06/23/2010	100.05	100.05	99.97	99.97	1
LG&E		C1SR	861950	08/2010	06/23/2010	100.09	100.09	99.92	100.14	1
LG&E		C1SR	861951	08/2010	06/23/2010	100.08	100.08	100.06	100.14	1
LG&E		C1SR	861952	08/2010	06/23/2010	100.09	100.09	99.84	100.06	1
LG&E		C1SR	861953	08/2010	06/23/2010	100.09	100.09	99.98	100.17	1
LG&E		C1SR	861954	08/2010	06/23/2010	100.10	100.10	100.00	100.15	1
LG&E		C1SR	861955	08/2010	06/23/2010	100.05	100.05	99.99	100.08	1
LG&E		C1SR	861956	08/2010	06/23/2010	100.10	100.10	99.98	100.03	1

LG&E	CISR	861957	08/2010	23/2010	100.08	100.00	100.16	1
LG&E	CISR	861958	08/2010	06/23/2010	100.08	99.91	100.10	1
LG&E	CISR	861959	08/2010	06/23/2010	100.09	99.95	100.12	1
LG&E	CISR	861960	08/2010	06/23/2010	100.09	100.03	100.10	1
LG&E	CISR	861961	08/2010	06/23/2010	100.09	99.85	100.11	1
LG&E	CISR	861962	08/2010	06/23/2010	100.06	99.91	100.09	1
LG&E	CISR	861963	08/2010	06/23/2010	100.09	100.08	100.10	1
LG&E	CISR	861964	08/2010	06/23/2010	100.06	99.96	100.04	1
LG&E	CISR	861965	08/2010	06/23/2010	100.09	100.06	100.15	1
LG&E	CISR	861966	08/2010	06/23/2010	100.10	100.12	100.15	1
LG&E	CISR	861967	08/2010	06/23/2010	100.09	100.02	100.11	1
LG&E	CISR	861968	08/2010	06/23/2010	100.09	99.91	100.07	1
LG&E	CISR	861969	08/2010	06/23/2010	100.09	99.92	100.07	1
LG&E	CISR	861970	08/2010	06/23/2010	100.05	99.94	100.03	1
LG&E	CISR	861971	08/2010	06/23/2010	100.10	99.97	100.17	1
LG&E	CISR	861972	08/2010	06/23/2010	100.07	100.05	100.10	1
LG&E	CISR	861973	08/2010	06/23/2010	100.07	99.91	100.13	1
LG&E	CISR	861974	08/2010	06/23/2010	100.06	100.02	99.97	1
LG&E	CISR	861975	08/2010	06/23/2010	100.06	99.96	100.10	1
LG&E	CISR	861976	08/2010	06/23/2010	100.09	99.96	100.15	1
LG&E	CISR	861977	08/2010	06/23/2010	100.09	100.13	100.19	1
LG&E	CISR	861978	08/2010	06/23/2010	100.06	99.93	100.06	1
LG&E	CISR	861979	08/2010	06/23/2010	100.08	99.87	100.11	1
LG&E	CISR	861980	08/2010	06/23/2010	100.08	100.05	100.15	1
LG&E	CISR	861981	08/2010	06/23/2010	100.08	100.00	100.17	1
LG&E	CISR	861982	08/2010	06/23/2010	100.08	99.96	100.03	1
LG&E	CISR	861983	08/2010	06/23/2010	100.06	99.93	100.08	1
LG&E	CISR	861984	08/2010	06/23/2010	100.09	99.92	100.09	1
LG&E	CISR	861985	08/2010	06/23/2010	100.06	99.91	100.05	1
LG&E	CISR	861986	08/2010	06/23/2010	100.09	100.09	100.13	1
LG&E	CISR	861987	08/2010	06/23/2010	100.06	99.92	99.97	1
LG&E	CISR	861988	08/2010	06/23/2010	100.09	100.08	100.23	1
LG&E	CISR	861989	08/2010	06/23/2010	100.08	99.97	100.09	1
LG&E	CISR	861990	08/2010	06/23/2010	100.09	99.97	99.99	1
LG&E	CISR	861991	08/2010	06/23/2010	100.11	100.10	100.17	1
LG&E	CISR	861992	08/2010	06/23/2010	100.07	100.06	100.18	1



LG&E		C1SR	861993	08/2010	03/2010	100.06	99.92	100.00	1
LG&E		C1SR	861994	08/2010	06/23/2010	100.08	100.02	100.13	1
LG&E		C1SR	861995	08/2010	06/23/2010	100.07	100.00	100.01	1
LG&E		C1SR	861996	08/2010	06/23/2010	100.08	99.91	99.96	1
LG&E		C1SR	861997	08/2010	06/23/2010	100.08	99.89	100.04	1
LG&E		C1SR	861998	08/2010	06/23/2010	100.06	99.92	100.08	1
LG&E		C1SR	861999	08/2010	06/23/2010	100.09	99.90	100.00	1
LG&E		C1SR	862000	08/2010	06/23/2010	100.08	99.97	99.92	1
LG&E		C1SR	862001	08/2010	06/23/2010	100.08	99.92	100.08	1
LG&E		C1SR	862002	08/2010	06/23/2010	100.09	99.93	100.03	1
LG&E		C1SR	862003	08/2010	06/23/2010	100.09	100.09	100.08	1
LG&E		C1SR	862004	08/2010	06/23/2010	100.05	99.96	100.12	1
LG&E		C1SR	862005	08/2010	06/23/2010	100.10	100.06	100.12	1
LG&E		C1SR	862006	08/2010	06/23/2010	100.09	100.06	100.17	1
LG&E		C1SR	862007	08/2010	06/23/2010	100.07	99.92	100.03	1
LG&E		C1SR	862008	08/2010	06/23/2010	100.10	99.89	100.08	1
LG&E		C1SR	862009	08/2010	06/23/2010	100.09	100.00	100.13	1
LG&E		C1SR	862010	08/2010	06/23/2010	100.10	99.96	100.11	1
LG&E		C1SR	862011	08/2010	06/23/2010	100.06	100.02	100.02	1
LG&E		C1SR	862012	08/2010	06/23/2010	100.10	100.05	100.18	1
LG&E		C1SR	862013	08/2010	06/23/2010	100.06	99.90	99.93	1
LG&E		C1SR	862014	08/2010	06/23/2010	100.06	99.99	99.95	1
LG&E		C1SR	862015	08/2010	06/23/2010	100.08	99.93	100.09	1
LG&E		C1SR	862016	08/2010	06/23/2010	100.09	100.13	100.17	1
LG&E		C1SR	862017	08/2010	06/23/2010	100.06	100.10	100.12	1
LG&E		C1SR	862018	08/2010	06/23/2010	100.08	100.08	100.14	1
LG&E		C1SR	862019	08/2010	06/23/2010	100.06	99.92	100.08	1
LG&E		C1SR	862020	08/2010	06/23/2010	100.06	100.04	100.16	1
LG&E		C1SR	862021	08/2010	06/23/2010	100.09	99.96	100.07	1
LG&E		C1SR	862022	08/2010	06/23/2010	100.07	99.93	100.03	1
LG&E		C1SR	862023	08/2010	06/23/2010	100.08	99.93	100.03	1
LG&E		C1SR	862024	08/2010	06/23/2010	100.07	99.95	100.06	1
LG&E		C1SR	862025	08/2010	06/23/2010	100.08	99.99	99.99	1
LG&E		C1SR	862026	08/2010	06/23/2010	100.06	99.99	100.14	1
LG&E		C1SR	862027	08/2010	06/23/2010	100.06	99.88	100.19	1
LG&E		C1SR	862028	08/2010	06/23/2010	100.05	99.97	100.02	1

LG&E	C1SR	862029	08/2010	06/23/2010	100.10	100.07	99.98	1
LG&E	C1SR	862030	08/2010	06/23/2010	100.09	100.04	100.11	1
LG&E	C1SR	862031	08/2010	06/23/2010	100.08	99.94	100.25	1
LG&E	C1SR	862032	08/2010	06/23/2010	100.09	100.05	100.10	1
LG&E	C1SR	862033	08/2010	06/23/2010	100.09	100.01	100.11	1
LG&E	C1SR	862034	08/2010	06/23/2010	100.10	99.92	100.02	1
LG&E	C1SR	862035	08/2010	06/23/2010	100.06	100.10	100.06	1
LG&E	C1SR	862036	08/2010	06/23/2010	100.08	99.89	100.01	1
LG&E	C1SR	862037	08/2010	06/23/2010	100.08	100.08	100.23	1
LG&E	C1SR	862038	08/2010	06/23/2010	100.08	99.98	100.03	1
LG&E	C1SR	862039	08/2010	06/23/2010	100.10	100.00	100.13	1
LG&E	C1SR	862040	08/2010	06/23/2010	100.07	100.02	100.19	1
LG&E	C1SR	862041	08/2010	06/23/2010	100.09	99.91	100.03	1
LG&E	C1SR	862042	08/2010	06/23/2010	100.09	100.08	100.09	1
LG&E	C1SR	862043	08/2010	06/23/2010	100.06	100.00	100.06	1
LG&E	C1SR	862044	08/2010	06/23/2010	100.06	99.91	100.08	1
LG&E	C1SR	862045	08/2010	06/23/2010	100.09	100.03	100.04	1
LG&E	C1SR	862046	08/2010	06/23/2010	100.06	99.99	100.06	1
LG&E	C1SR	862047	08/2010	06/23/2010	100.09	100.02	100.07	1
LG&E	C1SR	862048	08/2010	06/23/2010	100.10	99.93	100.13	1
LG&E	C1SR	862049	08/2010	06/23/2010	100.08	99.95	100.12	1
LG&E	C1SR	862050	08/2010	06/23/2010	100.08	100.06	100.18	1
LG&E	C1SR	862051	08/2010	06/23/2010	100.07	100.04	100.07	1
LG&E	C1SR	862052	08/2010	06/23/2010	100.06	99.90	100.09	1
LG&E	C1SR	862053	08/2010	06/23/2010	100.08	99.91	100.04	1
LG&E	C1SR	862054	08/2010	06/23/2010	100.09	100.00	100.08	1
LG&E	C1SR	862055	08/2010	06/23/2010	100.06	99.92	99.99	1
LG&E	C1SR	862056	08/2010	06/23/2010	100.10	99.95	100.14	1
LG&E	C1SR	862057	08/2010	06/23/2010	100.07	99.88	100.19	1
LG&E	C1SR	862058	08/2010	06/23/2010	100.08	99.95	100.12	1
LG&E	C1SR	862059	08/2010	06/23/2010	100.06	99.87	99.97	1
LG&E	C1SR	862060	08/2010	06/23/2010	100.08	99.98	100.05	1
LG&E	C1SR	862061	08/2010	06/23/2010	100.10	99.98	100.17	1
LG&E	C1SR	862062	08/2010	06/23/2010	100.09	99.99	100.08	1
LG&E	C1SR	862063	08/2010	06/23/2010	100.08	100.08	100.10	1
LG&E	C1SR	862064	08/2010	06/23/2010	100.06	100.01	100.16	1

LG&E		C1SR	862065	08/2010	23/2010	100.10	99.92	100.06	1
LG&E		C1SR	862066	08/2010	06/23/2010	100.08	99.98	100.01	1
LG&E		C1SR	862067	08/2010	06/23/2010	100.08	99.92	100.10	1
LG&E		C1SR	862068	08/2010	06/23/2010	100.08	100.03	100.03	1
LG&E		C1SR	862069	08/2010	06/23/2010	100.06	100.08	100.11	1
LG&E		C1SR	862070	08/2010	06/23/2010	100.06	99.99	100.05	1
LG&E		C1SR	862071	08/2010	06/23/2010	100.10	100.05	100.20	1
LG&E		C1SR	862072	08/2010	06/23/2010	100.07	99.96	100.05	1
LG&E		C1SR	862073	08/2010	06/23/2010	100.10	100.00	100.18	1
LG&E		C1SR	862074	08/2010	06/23/2010	100.09	99.99	100.05	1
LG&E		C1SR	862075	08/2010	06/23/2010	100.06	99.98	100.12	1
LG&E		C1SR	862076	08/2010	06/23/2010	100.08	100.03	100.05	1
LG&E		C1SR	862077	08/2010	06/23/2010	100.11	100.03	100.01	1
LG&E		C1SR	862078	08/2010	06/23/2010	100.09	99.97	100.02	1
LG&E		C1SR	862079	08/2010	06/23/2010	100.07	99.97	99.98	1
LG&E		C1SR	862080	08/2010	06/23/2010	100.06	100.06	100.10	1
LG&E		C1SR	862081	08/2010	06/23/2010	100.06	99.95	100.03	1
LG&E		C1SR	862082	08/2010	06/23/2010	100.08	100.05	100.19	1
LG&E		C1SR	862083	08/2010	06/23/2010	100.08	99.98	100.02	1
LG&E		C1SR	862084	08/2010	06/23/2010	100.09	100.05	100.19	1
LG&E		C1SR	862085	08/2010	06/23/2010	100.09	99.99	100.09	1
LG&E		C1SR	862086	08/2010	06/23/2010	100.08	100.05	100.02	1
LG&E		C1SR	862087	08/2010	06/23/2010	100.10	100.00	100.18	1
LG&E		C1SR	862088	08/2010	06/23/2010	100.08	100.03	100.10	1
LG&E		C1SR	862089	08/2010	06/23/2010	100.10	99.93	100.17	1
LG&E		C1SR	862090	08/2010	06/23/2010	100.09	100.03	100.06	1
LG&E		C1SR	862091	08/2010	06/23/2010	100.10	99.93	100.14	1
LG&E		C1SR	862092	08/2010	06/23/2010	100.09	99.92	100.05	1
LG&E		C1SR	862093	08/2010	06/23/2010	100.06	99.86	100.01	1
LG&E		C1SR	862094	08/2010	06/23/2010	100.06	99.87	99.96	1
LG&E		C1SR	862095	08/2010	06/23/2010	100.08	100.07	100.19	1
LG&E		C1SR	862096	08/2010	06/23/2010	100.05	100.00	100.17	1
LG&E		C1SR	862097	08/2010	06/23/2010	100.09	100.08	100.23	1
LG&E		C1SR	862098	08/2010	06/23/2010	100.05	99.93	99.95	1
LG&E		C1SR	862099	08/2010	06/23/2010	100.07	99.91	100.06	1
LG&E		C1SR	862100	08/2010	06/23/2010	100.07	99.91	100.02	1

LG&E	CISR	862101	08/2010	23/2010	100.06	99.86	99.97	1
LG&E	CISR	862102	08/2010	06/23/2010	100.08	100.05	100.04	1
LG&E	CISR	862103	08/2010	06/23/2010	100.10	99.91	100.05	1
LG&E	CISR	862104	08/2010	06/23/2010	100.10	99.99	100.04	1
LG&E	CISR	862105	08/2010	06/23/2010	100.06	99.97	100.00	1
LG&E	CISR	862106	08/2010	06/23/2010	100.07	99.99	100.07	1
LG&E	CISR	862107	08/2010	06/23/2010	100.08	99.99	100.15	1
LG&E	CISR	862108	08/2010	06/23/2010	100.06	99.89	100.05	1
LG&E	CISR	862109	08/2010	06/23/2010	100.10	100.01	100.04	1
LG&E	CISR	862110	08/2010	06/23/2010	100.05	100.00	100.06	1
LG&E	CISR	862111	08/2010	06/23/2010	100.09	99.94	100.03	1
LG&E	CISR	862112	08/2010	06/23/2010	100.08	100.07	100.14	1
LG&E	CISR	862113	08/2010	06/23/2010	100.09	99.89	100.03	1
LG&E	CISR	862114	08/2010	06/23/2010	100.07	99.91	100.02	1
LG&E	CISR	862115	08/2010	06/23/2010	100.09	99.97	100.03	1
LG&E	CISR	862116	08/2010	06/23/2010	100.06	99.98	100.08	1
LG&E	CISR	862117	08/2010	06/23/2010	100.06	99.94	100.02	1
LG&E	CISR	862118	08/2010	06/23/2010	100.08	100.08	100.10	1
LG&E	CISR	862119	08/2010	06/23/2010	100.08	99.97	100.00	1
LG&E	CISR	862120	08/2010	06/23/2010	100.06	100.01	100.07	1
LG&E	CISR	862121	08/2010	06/23/2010	100.10	100.02	100.18	1
LG&E	CISR	862122	08/2010	06/23/2010	100.05	99.92	100.06	1
LG&E	CISR	862123	08/2010	06/23/2010	100.08	99.97	100.13	1
LG&E	CISR	862124	08/2010	06/23/2010	100.09	100.04	100.14	1
LG&E	CISR	862125	08/2010	06/23/2010	100.09	99.95	100.10	1
LG&E	CISR	862126	08/2010	06/23/2010	100.08	100.00	100.07	1
LG&E	CISR	862127	08/2010	06/23/2010	100.06	99.95	100.04	1
LG&E	CISR	862128	08/2010	06/23/2010	100.08	99.98	100.06	1
LG&E	CISR	862129	08/2010	06/23/2010	100.07	100.07	100.07	1
LG&E	CISR	862130	08/2010	06/23/2010	100.10	100.07	100.06	1
LG&E	CISR	862131	08/2010	06/23/2010	100.06	99.98	100.15	1
LG&E	CISR	862132	08/2010	06/23/2010	100.06	100.04	100.12	1
LG&E	CISR	862133	08/2010	06/23/2010	100.07	100.03	100.13	1
LG&E	CISR	862134	08/2010	06/23/2010	100.09	100.04	100.16	1
LG&E	CISR	862135	08/2010	06/23/2010	100.06	99.98	100.02	1
LG&E	CISR	862136	08/2010	06/23/2010	100.07	99.96	100.03	1

LG&E		C1SR	862137	08/2010	03/2010	100.06	99.88	100.01	1
LG&E		C1SR	862138	08/2010	06/23/2010	100.07	99.91	100.08	1
LG&E		C1SR	862139	08/2010	06/23/2010	100.09	99.97	99.98	1
LG&E		C1SR	862140	08/2010	06/23/2010	100.07	99.98	100.06	1
LG&E		C1SR	862141	08/2010	06/23/2010	100.07	99.99	100.13	1
LG&E		C1SR	862142	08/2010	06/23/2010	100.10	99.93	100.12	1
LG&E		C1SR	862143	08/2010	06/23/2010	100.06	100.05	100.16	1
LG&E		C1SR	862144	08/2010	06/23/2010	100.07	100.08	100.15	1
LG&E		C1SR	862145	08/2010	06/23/2010	100.08	99.91	100.08	1
LG&E		C1SR	862146	08/2010	06/23/2010	100.06	100.04	100.11	1
LG&E		C1SR	862147	08/2010	06/23/2010	100.09	100.12	100.21	1
LG&E		C1SR	862148	08/2010	06/23/2010	100.10	100.07	100.03	1
LG&E		C1SR	862149	08/2010	06/23/2010	100.09	99.97	100.22	1
LG&E		C1SR	862150	08/2010	06/23/2010	100.07	99.95	100.13	1
LG&E		C1SR	862151	08/2010	06/23/2010	100.10	100.09	100.23	1
LG&E		C1SR	862152	08/2010	06/23/2010	100.08	99.96	100.09	1
LG&E		C1SR	862153	08/2010	06/23/2010	100.06	100.05	100.15	1
LG&E		C1SR	862154	08/2010	06/23/2010	100.09	99.96	99.99	1
LG&E		C1SR	862155	08/2010	06/23/2010	100.10	99.84	100.04	1
LG&E		C1SR	862156	08/2010	06/23/2010	100.08	99.89	100.14	1
LG&E		C1SR	862157	08/2010	06/23/2010	100.06	99.92	100.05	1
LG&E		C1SR	862158	08/2010	06/23/2010	100.07	99.96	100.10	1
LG&E		C1SR	862159	08/2010	06/23/2010	100.05	99.98	100.05	1
LG&E		C1SR	862160	08/2010	06/23/2010	100.08	99.96	100.09	1
LG&E		C1SR	862161	08/2010	06/23/2010	100.07	99.86	100.12	1
LG&E		C1SR	862162	08/2010	06/23/2010	100.07	100.00	100.11	1
LG&E		C1SR	862163	08/2010	06/23/2010	100.09	99.93	100.03	1
LG&E		C1SR	862164	08/2010	06/23/2010	100.06	99.98	100.01	1
LG&E		C1SR	862165	08/2010	06/23/2010	100.08	100.00	100.05	1
LG&E		C1SR	862166	08/2010	06/23/2010	100.08	99.95	100.07	1
LG&E		C1SR	862167	08/2010	06/23/2010	100.06	99.90	99.97	1
LG&E		C1SR	862168	08/2010	06/23/2010	100.09	99.89	100.14	1
LG&E		C1SR	862169	08/2010	06/23/2010	100.06	99.90	99.94	1
LG&E		C1SR	862170	08/2010	06/23/2010	100.10	99.93	99.97	1
LG&E		C1SR	862171	08/2010	06/23/2010	100.09	100.00	100.06	1
LG&E		C1SR	862172	08/2010	06/23/2010	100.10	100.05	100.20	1

LG&E	C1SR	862173	08/2010	06/23/2010	100.07	100.06	100.06	100.06	1
LG&E	C1SR	862174	08/2010	06/23/2010	100.07	99.94	100.06	100.06	1
LG&E	C1SR	862175	08/2010	06/23/2010	100.09	99.97	100.16	100.16	1
LG&E	C1SR	862176	08/2010	06/23/2010	100.09	100.06	100.14	100.14	1
LG&E	C1SR	862177	08/2010	06/23/2010	100.06	99.86	100.04	100.04	1
LG&E	C1SR	862178	08/2010	06/23/2010	100.05	100.10	100.16	100.16	1
LG&E	C1SR	862179	08/2010	06/23/2010	100.07	99.96	100.09	100.09	1
LG&E	C1SR	862180	08/2010	06/23/2010	100.05	100.08	100.06	100.06	1
LG&E	C1SR	862181	08/2010	06/23/2010	100.08	99.95	100.06	100.06	1
LG&E	C1SR	862182	08/2010	06/23/2010	100.10	100.00	100.04	100.04	1
LG&E	C1SR	862183	08/2010	06/23/2010	100.07	99.94	100.08	100.08	1
LG&E	C1SR	862184	08/2010	06/23/2010	100.07	99.87	100.01	100.01	1
LG&E	C1SR	862185	08/2010	06/23/2010	100.07	100.02	100.11	100.11	1
LG&E	C1SR	862186	08/2010	06/23/2010	100.10	100.00	100.10	100.10	1
LG&E	C1SR	862187	08/2010	06/23/2010	100.06	99.98	100.03	100.03	1
LG&E	C1SR	862188	08/2010	06/23/2010	100.09	99.95	100.16	100.16	1
LG&E	C1SR	862189	08/2010	06/23/2010	100.10	100.11	100.11	100.11	1
LG&E	C1SR	862190	08/2010	06/23/2010	100.09	100.10	100.14	100.14	1
LG&E	C1SR	862191	08/2010	06/23/2010	100.06	99.89	99.98	99.98	1
LG&E	C1SR	862192	08/2010	06/23/2010	100.10	99.97	100.07	100.07	1
LG&E	C1SR	862193	08/2010	06/23/2010	100.06	99.96	100.00	100.00	1
LG&E	C1SR	862194	08/2010	06/23/2010	100.06	99.99	100.16	100.16	1
LG&E	C1SR	862195	08/2010	06/23/2010	100.07	100.07	100.04	100.04	1
LG&E	C1SR	862196	08/2010	06/23/2010	100.08	99.98	100.11	100.11	1
LG&E	C1SR	862197	08/2010	06/23/2010	100.09	99.91	100.08	100.08	1
LG&E	C1SR	862198	08/2010	06/23/2010	100.08	99.90	100.10	100.10	1
LG&E	C1SR	862199	08/2010	06/23/2010	100.09	100.11	100.15	100.15	1
LG&E	C1SR	862200	08/2010	06/23/2010	100.06	100.08	100.14	100.14	1
LG&E	C1SR	862201	08/2010	06/23/2010	100.08	100.01	100.10	100.10	1
LG&E	C1SR	862202	08/2010	06/23/2010	100.07	99.87	100.01	100.01	1
LG&E	C1SR	862203	08/2010	06/23/2010	100.06	99.94	100.02	100.02	1
LG&E	C1SR	862204	08/2010	06/23/2010	100.06	99.88	100.00	100.00	1
LG&E	C1SR	862205	08/2010	06/23/2010	100.09	100.01	100.17	100.17	1
LG&E	C1SR	862206	08/2010	06/23/2010	100.10	99.92	100.10	100.10	1
LG&E	C1SR	862207	08/2010	06/23/2010	100.06	100.01	100.10	100.10	1
LG&E	C1SR	862208	08/2010	06/23/2010	100.07	99.90	100.11	100.11	1

LG&E		C1SR	862209	08/2010	03/2010	100.10	99.88	100.07	1
LG&E		C1SR	862210	08/2010	06/23/2010	100.08	100.09	100.18	1
LG&E		C1SR	862211	08/2010	06/23/2010	100.10	99.99	100.06	1
LG&E		C1SR	862212	08/2010	06/23/2010	100.06	100.06	100.11	1
LG&E		C1SR	862213	08/2010	06/23/2010	100.08	99.98	100.14	1
LG&E		C1SR	862214	08/2010	06/23/2010	100.08	99.96	100.05	1
LG&E		C1SR	862215	08/2010	06/23/2010	100.05	99.97	99.96	1
LG&E		C1SR	862216	08/2010	06/23/2010	100.07	99.88	100.11	1
LG&E		C1SR	862217	08/2010	06/23/2010	100.09	100.04	100.15	1
LG&E		C1SR	862218	08/2010	06/23/2010	100.08	99.97	100.01	1
LG&E		C1SR	862219	08/2010	06/23/2010	100.07	100.11	100.20	1
LG&E		C1SR	862220	08/2010	06/23/2010	100.05	100.05	100.13	1
LG&E		C1SR	862221	08/2010	06/23/2010	100.06	100.04	100.19	1
LG&E		C1SR	862222	08/2010	06/23/2010	100.10	99.97	100.00	1
LG&E		C1SR	862223	08/2010	06/23/2010	100.08	100.02	100.02	1
LG&E		C1SR	862224	08/2010	06/23/2010	100.10	99.96	100.14	1
LG&E		C1SR	862225	08/2010	06/23/2010	100.05	99.95	100.11	1
LG&E		C1SR	862226	08/2010	06/23/2010	100.07	99.99	100.11	1
LG&E		C1SR	862227	08/2010	06/23/2010	100.09	100.04	100.17	1
LG&E		C1SR	862228	08/2010	06/23/2010	100.08	99.95	100.17	1
LG&E		C1SR	862229	08/2010	06/23/2010	100.09	100.02	100.09	1
LG&E		C1SR	862230	08/2010	06/23/2010	100.07	99.90	100.00	1
LG&E		C1SR	862231	08/2010	06/23/2010	100.07	99.94	100.06	1
LG&E		C1SR	862232	08/2010	06/23/2010	100.10	99.94	99.99	1
LG&E		C1SR	862233	08/2010	06/23/2010	100.09	99.89	100.09	1
LG&E		C1SR	862234	08/2010	06/23/2010	100.09	99.92	100.06	1
LG&E		C1SR	862235	08/2010	06/23/2010	100.07	99.94	100.09	1
LG&E		C1SR	862236	08/2010	06/23/2010	100.06	99.94	100.05	1
LG&E		C1SR	862237	08/2010	06/23/2010	100.07	99.93	100.10	1
LG&E		C1SR	862238	08/2010	06/23/2010	100.08	100.01	100.06	1
LG&E		C1SR	862239	08/2010	06/23/2010	100.07	99.95	100.00	1
LG&E		C1SR	862240	08/2010	06/23/2010	100.05	99.93	100.10	1
LG&E		C1SR	862241	08/2010	06/23/2010	100.05	100.01	100.09	1
LG&E		C1SR	862242	08/2010	06/23/2010	100.10	99.99	100.03	1
LG&E		C1SR	862243	08/2010	06/23/2010	100.07	100.00	100.16	1
LG&E		C1SR	862244	08/2010	06/23/2010	100.07	100.04	100.01	1

LG&E	C1SR	862245	08/2010	06/23/2010	100.09	100.03	100.17	1
LG&E	C1SR	862246	08/2010	06/23/2010	100.10	100.02	100.21	1
LG&E	C1SR	862247	08/2010	06/23/2010	100.08	99.94	100.06	1
LG&E	C1SR	862248	08/2010	06/23/2010	100.07	100.06	100.16	1
LG&E	C1SR	862249	08/2010	06/23/2010	100.06	100.05	100.18	1
LG&E	C1SR	862250	08/2010	06/23/2010	100.08	100.07	100.13	1
LG&E	C1SR	862251	08/2010	06/23/2010	100.08	100.02	100.14	1
LG&E	C1SR	862252	08/2010	06/23/2010	100.10	99.97	100.08	1
LG&E	C1SR	862253	08/2010	06/23/2010	100.10	99.97	100.01	1
LG&E	C1SR	862254	08/2010	06/23/2010	100.06	99.91	100.06	1
LG&E	C1SR	862255	08/2010	06/23/2010	100.06	99.92	99.99	1
LG&E	C1SR	862256	08/2010	06/23/2010	100.07	99.92	100.07	1
LG&E	C1SR	862257	08/2010	06/23/2010	100.06	99.96	100.06	1
LG&E	C1SR	862258	08/2010	06/23/2010	100.07	100.07	100.14	1
LG&E	C1SR	862259	08/2010	06/23/2010	100.08	100.04	100.12	1
LG&E	C1SR	862260	08/2010	06/23/2010	100.10	100.06	100.16	1
LG&E	C1SR	862261	08/2010	06/23/2010	100.05	99.94	100.06	1
LG&E	C1SR	862262	08/2010	06/23/2010	100.09	99.97	100.07	1
LG&E	C1SR	862263	08/2010	06/23/2010	100.06	99.95	100.13	1
LG&E	C1SR	862264	08/2010	06/23/2010	100.10	100.08	100.26	1
LG&E	C1SR	862265	08/2010	06/23/2010	100.06	100.06	100.15	1
LG&E	C1SR	862266	08/2010	06/23/2010	100.07	99.91	100.03	1
LG&E	C1SR	862267	08/2010	06/23/2010	100.08	99.98	100.13	1
LG&E	C1SR	862268	08/2010	06/23/2010	100.08	99.97	100.03	1
LG&E	C1SR	862269	08/2010	06/23/2010	100.08	100.05	100.11	1
LG&E	C1SR	862270	08/2010	06/23/2010	100.06	99.96	99.97	1
LG&E	C1SR	862271	08/2010	06/23/2010	100.06	99.88	100.02	1
LG&E	C1SR	862272	08/2010	06/23/2010	100.07	100.05	100.15	1
LG&E	C1SR	862273	08/2010	06/23/2010	100.09	100.07	100.19	1
LG&E	C1SR	862274	08/2010	06/23/2010	100.07	99.94	100.00	1
LG&E	C1SR	862275	08/2010	06/23/2010	100.09	100.01	100.15	1
LG&E	C1SR	862276	08/2010	06/23/2010	100.07	100.01	100.15	1
LG&E	C1SR	862277	08/2010	06/23/2010	100.06	100.03	100.12	1
LG&E	C1SR	862278	08/2010	06/23/2010	100.08	100.03	100.03	1
LG&E	C1SR	862279	08/2010	06/23/2010	100.09	99.92	100.06	1
LG&E	C1SR	862280	08/2010	06/23/2010	100.10	99.97	100.12	1



LG&E		C1SR	862281	08/2010	03/2010	100.09	99.98	100.02	1
LG&E		C1SR	862282	08/2010	06/23/2010	100.10	99.98	100.06	1
LG&E		C1SR	862283	08/2010	06/23/2010	100.10	100.01	100.25	1
LG&E		C1SR	862284	08/2010	06/23/2010	100.09	100.08	100.20	1
LG&E		C1SR	862285	08/2010	06/23/2010	100.06	99.96	100.06	1
LG&E		C1SR	862286	08/2010	06/23/2010	100.06	99.96	99.96	1
LG&E		C1SR	862287	08/2010	06/23/2010	100.07	99.92	100.14	1
LG&E		C1SR	862288	08/2010	06/23/2010	100.08	100.07	100.17	1
LG&E		C1SR	862289	08/2010	06/23/2010	100.07	99.94	100.09	1
LG&E		C1SR	862290	08/2010	06/23/2010	100.07	99.93	100.11	1
LG&E		C1SR	862291	08/2010	06/23/2010	100.05	99.97	100.00	1
LG&E		C1SR	862292	08/2010	06/23/2010	100.07	100.04	100.19	1
LG&E		C1SR	862293	08/2010	06/23/2010	100.07	99.90	100.18	1
LG&E		C1SR	862294	08/2010	06/23/2010	100.07	99.94	99.96	1
LG&E		C1SR	862295	08/2010	06/23/2010	100.06	100.05	100.19	1
LG&E		C1SR	862296	08/2010	06/23/2010	100.08	100.01	100.15	1
LG&E		C1SR	862297	08/2010	06/23/2010	100.08	99.99	100.07	1
LG&E		C1SR	862298	08/2010	06/23/2010	100.06	99.89	100.03	1
LG&E		C1SR	862299	08/2010	06/23/2010	100.08	100.09	100.17	1
LG&E		C1SR	862300	08/2010	06/23/2010	100.07	99.91	100.00	1
LG&E		C1SR	862301	08/2010	06/23/2010	100.10	100.03	100.06	1
LG&E		C1SR	862302	08/2010	06/23/2010	100.09	100.07	100.11	1
LG&E		C1SR	862303	08/2010	06/23/2010	100.06	99.88	99.97	1
LG&E		C1SR	862304	08/2010	06/23/2010	100.10	99.98	100.05	1
LG&E		C1SR	862305	08/2010	06/23/2010	100.06	99.94	100.10	1
LG&E		C1SR	862306	08/2010	06/23/2010	100.08	100.03	100.23	1
LG&E		C1SR	862307	08/2010	06/23/2010	100.10	100.09	100.02	1
LG&E		C1SR	862308	08/2010	06/23/2010	100.07	99.96	100.11	1
LG&E		C1SR	862309	08/2010	06/23/2010	100.06	99.95	100.08	1
LG&E		C1SR	862310	08/2010	06/23/2010	100.07	99.99	100.04	1
LG&E		C1SR	862311	08/2010	06/23/2010	100.10	100.02	100.16	1
LG&E		C1SR	862312	08/2010	06/23/2010	100.06	100.06	100.14	1
LG&E		C1SR	862313	08/2010	06/23/2010	100.09	100.02	100.23	1
LG&E		C1SR	862314	08/2010	06/23/2010	100.10	99.97	100.05	1
LG&E		C1SR	862315	08/2010	06/23/2010	100.09	100.02	100.02	1
LG&E		C1SR	862316	08/2010	06/23/2010	100.10	99.97	100.15	1

LG&E	CISR	862317	08/2010	06/23/2010	100.09	100.07	100.12	1
LG&E	CISR	862318	08/2010	06/23/2010	100.10	99.96	100.00	1
LG&E	CISR	862319	08/2010	06/23/2010	100.05	99.97	100.17	1
LG&E	CISR	862320	08/2010	06/23/2010	100.09	99.82	100.03	1
LG&E	CISR	862321	08/2010	06/23/2010	100.07	99.97	100.20	1
LG&E	CISR	862322	08/2010	06/23/2010	100.06	99.94	100.16	1
LG&E	CISR	862323	08/2010	06/23/2010	100.06	99.96	100.03	1
LG&E	CISR	862324	08/2010	06/23/2010	100.06	99.94	100.06	1
LG&E	CISR	862325	08/2010	06/23/2010	100.08	100.17	100.17	1
LG&E	CISR	862326	08/2010	06/23/2010	100.07	99.96	100.04	1
LG&E	CISR	862327	08/2010	06/23/2010	100.08	100.02	100.17	1
LG&E	CISR	862328	08/2010	06/23/2010	100.07	100.14	100.15	1
LG&E	CISR	862329	08/2010	06/23/2010	100.08	100.06	100.15	1
LG&E	CISR	862330	08/2010	06/23/2010	100.07	99.99	100.10	1
LG&E	CISR	862331	08/2010	06/23/2010	100.09	99.88	100.03	1
LG&E	CISR	862332	08/2010	06/23/2010	100.10	99.98	100.15	1
LG&E	CISR	862333	08/2010	06/23/2010	100.10	100.06	100.24	1
LG&E	CISR	862334	08/2010	06/23/2010	100.10	99.99	100.17	1
LG&E	CISR	862335	08/2010	06/23/2010	100.08	99.88	100.04	1
LG&E	CISR	862336	08/2010	06/23/2010	100.07	99.81	100.06	1
LG&E	CISR	862337	08/2010	06/23/2010	100.10	99.97	100.09	1
LG&E	CISR	862338	08/2010	06/23/2010	100.06	99.98	100.07	1
LG&E	CISR	862339	08/2010	06/23/2010	100.08	100.03	100.01	1
LG&E	CISR	862340	08/2010	06/23/2010	100.10	99.87	100.04	1
LG&E	CISR	862341	08/2010	06/23/2010	100.06	99.90	100.15	1
LG&E	CISR	862342	08/2010	06/23/2010	100.09	99.96	100.11	1
LG&E	CISR	862343	08/2010	06/23/2010	100.08	99.97	99.97	1
LG&E	CISR	862344	08/2010	06/23/2010	100.05	99.93	100.02	1
LG&E	CISR	862345	08/2010	06/23/2010	100.07	100.03	100.14	1
LG&E	CISR	862346	08/2010	06/23/2010	100.06	99.89	100.00	1
LG&E	CISR	862347	08/2010	06/23/2010	100.06	100.06	100.13	1
LG&E	CISR	862348	08/2010	06/23/2010	100.07	100.01	100.17	1
LG&E	CISR	862349	08/2010	06/23/2010	100.09	99.92	99.91	1
LG&E	CISR	862350	08/2010	06/23/2010	100.06	99.90	100.06	1
LG&E	CISR	862351	08/2010	06/23/2010	100.10	99.95	100.15	1
LG&E	CISR	862352	08/2010	06/23/2010	100.06	100.04	100.17	1

LG&E	C1SR	862353	08/2010	03/2010	100.09	100.06	100.09	1
LG&E	C1SR	862354	08/2010	06/23/2010	100.10	100.02	100.09	1
LG&E	C1SR	862355	08/2010	06/23/2010	100.09	99.93	100.08	1
LG&E	C1SR	862356	08/2010	06/23/2010	100.10	100.00	100.12	1
LG&E	C1SR	862357	08/2010	06/23/2010	100.07	100.02	100.14	1
LG&E	C1SR	862358	08/2010	06/23/2010	100.09	99.94	100.02	1
LG&E	C1SR	862359	08/2010	06/23/2010	100.06	99.97	100.14	1
LG&E	C1SR	862360	08/2010	06/23/2010	100.06	100.01	100.16	1
LG&E	C1SR	862361	08/2010	06/23/2010	100.06	100.00	100.13	1
LG&E	C1SR	862362	08/2010	06/23/2010	100.08	99.95	100.06	1
LG&E	C1SR	862363	08/2010	06/23/2010	100.07	100.06	100.19	1
LG&E	C1SR	862364	08/2010	06/23/2010	100.08	100.02	100.18	1
LG&E	C1SR	862365	08/2010	06/23/2010	100.08	99.97	100.04	1
LG&E	C1SR	862366	08/2010	06/23/2010	100.06	99.96	100.12	1
LG&E	C1SR	862367	08/2010	06/23/2010	100.06	99.88	99.98	1
LG&E	C1SR	862368	08/2010	06/23/2010	100.10	100.07	100.12	1
LG&E	C1SR	862369	08/2010	06/23/2010	100.05	100.00	100.01	1
LG&E	C1SR	862370	08/2010	06/23/2010	100.10	100.01	100.09	1
LG&E	C1SR	862371	08/2010	06/23/2010	100.09	100.06	100.10	1
LG&E	C1SR	862372	08/2010	06/23/2010	100.06	100.02	100.06	1
LG&E	C1SR	862373	08/2010	06/23/2010	100.07	99.90	100.03	1
LG&E	C1SR	862374	08/2010	06/23/2010	100.09	100.10	100.22	1
LG&E	C1SR	862375	08/2010	06/23/2010	100.08	100.06	100.11	1
LG&E	C1SR	862376	08/2010	06/23/2010	100.09	100.00	100.08	1
LG&E	C1SR	862377	08/2010	06/23/2010	100.05	99.98	100.10	1
LG&E	C1SR	862378	08/2010	06/23/2010	100.06	99.91	99.98	1
LG&E	C1SR	862379	08/2010	06/23/2010	100.08	99.96	100.20	1
LG&E	C1SR	862380	08/2010	06/23/2010	100.09	100.02	100.16	1
LG&E	C1SR	862381	08/2010	06/23/2010	100.07	99.89	100.05	1
LG&E	C1SR	862382	08/2010	06/23/2010	100.10	99.97	99.99	1
LG&E	C1SR	862383	08/2010	06/23/2010	100.08	99.88	100.10	1
LG&E	C1SR	862384	08/2010	06/23/2010	100.08	99.96	100.05	1
LG&E	C1SR	862385	08/2010	06/23/2010	100.07	100.03	100.20	1
LG&E	C1SR	862386	08/2010	06/23/2010	100.06	100.04	100.11	1
LG&E	C1SR	862387	08/2010	06/23/2010	100.09	100.08	100.14	1
LG&E	C1SR	862388	08/2010	06/23/2010	100.07	100.09	100.14	1

LG&E	C1SR	862389	08/2010	06/23/2010	100.09	100.10	100.08	1
LG&E	C1SR	862390	08/2010	06/23/2010	100.08	100.00	100.00	1
LG&E	C1SR	862391	08/2010	06/23/2010	100.08	100.07	100.17	1
LG&E	C1SR	862392	08/2010	06/23/2010	100.09	99.98	100.06	1
LG&E	C1SR	862393	08/2010	06/23/2010	100.10	99.98	99.99	1
LG&E	C1SR	862394	08/2010	06/23/2010	100.09	100.02	100.06	1
LG&E	C1SR	862395	08/2010	06/23/2010	100.10	99.98	100.12	1
LG&E	C1SR	862396	08/2010	06/23/2010	100.06	99.92	99.92	1
LG&E	C1SR	862397	08/2010	06/23/2010	100.09	100.02	100.13	1
LG&E	C1SR	862398	08/2010	06/23/2010	100.07	99.91	100.14	1
LG&E	C1SR	862399	08/2010	06/23/2010	100.06	100.08	100.07	1
LG&E	C1SR	862400	08/2010	06/23/2010	100.06	99.95	99.97	1
LG&E	C1SR	862401	08/2010	06/23/2010	100.09	100.06	100.16	1
LG&E	C1SR	862402	08/2010	06/23/2010	100.06	100.07	100.18	1
LG&E	C1SR	862403	08/2010	06/23/2010	100.05	99.93	100.01	1
LG&E	C1SR	862404	08/2010	06/23/2010	100.07	99.98	100.03	1
LG&E	C1SR	862405	08/2010	06/23/2010	100.08	99.88	100.08	1
LG&E	C1SR	862406	08/2010	06/23/2010	100.09	99.86	100.07	1
LG&E	C1SR	862407	08/2010	06/23/2010	100.07	99.91	100.07	1
LG&E	C1SR	862408	08/2010	06/23/2010	100.05	99.94	100.00	1
LG&E	C1SR	862409	08/2010	06/23/2010	100.08	100.02	100.15	1
LG&E	C1SR	862410	08/2010	06/23/2010	100.10	100.12	100.19	1
LG&E	C1SR	862411	08/2010	06/23/2010	100.06	99.98	100.06	1
LG&E	C1SR	862412	08/2010	06/23/2010	100.07	100.06	100.08	1
LG&E	C1SR	862413	08/2010	06/23/2010	100.06	99.87	99.98	1
LG&E	C1SR	862414	08/2010	06/23/2010	100.08	99.97	100.07	1
LG&E	C1SR	862415	08/2010	06/23/2010	100.07	100.04	100.14	1
LG&E	C1SR	862416	08/2010	06/23/2010	100.10	99.94	100.16	1
LG&E	C1SR	862417	08/2010	06/23/2010	100.07	99.98	100.18	1
LG&E	C1SR	862418	08/2010	06/23/2010	100.06	99.92	100.06	1
LG&E	C1SR	862419	08/2010	06/23/2010	100.08	100.04	100.00	1
LG&E	C1SR	862420	08/2010	06/23/2010	100.07	100.00	100.04	1
LG&E	C1SR	862421	08/2010	06/23/2010	100.08	99.88	99.98	1
LG&E	C1SR	862422	08/2010	06/23/2010	100.10	99.86	100.02	1
LG&E	C1SR	862423	08/2010	06/23/2010	100.06	99.97	99.91	1
LG&E	C1SR	862424	08/2010	06/23/2010	100.09	100.04	100.18	1

LG&E	C1SR	862425	08/2010	23/2010	100.08	99.92	100.08	1
LG&E	C1SR	862426	08/2010	06/23/2010	100.08	99.93	100.00	1
LG&E	C1SR	862427	08/2010	06/23/2010	100.11	99.92	100.06	1
LG&E	C1SR	862428	08/2010	06/23/2010	100.09	100.03	100.19	1
LG&E	C1SR	862429	08/2010	06/23/2010	100.06	99.91	99.94	1
LG&E	C1SR	862430	08/2010	06/23/2010	100.08	99.92	100.03	1
LG&E	C1SR	862431	08/2010	06/23/2010	100.07	99.99	100.08	1
LG&E	C1SR	862432	08/2010	06/23/2010	100.06	100.03	100.11	1
LG&E	C1SR	862433	08/2010	06/23/2010	100.07	100.01	100.06	1
LG&E	C1SR	862434	08/2010	06/23/2010	100.10	100.03	100.13	1
LG&E	C1SR	862435	08/2010	06/23/2010	100.10	99.89	99.96	1
LG&E	C1SR	862436	08/2010	06/23/2010	100.07	99.87	100.07	1
LG&E	C1SR	862437	08/2010	06/23/2010	100.10	99.96	100.03	1
LG&E	C1SR	862438	08/2010	06/23/2010	100.06	99.85	100.08	1
LG&E	C1SR	862439	08/2010	06/23/2010	100.09	100.02	100.16	1
LG&E	C1SR	862440	08/2010	06/23/2010	100.09	99.95	100.08	1
LG&E	C1SR	862441	08/2010	06/23/2010	100.08	99.96	99.94	1
LG&E	C1SR	862442	08/2010	06/23/2010	100.08	100.09	100.17	1
LG&E	C1SR	862443	08/2010	06/23/2010	100.07	100.04	100.09	1
LG&E	C1SR	862444	08/2010	06/23/2010	100.07	99.98	100.08	1
LG&E	C1SR	862445	08/2010	06/23/2010	100.07	100.12	100.16	1
LG&E	C1SR	862446	08/2010	06/23/2010	100.07	100.03	100.10	1
LG&E	C1SR	862447	08/2010	06/23/2010	100.10	99.99	100.09	1
LG&E	C1SR	862448	08/2010	06/23/2010	100.09	100.05	100.07	1
LG&E	C1SR	862449	08/2010	06/23/2010	100.06	99.92	100.03	1
LG&E	C1SR	862450	08/2010	06/23/2010	100.06	100.07	100.06	1
LG&E	C1SR	862451	08/2010	06/23/2010	100.05	100.06	100.20	1
LG&E	C1SR	862452	08/2010	06/23/2010	100.06	100.00	100.06	1
LG&E	C1SR	862453	08/2010	06/23/2010	100.06	99.92	99.94	1
LG&E	C1SR	862454	08/2010	06/23/2010	100.10	99.93	100.08	1
LG&E	C1SR	862455	08/2010	06/23/2010	100.07	99.98	100.18	1
LG&E	C1SR	862456	08/2010	06/23/2010	100.08	99.94	100.01	1
LG&E	C1SR	862457	08/2010	06/23/2010	100.10	100.07	100.18	1
LG&E	C1SR	862458	08/2010	06/23/2010	100.06	100.09	100.19	1
LG&E	C1SR	862459	08/2010	06/23/2010	100.07	100.01	100.26	1
LG&E	C1SR	862460	08/2010	06/23/2010	100.10	100.02	100.15	1

LG&E	C1SR	862461	08/2010	23/2010	100.10	100.09	100.22	1
LG&E	C1SR	862462	08/2010	06/23/2010	100.07	100.04	100.17	1
LG&E	C1SR	862463	08/2010	06/23/2010	100.08	99.94	100.04	1
LG&E	C1SR	862464	08/2010	06/23/2010	100.07	99.98	100.05	1
LG&E	C1SR	862465	08/2010	06/23/2010	100.09	99.97	100.06	1
LG&E	C1SR	862466	08/2010	06/23/2010	100.08	99.89	100.12	1
LG&E	C1SR	862467	08/2010	06/23/2010	100.06	99.97	100.04	1
LG&E	C1SR	862468	08/2010	06/23/2010	100.07	99.88	100.09	1
LG&E	C1SR	862469	08/2010	06/23/2010	100.08	100.01	100.16	1
LG&E	C1SR	862470	08/2010	06/23/2010	100.09	99.88	100.02	1
LG&E	C1SR	862471	08/2010	06/23/2010	100.06	99.98	99.96	1
LG&E	C1SR	862472	08/2010	06/23/2010	100.08	99.89	100.02	1
LG&E	C1SR	862473	08/2010	06/23/2010	100.07	100.00	100.14	1
LG&E	C1SR	862474	08/2010	06/23/2010	100.06	99.92	100.00	1
LG&E	C1SR	862475	08/2010	06/23/2010	100.08	99.94	99.97	1
LG&E	C1SR	862476	08/2010	06/23/2010	100.06	99.94	99.99	1
LG&E	C1SR	862477	08/2010	06/23/2010	100.09	99.91	100.03	1
LG&E	C1SR	862478	08/2010	06/23/2010	100.07	99.99	99.97	1
LG&E	C1SR	862479	08/2010	06/23/2010	100.06	99.96	99.99	1
LG&E	C1SR	862480	08/2010	06/23/2010	100.09	99.97	100.16	1
LG&E	C1SR	862481	08/2010	06/23/2010	100.08	99.89	100.02	1
LG&E	C1SR	862482	08/2010	06/23/2010	100.09	99.94	100.02	1
LG&E	C1SR	862483	08/2010	06/23/2010	100.09	100.13	100.19	1
LG&E	C1SR	862484	08/2010	06/23/2010	100.09	100.05	100.12	1
LG&E	C1SR	862485	08/2010	06/23/2010	100.09	100.04	100.08	1
LG&E	C1SR	862486	08/2010	06/23/2010	100.08	100.02	100.14	1
LG&E	C1SR	862487	08/2010	06/23/2010	100.08	99.95	100.14	1
LG&E	C1SR	862488	08/2010	06/23/2010	100.07	100.06	100.14	1
LG&E	C1SR	862489	08/2010	06/23/2010	100.09	100.02	100.11	1
LG&E	C1SR	862490	08/2010	06/23/2010	100.08	100.02	100.17	1
LG&E	C1SR	862491	08/2010	06/23/2010	100.08	100.06	100.13	1
LG&E	C1SR	862492	08/2010	06/23/2010	100.07	99.98	100.11	1
LG&E	C1SR	862493	08/2010	06/23/2010	100.07	99.97	100.04	1
LG&E	C1SR	862494	08/2010	06/23/2010	100.09	99.96	100.08	1
LG&E	C1SR	862495	08/2010	06/23/2010	100.07	99.88	100.02	1
LG&E	C1SR	862496	08/2010	06/23/2010	100.07	99.95	100.09	1

LG&E	C1SR	862497	08/2010	03/2010	100.08	100.08	100.08	100.20	1
LG&E	C1SR	862498	08/2010	06/23/2010	100.06	100.06	100.04	100.04	1
LG&E	C1SR	862499	08/2010	06/23/2010	100.06	100.06	100.10	100.10	1
LG&E	C1SR	862500	08/2010	06/23/2010	100.06	100.06	100.16	100.16	1
LG&E	C1SR	862501	08/2010	06/23/2010	100.08	100.08	100.00	100.00	1
LG&E	C1SR	862502	08/2010	06/23/2010	100.09	100.09	100.05	100.05	1
LG&E	C1SR	862503	08/2010	06/23/2010	100.10	100.10	100.03	100.03	1
LG&E	C1SR	862504	08/2010	06/23/2010	100.09	100.09	100.06	100.06	1
LG&E	C1SR	862505	08/2010	06/23/2010	100.08	100.08	100.01	100.01	1
LG&E	C1SR	862506	08/2010	06/23/2010	100.08	100.08	100.12	100.12	1
LG&E	C1SR	862507	08/2010	06/23/2010	100.07	100.07	100.07	100.07	1
LG&E	C1SR	862508	08/2010	06/23/2010	100.08	100.08	100.06	100.06	1
LG&E	C1SR	862509	08/2010	06/23/2010	100.10	100.10	100.14	100.14	1
LG&E	C1SR	862510	08/2010	06/23/2010	100.05	100.05	100.20	100.20	1
LG&E	C1SR	862511	08/2010	06/23/2010	100.07	100.07	100.14	100.14	1
LG&E	C1SR	862512	08/2010	06/23/2010	100.10	100.10	100.06	100.06	1
LG&E	C1SR	862513	08/2010	06/23/2010	100.09	100.09	100.01	100.01	1
LG&E	C1SR	862514	08/2010	06/23/2010	100.08	100.08	100.19	100.19	1
LG&E	C1SR	862515	08/2010	06/23/2010	100.10	100.10	100.12	100.12	1
LG&E	C1SR	862516	08/2010	06/23/2010	100.08	100.08	100.05	100.05	1
LG&E	C1SR	862517	08/2010	06/23/2010	100.07	100.07	100.05	100.05	1
LG&E	C1SR	862518	08/2010	06/23/2010	100.05	100.05	100.08	100.08	1
LG&E	C1SR	862519	08/2010	06/23/2010	100.06	100.06	99.92	99.92	1
LG&E	C1SR	862520	08/2010	06/23/2010	100.06	100.06	100.14	100.14	1
LG&E	C1SR	862521	08/2010	06/23/2010	100.09	100.09	100.12	100.12	1
LG&E	C1SR	862522	08/2010	06/23/2010	100.05	100.05	99.96	99.96	1
LG&E	C1SR	862523	08/2010	06/23/2010	100.07	100.07	99.98	99.98	1
LG&E	C1SR	862524	08/2010	06/23/2010	100.10	100.10	100.20	100.20	1
LG&E	C1SR	862525	08/2010	06/23/2010	100.10	100.10	100.17	100.17	1
LG&E	C1SR	862526	08/2010	06/23/2010	100.09	100.09	100.10	100.10	1
LG&E	C1SR	862527	08/2010	06/23/2010	100.09	100.09	100.09	100.09	1
LG&E	C1SR	862528	08/2010	06/23/2010	100.05	100.05	100.12	100.12	1
LG&E	C1SR	862529	08/2010	06/23/2010	100.07	100.07	100.17	100.17	1
LG&E	C1SR	862530	08/2010	06/23/2010	100.08	100.08	100.00	100.00	1
LG&E	C1SR	862531	08/2010	06/23/2010	100.06	100.06	100.05	100.05	1
LG&E	C1SR	862532	08/2010	06/23/2010	100.10	100.10	100.07	100.07	1

LG&E	CISR	862533	08/2010	06/23/2010	100.08	99.93	100.08	1
LG&E	CISR	862534	08/2010	06/23/2010	100.08	99.96	100.05	1
LG&E	CISR	862535	08/2010	06/23/2010	100.06	99.81	100.00	1
LG&E	CISR	862536	08/2010	06/23/2010	100.05	99.94	100.04	1
LG&E	CISR	862537	08/2010	06/23/2010	100.09	100.00	100.02	1
LG&E	CISR	862538	08/2010	06/23/2010	100.10	100.09	100.17	1
LG&E	CISR	862539	08/2010	06/23/2010	100.07	100.10	100.11	1
LG&E	CISR	862540	08/2010	06/23/2010	100.06	100.02	100.08	1
LG&E	CISR	862541	08/2010	06/23/2010	100.10	100.09	100.15	1
LG&E	CISR	862542	08/2010	06/23/2010	100.08	100.00	100.08	1
LG&E	CISR	862543	08/2010	06/23/2010	100.07	99.94	100.01	1
LG&E	CISR	862544	08/2010	06/23/2010	100.07	100.01	100.12	1
LG&E	CISR	862545	08/2010	06/23/2010	100.06	99.95	100.05	1
LG&E	CISR	862546	08/2010	06/23/2010	100.10	100.04	100.18	1
LG&E	CISR	862547	08/2010	06/23/2010	100.07	99.97	99.94	1
LG&E	CISR	862548	08/2010	06/23/2010	100.09	100.11	100.16	1
LG&E	CISR	862549	08/2010	06/23/2010	100.06	100.02	99.96	1
LG&E	CISR	862550	08/2010	06/23/2010	100.06	99.80	99.98	1
LG&E	CISR	862551	08/2010	06/23/2010	100.08	100.01	100.08	1
LG&E	CISR	862552	08/2010	06/23/2010	100.06	100.01	100.11	1
LG&E	CISR	862553	08/2010	06/23/2010	100.06	99.95	100.08	1
LG&E	CISR	862554	08/2010	06/23/2010	100.08	100.07	100.13	1
LG&E	CISR	862555	08/2010	06/23/2010	100.06	100.05	100.09	1
LG&E	CISR	862556	08/2010	06/23/2010	100.06	99.95	100.09	1
LG&E	CISR	862557	08/2010	06/23/2010	100.06	99.95	100.02	1
LG&E	CISR	862558	08/2010	06/23/2010	100.08	100.06	100.17	1
LG&E	CISR	862559	08/2010	06/23/2010	100.10	100.00	100.08	1
LG&E	CISR	862560	08/2010	06/23/2010	100.07	99.97	100.13	1
LG&E	CISR	862561	08/2010	06/23/2010	100.06	99.85	99.92	1
LG&E	CISR	862562	08/2010	06/23/2010	100.08	99.99	100.16	1
LG&E	CISR	862563	08/2010	06/23/2010	100.07	99.84	100.13	1
LG&E	CISR	862564	08/2010	06/23/2010	100.08	100.09	100.15	1
LG&E	CISR	862565	08/2010	06/23/2010	100.07	100.02	100.02	1
LG&E	CISR	862566	08/2010	06/23/2010	100.09	100.11	100.17	1
LG&E	CISR	862567	08/2010	06/23/2010	100.08	100.09	100.17	1
LG&E	CISR	862568	08/2010	06/23/2010	100.07	99.94	99.99	1



LG&E		C1SR	862569	08/2010	23/2010	100.10	99.93	100.13	1
LG&E		C1SR	862570	08/2010	06/23/2010	100.09	100.01	100.11	1
LG&E		C1SR	862571	08/2010	06/23/2010	100.10	100.01	100.00	1
LG&E		C1SR	862572	08/2010	06/23/2010	100.06	99.89	100.06	1
LG&E		C1SR	862573	08/2010	06/23/2010	100.10	99.97	100.01	1
LG&E		C1SR	862574	08/2010	06/23/2010	100.09	100.06	100.20	1
LG&E		C1SR	862575	08/2010	06/23/2010	100.10	100.02	100.20	1
LG&E		C1SR	862576	08/2010	06/23/2010	100.06	100.03	100.13	1
LG&E		C1SR	862577	08/2010	06/23/2010	100.09	100.09	100.22	1
LG&E		C1SR	862578	08/2010	06/23/2010	100.09	99.95	100.06	1
LG&E		C1SR	862579	08/2010	06/23/2010	100.07	100.04	100.23	1
LG&E		C1SR	862580	08/2010	06/23/2010	100.06	100.04	100.19	1
LG&E		C1SR	862581	08/2010	06/23/2010	100.10	99.94	100.03	1
LG&E		C1SR	862582	08/2010	06/23/2010	100.09	100.00	100.15	1
LG&E		C1SR	862583	08/2010	06/23/2010	100.07	99.96	100.02	1
LG&E		C1SR	862584	08/2010	06/23/2010	100.09	100.03	100.12	1
LG&E		C1SR	862585	08/2010	06/23/2010	100.05	100.05	100.11	1
LG&E		C1SR	862586	08/2010	06/23/2010	100.07	99.94	100.08	1
LG&E		C1SR	862587	08/2010	06/23/2010	100.08	99.93	99.92	1
LG&E		C1SR	862588	08/2010	06/23/2010	100.05	100.07	100.23	1
LG&E		C1SR	862589	08/2010	06/23/2010	100.06	99.95	100.03	1
LG&E		C1SR	862590	08/2010	06/23/2010	100.07	99.90	100.05	1
LG&E		C1SR	862591	08/2010	06/23/2010	100.06	99.91	100.04	1
LG&E		C1SR	862592	08/2010	06/23/2010	100.10	100.06	100.02	1
LG&E		C1SR	862593	08/2010	06/23/2010	100.05	99.92	100.17	1
LG&E		C1SR	862594	08/2010	06/23/2010	100.10	99.97	100.10	1
LG&E		C1SR	862595	08/2010	06/23/2010	100.10	100.03	100.14	1
LG&E		C1SR	862596	08/2010	06/23/2010	100.07	99.97	100.08	1
LG&E		C1SR	862597	08/2010	06/23/2010	100.08	99.95	100.19	1
LG&E		C1SR	862598	08/2010	06/23/2010	100.09	99.95	100.08	1
LG&E		C1SR	862599	08/2010	06/23/2010	100.07	100.03	100.18	1
LG&E		C1SR	862600	08/2010	06/23/2010	100.08	99.94	100.03	1
LG&E		C1SR	862601	08/2010	06/23/2010	100.10	99.90	100.10	1
LG&E		C1SR	862602	08/2010	06/23/2010	100.09	100.07	100.13	1
LG&E		C1SR	862603	08/2010	06/23/2010	100.10	99.96	100.10	1
LG&E		C1SR	862604	08/2010	06/23/2010	100.08	99.94	100.06	1

LG&E	C1SR	862605	08/2010	06/23/2010	100.07	99.93	100.07	1
LG&E	C1SR	862606	08/2010	06/23/2010	100.06	99.92	100.12	1
LG&E	C1SR	862607	08/2010	06/23/2010	100.10	100.06	100.20	1
LG&E	C1SR	862608	08/2010	06/23/2010	100.09	99.97	100.06	1
LG&E	C1SR	862609	08/2010	06/23/2010	100.10	100.07	100.20	1
LG&E	C1SR	862610	08/2010	06/23/2010	100.07	99.98	100.11	1
LG&E	C1SR	862611	08/2010	06/23/2010	100.07	99.98	100.03	1
LG&E	C1SR	862612	08/2010	06/23/2010	100.08	99.99	100.05	1
LG&E	C1SR	862613	08/2010	06/23/2010	100.08	100.09	100.21	1
LG&E	C1SR	862614	08/2010	06/23/2010	100.06	100.03	100.09	1
LG&E	C1SR	862615	08/2010	06/23/2010	100.06	100.00	100.09	1
LG&E	C1SR	862616	08/2010	06/23/2010	100.07	100.00	100.11	1
LG&E	C1SR	862617	08/2010	06/23/2010	100.08	99.93	100.02	1
LG&E	C1SR	862618	08/2010	06/23/2010	100.09	100.00	100.05	1
LG&E	C1SR	862619	08/2010	06/23/2010	100.10	99.99	100.03	1
LG&E	C1SR	862620	08/2010	06/23/2010	100.08	99.97	100.10	1
LG&E	C1SR	862621	08/2010	06/23/2010	100.05	99.91	100.03	1
LG&E	C1SR	862622	08/2010	06/23/2010	100.09	100.00	100.02	1
LG&E	C1SR	862623	08/2010	06/23/2010	100.07	100.00	99.97	1
LG&E	C1SR	862624	08/2010	06/23/2010	100.09	99.93	99.97	1
LG&E	C1SR	862625	08/2010	06/23/2010	100.08	100.09	100.11	1
LG&E	C1SR	862626	08/2010	06/23/2010	100.06	99.90	100.06	1
LG&E	C1SR	862627	08/2010	06/23/2010	100.06	100.00	100.02	1
LG&E	C1SR	862628	08/2010	06/23/2010	100.09	100.10	100.17	1
LG&E	C1SR	862629	08/2010	06/23/2010	100.07	100.04	100.04	1
LG&E	C1SR	862630	08/2010	06/23/2010	100.06	99.82	99.96	1
LG&E	C1SR	862631	08/2010	06/23/2010	100.07	100.00	100.15	1
LG&E	C1SR	862632	08/2010	06/23/2010	100.09	100.03	100.09	1
LG&E	C1SR	862633	08/2010	06/23/2010	100.08	100.03	100.11	1
LG&E	C1SR	862634	08/2010	06/23/2010	100.06	100.06	100.12	1
LG&E	C1SR	862635	08/2010	06/23/2010	100.08	100.00	100.11	1
LG&E	C1SR	862636	08/2010	06/23/2010	100.08	99.95	100.06	1
LG&E	C1SR	862637	08/2010	06/23/2010	100.08	99.99	99.96	1
LG&E	C1SR	862638	08/2010	06/23/2010	100.06	99.96	99.95	1
LG&E	C1SR	862639	08/2010	06/23/2010	100.08	99.95	99.99	1
LG&E	C1SR	862640	08/2010	06/23/2010	100.08	100.00	100.04	1

LG&E	C1SR	862641	08/2010	03/2010	100.07	99.94	100.05	1
LG&E	C1SR	862642	08/2010	06/23/2010	100.06	100.07	99.97	1
LG&E	C1SR	862643	08/2010	06/23/2010	100.09	99.91	100.08	1
LG&E	C1SR	862644	08/2010	06/23/2010	100.08	99.97	100.06	1
LG&E	C1SR	862645	08/2010	06/23/2010	100.05	99.98	99.98	1
LG&E	C1SR	862646	08/2010	06/23/2010	100.06	99.90	100.02	1
LG&E	C1SR	862647	08/2010	06/23/2010	100.07	99.90	100.09	1
LG&E	C1SR	862648	08/2010	06/23/2010	100.07	99.96	100.05	1
LG&E	C1SR	862649	08/2010	06/23/2010	100.06	99.95	100.03	1
LG&E	C1SR	862650	08/2010	06/23/2010	100.08	99.91	100.13	1
LG&E	C1SR	862651	08/2010	06/23/2010	100.08	99.87	99.99	1
LG&E	C1SR	862652	08/2010	06/23/2010	100.08	100.09	99.99	1
LG&E	C1SR	862653	08/2010	06/23/2010	100.10	100.02	100.07	1
LG&E	C1SR	862654	08/2010	06/23/2010	100.09	100.07	100.14	1
LG&E	C1SR	862655	08/2010	06/23/2010	100.10	100.03	100.05	1
LG&E	C1SR	862656	08/2010	06/23/2010	100.09	99.94	100.05	1
LG&E	C1SR	862657	08/2010	06/23/2010	100.06	99.89	99.97	1
LG&E	C1SR	862658	08/2010	06/23/2010	100.06	99.86	99.97	1
LG&E	C1SR	862659	08/2010	06/23/2010	100.07	100.07	100.14	1
LG&E	C1SR	862660	08/2010	06/23/2010	100.07	99.90	100.03	1
LG&E	C1SR	862661	08/2010	06/23/2010	100.06	100.02	100.12	1
LG&E	C1SR	862662	08/2010	06/23/2010	100.10	99.97	100.00	1
LG&E	C1SR	862663	08/2010	06/23/2010	100.10	99.96	100.09	1
LG&E	C1SR	862664	08/2010	06/23/2010	100.08	100.02	100.06	1
LG&E	C1SR	862665	08/2010	06/23/2010	100.10	100.06	100.00	1
LG&E	C1SR	862666	08/2010	06/23/2010	100.09	100.08	100.17	1
LG&E	C1SR	862667	08/2010	06/23/2010	100.08	99.93	100.09	1
LG&E	C1SR	862668	08/2010	06/23/2010	100.06	99.95	99.96	1
LG&E	C1SR	862669	08/2010	06/23/2010	100.09	100.11	100.19	1
LG&E	C1SR	862670	08/2010	06/23/2010	100.07	100.00	100.14	1
LG&E	C1SR	862671	08/2010	06/23/2010	100.11	100.06	100.18	1
LG&E	C1SR	862672	08/2010	06/23/2010	100.07	100.00	100.12	1
LG&E	C1SR	862673	08/2010	06/23/2010	100.06	99.99	100.08	1
LG&E	C1SR	862674	08/2010	06/23/2010	100.07	100.12	100.13	1
LG&E	C1SR	862675	08/2010	06/23/2010	100.10	99.88	99.94	1
LG&E	C1SR	862676	08/2010	06/23/2010	100.07	99.95	100.11	1

LG&E	C1SR	862677	08/2010	23/2010	100.10	99.86	100.08	1
LG&E	C1SR	862678	08/2010	06/23/2010	100.06	100.03	99.96	1
LG&E	C1SR	862679	08/2010	06/23/2010	100.09	99.93	100.05	1
LG&E	C1SR	862680	08/2010	06/23/2010	100.08	99.93	100.09	1
LG&E	C1SR	862681	08/2010	06/23/2010	100.06	99.97	100.17	1
LG&E	C1SR	862682	08/2010	06/23/2010	100.06	99.97	100.13	1
LG&E	C1SR	862683	08/2010	06/23/2010	100.10	100.08	100.04	1
LG&E	C1SR	862684	08/2010	06/23/2010	100.09	100.05	100.22	1
LG&E	C1SR	862685	08/2010	06/23/2010	100.06	100.06	100.11	1
LG&E	C1SR	862686	08/2010	06/23/2010	100.07	100.04	100.00	1
LG&E	C1SR	862687	08/2010	06/23/2010	100.07	100.06	100.16	1
LG&E	C1SR	862688	08/2010	06/23/2010	100.06	100.04	100.11	1
LG&E	C1SR	862689	08/2010	06/23/2010	100.05	99.88	99.96	1
LG&E	C1SR	862690	08/2010	06/23/2010	100.08	99.85	100.02	1
LG&E	C1SR	862691	08/2010	06/23/2010	100.09	99.88	100.03	1
LG&E	C1SR	862692	08/2010	06/23/2010	100.08	100.02	99.93	1
LG&E	C1SR	862693	08/2010	06/23/2010	100.08	99.88	100.11	1
LG&E	C1SR	862694	08/2010	06/23/2010	100.09	99.90	100.02	1
LG&E	C1SR	862695	08/2010	06/23/2010	100.06	99.93	100.08	1
LG&E	C1SR	862696	08/2010	06/23/2010	100.10	99.89	100.03	1
LG&E	C1SR	862697	08/2010	06/23/2010	100.08	100.02	100.11	1
LG&E	C1SR	862698	08/2010	06/23/2010	100.07	99.86	99.99	1
LG&E	C1SR	862699	08/2010	06/23/2010	100.09	99.90	100.08	1
LG&E	C1SR	862700	08/2010	06/23/2010	100.05	99.95	99.98	1
LG&E	C1SR	862701	08/2010	06/23/2010	100.06	99.97	100.00	1
LG&E	C1SR	862702	08/2010	06/23/2010	100.10	99.95	100.13	1
LG&E	C1SR	862703	08/2010	06/23/2010	100.06	100.01	100.11	1
LG&E	C1SR	862704	08/2010	06/23/2010	100.09	99.92	100.13	1
LG&E	C1SR	862705	08/2010	06/23/2010	100.10	100.06	99.98	1
LG&E	C1SR	862706	08/2010	06/23/2010	100.08	99.94	100.05	1
LG&E	C1SR	862707	08/2010	06/23/2010	100.09	100.03	100.14	1
LG&E	C1SR	862708	08/2010	06/23/2010	100.10	100.05	100.25	1
LG&E	C1SR	862709	08/2010	06/23/2010	100.08	100.08	100.15	1
LG&E	C1SR	862710	08/2010	06/23/2010	100.09	100.06	100.18	1
LG&E	C1SR	862711	08/2010	06/23/2010	100.10	99.91	100.06	1
LG&E	C1SR	862712	08/2010	06/23/2010	100.09	99.97	100.01	1

LG&E	C1SR	862713	08/2010	23/2010	100.08	99.95	100.10	1
LG&E	C1SR	862714	08/2010	06/23/2010	100.09	100.04	100.13	1
LG&E	C1SR	862715	08/2010	06/23/2010	100.09	100.04	100.11	1
LG&E	C1SR	862716	08/2010	06/23/2010	100.10	99.97	99.97	1
LG&E	C1SR	862717	08/2010	06/23/2010	100.06	99.98	99.93	1
LG&E	C1SR	862718	08/2010	06/23/2010	100.05	99.85	100.01	1
LG&E	C1SR	862719	08/2010	06/23/2010	100.07	100.03	100.02	1
LG&E	C1SR	862720	08/2010	06/23/2010	100.08	99.92	100.05	1
LG&E	C1SR	862721	08/2010	06/23/2010	100.08	99.94	100.08	1
LG&E	C1SR	862722	08/2010	06/23/2010	100.06	99.93	100.04	1
LG&E	C1SR	862723	08/2010	06/23/2010	100.06	99.87	100.05	1
LG&E	C1SR	862724	08/2010	06/23/2010	100.07	100.02	100.07	1
LG&E	C1SR	862725	08/2010	06/23/2010	100.08	99.92	100.05	1
LG&E	C1SR	862726	08/2010	06/23/2010	100.06	99.86	99.94	1
LG&E	C1SR	862727	08/2010	06/23/2010	100.10	100.10	100.17	1
LG&E	C1SR	862728	08/2010	06/23/2010	100.09	100.05	100.17	1
LG&E	C1SR	862729	08/2010	06/23/2010	100.06	99.85	100.16	1
LG&E	C1SR	862730	08/2010	06/23/2010	100.08	99.90	100.10	1
LG&E	C1SR	862731	08/2010	06/23/2010	100.06	99.81	99.94	1
LG&E	C1SR	862732	08/2010	06/23/2010	100.09	100.01	99.98	1
LG&E	C1SR	862733	08/2010	06/23/2010	100.07	99.85	99.99	1
LG&E	C1SR	862734	08/2010	06/23/2010	100.10	100.06	100.14	1
LG&E	C1SR	862735	08/2010	06/23/2010	100.08	99.97	100.06	1
LG&E	C1SR	862736	08/2010	06/23/2010	100.09	99.97	100.01	1
LG&E	C1SR	862737	08/2010	06/23/2010	100.09	99.89	100.02	1
LG&E	C1SR	862738	08/2010	06/23/2010	100.06	99.94	99.98	1
LG&E	C1SR	862739	08/2010	06/23/2010	100.06	100.02	100.09	1
LG&E	C1SR	862740	08/2010	06/23/2010	100.08	100.00	100.02	1
LG&E	C1SR	862741	08/2010	06/23/2010	100.08	99.98	100.14	1
LG&E	C1SR	862742	08/2010	06/23/2010	100.09	100.07	100.19	1
LG&E	C1SR	862743	08/2010	06/23/2010	100.05	99.92	99.98	1
LG&E	C1SR	862744	08/2010	06/23/2010	100.07	99.82	100.00	1
LG&E	C1SR	862745	08/2010	06/23/2010	100.09	100.06	100.20	1
LG&E	C1SR	862746	08/2010	06/23/2010	100.07	99.97	100.12	1
LG&E	C1SR	862747	08/2010	06/23/2010	100.08	100.04	100.19	1
LG&E	C1SR	862748	08/2010	06/23/2010	100.10	99.94	100.06	1

LG&E	C1SR	862749	08/2010	06/23/2010	100.06	99.92	99.97	1
LG&E	C1SR	862750	08/2010	06/23/2010	100.07	100.07	100.12	1
LG&E	C1SR	862751	08/2010	06/23/2010	100.10	100.08	100.02	1
LG&E	C1SR	862752	08/2010	06/23/2010	100.06	99.99	100.18	1
LG&E	C1SR	862753	08/2010	06/23/2010	100.07	99.88	100.06	1
LG&E	C1SR	862754	08/2010	06/23/2010	100.08	99.96	100.02	1
LG&E	C1SR	862755	08/2010	06/23/2010	100.05	99.98	100.08	1
LG&E	C1SR	862756	08/2010	06/23/2010	100.10	99.99	100.01	1
LG&E	C1SR	862757	08/2010	06/23/2010	100.09	99.92	100.06	1
LG&E	C1SR	862758	08/2010	06/23/2010	100.06	100.02	100.08	1
LG&E	C1SR	862759	08/2010	06/23/2010	100.06	99.93	99.95	1
LG&E	C1SR	862760	08/2010	06/23/2010	100.06	99.92	99.95	1
LG&E	C1SR	862761	08/2010	06/23/2010	100.07	100.05	100.23	1
LG&E	C1SR	862762	08/2010	06/23/2010	100.07	99.97	100.00	1
LG&E	C1SR	862763	08/2010	06/23/2010	100.09	100.00	100.08	1
LG&E	C1SR	862764	08/2010	06/23/2010	100.09	100.05	100.09	1
LG&E	C1SR	862765	08/2010	06/23/2010	100.06	99.87	100.16	1
LG&E	C1SR	862766	08/2010	06/23/2010	100.06	99.92	100.08	1
LG&E	C1SR	862767	08/2010	06/23/2010	100.07	100.07	100.09	1
LG&E	C1SR	862768	08/2010	06/23/2010	100.10	100.04	100.14	1
LG&E	C1SR	862769	08/2010	06/23/2010	100.09	99.94	99.96	1
LG&E	C1SR	862770	08/2010	06/23/2010	100.08	99.99	100.03	1
LG&E	C1SR	862771	08/2010	06/23/2010	100.08	100.09	100.10	1
LG&E	C1SR	862772	08/2010	06/23/2010	100.10	100.01	100.11	1
LG&E	C1SR	862773	08/2010	06/23/2010	100.07	99.89	100.02	1
LG&E	C1SR	862774	08/2010	06/23/2010	100.06	99.84	100.09	1
LG&E	C1SR	862775	08/2010	06/23/2010	100.09	100.01	100.02	1
LG&E	C1SR	862776	08/2010	06/23/2010	100.09	99.97	100.03	1
LG&E	C1SR	862777	08/2010	06/23/2010	100.09	99.83	100.00	1
LG&E	C1SR	862778	08/2010	06/23/2010	100.10	100.11	100.08	1
LG&E	C1SR	862779	08/2010	06/23/2010	100.08	99.95	100.04	1
LG&E	C1SR	862780	08/2010	06/23/2010	100.10	100.02	100.12	1
LG&E	C1SR	862781	08/2010	06/23/2010	100.08	100.05	100.16	1
LG&E	C1SR	862782	08/2010	06/23/2010	100.05	99.95	99.98	1
LG&E	C1SR	862783	08/2010	06/23/2010	100.06	100.03	100.12	1
LG&E	C1SR	862784	08/2010	06/23/2010	100.06	99.90	100.00	1

LG&E		C1SR	862785	08/2010	23/2010	100.10	100.11	100.14	1
LG&E		C1SR	862786	08/2010	06/23/2010	100.10	100.12	100.18	1
LG&E		C1SR	862787	08/2010	06/23/2010	100.09	100.10	100.25	1
LG&E		C1SR	862788	08/2010	06/23/2010	100.06	99.91	100.00	1
LG&E		C1SR	862789	08/2010	06/23/2010	100.08	99.85	100.00	1
LG&E		C1SR	862790	08/2010	06/23/2010	100.09	99.91	100.01	1
LG&E		C1SR	862791	08/2010	06/23/2010	100.08	99.84	99.97	1
LG&E		C1SR	862792	08/2010	06/23/2010	100.10	99.95	99.92	1
LG&E		C1SR	862793	08/2010	06/23/2010	100.09	100.07	100.06	1
LG&E		C1SR	862794	08/2010	06/23/2010	100.09	99.97	100.02	1
LG&E		C1SR	862795	08/2010	06/23/2010	100.09	100.09	100.11	1
LG&E		C1SR	862796	08/2010	06/23/2010	100.06	99.83	100.06	1
LG&E		C1SR	862797	08/2010	06/23/2010	100.06	100.00	99.93	1
LG&E		C1SR	862798	08/2010	06/23/2010	100.06	100.00	100.13	1
LG&E		C1SR	862799	08/2010	06/23/2010	100.09	100.05	100.00	1
LG&E		C1SR	862800	08/2010	06/23/2010	100.09	100.02	100.15	1
LG&E		C1SR	862801	08/2010	06/23/2010	100.07	99.90	99.93	1
LG&E		C1SR	862802	08/2010	06/23/2010	100.10	99.94	100.01	1
LG&E		C1SR	862803	08/2010	06/23/2010	100.09	100.09	100.08	1
LG&E		C1SR	862804	08/2010	06/23/2010	100.07	99.93	100.12	1
LG&E		C1SR	862805	08/2010	06/23/2010	100.07	100.01	100.01	1
LG&E		C1SR	862806	08/2010	06/23/2010	100.08	99.93	100.05	1
LG&E		C1SR	862807	08/2010	06/23/2010	100.07	99.89	99.92	1
LG&E		C1SR	862808	08/2010	06/23/2010	100.08	100.02	100.08	1
LG&E		C1SR	862809	08/2010	06/23/2010	100.06	99.96	99.96	1
LG&E		C1SR	862810	08/2010	06/23/2010	100.07	99.87	99.95	1
LG&E		C1SR	862811	08/2010	06/23/2010	100.06	100.05	100.00	1
LG&E		C1SR	862812	08/2010	06/23/2010	100.08	99.93	100.07	1
LG&E		C1SR	862813	08/2010	06/23/2010	100.09	100.08	100.13	1
LG&E		C1SR	862814	08/2010	06/23/2010	100.09	99.86	100.14	1
LG&E		C1SR	862815	08/2010	06/23/2010	100.06	99.91	99.94	1
LG&E		C1SR	862816	08/2010	06/23/2010	100.08	100.08	100.13	1
LG&E		C1SR	862817	08/2010	06/23/2010	100.06	100.02	99.97	1
LG&E		C1SR	862818	08/2010	06/23/2010	100.06	100.02	100.07	1
LG&E		C1SR	862819	08/2010	06/23/2010	100.09	100.00	99.98	1
LG&E		C1SR	862820	08/2010	06/23/2010	100.07	100.05	100.08	1

LG&E	C1SR	862821	08/2010	06/23/2010	100.08	99.90	100.07	1
LG&E	C1SR	862822	08/2010	06/23/2010	100.09	99.92	100.14	1
LG&E	C1SR	862823	08/2010	06/23/2010	100.08	99.96	100.03	1
LG&E	C1SR	862824	08/2010	06/23/2010	100.06	99.98	100.12	1
LG&E	C1SR	862825	08/2010	06/23/2010	100.09	100.10	100.12	1
LG&E	C1SR	862826	08/2010	06/23/2010	100.09	99.95	100.07	1
LG&E	C1SR	862827	08/2010	06/23/2010	100.05	99.97	100.09	1
LG&E	C1SR	862828	08/2010	06/23/2010	100.08	100.06	100.15	1
LG&E	C1SR	862829	08/2010	06/23/2010	100.06	100.04	100.16	1
LG&E	C1SR	862830	08/2010	06/23/2010	100.07	99.98	100.05	1
LG&E	C1SR	862831	08/2010	06/23/2010	100.09	100.04	100.07	1
LG&E	C1SR	862832	08/2010	06/23/2010	100.07	100.04	100.17	1
LG&E	C1SR	862833	08/2010	06/23/2010	100.08	100.02	100.07	1
LG&E	C1SR	862834	08/2010	06/23/2010	100.09	99.92	100.00	1
LG&E	C1SR	862835	08/2010	06/23/2010	100.09	99.94	100.03	1
LG&E	C1SR	862836	08/2010	06/23/2010	100.07	100.08	100.07	1
LG&E	C1SR	862837	08/2010	06/23/2010	100.08	99.97	100.09	1
LG&E	C1SR	862838	08/2010	06/23/2010	100.07	99.98	100.02	1
LG&E	C1SR	862839	08/2010	06/23/2010	100.09	100.05	100.18	1
Overall Result	Result				100.08	99.98	100.08	6,664
Overall Result					100.08	99.98	100.08	6,664



ATTACHMENT  
B

Sampling Test Results



**LG&E**  
**2010 SAMPLE**  
**ELECTRIC METER SUMMARY**

**SAMPLE**

In-Service Population	380,592	Divided into 48 Lots
Sample Quantity	3,260	
Meters Tested	3,260	
Meters Not Tested	0	
Failed Lots	0	
Failed Lot Meters	0	



Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F28240V30AC200 Model Number: AB1 Division: 01 Sample Lot: 348 Lot Descr: IGE AB1 - 1  
 In Service Population: 223 Sample Quantity: 15 Meters Tested: 15 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 1  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
725075	99.90	725137	100.20	725163	100.20	725181	99.90
725241	99.90	725263	100.30	725288	100.20	725289	100.20
725350	100.20	725365	100.30	725377	100.10	725565	99.80
							99.80

INFORMATION NEEDED

- 1 Sample Size (N) 15
- 2 Sum of Measurements: (Sum X) 1501.40
- 3 Sum of Squared Measurements 150280.66
- 4 Correction Factor (CF): Sum of Measurements Squared / N 150280.13
- 5 Corrected Sum of Squares (SS) 0.53
- 6 Variance (V) : SS/(N-1) 0.0378
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.1944
- 8 Sample Mean(XBAR) : Sum X/N 100.09
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 9.81
- 12 Quality Index Lower (QL) : (XBAR-L) / S 10.77
- 13 Estimate of Lot Percent NCF Above U (FU) 0.00
- 14 Estimate of Lot Percent NCF Below L (FL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : FU+FL 6.55
- 16 Maximum Allowable Percent NCF(M)

PASS

- 17 Acceptability Criterion: Compare P with M
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Device Category: F2S240V30RCC200E Model Number: ALF (Trilliant) Division: 01 Sample Lot: 349 Lot Descr: LGE ALF - 1  
 In Service Population: 1,593 Sample Quantity: 50 Meters Tested: 50 Pass/Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method Page 2  
 One AQL Value for Both Upper and Lower Specification Limit Combined Run Date: 12/31/2010  
 AQL = 2.5% - Inspection Level II "e" # Normal Inspection Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
833384	100.10	833408	99.98	833412	100.00	833447	100.00
833598	99.90	833645	100.00	833650	99.90	833655	99.90
833759	100.00	833774	100.00	833822	100.00	833827	100.00
833924	100.00	833949	99.90	833951	100.00	834003	99.90
834096	100.00	834128	100.00	834191	100.10	834216	99.90
834237	100.00	834289	100.10	834292	99.98	834305	100.00
834395	100.00	834427	100.10	834526	100.10	834571	100.00
834588	100.10	834656	100.10	834671	100.00	834694	100.10
834916	100.10	834948	100.00	835004	100.10	835038	100.00
835094	100.00	835104	100.00	835113	100.00	835119	100.00

INFORMATION NEEDED VALUE OBTAINED

- 1 Sample Size (N) 50
- 2 Sum of Measurements: (Sum X) 5000.34
- 3 Sum of Squared Measurements 500068.22
- 4 Correction Factor (CF): Sum of Measurements Squared / N 500068.00
- 5 Corrected Sum of Squares (SS) 0.22
- 6 Variance (V) : SS/(N-1) 0.0045
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.0668
- 8 Sample Mean(XBAR) : Sum X/N 100.01
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 29.82
- 12 Quality Index Lower (QL) : (XBAR-L) / S 30.03
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 5.21
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: FZS240V30AC200E Model Number: C1SR (ERR) Division: 01 Sample Lot: 350  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: IGE CI - 1

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 3  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
739786	100.10	754098	100.20	754135	100.00	754296	100.00	754301	100.20
754330	100.30	754452	99.90	755471	100.00	755892	100.10	755943	100.10
756097	100.10	756101	100.30	756193	100.10	756418	99.90	766120	100.20
766546	100.30	766808	100.00	766817	100.10	767252	100.20	767277	100.10
776515	100.00	776536	100.27	776560	100.05	776948	100.10	777170	100.00
777216	99.90	777343	100.30	777703	100.00	777784	100.30	777794	99.90
778109	100.10	778495	100.10	778589	100.10	779835	100.10	779839	100.20
779894	100.00	793864	100.00	793909	100.00	793914	99.90	793972	100.00
794207	100.10	794617	100.00	794756	100.20	794807	99.70	794862	100.10
794934	100.20	795007	100.10	795066	100.10	795172	100.00	795199	100.20
795310	100.00	795880	100.10	796090	100.00	796103	100.10	796340	100.00
796413	100.10	796415	100.00	796890	100.20	796917	100.00	796938	100.10
797111	99.80	797304	100.10	797323	100.10	797409	100.20	797691	100.20
797838	100.10	797883	100.10	798027	100.30	798049	100.10	798205	100.20
798356	100.10	798364	100.00	798510	100.10	798559	100.10	798577	100.20

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7506.82
- 3 Sum of Squared Measurements 751365.69
- 4 Correction Factor (CF): Sum of Measurements Squared / N 751364.62
- 5 Corrected Sum of Squares (SS) 1.07
- 6 Variance (V) : SS/(N-1) 0.0144
- 7 Estimate of Lot Standard Deviation (S) : SQRT of V 0.1200
- 8 Sample Mean (XBAR) : Sum X/N 100.09
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 15.91
- 12 Quality Index Lower (QL) : (XBAR-L) / S 17.43
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200E Model Number: CIS Division: 01  
 In Service Population: 8,488 Sample Quantity: 75 Meters Tested: 75 Sample Lot: 351 Lot Descr: IGE C1 - 2  
 Pass/Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "M" # Normal Inspection  
 Page 4  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
798690	100.20	798855	100.10	798890	100.10	798927	100.20
799102	100.10	799146	100.10	799229	100.20	799291	100.00
799516	100.10	808919	100.10	809054	100.10	809085	99.90
809299	100.10	843356	100.00	843560	100.00	844006	100.00
844419	100.00	844436	100.00	844538	100.20	844575	100.00
845130	100.10	845246	100.00	845386	100.00	845566	100.00
846170	100.10	846191	100.00	846292	100.10	846332	100.00
846534	100.10	846565	100.20	846649	100.10	847617	100.10
848017	100.00	848106	100.00	848121	100.10	848162	100.10
848276	99.80	848443	100.10	848538	100.00	848582	99.90
849115	100.00	849175	99.90	849818	100.10	849884	100.10
850084	100.10	850138	100.10	850232	100.00	850290	100.20
850782	100.10	850832	100.20	850877	100.10	850991	100.00
851236	100.20	851482	100.00	851510	100.20	851565	100.00
852597	99.90	852601	100.20	852968	100.00	853023	100.00

INFORMATION NEEDED VALUE OBTAINED  
 75

- 1 Sample Size (N) 7504.40
- 2 Sum of Measurements: (Sum X) 750880.90
- 3 Sum of Squared Measurements 750880.26
- 4 Correction Factor (CF): Sum of Measurements Squared / N 0.64
- 5 Corrected Sum of Squares (SS) 0.0087
- 6 Variance (V) : SS/(N-1) 0.0931
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 100.06
- 8 Sample Mean(XBAR): Sum X/N 102.06
- 9 Upper Specification Limit (U) 20.84
- 10 Lower Specification Limit (L) 22.10
- 11 Quality Index Upper (QU) : (U-XBAR) / S 0.00
- 12 Quality Index Lower (QL) : (XBAR-L) / S 0.00
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 4.83
- 16 Maximum Allowable Percent NCF (M)
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Falls the Acceptability Criterion if P > M



Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: FZS240V30AC200 Model Number: D4S Division: 01 Sample Lot: 352  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/Fail: PASS Lot Descr: IGE D4 - I

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 5  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
367295	99.70	367302	99.80	367484	99.90	367574	99.30	371637	99.10
372259	99.80	372305	99.50	372349	100.10	372407	100.50	372491	100.10
372533	99.70	376499	100.50	376608	100.20	376690	99.30	376852	99.30
381555	100.20	386004	99.60	386161	100.30	386189	99.90	386606	100.10
386811	99.80	386882	99.50	386891	99.60	386892	99.60	389053	99.90
389321	100.10	391208	99.60	391531	100.00	395597	99.40	395755	99.80
396107	99.20	396359	98.90	399137	99.80	400124	100.00	400627	99.60
401043	100.00	401074	99.60	401179	99.70	401256	99.80	401441	100.00
401458	99.70	405587	100.40	405971	100.70	406191	99.90	407582	99.70
410064	99.90	410339	100.10	410748	100.10	410792	99.80	414918	100.10
414936	99.40	415108	100.10	415131	99.90	420250	100.20	425352	99.70
425547	99.70	431336	99.40	431492	100.20	431883	99.90	436960	100.20
437415	100.20	440399	99.90	440490	100.00	440542	100.30	443520	100.00
446611	100.50	448883	99.50	449022	100.10	451565	100.20	451615	100.30
451869	99.90	451964	100.20	452672	100.10	452755	100.10	453883	100.00

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7491.20
- 3 Sum of Squared Measurements 748250.02
- 4 Correction Factor (CF): Sum of Measurements Squared / N 748241.03
- 5 Corrected Sum of Squares (SS) 8.99
- 6 Variance (V) : SS/(N-1) 0.1215
- 7 Estimate of Lot Standard Deviation (S): SQRT of V 0.3485
- 8 Sample Mean(XBAR): Sum X/N 99.88
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 6.08
- 12 Quality Index Lower (QL): (XBAR-L) / S 5.40
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection  
 Page 6  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
454146	99.30	456249	100.20	456336	100.10	456459	99.80
456674	100.40	457303	100.00	457305	100.50	458334	99.60
458440	100.00	458992	100.50	459021	100.10	461182	100.10
464254	100.20	464274	100.10	464343	100.10	464701	99.50
465395	100.00	465471	100.20	468769	100.10	468931	99.80
471057	100.20	472584	100.60	472676	100.20	472729	99.80
472942	100.30	472946	100.00	472953	99.70	475059	100.20
475465	100.00	475733	100.07	475861	100.10	475865	99.90
478347	100.20	478395	99.90	478453	100.00	478503	100.00
481725	99.90	481736	99.90	483278	100.30	483293	100.30
483492	99.80	483728	99.60	485550	99.80	485558	99.50
486651	99.70	485776	99.70	486591	99.90	488762	100.10
489083	99.80	490259	99.70	490274	99.80	490349	99.90
490517	99.80	490558	99.70	496542	99.70	496570	100.00
496655	99.80	496704	99.80	496743	99.60	497574	100.00

INFORMATION NEEDED

1 Sample Size (N) 75  
 2 Sum of Measurements: (Sum X) 7496.97  
 3 Sum of Squared Measurements 749398.97  
 4 Correction Factor (CF): Sum of Measurements Squared / N 749394.12  
 5 Corrected Sum of Squares (SS) 4.85  
 6 Variance (V) : SS/(N-1) 0.0656  
 7 Estimate of Lot Standard Deviation (S) : SQRT of V 0.2561  
 8 Sample Mean(XBAR) : Sum X/N 99.96  
 9 Upper Specification Limit (U) 102.00  
 10 Lower Specification Limit (L) 98.00  
 11 Quality Index Upper (QU) : (U-XBAR) / S 7.97  
 12 Quality Index Lower (QL) : (XBAR-L) / S 7.65  
 13 Estimate of Lot Percent NCF Above U (PU) 0.00  
 14 Estimate of Lot Percent NCF Below L (PL) 0.00  
 15 Total Estimate Percent NCF In Lot (P) : PU+PL 0.00  
 16 Maximum Allowable Percent NCF (M) 4.83  
 17 Acceptability Criterion: Compare P with M  
 18 The Lot Meets the Acceptability Criterion if P <= M  
 19 The Lot Fails the Acceptability Criterion if P > M

VALUE OBTAINED

75  
 7496.97  
 749398.97  
 749394.12  
 4.85  
 0.0656  
 0.2561  
 99.96  
 102.00  
 98.00  
 7.97  
 7.65  
 0.00  
 0.00  
 0.00  
 4.83  
 PASS

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200E Model Number: I-210 (ERT) Division: 01 Sample Lot: 354  
 In Service Population: 1,152 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS Lot Descr: IGE I210 - 1

Test Results Per ANSI/ASQC Z1.9-1993 Page 7  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined Run Date: 12/31/2010  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
832133	100.00	832218	100.10	832282	99.90	832381	100.00
832394	99.90	832441	100.00	832494	100.00	832530	100.00
832595	100.30	832599	100.00	832606	100.00	832647	100.00
832716	100.00	832844	100.10	832890	100.00	832894	100.00
835334	100.00	835350	99.97	835358	100.00	835373	99.90
838217	100.00	838244	100.10	838247	100.20	838301	100.00
838357	100.00	838386	100.10	838414	100.00	838420	100.00

INFORMATION NEEDED VALUE OBTAINED

- 1 Sample Size (N) 35
- 2 Sum of Measurements: (Sum X) 3500.57
- 3 Sum of Squared Measurements 350114.20
- 4 Correction Factor (CF): Sum of Measurements Squared / N 350114.01
- 5 Corrected Sum of Squares (SS) 0.19
- 6 Variance (V) : SS/(N-1) 0.0056
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.0751
- 8 Sample Mean(XBAR): Sum X/N 102.02
- 9 Upper Specification Limit (U) 98.00
- 10 Lower Specification Limit (L) 26.42
- 11 Quality Index Upper (QU): (U-XBAR) / S 26.86
- 12 Quality Index Lower (QL): (XBAR-L) / S 0.00
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 5.58
- 16 Maximum Allowable Percent NCF(M) PASS
- 17 Acceptability Criterion: Compare P with M
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Device Category: F28240V15ACT100 Model Number: I-505 Division: 01 Sample Lot: 355 Lot Descr: IGE 150 - 1  
 In Service Population: 1,370 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS Run Date: 12/31/2010  
 Page 8  
 Run Time: 06:28:11 AM

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
182081	100.00	182120	100.00	184026	100.20	185089	100.70
186565	100.00	195148	100.20	198321	100.00	199103	100.30
204473	100.60	205178	100.20	205281	99.90	207125	100.20
212922	99.50	214529	100.80	214631	100.40	216159	99.90
217179	100.00	217230	99.70	219326	100.70	219362	99.70
219632	100.40	221094	100.40	221399	100.60	222365	99.80
223094	100.60	223211	100.70	223800	100.20	223908	100.10
224537	100.10	225088	100.00	226820	100.20	228611	100.00
232695	100.20	233257	99.60	233273	99.90	233346	99.80
234221	100.10	235004	100.10	235841	99.90	236050	99.70

INFORMATION NEEDED

- 1 Sample Size (N)
- 2 Sum of Measurements: (Sum X)
- 3 Sum of Squared Measurements
- 4 Correction Factor (CF): Sum of Measurements Squared / N
- 5 Corrected Sum of Squares (SS)
- 6 Variance (V): SS/(N-1)
- 7 Estimate of Lot Standard Deviation (S): SQRT of V
- 8 Sample Mean (XBAR): Sum X/N
- 9 Upper Specification Limit (U)
- 10 Lower Specification Limit (L)
- 11 Quality Index Upper (QU): (U-XBAR) / S
- 12 Quality Index Lower (QL): (XBAR-L) / S
- 13 Estimate of Lot Percent NCF Above U (PU)
- 14 Estimate of Lot Percent NCF Below L (PL)
- 15 Total Estimate Percent NCF: In Lot (P): PU+PL
- 16 Maximum Allowable Percent NCF (M)
- 17 Acceptability Criterion: Compare P with M
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

VALUE OBTAINED

- 1 50
- 2 5007.40
- 3 501485.90
- 4 501481.10
- 5 4.80
- 6 0.0981
- 7 0.3131
- 8 100.15
- 9 102.00
- 10 98.00
- 11 5.91
- 12 6.86
- 13 0.00
- 14 0.00
- 15 0.00
- 16 5.21
- 17 PASS

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V15AC100 Model Number: I-55S Division: 01 Sample Lot: 356 Lot Descr: IGE I55 - 1  
 In Service Population: 1,704 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 9  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
238599	100.30	239393	99.40	239692	100.30	240541	100.20
242558	100.20	242664	100.80	242667	100.20	242962	100.60
243933	100.40	244070	99.90	244189	100.20	246193	100.30
247084	100.70	247767	100.40	248577	100.70	249860	100.60
249996	100.20	250199	100.40	250653	100.20	250785	100.10
250868	100.40	251800	100.20	251846	100.10	252788	100.40
252969	100.10	256586	99.60	256602	100.30	256628	99.80
263113	100.20	263169	99.90	263337	99.90	263621	100.20
264509	99.60	264641	99.80	264807	100.00	264962	100.20
265165	99.90	265313	100.00	265693	100.30	265713	99.80

INFORMATION NEEDED

VALUE OBTAINED

- 1 Sample Size (N) 50
- 2 Sum of Measurements: (Sum X) 5008.10
- 3 Sum of Squared Measurements 501625.73
- 4 Correction Factor (CF): Sum of Measurements Squared / N 501621.31
- 5 Corrected Sum of Squares (SS) 4.42
- 6 Variance (V) : SS/(N-1) 0.0902
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.3003
- 8 Sample Mean(XBAR): Sum X/N 100.16
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 6.12
- 12 Quality Index Lower (QL): (XBAR-L) / S 7.20
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 5.21
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Device Category: F2S240V30AC200 Model Number: I-60S Division: 01 Sample Lot: 357 Lot Descr: LGE I60 - 1  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Run Date: 12/31/2010  
 Page 10  
 Run Time: 06:28:11 AM

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "e" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
270773	99.80	270791	100.50	270808	100.00	271280	100.40
275432	100.30	276412	99.90	278641	99.90	280540	99.70
280860	100.00	280898	100.00	281186	100.10	281257	100.40
281973	99.90	284735	100.00	285334	100.30	285447	99.80
286167	100.10	291105	100.40	291160	100.10	291887	100.00
292451	100.10	294265	100.20	295082	100.00	295271	100.10
297837	99.90	297907	99.90	297918	99.60	298114	100.00
298560	99.70	298734	100.00	299716	100.20	300021	99.90
300161	99.20	303812	100.40	303854	99.90	304094	99.70
304613	99.20	307041	100.30	307084	100.20	307117	99.60
311708	99.69	311963	100.00	312079	99.90	312230	100.30
313368	99.60	313474	99.80	313687	100.20	313761	99.70
316713	100.10	316731	99.40	317551	100.20	317797	99.70
318180	99.90	318324	99.80	320041	99.50	320414	99.80
322041	99.70	322261	99.70	324168	99.80	324888	99.80

INFORMATION NEEDED

VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7494.89
- 3 Sum of Squared Measurements 748984.32
- 4 Correction Factor (CF): Sum of Measurements Squared / N 748978.35
- 5 Corrected Sum of Squares (SS) 5.97
- 6 Variance (V) : SS/(N-1) 0.0806
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.2840
- 8 Sample Mean(XBAR): Sum X/N 99.93
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 7.28
- 12 Quality Index Lower (QL): (XBAR-L) / S 6.80
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Falls the Acceptability Criterion if P > M

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: I-60S Division: 01 Sample Lot: 358  
 In Service Population: 3,872 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE I60 - 2

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 11  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
327224	100.00	329176	100.00	329228	100.40	329304	100.30	329326	100.00
329501	100.50	329631	99.90	331194	100.20	331288	99.70	331570	100.00
331584	99.40	331865	99.80	333773	99.70	333834	100.20	333855	99.90
333865	100.00	333958	100.00	335634	99.90	335672	99.60	335725	99.90
335740	100.40	335909	99.50	335970	100.20	336083	100.50	336357	100.30
336375	100.00	336381	99.90	336457	100.10	336089	99.90	338131	100.00
338174	99.90	338412	100.10	338529	100.80	338632	99.80	338671	100.00
338846	100.00	340142	100.10	340263	100.00	340990	100.10	342912	100.50
343279	100.00	343499	100.10	343544	99.80	343621	100.20	344927	100.10
344961	100.30	345160	99.90	345165	99.90	345355	100.20	347401	100.10
347639	100.00	347777	100.00	347810	100.00	348162	100.00	348215	100.30
349539	100.20	349662	99.90	349828	100.00	349853	100.10	349874	99.80
350055	100.20	352591	100.10	352762	99.80	352936	99.70	355165	100.30
355232	100.20	357192	100.20	357213	100.30	357427	100.60	357469	99.90
357804	100.20	357849	99.80	359183	100.10	359570	100.30	359595	99.90

VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7504.00
- 3 Sum of Squared Measurements 750804.60
- 4 Correction Factor (CF): Sum of Measurements Squared / N 750800.21
- 5 Corrected Sum of Squares (SS) 4.39
- 6 Variance (V) : SS/(N-1) 0.0593
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.2435
- 8 Sample Mean(XBAR): Sum X/N 102.05
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 8.00
- 12 Quality Index Lower (QL) : (XBAR-L) / S 8.43
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Device Category: R2S240V30K2C00 Model Number: I-70S Division: 01 Sample Lot: 359 Lot Descr: IGE I70 - 1  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method Page 12  
 One AQL Value for Both Upper and Lower Specification Limit Combined Run Date: 12/31/2010  
 AQL = 2.5% - Inspection Level II "G" # Normal Inspection Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
361273	100.40	361304	100.30	361578	100.00	361679	99.90
363774	100.20	363883	100.00	363994	99.90	365857	100.00
365979	100.10	366032	100.10	366280	100.20	366375	100.20
366663	100.20	368123	99.50	368279	99.80	368428	100.00
368710	99.90	368771	100.00	368795	99.70	370756	100.30
371071	100.00	371241	100.40	371327	99.60	371342	99.70
373005	100.20	373064	100.40	373094	100.50	373168	100.30
373431	100.30	373487	100.40	373648	100.50	375435	100.30
375850	100.10	376047	100.10	377179	100.40	377234	100.40
377584	100.00	377613	100.20	380453	100.20	380555	100.40
380816	100.60	380847	100.20	380968	100.20	381247	100.10
382603	100.50	382683	100.10	382941	100.10	382544	100.30
385074	100.60	385150	100.20	385215	100.30	383123	100.30
387191	100.50	387440	100.40	387545	100.20	387188	100.50
387729	100.10	390409	100.10	390475	100.40	387574	100.30
				390797	100.10	392075	100.00

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7512.35
- 3 Sum of Squared Measurements 752476.68
- 4 Correction Factor (CF): Sum of Measurements Squared / N 752472.03
- 5 Corrected Sum of Squares (SS) 4.65
- 6 Variance (V) : SS/(N-1) 0.0628
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.2506
- 8 Sample Mean (XBAR) : Sum X/N 102.16
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 7.32
- 12 Quality Index Lower (QL) : (XBAR-L) / S 8.64
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF in Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

VALUE OBTAINED



Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 360 Lot Descr: IGE I70 - 2  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 13  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
392144	100.10	392177	100.20	392231	100.20	392256	100.00	392370	100.20
392388	99.70	392828	100.40	392877	100.20	394673	100.30	395103	100.30
395120	100.10	395226	100.10	395386	100.10	395506	100.70	395526	100.00
395583	100.00	396786	100.20	396959	99.80	397344	99.70	399016	100.30
399231	100.40	399398	99.90	399401	99.90	399438	99.90	399526	99.50
399943	100.20	401482	99.90	401602	100.60	401798	100.20	401991	100.10
402021	100.10	404413	100.20	404536	100.30	404595	100.20	404647	100.30
404660	100.20	404702	99.90	404760	99.90	404860	100.30	405080	100.70
405128	100.40	406400	100.10	406673	99.90	406895	100.30	407104	99.70
409263	100.60	409371	100.00	409942	100.10	411231	99.90	411428	99.90
411583	99.60	411861	100.30	411882	100.10	411909	99.90	414086	99.80
414232	99.80	416479	100.20	416502	100.10	416545	99.80	416892	100.30
417133	100.30	418825	100.10	418999	99.90	419172	100.00	419190	99.80
419246	99.80	419328	100.00	419356	100.00	419373	100.00	419414	99.80
420952	99.70	421018	99.90	421225	100.40	421324	100.20	421389	100.00

VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7505.90
- 3 Sum of Squared Measurements 751184.99
- 4 Correction Factor (CF): Sum of Measurements Squared / N 751180.46
- 5 Corrected Sum of Squares (SS) 4.53
- 6 Variance (V) : SS / (N-1) 0.0612
- 7 Estimate of Lot Standard Deviation (S) : SQRT of V 0.2473
- 8 Sample Mean (XBAR) : Sum X / N 102.00
- 9 Upper Specification Limit (U) 98.00
- 10 Lower Specification Limit (L) 7.77
- 11 Quality Index Upper (QU) : (U-XBAR) / S 8.41
- 12 Quality Index Lower (QL) : (XBAR-L) / S 0.00
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 361 Lot Descr: IGE I70 - 3  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Run Date: 12/31/2010  
 Page 14  
 Run Time: 06:28:11 AM

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "e" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
421431	100.10	421614	99.90	421785	100.10	423824	100.10
424207	99.90	424295	100.10	424499	100.20	424708	100.10
426918	100.10	429046	100.00	429099	100.40	429357	100.20
429758	100.00	429857	100.30	429916	100.10	431972	99.90
432155	100.10	432191	100.00	432453	100.10	432458	100.10
432551	100.10	432631	100.00	435610	100.00	435623	100.20
435819	100.50	435864	100.30	436010	100.10	436082	99.90
437540	99.70	437621	100.30	437622	100.00	437689	100.00
437923	99.80	438264	99.90	438427	99.80	438467	99.80
442519	99.90	442820	100.00	442890	100.20	442961	100.10
445206	99.80	445268	100.10	445355	100.10	445581	99.80
445999	100.10	445719	99.90	448504	100.00	449258	99.90
449469	100.00	450828	100.10	450884	100.00	450964	99.90
451245	100.10	455337	100.20	455347	100.20	455432	100.40
455634	100.20	455719	100.30	455796	99.90	459046	99.90

INFORMATION NEEDED VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7502.90
- 3 Sum of Squared Measurements 750582.23
- 4 Correction Factor (CF): Sum of Measurements Squared / N 750580.11
- 5 Corrected Sum of Squares (SS) 2.12
- 6 Variance (V) : SS/(N-1) 0.0286
- 7 Estimate of Lot Standard Deviation (S) : SQRT of V 0.1692
- 8 Sample Mean(XBAR): Sum X/N 100.04
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 11.59
- 12 Quality Index Lower (QL) : (XBAR-L) / S 12.05
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 362 Lot Descr: IGE I70 - 4  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 15  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
459706	100.10	459712	100.00	459815	100.20	461498	99.90
461539	100.10	461747	99.90	461899	100.20	462089	100.20
465689	100.50	465896	100.10	466165	99.90	466169	100.40
466424	100.20	466454	100.10	467119	100.10	467152	100.20
467823	100.00	467842	100.20	467864	100.20	471720	100.20
471874	99.70	472085	100.10	472108	100.10	472325	100.00
474198	100.10	474318	99.60	474585	99.90	474622	99.60
474646	100.00	476175	100.10	476362	100.00	476410	99.40
476721	99.90	479063	100.00	479208	100.00	479564	99.90
479729	100.20	479760	100.30	480153	99.90	481022	100.30
481202	100.10	481268	100.30	482498	100.10	482723	100.20
483202	100.60	484051	100.00	484101	100.00	484244	99.90
484431	99.90	484438	99.80	484557	99.90	484673	100.00
487434	99.90	487728	100.40	487876	99.50	487950	100.20
489262	99.40	489265	99.10	489455	100.30	489749	99.80

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7501.80
- 3 Sum of Squared Measurements 750364.58
- 4 Correction Factor (CF): Sum of Measurements Squared / N 750360.04
- 5 Corrected Sum of Squares (SS) 4.54
- 6 Variance (V) : SS/(N-1) 0.0613
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.2476
- 8 Sample Mean (XBAR): Sum X/N 100.02
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 7.98
- 12 Quality Index Lower (QL): (XBAR-L) / S 8.17
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Device Category: F28240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 363 Lot Descr: LGE I70 - 5  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Run Date: 12/31/2010  
 Page 16  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "e" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
490874	100.40	492343	100.30	493120	99.80	493529	99.80
493716	99.90	493736	99.90	495499	100.50	495704	100.00
495825	99.60	498348	99.70	498374	100.00	498666	100.20
499126	99.40	499163	100.00	499429	99.70	499447	100.10
500150	100.20	500379	99.70	500916	99.90	500989	99.90
501415	100.20	501453	100.20	501557	100.00	501716	100.10
506288	100.00	506357	99.60	506383	99.40	506522	100.10
506696	99.80	506758	99.90	506839	100.10	506979	100.30
507079	100.10	510074	100.20	510085	99.90	510143	99.90
510495	100.10	510694	100.10	511221	99.80	511274	99.90
511651	100.00	511717	100.20	511779	99.90	511803	100.20
515794	100.00	515852	99.90	516088	99.90	516473	99.70
516651	99.90	516653	100.00	522109	100.10	522149	100.10
522334	99.70	522402	100.00	522438	99.90	522482	99.90
522839	99.80	524317	100.10	524326	99.80	524877	100.30

INFORMATION NEEDED

VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7497.30
- 3 Sum of Squared Measurements 749463.25
- 4 Correction Factor (CF): Sum of Measurements Squared / N 749460.10
- 5 Corrected Sum of Squares (SS) 3.15
- 6 Variance (V) : SS/(N-1) 0.0426
- 7 Estimate of Lot Standard Deviation(s): SQRT of V 0.2064
- 8 Sample Mean(XBAR): Sum X/N 99.96
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 9.86
- 12 Quality Index Lower (QL): (XBAR-L) / S 9.52
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Falls the Acceptability Criterion if P > M

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 364  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS  
 Lot Descr: IGE I70 - 6

Page 17  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
526829	100.00	526846	100.20	529248	100.00	529440	100.10	529735	99.90
529783	99.80	532812	99.70	533015	99.70	533022	99.80	533072	100.10
533150	100.00	533279	99.80	533286	100.10	533435	100.00	533535	100.10
533674	99.80	533694	99.80	540588	100.00	540601	99.20	541096	100.10
541104	100.10	541190	100.20	541256	100.20	541357	100.10	541460	100.00
541651	100.00	541708	100.20	541730	100.00	541775	100.00	542059	100.10
542103	100.20	542114	100.00	542522	99.80	551496	100.20	551577	100.20
551737	100.00	551748	100.20	551861	100.00	551940	100.10	552331	100.10
552336	100.20	552607	100.00	552821	100.00	553053	99.90	553287	100.00
553317	100.10	553781	100.20	553793	100.10	554014	99.90	554045	100.50
554276	99.90	555397	100.30	555541	100.00	561743	100.10	561889	99.90
561936	100.10	562175	100.20	562251	100.10	562258	100.30	562303	100.00
562373	100.10	562493	100.10	562516	99.90	562544	100.00	562551	100.40
562690	100.20	563087	99.80	563671	100.00	564225	100.00	564623	100.10
564710	100.40	564726	100.00	564770	99.90	564874	99.90	564902	99.80

VALUE OBTAINED

- 1 Sample size (N) 75
- 2 Sum of Measurements: (Sum X) 7502.30
- 3 Sum of Squared Measurements 750462.63
- 4 Correction Factor (CF): Sum of Measurements Squared / N 750460.07
- 5 Corrected Sum of Squares (SS) 2.56
- 6 Variance (V) : SS/(N-1) 0.0346
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.1860
- 8 Sample Mean(XBAR): Sum X/N 100.03
- 9 Upper Specification Limit 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 10.59
- 12 Quality Index Lower (QL): (XBAR-L) / S 10.92
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: E28240V30AC200 Model Number: I-70S Division: 01  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Sample Lot: 365 Lot Descr: IGE I70 - 7  
 Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "e" # Normal Inspection  
 Page 18  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
565219	99.60	565232	100.20	565283	100.00	565341	100.00
568413	100.10	568451	99.80	568560	99.90	569183	100.30
570041	100.10	570064	99.90	570067	99.90	570352	100.10
570636	99.90	570826	100.20	570943	99.80	571167	99.70
571880	99.90	572081	100.30	572139	99.90	572154	100.30
572273	100.30	572427	100.00	572448	100.20	572831	100.80
573255	100.00	573281	100.10	573569	100.00	573575	100.30
582130	100.00	582370	100.00	582465	100.10	582583	100.00
582748	100.10	583121	100.00	583411	100.10	583499	100.10
583655	99.80	583715	99.90	583774	101.00	591622	100.00
591882	100.10	591894	99.90	591919	100.10	591923	99.90
592402	100.10	592522	99.90	592611	100.20	592683	100.00
592821	100.00	593200	100.00	593347	100.30	593454	100.00
593597	100.00	593621	99.90	593680	100.10	594223	100.00
594413	100.40	594431	100.20	594470	100.40	594473	100.10

INFORMATION NEEDED

VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7503.60
- 3 Sum of Squared Measurements 750723.60
- 4 Correction Factor (CF): Sum of Measurements Squared / N 750720.17
- 5 Corrected Sum of Squares (SS) 3.43
- 6 Variance (V) : SS/(N-1) 0.0463
- 7 Estimate of Lot Standard Deviation (S): SQRT of V 0.2152
- 8 Sample Mean(XBAR): Sum X/N 100.05
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 9.07
- 12 Quality Index Lower (QL): (XBAR-L) / S 9.52
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 366  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS  
 Lot Descr: IGE I70 - 8

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 19  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
594695	99.80	594780	100.30	594848	100.00	594851	100.00	594887	100.00
595012	100.30	599169	99.90	599421	100.10	602781	99.80	602802	99.90
602851	100.10	603159	100.00	603359	100.00	603474	100.10	603614	100.00
603640	100.10	603815	100.20	604057	100.00	604081	100.00	604106	99.90
604212	99.70	604323	100.00	604337	100.00	604445	99.70	604458	99.90
604811	99.80	604989	99.80	605033	100.20	605311	100.00	605673	100.20
605846	100.10	605869	100.10	606102	99.90	606368	99.90	606371	99.70
606454	100.10	610693	99.50	623551	100.30	623702	100.30	623774	100.20
623908	100.20	623949	100.00	624010	100.00	624016	100.00	624192	100.00
624205	100.30	624332	100.30	624805	100.10	625051	100.10	625540	100.00
625643	100.20	625704	99.94	625850	100.00	625912	100.20	626051	100.00
626092	100.00	626139	100.10	626351	99.80	626724	100.30	626782	100.10
626887	100.20	627084	100.00	627143	100.20	627288	99.70	627681	100.10
627837	99.70	627967	99.90	628070	99.70	628106	100.00	628350	99.60
628780	100.00	629139	99.80	629278	100.20	629317	100.20	629474	100.20

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7501.04
- 3 Sum of Squared Measurements 750210.49
- 4 Correction Factor (CF): Sum of Measurements Squared / N 750208.01
- 5 Corrected Sum of Squares (SS) 2.48
- 6 Variance (V) : SS/(N-1) 0.0335
- 7 Estimate of Lot Standard Deviation (S) : SQRT of V 0.1830
- 8 Sample Mean (XBAR) : Sum X/N 100.01
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 10.85
- 12 Quality Index Lower (QL) : (XBAR-L) / S 11.00
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program (01/01/2010) to (12/31/2010)  
 Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 367 Lot Descr: IGE I70 - 9  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection  
 Page 20  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
629591	100.30	629682	100.10	629993	100.30	630084	100.20
630512	100.10	630519	100.10	630541	100.10	630592	100.30
630622	100.50	631000	100.20	631011	100.20	631136	100.40
631312	100.00	631430	100.10	631662	100.10	631714	100.10
631917	100.10	631928	100.10	639697	100.20	639784	99.90
639890	99.70	640159	100.10	640315	100.20	640372	100.00
640806	100.20	640896	100.10	641061	100.00	641209	100.20
641790	100.20	641981	100.00	642104	100.20	642138	100.00
642709	100.10	643049	100.00	643187	100.10	643258	100.20
643624	99.90	643660	100.10	643779	100.10	644085	100.20
644273	100.00	644382	99.80	644621	99.70	644882	100.00
645054	99.80	654171	100.10	654203	99.70	654364	100.00
655249	100.00	655313	100.20	655511	99.90	655529	100.10
655659	99.90	655689	100.00	655829	100.00	655850	100.00
655957	99.80	656096	100.00	656265	99.90	656630	100.30

INFORMATION NEEDED  
 VALUE OBTAINED  
 75

- 1 Sample Size (N) 7505.80
- 2 Sum of Measurements: (Sum X) 751162.32
- 3 Sum of Squared Measurements 751160.45
- 4 Correction Factor (CF): Sum of Measurements Squared / N 1.87
- 5 Corrected Sum of Squares (SS) 0.0253
- 6 Variance (V) : SS/(N-1) 0.1590
- 7 Estimate of Lot Standard Deviation (S) : SQRT of V 100.08
- 8 Sample Mean (XBAR) : Sum X/N 102.00
- 9 Upper Specification Limit (U) 98.00
- 10 Lower Specification Limit (L) 12.09
- 11 Quality Index Upper (QU) : (U-XBAR) / S 13.06
- 12 Quality Index Lower (QL) : (XBAR-L) / S 0.00
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 4.83
- 16 Maximum Allowable Percent NCF (M)
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M



Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 368  
 In Service Population: 9,472 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS  
 Lot Descr: LGE I70 - 10

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 21  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
645373	100.30	645394	99.90	645443	99.90	656856	100.10	656964	100.00
657746	100.10	657813	99.90	661069	100.00	676975	99.40	676980	99.70
677320	99.80	677335	100.10	677350	100.30	677556	100.00	677642	99.80
677765	100.20	678207	100.10	678218	100.10	678372	99.90	678463	99.80
678468	100.00	678514	100.30	678560	99.70	678611	99.90	678724	100.00
678963	100.10	679457	99.90	679679	100.10	679775	100.00	679813	100.10
679864	100.00	680051	100.20	680076	99.60	680078	100.00	680097	99.90
680224	100.00	680232	99.90	680253	99.60	680348	100.10	680479	100.10
680538	100.00	680673	100.20	680718	99.90	681249	99.90	681427	99.90
681499	100.10	681716	100.00	681796	99.60	681883	99.70	682442	100.00
682475	100.00	682490	100.00	683161	99.90	689507	100.20	689790	100.40
689846	100.10	689952	99.70	690001	100.10	690108	99.90	690130	100.00
690138	100.10	690231	100.20	690614	99.90	690752	100.10	690947	100.10
691175	100.20	691246	99.94	691302	99.90	691323	100.00	691350	99.90
691404	99.90	691714	100.50	691749	100.20	698654	99.20	702163	100.00

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7498.64
- 3 Sum of Squared Measurements 749731.25
- 4 Correction Factor (CF): Sum of Measurements Squared / N 749728.02
- 5 Corrected Sum of Squares (SS) 3.23
- 6 Variance (V) : SS/(N-1) 0.0436
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.2089
- 8 Sample Mean(XBAR): Sum X/N 99.98
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 9.66
- 12 Quality Index Lower (QL) : (XBAR-L) / S 9.49
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 4.83
- 16 Maximum Allowable Percent NCF(M)
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Model Number: J4S  
 Division: 01  
 Sample Lot: 369  
 Lot Descr: LGE J4 - 1  
 In Service Population: 10,000  
 Sample Quantity: 75  
 Meters Tested: 75  
 Pass/Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "G" # Normal Inspection  
 Page 22  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
388343	100.20	388609	100.90	388661	100.40	388923	100.40
393394	100.60	393430	100.00	393910	100.60	397839	99.60
398213	100.10	402473	100.40	402496	99.60	402528	100.30
402820	100.30	402876	99.80	402925	99.80	402996	100.20
403350	100.30	403380	100.30	408440	100.40	412009	100.30
412424	100.20	412481	100.30	412708	99.90	417172	100.20
417340	100.00	417376	100.00	417498	99.80	417692	100.20
421879	100.40	422014	100.00	422638	100.50	422826	100.80
427920	100.20	433116	100.20	433232	100.40	433280	100.20
433611	100.00	433623	100.00	439136	99.80	439189	100.00
443372	100.50	447203	99.40	449688	100.30	449815	101.00
450070	99.80	453434	100.60	453561	100.00	453674	99.90
456721	99.60	456929	100.10	456931	99.80	457015	101.40
468408	100.40	470100	99.80	470204	99.20	470279	100.10
473515	99.80	473643	100.00	473830	99.80	477823	99.90

INFORMATION NEEDED VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7509.00
- 3 Sum of Squared Measurements 751812.60
- 4 Correction Factor (CF): Sum of Measurements Squared / N 751801.08
- 5 Corrected Sum of Squares (SS) 11.52
- 6 Variance (V) : SS/(N-1) 0.1557
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.3946
- 8 Sample Mean(XBAR) : Sum X/N 100.12
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 4.76
- 12 Quality Index Lower (QL) : (XBAR-L) / S 5.37
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: J4S Division: 01 Sample Lot: 370  
 In Service Population: 2,259 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS Lot Descr: IGE J4 - 2

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 23  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
485978	100.20	486196	99.70	486251	100.60	486265	99.70	486352	100.00
492672	99.50	492748	99.10	492804	99.70	492854	99.10	492989	100.10
493003	99.40	493070	100.20	495936	99.90	495962	100.00	496011	99.80
496039	99.90	496106	99.80	496301	100.30	496353	99.90	496356	99.80
499591	100.00	499704	99.80	499719	100.10	499723	99.70	499804	100.00
499850	99.90	499879	100.20	499910	100.10	499948	99.80	734151	100.00
734156	100.30	734180	100.10	734193	100.60	734207	99.90	734240	100.00
734293	99.32	739996	100.30	740068	100.90	740080	100.00	740098	100.00
740099	99.20	740111	100.60	740266	100.10	740287	100.20	740360	100.80
740368	100.10	740381	100.50	740390	99.90	756242	99.90	756271	100.20

INFORMATION NEEDED

VALUE OBTAINED

- 1 Sample Size (N) 50
- 2 Sum of Measurements: (Sum X) 4999.22
- 3 Sum of Squared Measurements 499851.27
- 4 Correction Factor (CF): Sum of Measurements Squared / N 499844.01
- 5 Corrected Sum of Squares (SS) 7.26
- 6 Variance (V) : SS/(N-1) 0.1482
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.3849
- 8 Sample Mean(XBAR): Sum X/N 99.98
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 5.24
- 12 Quality Index Lower (QL) : (XBAR-L) / S 5.16
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 5.21
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program (01/01/2010) to (12/31/2010)  
 Device Category: F2S240V30AC200 Model Number: JSS Division: 01 Sample Lot: 371 Lot Descr: IGE J5 - 1  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/Fail: PASS Run Date: 12/31/2010  
 Page 24  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "e" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
512596	100.00	512892	100.00	512989	99.60	513808	99.60
514065	99.70	514126	99.60	514168	100.30	514421	100.20
514648	99.81	514753	99.80	516910	100.30	516914	99.90
516970	100.60	516974	99.90	517426	99.80	517510	99.90
517807	100.00	517959	100.00	518115	99.90	518322	99.90
521234	100.00	521399	99.40	521480	100.20	521509	100.00
521827	99.70	521895	99.50	525601	100.40	525788	99.70
525875	100.40	525955	99.60	525962	100.00	526189	100.10
526306	100.20	526342	100.10	527193	99.90	527195	100.30
527637	100.10	528212	99.90	528300	100.20	528725	99.70
530367	99.40	530655	100.20	530670	99.90	531106	99.60
531227	99.40	531373	99.40	533909	99.80	534311	100.10
534357	99.60	534422	100.10	534453	99.70	534556	100.10
534837	100.40	534878	99.60	534980	99.70	535094	99.80
535522	100.10	539580	99.80	539662	99.80	539680	100.30

INFORMATION NEEDED

VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7494.71
- 3 Sum of Squared Measurements 748948.47
- 4 Correction Factor (CF): Sum of Measurements Squared / N 748942.37
- 5 Corrected Sum of Squares (SS) 6.09
- 6 Variance (V) : SS/(N-1) 0.0823
- 7 Estimate of Lot Standard Deviation(s): SQRT of V 0.2869
- 8 Sample Mean(XBAR): Sum X/N 99.93
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 7.22
- 12 Quality Index Lower (QL): (XBAR-L) / S 6.72
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Division: 01  
 Meters Tested: 75  
 Sample Lot: 372  
 Pass/ Fail: PASS  
 Device Category: F28240V30AC200 Model Number: JFS  
 Sample Quantity: 75

Lot Descr: IGE J5 - 2

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 25  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
540294	100.00	540314	100.10	543312	100.30	543399	99.80	543599	99.70
543839	100.10	543862	100.00	544245	100.40	544556	100.60	544769	100.40
544793	99.80	544866	100.30	548773	100.10	548876	99.50	548915	100.30
548950	100.10	549191	99.80	549205	100.30	549275	99.90	549484	99.50
549637	100.10	549690	100.40	549795	100.30	549830	99.80	550372	100.20
550498	99.60	550530	99.90	550729	100.20	550757	99.80	550844	99.90
551225	100.00	555810	100.10	555882	100.20	556363	100.00	556466	100.10
556642	99.90	556800	99.80	556926	99.60	557062	99.90	557593	99.80
557624	100.10	557631	99.70	557757	100.00	557870	100.00	558148	99.51
558242	99.50	558484	99.80	558549	99.90	558895	100.30	559549	99.80
565982	100.40	566145	99.90	566327	99.60	566377	100.30	566456	100.70
566831	99.70	567008	99.70	567216	99.60	567300	99.90	567312	100.10
567588	99.90	567649	99.90	567672	99.30	568117	100.40	574110	100.60
574307	100.00	579457	99.80	579536	100.10	579616	99.70	579759	100.20
579771	99.80	579861	100.10	580094	100.20	580173	100.30	580234	100.10

VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7499.51
- 3 Sum of Squared Measurements 749908.16
- 4 Correction Factor (CF): Sum of Measurements Squared / N 749902.00
- 5 Corrected Sum of Squares (SS) 6.16
- 6 Variance (V) : SS/(N-1) 0.0832
- 7 Estimate of Lot Standard Deviation (S) : SQRT of V 0.2884
- 8 Sample Mean (XBAR) : Sum X/N 99.99
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 6.96
- 12 Quality Index Lower (QL) : (XBAR-L) / S 6.91
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

PASS

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Device Category: F2S240V30AC200 Model Number: JSS Division: 01  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Sample Lot: 373

Lot Descr: IGE JS - 3

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "e" # Normal Inspection

Page 26  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
580268	99.60	580508	99.70	580539	99.60	580622	100.40
580767	100.80	581043	99.90	581205	100.10	581245	100.10
581330	100.20	581463	100.10	581490	99.60	581579	99.80
581643	99.80	583948	99.80	583962	100.40	584062	100.20
584380	99.80	584505	100.30	584676	99.70	584701	99.70
584825	100.00	585167	99.90	585175	100.40	585181	100.10
585352	99.90	585755	100.10	585801	100.10	585874	100.30
586485	100.10	586574	99.80	586748	100.20	588885	100.10
589003	100.20	589190	100.10	589236	100.20	589347	100.00
589596	100.30	589703	100.40	589759	100.30	590174	99.90
590372	100.00	590540	99.90	590666	99.60	590865	100.10
591356	100.00	599708	100.40	600049	99.50	600363	100.50
601043	100.20	601107	100.20	601569	100.00	601650	100.20
601978	100.00	602054	100.10	602266	99.90	607680	99.80
608218	100.40	608263	100.10	608341	100.30	608350	100.30

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7504.70
- 3 Sum of Squared Measurements 750945.53
- 4 Correction Factor (CF) : Sum of Measurements Squared / N 750940.29
- 5 Corrected Sum of Squares (SS) 5.24
- 6 Variance (V) : SS/(N-1) 0.0707
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.2660
- 8 Sample Mean(XBAR) : Sum X/N 100.06
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 7.28
- 12 Quality Index Lower (QL) : (XBAR-L) / S 7.75
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

VALUE OBTAINED

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 374  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS  
 Lot Descr: IGE J5 - 4

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 27  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
608456	99.80	608558	100.20	608938	100.10	609229	100.00
609396	99.80	609553	99.80	609572	100.10	609709	99.80
610267	100.10	610348	99.80	633826	99.90	634383	99.90
634389	100.00	634401	100.20	634425	99.70	634496	100.20
634698	100.30	634949	99.80	634956	99.70	635091	100.20
635570	100.00	635612	100.50	635632	100.30	635765	99.90
636091	99.60	636255	100.00	636489	99.90	636535	100.10
636540	99.80	636554	100.00	636648	99.90	636662	100.00
657633	100.20	661935	99.40	662096	99.90	662198	99.70
662591	99.70	662932	99.50	663037	99.50	663059	100.00
663328	99.70	663462	99.80	663464	99.70	663703	99.40
663840	99.70	663912	99.60	664083	99.70	664228	98.80
664893	99.40	664931	99.70	665005	100.10	665191	100.10
665907	99.80	665923	99.70	666109	99.70	666222	99.60
666307	99.40	666355	99.80	666463	99.90	666565	100.20

INFORMATION NEEDED

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
1 Sample Size (N)							
2 Sum of Measurements: (Sum X)							
3 Sum of Squared Measurements							
4 Correction Factor (CF): Sum of Measurements Squared / N							
5 Corrected Sum of Squares (SS)							
6 Variance (V) : SS / (N-1)							
7 Estimate of Lot Standard Deviation(S) : SQRT of V							
8 Sample Mean(XBAR) : Sum X/N							
9 Upper Specification Limit (U)							
10 Lower Specification Limit (L)							
11 Quality Index Upper (QU) : (U-XBAR) / S							
12 Quality Index Lower (QL) : (XBAR-L) / S							
13 Estimate of Lot Percent NCF Above U (PU)							
14 Estimate of Lot Percent NCF Below L (PL)							
15 Total Estimate Percent NCF. In Lot (P) : PU+PL							
16 Maximum Allowable Percent NCF(M)							
17 Acceptability Criterion: Compare P with M							
18 The Lot Meets the Acceptability Criterion if P <= M							
19 The Lot Fails the Acceptability Criterion if P > M							

VALUE OBTAINED  
 75  
 7490.60  
 748126.82  
 748121.18  
 5.64  
 0.0762  
 0.2761  
 99.87  
 102.00  
 98.00  
 7.70  
 6.79  
 0.00  
 0.00  
 0.00  
 4.83  
 PASS

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Device Category: F2S240V30AKC200 Model Number: J5S (R200) Division: 01  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75

Sample Lot: 375  
 Pass/Fail: PASS

Lot Descr: LGE J5 - 5

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 28  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
667409	99.60	667575	99.80	667917	100.10	667980	99.40
668238	100.10	668447	99.70	668557	99.30	669155	99.80
669789	99.70	669805	99.10	669820	100.00	669984	99.80
670308	100.00	670343	99.50	670388	100.00	670476	99.50
670535	99.60	683816	100.00	684017	100.30	684046	100.10
684378	100.10	684471	100.00	684519	99.90	684562	99.50
684738	100.00	685112	100.30	685370	99.00	685497	100.10
685891	100.00	686395	99.80	686453	99.90	686881	100.60
686998	100.00	687057	100.20	687059	100.10	687077	100.20
687220	99.80	687244	100.00	687292	99.90	687500	99.90
687603	99.40	687839	100.30	688160	99.90	688176	100.10
688450	100.00	688840	100.10	688603	100.00	688716	100.70
688984	100.40	688986	100.30	689046	99.80	692298	100.60
692544	100.10	692587	100.00	692774	100.30	692844	99.60
693057	99.90	693516	100.10	693536	100.40	693611	99.80

INFORMATION NEEDED

VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7496.49
- 3 Sum of Squared Measurements 749306.04
- 4 Correction Factor (CF): Sum of Measurements Squared / N 749298.16
- 5 Corrected Sum of Squares (SS) 7.88
- 6 Variance (V) : SS/(N-1) 0.1065
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.3263
- 8 Sample Mean (XBAR): Sum X/N 99.95
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 6.27
- 12 Quality Index Lower (QL) : (XBAR-L) / S 5.99
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M



2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Division: 01  
 Sample Lot: 376  
 Lot Descr: IGE J5 - 6  
 Model Number: J5S (R200)  
 Meters Tested: 75  
 Pass/ Fail: PASS  
 In Service Population: 10,000  
 Sample Quantity: 75

Page 29  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
694080	100.00	694091	99.70	694243	100.40	694343	100.40	694382	100.00	694382	100.00
694640	100.30	694759	100.10	694922	99.60	694996	99.60	695058	99.60	695058	100.00
695282	100.10	695569	100.00	695689	99.80	695825	99.80	695855	99.90	695855	100.10
696766	100.10	696871	99.90	697148	100.20	697331	100.20	697408	99.80	697408	100.10
697409	99.60	697444	100.30	697548	100.00	697722	100.00	697896	100.20	697896	99.70
698078	100.30	698328	100.30	698333	100.00	698360	100.10	699081	100.40	699081	99.80
699307	100.00	699540	100.20	699692	99.60	699753	99.60	700544	100.40	700544	100.40
700663	100.30	700663	99.50	705596	99.80	705655	99.90	705762	99.20	705762	99.70
705963	99.70	706137	99.90	706193	100.20	706261	100.20	706375	99.60	706375	99.70
706731	99.60	706420	99.80	706636	100.10	706643	100.10	706677	99.80	706677	99.70
707365	99.80	707375	99.90	706957	99.80	706972	99.80	707056	99.90	707056	99.90
707751	100.00	707892	99.90	707479	100.00	707602	100.00	707642	99.90	707642	99.70
708039	99.80	724281	100.00	707978	99.70	707995	100.00	724518	99.90	724518	100.20
724530	99.70	724693	100.20	724451	99.30	724470	99.30	726738	100.20	726738	100.20
				726233	99.90						

VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7496.90
- 3 Sum of Squared Measurements 749384.67
- 4 Correction Factor (CF): Sum of Measurements Squared / N 749380.13
- 5 Corrected Sum of Squares (SS) 4.54
- 6 Variance (V) : SS/(N-1) 0.0614
- 7 Estimate of Lot Standard Deviation (S): SQRT of V 0.2477
- 8 Sample Mean (XBAR) : Sum X/N 99.96
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 8.24
- 12 Quality Index Lower (QL) : (XBAR-L) / S 7.91
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

PASS

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Device Category: R2S240V30AC200 Model Number: J55 Division: 01 Sample Lot: 377 Lot Descr: IGE J5 - 7  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection  
 Page 30  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
727717	99.90	727730	100.37	727858	100.10	727918	99.90
728109	99.80	728194	100.40	728285	99.80	728598	99.80
729000	100.30	729118	100.30	729167	100.00	729210	100.30
729494	100.60	729508	100.00	729891	100.10	729958	100.10
730211	99.90	730368	100.40	730425	100.30	730875	100.00
730978	100.00	730989	100.40	730994	99.90	731576	100.30
731838	100.00	731919	100.20	731949	99.80	731958	99.70
732041	99.90	732105	99.50	732171	99.90	732979	100.30
733484	100.50	733500	100.20	733517	100.30	733568	99.80
733879	99.82	734007	99.80	734518	100.20	734821	100.00
734982	100.20	735111	99.90	735152	100.40	735466	99.70
735689	100.10	736000	100.00	736004	99.70	736078	99.40
736451	100.40	737626	99.80	737761	100.30	737812	100.10
737985	100.40	738054	100.30	738388	100.00	738392	99.70
739319	100.00	739355	99.90	739493	100.00	739547	99.40
				739560	100.30		

INFORMATION NEEDED VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7503.57
- 3 Sum of Squared Measurements 750720.28
- 4 Correction Factor (CF): Sum of Measurements Squared / N 750714.17
- 5 Corrected Sum of Squares (SS) 6.11
- 6 Variance (V) : SS/(N-1) 0.0825
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.2873
- 8 Sample Mean(XBAR): Sum X/N 100.05
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 6.80
- 12 Quality Index Lower (QL) : (XBAR-L) / S 7.13
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 378  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: IGE J5 - 8

Test Results Per ANSI/ASQC Z1.9-1993 Page 31  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined Run Date: 12/31/2010  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
736643	100.00	736788	99.80	739659	100.00	740592	99.80	740661	99.90
740851	99.80	741052	99.80	741165	99.40	741175	100.40	741200	100.10
741408	99.80	741472	99.70	741772	100.00	741875	100.30	741881	100.10
741989	100.30	742220	100.10	742449	98.40	743178	99.70	743324	100.20
743338	100.30	743563	99.90	743883	100.20	743985	99.70	744196	99.00
744222	99.50	744441	99.20	744446	100.00	744547	99.90	744579	99.20
744611	100.10	744782	99.40	745536	100.10	745648	99.80	745672	99.50
745832	100.00	745924	100.00	746040	99.90	746208	99.30	746329	99.60
746612	100.00	746761	99.60	746805	98.90	746829	100.00	746945	99.40
746956	99.20	747143	99.90	747148	99.60	747309	98.90	747680	99.40
747697	99.20	747731	99.50	747790	99.80	747802	99.90	747809	99.80
747837	99.60	748029	99.50	748068	99.30	748356	99.70	748495	99.40
748563	99.00	748756	99.10	749129	99.90	749239	99.10	749291	99.70
749561	99.80	749664	100.00	749924	99.50	750032	99.80	750049	99.90
750136	99.80	750264	99.50	750535	99.70	750717	100.20	750769	100.00

INFORMATION NEEDED VALUE OBTAINED

- Sample Size (N) 75
- Sum of Measurements: (Sum X) 7477.80
- Sum of Squared Measurements 745577.74
- Correction Factor (CF): Sum of Measurements Squared / N 745566.57
- Corrected Sum of Squares (SS) 11.17
- Variance (V) : SS/(N-1) 0.1509
- Estimate of Lot Standard Deviation(S) : SQRT of V 0.3885
- Sample Mean(XBAR) : Sum X/N 99.70
- Upper Specification Limit (U) 102.00
- Lower Specification Limit (L) 98.00
- Quality Index Upper (QU) : (U-XBAR) / S 5.91
- Quality Index Lower (QL) : (XBAR-L) / S 4.39
- Estimate of Lot Percent NCF Above U (PU) 0.00
- Estimate of Lot Percent NCF Below L (PL) 0.00
- Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- Maximum Allowable Percent NCF(M) 4.83
- Acceptability Criterion: Compare P with M PASS
- The Lot Meets the Acceptability Criterion if P <= M
- The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Division: 01  
 Meters Tested: 75  
 Sample Lot: 379  
 Pass/Fail: PASS  
 Lot Descr: IGB J5 - 9

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection  
 Page 32  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
751311	99.10	751319	99.70	751641	99.50	751774	100.20
751927	99.50	751942	99.30	751955	99.50	752051	99.00
752192	99.50	752234	99.80	752253	99.00	752756	99.80
752810	99.70	753078	99.90	753086	100.20	753745	99.80
757542	100.00	757679	99.60	757687	99.70	757760	99.70
757852	100.00	757943	99.90	757983	99.20	758376	99.80
758565	99.80	758814	99.20	758990	99.80	758996	99.70
759299	100.20	759465	100.80	759520	99.80	759921	100.20
760113	100.30	760591	100.00	760629	99.60	760791	100.00
760919	99.80	761008	99.60	761120	99.90	761402	99.90
761499	99.70	761525	100.00	761844	99.60	762146	99.80
762154	99.20	762243	100.00	762425	99.90	762847	100.00
762867	99.70	763078	99.50	763129	100.10	763378	99.70
764069	99.70	764124	99.50	764416	99.70	764497	99.80
764852	99.60	767554	99.70	767626	99.80	764751	99.90
						768030	99.90

INFORMATION NEEDED VALUE OBTAINED  
 75

- 1 Sample Size (N) 7481.80
- 2 Sum of Measurements: (Sum X) 746373.16
- 3 Sum of Squared Measurements 746364.42
- 4 Correction Factor (CF): Sum of Measurements Squared / N 8.74
- 5 Corrected Sum of Squares (SS) 0.1182
- 6 Variance (V) : SS/(N-1) 0.3437
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 99.76
- 8 Sample Mean(XBAR): Sum X/N 102.00
- 9 Upper Specification Limit (U) 98.00
- 10 Lower Specification Limit (L) 6.52
- 11 Quality Index Upper (QU) : (U-XBAR) / S 5.11
- 12 Quality Index Lower (QL) : (XBAR-L) / S 0.00
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 380  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: IGE J5 - 10

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 33  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
768143	99.80	768339	99.90	768351	100.10	768466	100.10
768753	99.60	768786	99.90	769040	100.10	769154	100.00
769177	100.00	769230	99.80	769269	99.70	769336	99.90
769547	99.90	769570	99.50	769605	99.50	769617	99.70
769874	99.60	769995	100.20	770258	99.80	771309	100.40
771349	99.90	771373	100.00	771398	99.80	771493	99.70
771703	100.20	772121	100.10	772128	99.90	772175	100.20
772609	100.00	773149	100.20	773297	99.80	774317	100.30
774561	100.20	774599	100.10	774769	100.20	774825	99.60
774826	99.80	774864	99.80	775055	100.00	775360	100.10
775520	99.80	775587	100.20	779905	100.00	780156	100.00
780227	100.70	780346	100.60	780368	100.00	780944	99.80
781041	99.50	781143	99.60	781338	99.30	781538	100.60
781772	100.50	782062	100.00	782106	99.60	782231	99.60
792643	100.40	792671	100.20	792980	99.90	792996	100.10

INFORMATION NEEDED

1 Sample Size (N) 75

2 Sum of Measurements: (Sum X) 7495.85

3 Sum of Squared Measurements 749176.33

4 Correction Factor (CF): Sum of Measurements Squared / N 749170.23

5 Corrected Sum of Squares (SS) 6.10

6 Variance (V) : SS / (N-1) 0.0825

7 Estimate of Lot standard Deviation(S) : SQRT of V 0.2872

8 Sample Mean(XBAR) : Sum X/N 99.94

9 Upper Specification Limit (U) 102.00

10 Lower Specification Limit (L) 98.00

11 Quality Index Upper (QU) : (U-XBAR) / S 7.16

12 Quality Index Lower (QL) : (XBAR-L) / S 6.77

13 Estimate of Lot Percent NCF Above U (PU) 0.00

14 Estimate of Lot Percent NCF Below L (PL) 0.00

15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00

16 Maximum Allowable Percent NCF(M) 4.83

17 Acceptability Criterion: Compare P with M PASS

18 The Lot Meets the Acceptability Criterion if P <= M

19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Device Category: E2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 381 Lot Descr: IGE J5 - 11  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/Fail: PASS Run Date: 12/31/2010  
 Page 34  
 Run Date: 06:28:11 AM  
 Run Time: 06:28:11 AM

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "e" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
782508	99.50	782530	99.30	782644	99.70	782647	99.90
783179	99.20	783197	99.80	783330	99.90	783622	99.90
783658	100.00	783665	99.60	783749	99.90	783857	100.00
784512	99.10	784549	99.90	784552	100.20	784623	99.80
784836	99.90	784875	100.00	784896	100.40	784899	99.70
785119	100.00	785194	100.40	785288	100.20	785471	100.00
785871	99.80	785877	100.70	786123	99.80	786423	100.20
787071	100.70	787483	100.20	787496	99.90	787580	100.60
788217	99.90	788321	100.20	788335	100.00	788528	100.10
788810	99.70	788840	100.00	788845	99.70	788854	99.90
789072	99.90	789098	99.90	789200	100.00	789228	100.00
789623	99.80	789875	99.30	789972	99.70	790074	100.10
790107	100.10	790199	100.00	790350	99.80	790434	100.10
791111	99.60	791401	99.70	791453	99.90	793092	100.30
793376	100.20	793434	100.90	793493	100.50	801304	99.00

INFORMATION NEEDED VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7495.20
- 3 Sum of Squared Measurements 749049.90
- 4 Correction Factor (CF): Sum of Measurements Squared / N 749040.31
- 5 Corrected Sum of Squares (SS) 9.59
- 6 Variance (V) : SS/(N-1) 0.1296
- 7 Estimate of Lot Standard Deviation (S) : SQRT of V 0.3600
- 8 Sample Mean (XBAR) : Sum X/N 99.94
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 5.73
- 12 Quality Index Lower (QL) : (XBAR-L) / S 5.38
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 382  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: IGE J5 - 12

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 35  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
801854	99.00	802105	99.50	802117	99.40	802209	99.70	802295	99.00
802356	99.30	802530	99.00	802559	99.80	802670	100.10	802775	99.80
803299	99.80	803337	100.30	803866	99.70	804195	99.70	804227	99.50
804306	99.90	804389	99.70	804494	99.70	804655	99.00	804863	99.40
804872	99.40	804954	99.50	805024	99.60	805291	99.20	805400	99.40
805548	99.70	805568	99.30	805697	100.10	805788	99.90	805823	98.60
805953	99.70	806162	99.40	806201	99.50	806206	99.20	806463	99.50
806925	99.60	806975	100.20	807012	99.50	807256	98.90	807307	98.90
807332	100.20	807387	99.90	807516	99.90	807976	100.10	808013	99.00
809962	99.40	809966	99.90	809992	99.90	810276	100.20	810355	99.20
810369	99.40	810485	99.80	810537	99.90	810581	100.10	810638	100.10
810758	99.80	810759	99.80	811024	99.40	811182	100.10	811199	99.40
811592	99.70	811680	99.40	811775	99.70	811802	99.60	811818	99.20
811853	99.80	811942	99.80	812278	99.50	812321	99.40	812392	100.10
812491	100.40	812493	99.80	812577	99.40	813122	100.30	813270	99.20

INFORMATION NEEDED

1 Sample Size (N) 75

2 Sum of Measurements: (Sum X) 7470.20

3 Sum of Squared Measurements 744063.28

4 Correction Factor (CF): Sum of Measurements Squared / N 744051.84

5 Corrected Sum of Squares (SS) 11.44

6 Variance (V) : SS/(N-1) 0.1546

7 Estimate of Lot standard Deviation(S): SQRT of V 0.3932

8 Sample Mean(XBAR): Sum X/N 99.60

9 Upper Specification Limit (U) 102.00

10 Lower Specification Limit (L) 98.00

11 Quality Index Upper (QU) : (U-XBAR) / S 6.10

12 Quality Index Lower (QL) : (XBAR-L) / S 4.08

13 Estimate of Lot Percent NCF Above U (PU) 0.00

14 Estimate of Lot Percent NCF Below L (PL) 0.00

15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00

16 Maximum Allowable Percent NCF(M) 4.83

17 Acceptability Criterion: Compare P with M PASS

18 The Lot Meets the Acceptability Criterion if P <= M

19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 383 Lot Descr: LGE J5 - 13  
 In Service Population: 774 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS Run Date: 12/31/2010  
 Page 36  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
---------------	--------------------	---------------	--------------------	---------------	--------------------	---------------	--------------------

813438	100.10	813452	99.80	813459	99.80	813509	99.70	813528	99.50
813549	99.40	813564	99.90	813601	99.90	813654	99.60	813664	99.50
813700	98.70	813711	100.00	813730	99.30	813748	100.00	813754	100.10
814079	99.70	814086	99.80	814134	99.10	814135	100.00	814174	99.90
814202	99.70	814229	100.10	814231	99.70	814272	99.80	814296	99.70
814312	99.50	814341	99.40	814376	99.60	814409	99.70	814420	99.70
814442	100.00	814445	99.80	814466	99.70	814534	99.70	814536	99.10

INFORMATION NEEDED

- 1 Sample Size (N)
- 2 Sum of Measurements: (Sum X)
- 3 Sum of Squared Measurements
- 4 Correction Factor (CF): Sum of Measurements Squared / N
- 5 Corrected Sum of Squares (SS)
- 6 Variance (V) : SS/(N-1)
- 7 Estimate of Lot Standard Deviation (S) : SQRT of V
- 8 Sample Mean (XBAR) : Sum X/N
- 9 Upper Specification Limit (U)
- 10 Lower Specification Limit (L)
- 11 Quality Index Upper (QU) : (U-XBAR) / S
- 12 Quality Index Lower (QL) : (XBAR-L) / S
- 13 Estimate of Lot Percent NCF Above U (PU)
- 14 Estimate of Lot Percent NCF Below L (PL)
- 15 Total Estimate Percent NCF In Lot (P) : PU+PL
- 16 Maximum Allowable Percent NCF (M)
- 17 Acceptability Criterion: Compare P with M
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

VALUE OBTAINED

- 1 35
- 2 3489.00
- 3 347806.66
- 4 347803.46
- 5 3.20
- 6 0.0942
- 7 0.3069
- 8 99.69
- 9 102.00
- 10 98.00
- 11 7.54
- 12 5.49
- 13 0.00
- 14 0.00
- 15 0.00
- 16 5.58
- 17 PASS



Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: MQS Division: 01  
 In Service Population: 242 Sample Quantity: 15 Meters Tested: 15 Pass/ Fail: PASS Lot Descr: IGE MQ - 1

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 37  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
328795	99.90	337780	100.00	337831	100.30	337917	99.80
347131	100.70	351636	100.00	351720	100.10	356710	99.70
361033	100.60	365358	99.70	365374	100.10	365659	100.10
						370401	100.20

INFORMATION NEEDED

- 1 Sample Size (N) 15
- 2 Sum of Measurements: (Sum X) 1501.30
- 3 Sum of Squared Measurements 150261.37
- 4 Correction Factor (CF): Sum of Measurements Squared / N 150260.11
- 5 Corrected Sum of Squares (SS) 1.26
- 6 Variance (V) : SS/(N-1) 0.0898
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.2997
- 8 Sample Mean(XBAR) : Sum X/N 100.09
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 6.38
- 12 Quality Index Lower (QL) : (XBAR-L) / S 6.96
- 13 Estimate of Lot Percent NCF Above U (FU) 0.00
- 14 Estimate of Lot Percent NCF Below L (FL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : FU+FL 0.00
- 16 Maximum Allowable Percent NCF(M) 6.55

PASS

- 17 The Lot Meets the Acceptability Criterion: Compare P with M
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method      Page 38  
 One AQL Value for Both Upper and Lower Specification Limit Combined      Run Date: 12/31/2010  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection      Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
378297	100.50	378605	100.50	378627	100.30	379964	100.40
384473	100.10	384540	100.30	384595	100.40	389540	101.10
394366	100.50	394386	100.40	398619	100.00	398693	100.80
403744	100.80	403749	100.30	403861	100.10	403999	100.50
404250	100.00	408788	99.90	408793	100.10	408922	100.40
409065	100.80	412958	100.50	413705	100.20	413861	100.00
418266	100.20	418351	100.10	418515	101.10	422894	100.80
423618	100.60	423767	100.10	428563	100.00	428725	99.90
428959	100.10	428967	100.40	434664	100.40	434842	99.80
435146	100.50	435175	99.80	435266	99.60	435380	100.20
439556	100.20	439950	99.90	439995	100.70	440262	100.30
444482	100.00	445939	99.90	446046	99.30	446183	99.20
446273	99.90	447377	99.80	447410	99.30	447485	99.90
447638	99.60	450275	100.00	450370	100.20	450555	100.00
452262	99.10	452353	99.60	452366	99.50	452151	99.40
						473298	100.10

INFORMATION NEEDED      VALUE OBTAINED  
 75

- 1 Sample Size (N)      7512.50
- 2 Sum of Measurements: (Sum X)      752516.65
- 3 Sum of Squared Measurements      752502.08
- 4 Correction Factor (CF): Sum of Measurements Squared / N      14.57
- 5 Corrected Sum of Squares (SS)      0.1968
- 6 Variance (V) : SS/(N-1)      0.4437
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V      100.17
- 8 Sample Mean (XBAR) : Sum X/N      102.00
- 9 Upper Specification Limit (U)      98.00
- 10 Lower Specification Limit (L)      4.13
- 11 Quality Index Upper (QU) : (U-XBAR) / S      4.88
- 12 Quality Index Lower (QL) : (XBAR-L) / S      0.00
- 13 Estimate of Lot Percent NCF Above U (PU)      0.00
- 14 Estimate of Lot Percent NCF Below L (PL)      0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL      0.00
- 16 Maximum Allowable Percent NCF(M)      4.83
- 17 Acceptability Criterion: Compare P with M      PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Falls the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Device Category: F2S240V30AC200 Model Number: MSII Division: 01  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Lot Descr: IGE MSII - 1

Page 39  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
454430	99.80	457721	100.20	460573	100.00	460581	100.70	460702	100.30	460710	99.90
462805	100.00	462867	100.38	462999	100.50	466672	100.30	469432	100.30	469440	99.90
473132	99.40	480457	99.80	480570	100.20	480773	99.60	480775	99.60	480783	99.30
480845	99.80	480880	100.30	481999	100.30	482111	99.90	482129	99.90	482137	100.50
482410	100.20	485116	99.90	485242	100.50	485341	99.90	485435	99.90	485443	99.90
485441	100.40	485453	100.20	488245	100.00	491130	100.40	491214	100.30	491222	100.30
491236	100.20	491293	99.80	491404	100.30	494737	100.10	494916	100.10	494924	100.10
494939	100.20	495178	100.10	497896	99.20	498216	100.30	502255	100.30	502263	99.60
502309	99.80	502717	99.90	502724	99.70	502988	99.80	503093	99.80	503101	100.50
503244	99.80	503374	100.10	503480	100.10	503518	99.90	503632	99.90	503640	100.00
503641	100.00	503684	100.20	503985	100.20	504043	100.00	507344	100.00	507352	99.90
507434	99.80	507435	100.20	507481	100.10	508116	100.40	508148	100.40	508156	100.10
508209	100.40	508364	100.00	508372	100.40	508434	100.30	508517	100.30	508525	99.90
519301	100.30	519581	100.30	519650	100.10	519677	100.20	519714	100.20	519722	100.20
519717	100.10	523257	100.00	523375	100.40	523417	100.20	523612	100.20	523620	100.30

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7505.98
- 3 Sum of Squared Measurements 751202.38
- 4 Correction Factor (CF): Sum of Measurements Squared / N 751196.48
- 5 Corrected Sum of Squares (SS) 5.91
- 6 Variance (V) : SS/(N-1) 0.0798
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.2825
- 8 Sample Mean(XBAR) : Sum X/N 100.08
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 6.80
- 12 Quality Index Lower (QL) : (XBAR-L) / S 7.36
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Device Category: F2S240V30AC200 Model Number: MSIT Division: 01 Sample Lot: 387  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/Fail: PASS Lot Descr: LGB MSIT - 2

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection  
 Page 40  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
523737	99.70	523801	100.80	523845	100.10	531854	99.80
532102	100.10	532306	100.30	532415	99.60	532514	99.80
535994	99.90	536031	99.90	536118	99.90	536314	99.90
536728	99.80	536775	99.90	536977	100.40	537159	100.00
537571	100.30	537688	99.70	542372	99.50	542431	100.20
542615	100.00	542631	100.10	542863	100.30	543176	100.20
545760	100.40	545831	100.20	545888	99.70	545993	100.20
546143	100.20	546200	100.30	546350	100.60	546834	100.10
547063	100.10	547312	100.10	547324	100.50	547351	100.40
548071	99.70	548151	99.80	548632	100.10	548934	99.80
559028	100.40	559081	100.10	559532	100.30	559543	100.10
560007	100.30	560066	99.80	560530	100.20	560552	100.20
561043	100.20	561057	100.10	561089	100.30	561347	100.30
575594	100.20	575887	100.10	575999	100.30	576005	100.20
576168	100.00	576307	99.90	576545	100.40	576575	99.30

INFORMATION NEEDED

VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7508.20
- 3 Sum of Squared Measurements 751646.32
- 4 Correction Factor (CF): Sum of Measurements Squared / N 751640.90
- 5 Corrected Sum of Squares (SS) 5.42
- 6 Variance (V) : SS / (N-1) 0.0733
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.2707
- 8 Sample Mean (XBAR) : Sum X/N 100.11
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 6.98
- 12 Quality Index Lower (QL) : (XBAR-L) / S 7.79
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF in Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Division: 01  
 Model Number: MSII  
 Sample Lot: 388  
 In Service Population: 10,000  
 Sample Quantity: 75  
 Meters Tested: 75  
 Pass/ Fail: PASS  
 Lot Descr: IGE MSII - 3

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 41  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
576999	100.50	577037	100.20	577074	100.20	577155	100.20
577203	100.50	577277	99.90	577917	100.20	577924	100.60
578146	100.30	578177	100.20	578291	99.70	578328	100.20
595993	100.00	596017	100.20	596226	100.00	596272	100.30
596655	100.90	596678	100.00	596954	99.90	597238	100.00
597527	100.50	597775	100.10	598079	100.50	598082	99.90
598266	100.20	598296	100.10	598320	99.80	598417	100.00
598563	99.60	598583	100.10	611528	100.20	611836	100.20
611904	100.50	612404	100.00	612517	100.20	612520	100.30
613259	100.20	613378	100.30	613584	100.00	613634	100.30
613915	100.10	614244	100.40	614362	100.20	614758	100.10
615139	99.50	615164	100.60	615470	100.20	615509	100.30
615772	99.90	615914	99.90	616242	99.70	616444	100.40
616965	99.90	617045	100.00	617057	100.20	617225	100.30
617865	99.60	618116	99.50	618136	99.30	618356	99.70

INFORMATION NEEDED  
 1 Sample Size (N) 75  
 2 Sum of Measurements: (Sum X) 7508.60  
 3 Sum of Squared Measurements 751727.36  
 4 Correction Factor (CF): Sum of Measurements Squared / N 751720.99  
 5 Corrected Sum of Squares (SS) 6.37  
 6 Variance (V) : SS/(N-1) 0.0861  
 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.2935  
 8 Sample Mean(XBAR) : Sum X/N 100.11  
 9 Upper Specification Limit (U) 102.00  
 10 Lower Specification Limit (L) 98.00  
 11 Quality Index Upper (QU) : (U-XBAR) / S 6.42  
 12 Quality Index Lower (QL) : (XBAR-L) / S 7.21  
 13 Estimate of Lot Percent NCF Above U (PU) 0.00  
 14 Estimate of Lot Percent NCF Below L (PL) 0.00  
 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00  
 16 Maximum Allowable Percent NCF (M) 4.83  
 17 Acceptability Criterion: Compare P with M PASS  
 18 The Lot Meets the Acceptability Criterion if P <= M  
 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Division: 01  
 Device Category: E2S240V30AC200 Model Number: MS11 Sample Lot: 389  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/Fail: PASS

Lot Descr: IGB MS11 - 4

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection  
 Page 42  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
618586	100.60	618839	99.30	618899	100.40	619265	100.00
619283	100.00	619379	99.40	619491	100.50	619805	99.90
619838	100.20	619949	99.80	620025	100.40	620395	99.70
621040	99.90	621494	100.20	621818	99.90	621921	99.60
622035	100.30	622109	100.20	622280	99.50	622742	99.80
622981	99.50	623042	100.20	623064	99.70	623079	100.00
636713	100.10	636884	100.10	636965	100.30	637003	100.10
637315	100.10	637510	100.10	637650	100.10	637902	100.10
638164	100.20	638445	99.90	638547	100.20	638577	100.30
639132	100.20	639134	100.00	639191	100.00	639194	100.40
639494	100.20	645747	100.00	645775	100.10	645824	100.10
645928	100.20	646281	99.80	646575	100.10	646597	100.30
646708	100.00	646745	100.30	646965	100.30	646976	100.00
647191	100.20	647372	100.00	647444	99.80	647744	100.20
647896	100.20	648309	99.80	648365	100.00	648522	100.10

INFORMATION NEEDED VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7505.30
- 3 Sum of Squared Measurements 751066.59
- 4 Correction Factor (CF) : Sum of Measurements Squared / N 751060.37
- 5 Corrected Sum of Squares (SS) 6.22
- 6 Variance (V) : SS / (N-1) 0.0840
- 7 Estimate of Lot Standard Deviation (S) : SQRT of V 0.2898
- 8 Sample Mean (XBAR) : Sum X/N 100.07
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 6.66
- 12 Quality Index Lower (QL) : (XBAR-L) / S 7.14
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 390  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/Fail: PASS Lot Descr: IGB MSII - 5

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
648618	100.10	648757	100.20	648811	100.20	648869	100.20
649163	100.00	649340	100.80	649556	100.00	649798	100.20
650174	100.10	650244	99.90	650646	100.10	651011	100.20
651283	100.20	651303	100.10	651516	100.20	651604	100.20
651894	100.30	651901	100.30	652032	99.90	652082	99.90
652495	100.10	652598	99.90	653202	100.00	653496	100.10
653805	100.10	653834	100.20	654139	100.20	658297	100.20
658363	100.00	658448	100.20	658600	100.40	658839	100.60
659117	100.70	659124	100.20	659263	100.50	659313	100.30
659469	99.70	659501	100.30	659566	100.30	659297	100.40
659819	100.40	659946	100.30	659986	100.20	659743	100.10
660427	100.20	660499	100.20	660581	100.40	660166	100.10
660641	100.30	670944	100.20	671194	100.20	660639	100.30
671495	100.00	671656	100.00	671827	100.20	671447	100.30
672197	100.30	672546	100.20	672689	100.20	671937	100.10
						672883	100.30

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7513.90
- 3 Sum of Squared Measurements 752784.87
- 4 Correction Factor (CF): Sum of Measurements Squared / N 752782.58
- 5 Corrected Sum of Squares (SS) 2.29
- 6 Variance (V) : SS/(N-1) 0.0310
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.1761
- 8 Sample Mean(XBAR): Sum X/N 100.19
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 10.31
- 12 Quality Index Lower (QL): (XBAR-L) / S 12.41
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 4.83
- 16 Maximum Allowable Percent NCF(M)
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Device Category: E2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 391 Lot Descr: LGE MSII - 6  
 In Service Population: 3,202 Model Number: MSII Meters Tested: 75 Pass/Fail: PASS Run Date: 12/31/2010  
 Test Results Per ANSI/ASQC Z1.9-1993 Page 44  
 Double Specification Limit - Variability Unknown - Standard Deviation Method Run Date: 12/31/2010  
 One AQL Value for Both Upper and Lower Specification Limit Combined Run Time: 06:28:11 AM  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
673188	100.20	673215	100.10	673274	100.20	673304	100.00
673350	100.00	673361	100.00	673385	100.20	673485	100.30
673646	100.30	673688	100.10	673905	100.00	673973	100.20
674005	100.10	674017	99.80	674045	100.10	674151	100.20
674244	100.30	674245	100.10	674343	100.20	674388	100.00
674524	100.30	674531	100.10	674544	100.00	674597	100.20
674663	99.90	674764	100.10	674816	100.00	674887	100.00
674981	100.10	675045	100.10	675083	100.20	675092	100.00
675142	100.30	675144	100.10	675159	100.00	675182	100.20
675220	100.20	675234	99.90	675290	100.10	675323	100.30
675473	100.10	675477	100.20	675496	100.30	675529	100.30
675566	100.30	675677	100.10	675720	99.90	675739	100.20
675834	100.40	675874	100.30	676019	100.10	676173	100.20
676314	99.90	676334	100.20	676425	100.20	676439	100.30
676503	100.20	676504	100.30	676546	100.10	676553	100.10

INFORMATION NEEDED

VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7510.69
- 3 Sum of Squared Measurements 752140.69
- 4 Correction Factor (CF): Sum of Measurements Squared / N 752139.52
- 5 Corrected Sum of Squares (SS) 1.16
- 6 Variance (V) : SS/(N-1) 0.0157
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.1253
- 8 Sample Mean (XBAR) : Sum X/N 100.14
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 14.82
- 12 Quality Index Lower (QL) : (XBAR-L) / S 17.09
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF in Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M



Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 392  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: IGE MX - 1

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 45  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
702532	100.10	702884	100.10	703172	99.90	703425	99.90	703544	99.90
703589	100.20	703597	99.90	703801	100.00	703927	99.90	704403	99.80
704542	99.90	705040	100.90	705300	100.00	708877	99.97	708885	99.80
709111	99.80	709127	99.70	709138	99.80	709146	100.00	709212	99.90
709294	99.80	709333	100.00	709345	99.90	709521	99.90	709565	99.90
709606	100.10	709632	100.00	710215	100.20	710487	100.20	710508	99.70
710531	100.10	710684	99.60	710710	99.80	710850	100.20	710961	100.00
711111	99.60	711125	99.40	711279	100.00	711393	100.10	711477	100.10
711740	99.70	711931	99.70	712941	99.60	713020	99.90	713041	99.80
713214	99.80	713315	100.00	713400	99.90	713416	100.00	713476	99.80
713610	99.40	713701	99.70	713901	99.00	713935	99.60	713966	99.60
713994	99.90	714298	99.50	714373	99.50	714530	100.20	714727	99.60
714832	99.80	714960	99.70	715109	99.60	715122	99.80	715166	99.70
715285	99.60	715315	99.80	715879	100.00	716037	99.90	716155	99.80
716184	100.20	716330	100.00	716393	100.00	716557	99.90	716591	99.70

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7489.77
- 3 Sum of Squared Measurements 747960.00
- 4 Correction Factor (CF): Sum of Measurements Squared / N 747955.40
- 5 Corrected Sum of Squares (SS) 4.61
- 6 Variance (V) : SS/(N-1) 0.0622
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.2495
- 8 Sample Mean(XBAR) : Sum X/N 99.86
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 8.56
- 12 Quality Index Lower (QL) : (XBAR-L) / S 7.47
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Louisville Gas and Electric  
 Division: 01  
 Model Number: MX  
 Sample Lot: 393  
 In Service Population: 10,000  
 Sample Quantity: 75  
 Meters Tested: 75  
 Pass/ Fail: PASS

Lot Descr: IGE MX - 2

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection  
 Page 46  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
717264	99.60	717456	99.90	717676	99.90	717692	99.80
717812	99.90	717822	99.70	718156	99.70	718294	99.90
718373	99.80	718416	99.90	718509	99.90	718604	99.80
718623	100.00	718627	99.81	718688	99.50	718763	99.70
718825	100.00	718847	99.10	718900	99.70	719244	100.20
719428	99.60	719547	99.40	720061	99.90	720172	99.90
720228	99.60	720618	99.80	720730	99.90	720926	99.70
721644	99.90	721781	99.90	721893	100.10	722046	99.80
722251	99.80	722254	100.00	722425	99.90	722570	99.60
722608	99.90	722724	99.60	722857	100.00	723029	99.70
815160	100.00	815418	99.80	815521	100.20	815883	99.90
816216	100.00	816384	99.90	816452	99.90	816696	99.90
816998	99.70	817355	99.20	817380	99.60	817436	99.70
817649	99.70	817788	99.70	817818	99.90	817904	99.90
817986	99.90	818013	99.90	818267	99.60	818313	99.70
						818425	99.60

INFORMATION NEEDED

VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7484.81
- 3 Sum of Squared Measurements 746967.74
- 4 Correction Factor (CF): Sum of Measurements Squared / N 746965.08
- 5 Corrected Sum of Squares (SS) 2.66
- 6 Variance (V) : SS/(N-1) 0.0359
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.1896
- 8 Sample Mean(XBAR): Sum X/N 99.80
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 11.62
- 12 Quality Index Lower (QL): (XBAR-L) / S 9.48
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 394  
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: IGE MX - 3

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 47  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
821389	99.50	821966	99.90	822013	99.50	822136	100.00	822182	99.40
822355	99.50	822357	99.80	822735	99.90	822861	100.00	822875	99.60
823021	99.70	824204	99.70	824260	99.50	824394	99.80	824399	99.80
824516	99.70	824588	99.80	824632	99.90	824674	99.90	824689	99.80
824699	99.40	824778	99.60	825065	99.60	825124	99.80	825127	99.90
825334	99.70	825542	99.90	825663	99.60	825880	99.60	825937	99.70
825997	99.70	826258	99.60	826360	99.90	826764	99.40	826830	99.80
827034	99.80	827073	99.60	827504	99.70	827555	99.40	830164	99.80
830195	99.90	830470	99.80	831007	99.20	831050	99.60	831258	99.70
831369	99.60	831459	99.00	831502	99.30	831606	99.60	831839	99.50
831899	99.70	836269	100.10	836279	100.00	836331	99.80	836413	99.90
836748	99.80	836902	99.80	836934	100.10	837064	100.20	837151	100.00
837327	99.80	837394	100.00	837502	99.80	837541	99.90	837758	99.90
837843	99.90	837925	99.20	838058	99.80	839181	100.00	839195	100.10
839210	99.80	839415	99.80	839678	99.80	839758	99.80	839829	99.90

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7480.30
- 3 Sum of Squared Measurements 746068.87
- 4 Correction Factor (CF): Sum of Measurements Squared / N 746065.17
- 5 Corrected Sum of Squares (SS) 3.70
- 6 Variance (V) : SS / (N-1) 0.0499
- 7 Estimate of Lot Standard Deviation (S) : SQRT of V 0.2235
- 8 Sample Mean (XBAR) : Sum X/N 99.74
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 10.13
- 12 Quality Index Lower (QL) : (XBAR-L) / S 7.77
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )  
 Device Category: F2S240V30ACC200 Model Number: MK Division: 01 Sample Lot: 395 Lot Descr: IGE MK - 4  
 In Service Population: 1,005 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993  
 Double Specification Limit - Variability Unknown - Standard Deviation Method  
 One AQL Value for Both Upper and Lower Specification Limit Combined  
 AQL = 2.5% - Inspection Level II "G" # Normal Inspection  
 Page 48  
 Run Date: 12/31/2010  
 Run Time: 06:28:11 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
---------------	--------------------	---------------	--------------------	---------------	--------------------	---------------	--------------------

839885	99.80	839911	100.00	839947	99.80	839950	99.90	839955	100.00
839964	100.00	839973	99.90	839985	100.00	840071	100.00	840092	100.00
840114	100.00	840118	99.90	840120	99.90	840155	100.00	840160	99.90
840169	100.00	840173	99.60	840232	100.00	840295	100.00	840309	99.90
840314	99.80	840319	99.90	840356	99.70	840455	100.00	840459	99.80
840484	99.80	840488	99.90	840554	99.90	840582	99.90	840584	99.70
840613	99.90	840657	99.90	840804	99.60	840897	99.90	840898	100.00

INFORMATION NEEDED

VALUE OBTAINED

- 1 Sample Size (N) 35
- 2 Sum of Measurements: (Sum X) 3496.30
- 3 Sum of Squared Measurements 349260.83
- 4 Correction Factor (CF): Sum of Measurements Squared / N 349260.39
- 5 Corrected Sum of Squares (SS) 0.44
- 6 Variance (V) : SS/(N-1) 0.0129
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.1136
- 8 Sample Mean (XBAR): Sum X/N 99.89
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 18.53
- 12 Quality Index Lower (QL): (XBAR-L) / S 16.67
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 5.58
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric  
 2010 Sample Test Program ( 01/01/2010 ) to ( 12/31/2010 )

LOT NAME	MANUFACTURER	MODEL	IN-SERV POP	SAMP QTY	MTRS TST	PASS/FAIL	LOT NUMBER
LGE AB1 - 1	Westinghouse	AB1	223	15	15	PASS TESTING COMPLETE	348
LGE ALF - 1	Landis + Gyr	ALF (Trilliant)	1,593	50	50	PASS TESTING COMPLETE	349
LGE C1 - 1	Itron	C1SR (ERT)	10,000	75	75	PASS TESTING COMPLETE	350
LGE C1 - 2	Itron	C1S	8,488	75	75	PASS TESTING COMPLETE	351
LGE D4 - 1	Westinghouse	D4S	10,000	75	75	PASS TESTING COMPLETE	352
LGE D4 - 2	Westinghouse	D4S	5,891	75	75	PASS TESTING COMPLETE	353
LGE I210 - 1	General Electric	I-210 (ERT)	1,152	35	35	PASS TESTING COMPLETE	354
LGE I50 - 1	General Electric	I-50S	1,370	50	50	PASS TESTING COMPLETE	355
LGE I55 - 1	General Electric	I-55S	1,704	50	50	PASS TESTING COMPLETE	356
LGE I60 - 1	General Electric	I-60S	10,000	75	75	PASS TESTING COMPLETE	357
LGE I60 - 2	General Electric	I-60S	3,872	75	75	PASS TESTING COMPLETE	358
LGE I70 - 1	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	359
LGE I70 - 2	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	360
LGE I70 - 3	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	361
LGE I70 - 4	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	362
LGE I70 - 5	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	363
LGE I70 - 6	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	364
LGE I70 - 7	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	365
LGE I70 - 8	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	366
LGE I70 - 9	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	367
LGE I70 - 10	General Electric	I-70S	9,472	75	75	PASS TESTING COMPLETE	368
LGE J4 - 1	Itron	J4S	10,000	75	75	PASS TESTING COMPLETE	369
LGE J4 - 2	Itron	J4S	2,259	50	50	PASS TESTING COMPLETE	370
LGE J5 - 1	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	371
LGE J5 - 2	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	372
LGE J5 - 3	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	373
LGE J5 - 4	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	374
LGE J5 - 5	Itron	J5S (R200)	10,000	75	75	PASS TESTING COMPLETE	375
LGE J5 - 6	Itron	J5S (R200)	10,000	75	75	PASS TESTING COMPLETE	376
LGE J5 - 7	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	377
LGE J5 - 8	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	378
LGE J5 - 9	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	379
LGE J5 - 10	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	380
LGE J5 - 11	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	381
LGE J5 - 12	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	382
LGE J5 - 13	Itron	J5S	774	35	35	PASS TESTING COMPLETE	383
LGE MQ - 1	Landis + Gyr	MQS	242	15	15	PASS TESTING COMPLETE	384
LGE MS - 1	Landis + Gyr	MS	9,345	75	75	PASS TESTING COMPLETE	385
LGE MSII - 1	Landis + Gyr	MSII	10,000	75	75	PASS TESTING COMPLETE	386
LGE MSII - 2	Landis + Gyr	MSII	10,000	75	75	PASS TESTING COMPLETE	387
LGE MSII - 3	Landis + Gyr	MSII	10,000	75	75	PASS TESTING COMPLETE	388
LGE MSII - 4	Landis + Gyr	MSII	10,000	75	75	PASS TESTING COMPLETE	389
LGE MSII - 5	Landis + Gyr	MSII	10,000	75	75	PASS TESTING COMPLETE	390
LGE MSII - 6	Landis + Gyr	MSII	3,202	75	75	PASS TESTING COMPLETE	391
LGE MX - 1	Landis + Gyr	MX	10,000	75	75	PASS TESTING COMPLETE	392
LGE MX - 2	Landis + Gyr	MX	10,000	75	75	PASS TESTING COMPLETE	393
LGE MX - 3	Landis + Gyr	MX	10,000	75	75	PASS TESTING COMPLETE	394
LGE MX - 4	Landis + Gyr	MX	1,005	35	35	PASS TESTING COMPLETE	395

TOTALS	380,592	3,260	3,260	48
TOTAL LOTS PASSED:				0
TOTAL LOTS FAILED:				0
METERS CANNOT TEST:				0

Report completed successfully with results.