

400 West Market Street
Suite 1800
Louisville, KY 40202-3352
(502) 587-3400
(502) 587-6391 FAX

Katie M. Glass
(502) 209-1212
kglass@stites.com

March 16, 2026

VIA E-MAIL TRANSMISSION PSCED@KY.GOV

Linda C. Bridwell
Executive Director
Public Service Commission
211 Sower Boulevard
P.O. Box 615
Frankfort, KY 40602-0615

RECEIVED

MAR 16 2026

**PUBLIC SERVICE
COMMISSION**

RE: **Case No. 2005-00276 (Post-Case Correspondence File)**
Kentucky Power Company's 2025 Meter Test Reports

Dear Ms. Bridwell:

Pursuant to Section I, paragraph 4 of Kentucky Power Company's 2006 Sample Meter Testing Plan, I enclose the Company's certified test results of all new meters received during calendar year 2025 (KY 2025 Factory Certified Tests.xlsx). The Company did not receive any new meters in 2025 as it begins its implementation of its Advanced Metering Infrastructure ("AMI") deployment; therefore, there are no factory certified tests for 2025.

I am also enclosing the 2025 results of Kentucky Power's statistical sampling plan (2025 Kentucky Power Sample Meter Test Report.pdf). Each of the lots tested satisfied the test criteria. Specifically, all the lots average accuracy tested at 99.78% or better and all lots passed the sample testing. As informally requested, I am also enclosing the results of all meters tested in 2025 (KY 2024 All Tests.xlsx).

Please do not hesitate to contact me if you have any questions.

Very truly yours,

STITES & HARBISON PLLC



Katie M. Glass

KMG

