

LICKING VALLEY

RURAL ELECTRIC COOPERATIVE CORPORATION

P. O. Box 605 • 271 Main Street West Liberty, KY 41472-0605 (606) 743-3179



RECEIVED

APR 1 7 2013

April 15, 2013

PUBLIC SERVICE COMMISSION

Director of Engineering Public Service Commission 211 Sower Boulevard P.O. Box 615 Frankfort, KY 40602

Case No. 2006-00194

Dear Sir:

Enclosed you will find Licking Valley Rural Electric Cooperative Corporation's Electric Distribution Utility Annual Reliability Report for the year ending 2012.

If additional information is needed, please let us know.

Sincerely,

Tommy Conley

Tommy Contes


Superintendent of Operations

Report prepared for:

Licking Valley Rural Electric Cooperative Corporation

Prepared by:

Tommy Conley, Superintendent of Operations tconley1@lvrecc.com 606-743-3179



	Major Event Days
T MED (major event day) could not b	be calculated as Licking Valley RECC does not keep a daily log of SAIDI values.

LICKING VALLEY RURAL ELECTRIC COOPERATIVE CORPORATION

Annual	Reliability	Report	2012
--------	-------------	--------	------

The attached report shows the reliability indices which reflect all outages, including outages caused by major storms and substation outages. The report also shows the contributing causes of outages per circuit.

T MED is not available, Licking Valley RECC does not keep a log on daily SAIDI values.

				CANDADA O	Reliability	Report						
		Substation	Storm	Planned	R-O-W	Unknown	Line Down	Equip Fail	Consumer	Sub Equip	Animals	Total
Helechay	va Substatio											
	een Circuit											
	SAIFI		. 2240	. 1053	. 1736	. 9525	.0119	1.0401	.0148		. 0549	2.577
	SAIDI		217.8412	6.6246	1	98.4555	. 9/99	20.0742	1.0682		3.2270	378.9
	CAIDI		972.50	62.91	177.19	103.31	71.30	19.30	72.17		58.18	147.05
Cannel C	ity Circuit											
Carmer	SAIFI		.0802	.2851	. 9065	.0122	.1047	-0145	.0445		.0635	1.511
	SAIDI		94.9276	8.7127	138.0623	1	51, 13/6	1,1024	3.8085		5.2617	304.6
	CAIDI		1183.63	30.56	152.30	84.88	494.09	76.03	85.58		82.86	2.01.5
Lee City	Circuit											
	SAIFI		9781	1.5958	1.4518	. 2701	. 3962	. 1901	.0040		.0199	1
	SAIDI		121.1321		1	26.5740	19.9801	14.7170	.5958		1. 4300	460.6
	CAIDI		123,84	42.68	102.02	98.39	201.87	77.17	148.95	+(71.86	93,88
	Mix Subs	tation										
Wrigley										+	2.200	4.04
(5)	SAIFI		1.3568	1.3970	.0653	1.1533	.0352				.0377	383.1
	SAIDI			58.4548	9.3461					 	4.2211	94.8
	CAIDI		190.19	41.84	1.43.13	43.11	111.35)//.//	17.8
Elk Fork	Circuit									-	A .// 2	
(1)	SAIFI		1.5531	1.6007	2.0659	.0842	,0696	,0330		 	.0403	
	SAIDI		469.2491		191.7582.		5.2198	14.2857		+	2.5824 64.08	153.7
	CAIDI		302.14	92.11	92.82	80.26	75.00	432.90			67.08	100.
519											0/0/	1.612
(4)	SAIFI		. 3404	1	.5230	1		. 0323	.1682		.0696 4.1102	
	SAIDI CAIDI		192.9255	1	85.8447	84.52/7 235.44		2.4831 74.42	5.6646 35.36		68.54	238.
Liberty	Road Circu	eit	566.76	11.dex	167.14		.0811	.0135				.175
(2)	Saiti					, 0811 4.8649	4.8649	. 4054	٤			10.19
	Saidi					59.99	59.99	30.03				57.7

				Reliability	Report						
	Substation	Storm	Planned	anned R-O-W U	Unknown	Line Down	Equip Fail	Consumer	Sub Equip	Animals	Total
Crockett Substatio	n										
Lenox Circuit											
SAIFI		.907/	,0273	.0546	. 109.3			. 0348		.0874	1.218
SAIDI		80.7650		9.8361	149.5082			1.6393		3.9344	246,5
CAIDI		89.04	30.02	180.15	1			49.98	-	45.02	200.3
Williams Creek Circ	cuit										
SAIFI		. 4162	.0869	. 0222	1576		. 2828	.0889		.0162	1
SAIDI		324.9394	4.7657	3.0909	9.3636		29.4848	10.6667	<u> </u>	1	385.0
CAIDI		180.13	54.84	139.23	59.41		104.26	119.99		168.35	359.5
Crockett Circuit											3.776
SAIFI		. 2215	2.1398	. 2301	.1505	.0989	. 9355				716.7
SAIDI			164.5355	20.6021	17.5806	41.1097	111.7419		 		189.8
CAIDI		1330.08	76.89	89.53	515.49	482.40	119.45		+		
School Circuit											
SAIFI							.0435				. 043
SAIDI							44.9565		-		46.95
CAIDI											1079,40

Γ					Reliabiltiy	Report						
-		Substation	Storm	Planned	ned R-O-W	Unknown	Line Down	Equip Fail	Consumer	Sub Equip	Animals	Total
	ndex Substation											
,,	Caney Circuit										.0152	1.5584
T	SAIFI		. 8325	.6168	.0203	,0219	.0127	. 0330			. 9518	3.30.20
Ī	SAIDI		295-1269	25.6853	1.3706	1.3325	1.9036	3.8325			62.62	
	CAIDI		354.51	41.64	41.52	47.16	149.89	102.50			φ α. 6α	
	Index Circuit										.0059	1.5412
	SAIFI		. 3418	. 5394	,5559	1		.0529			1.9412	
Ī	SAIDI		209.0135	24.0882	71.5147	i		6.3970				204.16
İ	CAIDI		577.87	45.50	148.65	46.24		120.93			041,02	
0	Mize Circuit								1678			3,501
	SAIFI		1.4545	. 2742	1.1864	I .	1	}	. 2939			1032.9
	SAIDI		828.9697	16.7410	145.2121	1 10.3030	25.2/2/	1.9113	1	İ		294.40
	CAIDI		569.93	61.07	122.45	69.38	184.84	145.39	15.1565			2011
2	Prison Circuit											
_	SAIFI											
	SAIDI											
	CAIDI											
6	School Circuit											
	SAIFI											
	SAIDI											
	CAIDI											

				Reliability	Report						
	Substation	Storm	Planned	R-O-W	Unknown	Line Down	Equip Fail	Consumer	Sub Equip	Animals	Total
Campton Substation	Japatation	0.01111									
Pine Ridge Circuit									1		
SAIFI		. 7465	.0/28	.0234	. 1262	. 0070	. 7278	.6963		.0245	2.3
SAIDI		78.4334	1	37.8972	1	- 7009	15.3680	20.89		2.1920	2.43
CAIDI		1-31.86	103.58	1192-19		100.13	103.55	3000		113.96	111
Stillwater Circuit		101,00	72,500	1,1,000							
SAIFI		. 1450	- 1152	./803	- 2305		.0/21			.0046	-6
SAIDI		136.7844		21.5520			1.4219			- 1952.	378
CAIDI		943.34	53.41	119.53	9/9.29		117.51	,	1 1	42.43	549
Vortex Circuit		1,5		- /					<u> </u>		
SAIFI		-26.50		. 6393	.0564	-0188	.0650	.0017		. 2068	1.6
SAIDI		163.7436		31.1282	6.9213	2.2564	5.5385	- 1026		14.6154	82
CAIDI		2882.05		48.69	122.12	120.02	85.21	60.35	/_	70.67	65
Elkins Road Circuit											
SAIFI		1.3139	. 1533	,0146	. 2117	.0803			\	.0876	1.8
SAIDI		414. 4891	11.7153	2.1898	23.1591	18.0657			-	6.1883	47
CAIDI		315.46	76.42	149.99	112.23	224.98				77.49	256
Maytown Substation	1.6900			,							
Ezel Circuit	350.0335							-			
SAIFI		.2083	.0625	.0097	. 1236	, 3153	.0194	-0097		.0153	. 7
SAIDI		6.32.1458	6.1042	.8333	21. /875	22.5833	5. 9167	31.4792		1.2500	T
CAIDI		3034.78	97.67	85.91	171.42	71.62	304.98	3345.28		81.70	94
Hazel Green Circuit											-
SAIFI		.0119	. 1935	12738	-1667	. 0208	.0417	.0178	 	.0438	. 7.
SAIDI		1.6011	6.9643	16.8001	15.2232	2.5000	5.8928	1.3393		1.5149	5/
CAIDI		135.05	35,99	61.36	91.32	120.19	141.31	75.24		63,65	69
Pomeroyton Circuit					-						
SAIFI		. 7218	.8621	. 0966	. 1770		. 0069		+ (.0115	
SAIDI		1978.0344	96.6431	14.3103	16.4942		.5172		1	. 9655	210
CAIDI		2740.42	112.10	148.14	93.19		74.96			83.96	1123

				Reliability Report								
		Substation	Storm	Planned	R-O-W	Unknown	Line Down	Equip Fail	Consumer	Sub Equip	Animals	Total
NA	d Substation	Substation	3.01111	riainica	IN-O-W	Onknown	Line Donn	-quip				
	use Circuit											
ROCKHOU	SAIFI		2000		.0174	. 0035		.0691	. 1115		.0035	.533
	SAIDI		36,3240		1.0453	.2091		8.9895	9.3031		. 2787	56.15
	CAIDI		1/0.91		60.07	59,14		128.97	83.43		19.63	105.3
Flat Fork			770.71		60.01	37,77		70,0				
l lac i oii	SAIFI	70100	.3030	.3903	. 2063	. 0985		.0014	.0167		. 1840	1.206
	SAIDI		665.9108	38.5502	19.3587	18.0396		1. 17/0	. 15.18		35.5297	189.3
	CAIDI		2191,72	98.17	142.31	183.14		158.24	45.08		193.10	654.3
Lick Cre	ek Circuit		2////a	10.77	1.7.0.01							
	SAIFI		.3269	.5946	. 1619	-0865	.3766	.0769	.0321		.0176	1.67
	SAIDI		1	22.8846	15.9856	7.6202	45.7452	11.8269	3.3654		1.2500	414.85
	CAIDI		936,61	38.49	98.14	88.09	121.47	153.79	104.84		71.02	247.9
Sublett	Substation											
Carver (Circuit											
	SAIFI		.1945	. 4076	.0197	. 0913	.0814	.0011	.0055		.3836	1.19
	SAIDI		18.7268	21.2295	3.7049	9.8306	16.1639	. 1803	. 4098		23.0984	15.3.
	CAIDI		404.76	52.08	188.06	101.03	184.94	163.91	74.51		60.21	128.
Lakevill	e Circuit											
	SAIFI		. 9745	.1234	. 8957	. 5894	. 1234	.0085	. 1085		.02/3	2.84
	SAIDI		247.425	9.6383		45. 4362		16.6596			2.0106	
	CAIDI		253.90	18.11	36.39	77.09	162.68	1959.95	224.43		94.39	139.9
Gunlock	k Circuit											100
	SAIFI		.0812	.0911	. 2151	T	. 0314	.0233	. 3814	,	.0267	
	SAIDI		89.6512			34.6047	4.9360	14.9593			J. 5291	ì
	CAIDI		1028.11	193.82	183.66	98.23	157.20	642.03	161.87	+	94.12	219.6
Gun Cre	eek Circuit							1	-	+ -		1,510
	SAIFI			. 4110	- 1288	.2393	13,9877	. 4958	. 2086		. 2331	15.69
	SAIDI			24.6626	13.5276		861.9632	55.2147	12.7607		6.9939	
1	CAIDI			60.01	105.03	39.35	61.62	112.50	61.17		30.00	62-1

				Reliability	Report						
	Substation	Storm	Planned	R-O-W	Unknown	Line Down	Equip Fail	Consumer	Sub Equip	Animals	Total
Zachariah Subs		300111	lamea						1		
Leeco Circuit											
SAIFI		. 4571	. 0753	.0182	. 0805	.0597	. 0130	. 4208		.0026	1.1272
SAID		72.5454		2.6883	11.1428	32.3317	5.1039	124.1299		. 2338	250.09
CAID		158.71	25.35	147.71	138.42	541.61	394.61	294.98		89.92	221.37
Pine Ridge Circ	uit						4				
SAIFI		- 1/17	.0215	1.0149	1.3582	.0298	.0332	.00/7		.0580	2.6350
SAID	l	33.6070	1.4511	132.6534	191.8905	4.0196	5.7463	4.7761		5. 4229	319.63
CAID	1	285.53	67.49	130.10	141.28	136.90	173.08	2809.47		93.50	144.07
Oakdale Subst	ation										
Athol Circuit									1		
SAIF		.0087		. 1043	. 1043		.0609	.0087	-		-2869
SAID	l	.5217		9.39/3	45.3913		7.5217	1.1739	 		64.00
CAID)]	59.97		90.04	435.20		123.51	134.93			223.07
Highland Circu	it										
SAIF	l	. 1158	.2999	.1364	.1622	. 0541			 	- 00 13	
SAID)	9.6782	50.9395	17.8192	18.9168	11.9691			+	.0965	
CAID	DI .	83.58	169.85	130.62	117.00	221.24				14.43	142.24
Elkatawa Circu											
SAIF		. 7778	.0631	- 1490		, 2020	, 0050		 	,0101	2.0000
SAID)l	66.1111	16.9697	23.8384	87.6894	27.0016	. 2651		+-/	. 8081	
CAID	DI .	85.00	36893	159.99	110.59	133.70	53.02			80.01	111.34
War Creek Circ											
SAIF		.0095		. 0332	.0546	<u> </u>	1.9572			. 0380	
SAID)I	2.2803		1,9952			581. 1134			4.8812	
CAIL	OI .	240.03	10.47	60.10	8.5.48		300.01			128.45	210.15

According to the calculations of SAIFI, SAIDI, and CAIDI, the ten worst performing circuits are:

Maytown Substation Pomeroyton Circuit

Crockett Substation School Circuit

Maytown Substation Ezel Circuit

Campton Substation Vortex Circuit

Maggard Substation Flat Fork Circuit

Campton Substation Stillwater Circuit

Crockett Substation Williams Creek Circuit

Index Substation Mize Circuit

Campton Substation Elkins Road Circuit

Maggard Substation Lick Creek Circuit

LICKING VALLEY RURAL ELECTRIC COOPERATIVE CORPORATION VEGETATION MANAGEMENT PLAN

Licking Valley Rural Electric Cooperative Corporation has an aggressive vegetation management program and has contracted W. A. Kendall and B M C Contracting to address our cooperatives right-of-way requirements. Our cooperative likes to maintain a forty-foot ground to sky right-of-way clearance on new and existing accounts, however some variety in right-of-way clearing is based on geography/terrain, easement widths, line voltages and property owner issues. LVRECC is currently on a 5 year rotation cycle. W. A. Kendall and B M C Contracting is contracting circuit by circuit clearing. One crew runs a bucket truck and a chipper and their main concern are consumer requests and hot spots. In addition to W.A. Kendall, the cooperative has a bush hog that is used for right-of-way clearing when not in use by construction or maintenance crews. The cooperative has a right-of-way foreman that oversees W.A. Kendall and B M C Contracting crews. B M C Contracting also provides a crew that concentrates on Herbicide Treatment, primarily for the months of May until August or September.