

**CANNONSBURG WATER DISTRICT**

1606 CANNONSBURG ROAD

ASHLAND, KY 41102

606-928-9808

FAX# 606-928-4788

[www.cannonsburgwater.com](http://www.cannonsburgwater.com)

**RECEIVED**

**MAY 13 2014**

**PUBLIC SERVICE  
COMMISSION**

May 7, 2014

Mr. Jeff Derouen  
Executive Director  
Public Service Commission  
PO Box 615  
Frankfort, KY 40602

Re: Case No. 2011-00217  
Water Loss Report

Dear Mr. Derouen:

Please find enclosed copy of our water loss for February, 2014.

If you have any further questions, please let me know.



Danny R. Clarkson  
Manager

Enclosures

# Water Use Report

Water Utility: Cannonsburg Water District PWSID: KY0100064

For the Month of: February Year: 2014

|   |                              |        |  |
|---|------------------------------|--------|--|
| 1 | PRODUCTION COST PER THOUSAND | \$0.00 |  |
| 2 | PURCHASE COST PER THOUSAND   | \$0.00 |  |

**GALLONS**

|                                    |                                     |        |            |
|------------------------------------|-------------------------------------|--------|------------|
| <b>WATER PRODUCED or PURCHASED</b> |                                     |        |            |
| 3                                  | Water Produced                      | \$0.00 | 0          |
| 4                                  | Water Purchased                     | \$0.00 | 40,970,300 |
| 5                                  | <b>TOTAL PRODUCED AND PURCHASED</b> |        | 40,970,300 |
| 6                                  | <b>TOTAL COST</b>                   | \$0.00 |            |

**WATER SOLD**

|    |   |  |  |
|----|---|--|--|
| 7  | Residential   |  | 16,660,300   |
| 8  | Commercial  |  | 4,332,900  |
| 9  | Industrial  |  | 8,031,600  |
| 10 | Bulk Loading Stations   |  | 1,000  |
| 11 | Wholesale   |  | 0  |
| 12 | Other Sales (explain) <span style="margin-left: 20px;">Meter Loss @ 2% asper PSC</span> |  | 819,406  |
| 13 | <b>TOTAL WATER SOLD</b>   |  | 29,845,206 <span style="float: right;">72.85%</span> |
| 14 | <b>TOTAL WATER NOT SOLD</b>   |  | 11,125,094 <span style="float: right;">27.15%</span> |

**BREAKDOWN OF WATER USAGE**

|    |                            |  |        |
|----|----------------------------|--|--------|
| 15 | Water Treatment Plant      |  | 25,000 |
| 16 | Wastewater Treatment Plant |  | 0      |
| 17 | System Flushing            |  | 60,000 |
| 18 | Fire Department Usage      |  | 0      |
| 19 | Other Usage (explain)      |  | 0      |

20 **TOTAL USAGE** 85,000

21 **WATER LOSS PERCENTAGE FOR RATE PURPOSES** 26.95%

**BREAKDOWN OF WATER LOST**

|    |                      |  |  |
|----|----------------------|--|--|
| 22 | Tank Overflows       |  | 0  |
| 23 | Excavation Breaks    |  | 0  |
| 24 | Repaired Line Breaks |  | 450,000  |
| 25 | Unknown Loss         |  | 10,590,094 <span style="float: right;">25.85%</span> |

26 **TOTAL WATER NOT SOLD OR USED** 11,040,094

27 **COST OF WATER NOT SOLD OR USED** \$0.00

**"UNKNOWN LOSS" FLOW RATE AND COST:**

|    |  |  |            |
|----|--|--|------------|
| 28 | "Unknown Loss"                           |  | 10,590,094 |
| 29 | % "Unknown Loss"                         |  | 25.85%     |
| 30 | Number of Days in Period                 |  | 28         |
| 31 | "Unknown Loss" per Day (Gallons per Day) |  | 378,218    |
| 32 | "Unknown Loss" per Minute (GPM)          |  | 262.65     |
| 33 | "Unknown Loss" Cost for Month            |  | \$0.00     |