



RECEIVED

DEC 16 2025

PUBLIC SERVICE
COMMISSION

December 15, 2025

DELIVERED VIA EMAIL

Public Service Commission
211 Sower Blvd
Frankfort, KY 40602
psc.water.notice@ky.gov

RE: Annual Sample Testing
Warren County Water District, Simpson County Water District, Butler
County Water System, Inc.
PSC Case No. 2011-00220

A random sample of 21-year-old meters in year 2024 have been tested, and the results exceeded the accuracy levels of meters tested in PSC Case No. 2011-00220. The meters tested are Sensus SRII meters, size 5/8". A comparison of the results is below.

Average meter accuracy of random sample group:	100.30%
Average meter accuracy of Case No. 2011-00220 group:	98.61%

An excerpt from Case No. 2011-00220 stating that annual sample test results are to be submitted to the PSC is below:

Meter Testing of Sample Group Each Year

To confirm that future meter accuracy trends conform to the data obtained in this study, a random sample of 21-year-old meters will be tested each year. As with the current sample testing, the size of the sample will be calculated to provide a 95 percent confidence level that the average meter accuracy determined for the sample group would be plus or minus 1 percent of the actual average accuracy of all 21-year-old meters. The results of these annual sample tests will be submitted to the PSC.

Also provided is a complete listing of the test results of the random sample. If you have any questions, please give me a call.

Sincerely,

Jeffrey B. Peebles
Manager of Finance & Administration

Providing high quality
water and wastewater
services to families and
businesses throughout
Warren County.



ANNUAL SAMPLE TESTS
METER TESTING OF 21 YEAR OLD METERS
WARREN, BUTLER, SIMPSON WATER DISTRICTS
Year 2024

SRII 5/8" Meter No.	----- Test Results-----			WAMA	Meets PSC Repaired Meter Stds.
	Low	Medium	High		
61396295	99.40	100.80	100.80	100.70	
61396299	99.60	100.70	99.80	100.57	
61396311	95.70	98.90	100.20	98.75	
61396312	98.90	101.00	100.20	100.81	
61396317	99.20	100.60	99.70	100.45	
61396328	98.60	100.90	99.60	100.66	
61396340	100.30	101.00	100.60	100.93	
61396362	99.90	100.70	99.70	100.58	
61396393	101.10	100.90	100.40	100.88	No
61396395	100.30	100.80	100.00	100.72	
61396398	99.90	100.90	100.30	100.79	
61396403	98.50	100.40	99.60	100.22	
61396405	99.80	101.00	100.00	100.86	
61396425	97.10	100.20	99.40	99.93	
61396429	99.40	100.70	100.00	100.57	
61396436	100.20	100.70	100.30	100.64	
61396444	99.00	100.40	99.30	100.24	
61396456	98.90	100.70	99.20	100.48	
61396464	100.40	100.70	100.00	100.64	
61396465	90.20	83.70	99.60	85.10	No
61827629	99.40	100.80	99.90	100.65	
61827631	100.10	100.90	99.90	100.78	
61827640	99.60	100.90	100.10	100.76	
61827643	100.30	100.80	100.00	100.72	
61827650	99.40	100.70	99.70	100.55	
61827652	100.20	101.10	99.80	100.96	
61827666	99.40	100.90	100.00	100.74	
61827670	98.90	100.70	99.80	100.52	
61827676	99.00	100.70	99.60	100.52	
61827690	99.90	100.60	99.60	100.49	
61827693	99.10	101.00	99.80	100.80	
61827697	98.70	100.60	99.90	100.43	
61827708	100.70	100.80	100.10	100.75	
61827709	100.60	100.60	100.00	100.56	
61827712	100.30	100.70	99.70	100.61	
61827723	97.10	100.30	99.50	100.03	
61827734	99.50	100.70	99.80	100.56	
61827735	99.60	100.60	99.30	100.45	
61827746	98.50	100.60	99.60	100.39	
61827753	99.00	101.30	100.20	101.07	
61827755	93.60	98.60	99.90	98.33	
61827759	99.40	100.50	99.50	100.36	
61827765	100.10	100.60	99.90	100.52	
61827772	100.30	100.80	99.90	100.71	
61827791	99.20	101.00	100.10	100.82	
61827807	100.40	100.80	99.80	100.71	
62139699	98.50	100.60	99.60	100.39	
62139709	99.40	100.80	99.60	100.63	
62139720	99.70	100.90	100.20	100.77	
62139722	101.20	101.10	100.20	101.05	No
62139726	100.50	101.10	100.20	101.00	
62139729	99.60	100.80	99.60	100.64	
62139731	100.00	100.60	100.00	100.52	
62139741	100.90	100.60	100.00	100.59	
62139743	100.30	100.90	100.30	100.82	
62139746	100.90	101.00	100.40	100.96	
62139780	100.70	100.90	100.30	100.85	
62139794	100.70	100.90	99.70	100.82	
62139796	97.10	95.00	99.10	95.39	No
62139800	99.90	101.00	99.50	100.83	

ANNUAL SAMPLE TESTS
METER TESTING OF 21 YEAR OLD METERS
WARREN, BUTLER, SIMPSON WATER DISTRICTS
Year 2024

SRII 5/8" Meter No.	----- Test Results-----			WAMA	Meets PSC Repaired Meter Stds.
	Low	Medium	High		
62139803	99.40	100.70	99.90	100.56	
62139805	97.60	99.90	98.90	99.68	
62139818	100.00	100.90	99.90	100.78	
62139835	99.50	100.90	99.50	100.72	
62139859	100.10	100.90	100.00	100.79	
62139863	100.00	101.00	100.30	100.89	
62400236	99.30	100.90	100.10	100.74	
62402799	99.80	100.60	99.80	100.50	
62403310	99.60	100.70	99.80	100.57	
62403311	99.00	101.20	99.90	100.97	
62403315	99.10	101.00	100.50	100.84	
62403327	99.90	100.80	99.90	100.68	
62403338	97.80	100.20	99.90	100.01	
62403345	99.20	100.30	99.20	100.16	
62403358	99.40	100.90	100.10	100.75	
62403361	97.50	94.70	98.90	95.15	No
62403362	100.90	100.90	100.50	100.88	
62403378	98.50	100.70	99.90	100.50	
62403381	100.00	100.90	100.40	100.81	
62403391	99.20	100.70	99.80	100.54	
62403393	99.10	100.90	100.20	100.73	
62403394	100.10	101.00	100.10	100.88	
62403402	99.40	100.80	99.60	100.63	
62403409	99.10	100.30	99.40	100.16	
62403413	100.40	100.90	100.40	100.84	
62403414	100.80	101.00	100.20	100.94	
62403426	99.30	100.90	99.40	100.70	
62403433	100.80	101.00	100.30	100.94	
62403443	100.40	99.90	99.70	99.92	
62403444	100.20	100.90	100.50	100.83	
62403453	96.90	100.70	100.20	100.40	
62403475	98.60	100.30	99.30	100.12	
62403478	99.30	100.30	99.80	100.20	
62403485	100.10	100.80	99.90	100.70	
62403486	99.70	100.60	99.70	100.48	

AVERAGES	99.35	100.41	99.88	100.30
MIN	90.20	83.70	98.90	85.10
MAX	101.20	101.30	100.80	101.07

% Meeting PSC Required Meter Stds.
Total Population Size
Sample Size (95% Conf. Level)

575
95

94.74%