



RECEIVED

DEC 16 2025

PUBLIC SERVICE
COMMISSION

December 15, 2025

DELIVERED VIA EMAIL

Public Service Commission
211 Sower Blvd
Frankfort, KY 40602
psc.water.notice@ky.gov

RE: Annual Sample Testing
Warren County Water District, Simpson County Water District, Butler
County Water System, Inc.
PSC Case No. 2011-00220

A random sample of 21-year-old meters as of year 2025 have been tested, and the results exceeded the accuracy levels of meters tested in PSC Case No. 2011-00220. The meters tested are Sensus SRII meters, size 5/8". A comparison of the results is below.

Average meter accuracy of random sample group:	100.48%
Average meter accuracy of Case No. 2011-00220 group:	98.61%

An excerpt from Case No. 2011-00220 stating that annual sample test results are to be submitted to the PSC is below:

Meter Testing of Sample Group Each Year

To confirm that future meter accuracy trends conform to the data obtained in this study, a random sample of 21-year-old meters will be tested each year. As with the current sample testing, the size of the sample will be calculated to provide a 95 percent confidence level that the average meter accuracy determined for the sample group would be plus or minus 1 percent of the actual average accuracy of all 21-year-old meters. The results of these annual sample tests will be submitted to the PSC.

Also provided is a complete listing of the test results of the random sample. If you have any questions, please give me a call.

Sincerely,

Jeffrey B. Peebles
Manager of Finance & Administration

Providing high quality
water and wastewater
services to families and
businesses throughout
Warren County.



ANNUAL SAMPLE TESTS
METER TESTING OF 21 YEAR OLD METERS
WARREN, BUTLER, SIMPSON WATER DISTRICTS
Year 2025

SRII 5/8" Meter No.	----- Test Results-----			WAMA	Meets PSC Repaired Meter Stds.
	Low	Medium	High		
62705676	100.60	100.90	99.90	100.82	No
62705844	100.00	101.30	100.10	101.14	
62705998	100.30	100.80	99.70	100.70	
62706002	99.30	100.80	99.90	100.64	
63101918	99.90	100.90	100.10	100.78	
63101951	99.20	100.50	99.30	100.34	
63102003	97.90	100.90	99.50	100.61	
63102016	99.10	100.70	99.50	100.52	
63102033	100.60	101.00	99.90	100.91	
63102057	100.80	100.70	99.90	100.66	
63262059	99.70	100.40	99.40	100.29	
63262108	98.20	99.10	98.40	99.00	
63262138	99.70	100.80	100.20	100.69	
63262142	98.40	101.00	99.80	100.75	
63281503	99.70	100.60	99.60	100.48	
63281512	100.50	100.60	98.90	100.49	
63281537	98.80	100.80	99.60	100.59	
63281573	100.10	100.90	99.90	100.78	
63281608	99.40	100.80	100.00	100.65	
63281674	99.10	100.30	99.30	100.16	
63337858	92.60	101.10	99.90	100.43	
63337870	96.60	99.60	100.30	99.43	
63337873	99.20	100.80	99.80	100.63	
63337973	99.30	100.60	99.20	100.43	
63338073	97.80	99.50	99.20	99.36	
63338134	99.30	100.90	99.80	100.72	
63338187	100.20	101.00	100.20	100.90	
63338205	100.40	100.70	100.00	100.64	
63338235	90.30	100.80	100.10	100.02	
63338341	99.80	100.40	99.30	100.29	
63338424	97.20	100.80	99.70	100.48	
63338668	100.90	100.80	100.00	100.76	No
63338841	99.80	100.80	99.70	100.66	
63338842	101.30	101.10	100.10	101.05	
63477707	98.90	100.30	99.30	100.14	
63477707	98.60	100.30	99.30	100.12	
63477755	99.10	100.20	99.10	100.06	
63477776	100.00	100.40	99.70	100.33	
63477850	99.60	100.70	100.00	100.58	
63477914	98.90	100.60	99.50	100.42	
63478084	98.80	100.80	100.00	100.61	
63478419	100.40	100.60	99.60	100.53	
63478463	98.80	100.50	99.40	100.32	
63478473	99.40	100.50	99.80	100.38	
63478484	99.60	100.60	99.80	100.48	
63478512	100.90	100.80	99.90	100.75	
63478516	99.90	101.20	100.30	101.06	
63478557	100.10	100.90	99.70	100.77	
63478684	100.60	100.70	99.50	100.62	
63834005	100.10	100.90	99.60	100.77	
63834054	98.30	100.60	99.40	100.37	
63834057	101.00	100.80	99.70	100.75	
63834250	95.70	101.50	100.40	101.03	
63834304	99.10	100.20	99.10	100.06	
63834351	100.60	101.00	100.20	100.92	
63834510	99.70	100.80	99.80	100.66	

ANNUAL SAMPLE TESTS
METER TESTING OF 21 YEAR OLD METERS
WARREN, BUTLER, SIMPSON WATER DISTRICTS
Year 2025

SRII 5/8" Meter No.	----- Test Results-----			WAMA	Meets PSC
	Low	Medium	High		Repaired Meter Stds.
63834601	101.40	101.00	100.20	100.98	No
63888376	100.00	100.70	99.70	100.59	
63888457	99.80	100.70	99.60	100.57	
63888467	99.80	100.50	100.00	100.42	
63888524	99.80	101.10	100.10	100.95	
63915773	100.10	100.60	99.30	100.49	
63915803	98.80	99.50	99.60	99.46	
63915806	99.10	99.60	99.50	99.56	
63915856	99.40	100.30	99.30	100.18	
63915880	99.10	100.60	99.40	100.42	
63926221	99.00	100.70	99.70	100.52	
63926254	99.80	100.70	99.90	100.59	
63926341	99.50	100.00	100.00	99.96	
63926345	99.00	100.50	99.60	100.34	
63926464	98.70	100.30	99.20	100.12	
63926662	99.00	100.70	99.50	100.51	
63926666	100.10	100.80	100.30	100.72	
63926686	100.00	100.40	99.20	100.30	
63926740	100.00	101.00	99.90	100.86	
63978691	99.10	101.20	99.50	100.95	
63978698	98.80	100.50	99.30	100.31	
63978706	99.00	100.20	99.40	100.07	
64144008	98.50	100.50	99.40	100.29	
64191576	100.20	100.90	99.80	100.79	
64191595	92.9	99.8	99.2	99.28	
64191676	98.90	100.90	99.60	100.68	
64191725	99.60	100.60	99.90	100.49	
64191775	99.40	101.00	99.90	100.82	
64191884	100.70	100.90	100.10	100.84	
64191903	97.60	100.10	99.60	99.89	
64353167	99.70	100.80	99.50	100.65	
64353264	98.50	100.60	99.50	100.39	
64353288	100.40	100.90	99.40	100.78	
64353296	98.60	100.50	99.80	100.33	
64353460	100.70	100.30	100.10	100.32	
64353476	99.40	101.00	99.80	100.82	
64353502	100.90	100.70	100.10	100.68	
64353553	99.90	100.50	99.90	100.42	
64353167	98.30	100.60	99.40	100.37	
AVERAGES	99.25	100.63	99.69	100.48	
MIN	90.30	99.10	98.40	99.00	
MAX	101.40	101.50	100.40	101.14	

% Meeting PSC Required Meter Stds.
Total Population Size
Sample Size (95% Conf. Level)

3368
95

96.81%