# RECEIVED

APR 29 2025

PUBLIC SERVICE COMMISSION

# KENTUCKY PUBLIC SERVICE COMMISSION

# Electric Distribution Utility Annual Reliability Report

#### **SECTION 1: CONTACT INFORMATION**

UTILITY NAME REPORT PREPARED BY E-MAIL ADDRESS OF PREPARER PHONE NUMBER OF PREPARER IIMMY TRIMBLE
JTRIMBLE@CLARKENERGY.COM
859-771-6095

### **SECTION 2: REPORTING YEAR**

**CALENDAR YEAR OF REPORT** 

01-01-2024 - 12-31-2024

### **SECTION 3: MAJOR EVENT DAYS (MED)**

T<sub>MED</sub>

28,555,836

FIRST DATE USED TO DETERMINE T<sub>MED</sub>

01-01-2024

LAST DATE USED TO DETERMINE T<sub>MED</sub>

12-31-2024

NUMBER OF MED IN REPORT YEAR

THIS YEAR

NOTE: Per IEEE 1366  $T_{\text{MED}}$  should be calculated using the daily SAIDI values for the five prior years. If five years of data are not available, then utilities should use what is available until five years are accumulated.

#### **SECTION 4: SYSTEM RELIABILITY INFORMATION AND RESULTS**

### **System-wide Information**

**TOTAL CUSTOMERS 27,722** 

**TOTAL CIRCUITS 74** 

### **Excluding MED**

**5 YEAR AVERAGE** 

**REPORTING YEAR** 

SAIDI 310 2 SAIFI 1.24

SAIDI 256.18

SAIFI 1.63

## **Including MED**

**5 YEAR AVERAGE** 

**REPORTING YEAR** 

SAIDI 1004.16

SAIDI 1155.5

SAIFI 1.8548

**SAIFI 2.52** 

#### Notes:

- 1) All duration indices (SAIDI) are to be reported in units of minutes.
- 2) Reports are due on the first business day of May of each year
- 3) Reports cover the calendar year ending in the December before the reports are due.
- 4) IEEE 1366 (latest version) is used to define SAIDI, SAIFI, and T<sub>MED</sub>

# **KENTUCKY PUBLIC SERVICE COMMISSION**

### SECTION 6: VEGETATION MANAGEMENT PLANREVIEW

### INCLUDE CURRENT VEGETATION MANAGEMENT PLAN

Additional page may be attached as needed.

At Clark Energy we have been working tirelessly to work on the right of way. We
have been targeting our right of ways to improve our outage numbers. We are
currently working on a complete system inventory to identify all areas that will
include trimming to assist with the bidding process.

We are turning our focus toward a significant number of dead trees that are also affecting outages. The main issue is the Ash tree population and Oak trees.

We have expanded our herbicide usage by more than double hoping to slow the tree and underbrush growth. We are working to get them in a more manageable condition.

SECTION 7; UTILITY COMMENTS			

Excluding Major Event Day Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: BECKNERVILLE

Substation	BECKNERVILLE
Substation Location	Combs Ferry Rd
Circuit	214 Water Works
Circuit Location	Water Works Rd
Total Circuit Length (miles)	23.90
Average Member Count	25
Date of last Trim	TRIM 2024

	Totals		5 Year A	verage
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	388.32	1.40	44.94	. 22
Animals	74.94%	71.43%	19.98%	35.71%
600 Small Animal/Bird	0%	0%	19.98%	35.71%
601 Squirrel	0%	0%	0%	0%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	74.94%	71.43%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0 %	0%	0%
690 Animal, Other	0%	0 응	0%	0%
Equipment or Installation/Design	13.65%	5.71%	2.46%	3.57%
300 Material or Equipment Fault/Failure	13.65%	5.71%	2.46%	3.57%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	5.15%	<b>11.</b> 43%	6.46%	17.86%
400 Decay/Age of Material/Equipment	0 %	0%	0%	0%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	0 %	0%	0%	0%
430 Tree failure from overhang or deadtr	5.15%	11.43%	6.46%	17.86%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

### Excluding Major Event Day outages, Planned outages, Customer Responsible outages and Momentary outages

### Substation: BECKNERVILLE

Substation	BECKNERVILLE
Substation Location	
Circuit	214 Water Works
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	25
Date of last Trim	

	Totals		5 Year Average	verage
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	388.32	1.40	44.94	. 22
Maintenance	5.15%	11.43%	6.46%	17.86%
490 Maintenance, Other	0%	0%	0%	0%
Other	0%	0%	0%	0 %
800 Other	0%	0%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0 %	0 %
100 Construction	0%	0%	0%	0 %
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
Public	0 %	0%	3.08%	3.57%
700 Customer-Caused	0%	0%	3.08%	3.57%
710 Motor Vehicle	0%	0%	0%	0%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0 %
Public, Other	0%	0%	0%	0%
Unknown	6.26%	11.43%	24.64%	14.29%
999 Cause Unknown	6.26%	11.43%	24.64%	14.29%
Weather	0%	0 %	43.39%	25%
500 Lightning	0%	0%	39.79%	17.86%

### Excluding Major Event Day Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: BECKNERVILLE

	_, _,
Substation	BECKNERVILLE
Substation Location	
Circuit	214 Water Works
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	25
Date of last Trim	

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	388.32	1.40	44.94	.22
Weather	0%	0%	43.39%	25%
510 Wind, Not Trees	0%	0%	0%	0%
520 Ice, Sleet, Frost, Not Trees	0%	0%	3.60%	7.14%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

Excluding Major Event Day Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: BECKNERVILLE

Substation	BECKNERVILLE
Substation Location	Combs Ferry Rd
Circuit	244 Grimes Mill
Circuit Location	Grimes Mill-Winchester
Total Circuit Length (miles)	43.41
Average Member Count	336
Date of last Trim	TRIM 2024

	Totals		5 Year <i>F</i>	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	235.67	1.28	225.48	1.11
Animals	22.91%	17.02%	0.06%	0.17%
600 Small Animal/Bird	21.50%	15.62%	0%	0%
601 Squirrel	1.41%	1.40%	0.04%	0.11%
610 Large Animal	0%	0%	0%	08
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0.03%	0.06%
Equipment or Installation/Design	0.53%	2.33%	10.27%	13.60%
300 Material or Equipment Fault/Failure	0.53%	2.33%	10.27%	13.60%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or InadequateClearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	57.64%	61.54%	75.05%	71.09%
400 Decay/Age of Material/Equipment	10.57%	10.49%	1.89%	2.54%
410 Corrosion/Abrasion of	0%	0%	0.04%	0.06%
Material/Equipment				
420 Tree Growth	22.62%	10.96%	8.84%	7.35%
430 Tree failure from overhang or deadtr	24.45%	40.09%	64.08%	60.70%
440 Trees With Ice/Snow	0%	0%	0.20%	0.44%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%

Excluding Major Event Day Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: BECKNERVILLE

Substation	BECKNERVILLE
Substation Location	
Circuit	244 Grimes Mill
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	336
Date of last Trim	

Totals		5 Year Average	
SAIDI	SAIFI	SAIDI	SAIFI
235.67	1.28	225.48	1.11
57.64%	61.54%	75.05%	71.09%
0%	0%	0%	0%
2.20%	2.33%	0%	0%
2.20%	2.33%	0%	0%
0 응	0%	0%	0%
0 %	0%	0%	0%
0%	0%	0%	0%
0%	0%	0%	0%
0%	0%	0%	0%
0 %	0 %	0%	0%
0%	0%	0%	0%
0.54%	1.17%	5.08%	3.81%
0.54%	1.17%	0.07%	0.11%
0%	0%	4.96%	3.59%
0%	0%	0%	0%
0%	0%	0%	0%
0%	0%	0.05%	0.11%
0%	0%	0%	0%
0%	0%	0%	0%
0%	0%	0%	0%
12.46%	11.66%	3.74%	6.30%
12.46%	11.66%	3.74%	6.30%
3.72%	3.96%	5.80%	5.03%
2.32%	2.80%	4.49%	3.43%
	SAIDI 235.67 57.64% 0% 2.20% 2.20% 0% 0% 0% 0% 0% 0% 0% 0% 0% 0% 0% 0% 0	SAIDI       SAIFI         235.67       1.28         57.64%       61.54%         0%       0%         2.20%       2.33%         2.20%       2.33%         0%       0%         0%<	SAIDI         SAIFI         SAIDI           235.67         1.28         225.48           57.64%         61.54%         75.05%           0%         0%         0%           2.20%         2.33%         0%           0%         0%         0%           0%

Excluding Major Event Day Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: BECKNERVILLE

Substation	BECKNERVILLE
Substation Location	
Circuit	244 Grimes Mill
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	336
Date of last Trim	

	Totals		5 Year Average		
	SAIDI	SAIFI	SAIDI	SAIFI	
Total Minutes/Frequency	235.67	1.28	225.48	1.11	
Weather	3.72%	3.96%	5.80%	5.03%	
510 Wind, Not Trees	1.25%	0.93%	0.67%	0.28%	
520 Ice, Sleet, Frost, Not Trees	0%	0%	0.64%	1.33%	
530 Flood	0%	0%	0%	0%	
590 Weather, Other	0.15%	0.23%	0%	0%	

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: BLEVINS VALLEY

1/1/2024 12:00:00 AM to 12/31/2024 11:59:59 PM

Substation	BLEVINS VALLEY
Substation Location	Blevins Valley Rd
Circuit	124 Hwy 36
Circuit Location	Old State Rd and Hwy 36
Total Circuit Length (miles)	41.85
Average Member Count	439
Date of last Trim	TRIM 2023 HERBICIDE 2024

	Totals		5 Year 1	verage
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	1100s.75	2.61	267.83	1.78
Animals	0.32%	2.35%	3.56%	7.08%
600 Small Animal/Bird	0.08%	0.52%	1.37%	2.57%
601 Squirrel	0.19%	1.48%	1.74%	3.59%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0.02%	0.05%
620 Animal damage-gnawing or boring	0.05%	0.35%	0%	0%
690 Animal, Other	0%	0%	0.44%	0.87%
Equipment or Installation/Design	0.16%	1.13%	<b>1</b> . 45%	2.41%
300 Material or Equipment Fault/Failure	0%	0%	1.07%	1.41%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0.16%	1.13%	0.36%	0.95%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0.02%	0.05%
Maintenance	98.49%	95.29%	85.49%	87.15%
400 Decay/Age of Material/Equipment	0.01%	0.09%	0.36%	0.41%
410 Corrosion/Abrasion of	0%	0%	1.56%	4.62%
Material/Equipment				
420 Tree Growth	0.12%	0.70%	0.69%	1.59%
430 Tree failure from overhang or deadtr	98.35%	94.51%	81.75%	79.66%
440 Trees With Ice/Snow	0%	0 %	1.10%	0.72%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%
				Printed 3/31/2025 10

Printed 3/31/2025 10:10:18 AM

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: BLEVINS VALLEY

Substation	BLEVINS VALLEY
Substation Location	
Circuit	124 Hwy 36
Circuit Location	_
Total Circuit Length (miles)	
Average Member Count	439
Date of last Trim	

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	1100s.75	2.61	267.83	1.78
Maintenance	98.49%	95.29%	85.49%	87.15%
490 Maintenance, Other	0%	0%	0.03%	0.15%
Other	0.13%	0.35%	0 %	0%
800 Other	0.13%	0.35%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0 %	0%	0 %
100 Construction	0 %	0 %	0%	0%
110 Maintenance	0%	0%	0%	0 %
190 Other Planned	0%	0%	0%	0%
Power Supply	0 %	0%	0 %	0%
000 Power Supply	0%	0%	0%	0%
Public	0.02%	0.17%	0.16%	0.33%
700 Customer-Caused	0%	0%	0.00%	0.03%
710 Motor Vehicle	0%	0%	0.16%	0.31%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0.02%	0.17%	0%	0%
Unknown	0.10%	0.52%	0.71%	<b>1</b> . 21%
999 Cause Unknown	0.10%	0.52%	0.71%	<b>1</b> .21%
Weather	0.77%	0.17%	8.64%	<b>1</b> .82%
500 Lightning	0%	0%	0.08%	0.15%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: BLEVINS VALLEY

Substation Substation Location	BLEVINS VALLEY
Circuit	124 Hwy 36
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	439
Date of last Trim	

	Totals		5 Year Average		
	SAIDI	SAIFI	SAIDI	SAIFI	
Total <u>Minutes/Frequency</u>	1,005.75	2.61	267.83	1.78	_
Weather	0.77%	0.17%	8.64%	<b>1</b> . 82%	
510 Wind, Not Trees	0%	0%	2.90%	0.31%	
520 Ice, Sleet, Frost, Not Trees	0%	0%	5.66%	1.36%	
530 Flood	0%	0%	0%	0%	
590 Weather, Other	0.77%	0.17%	0%	0%	

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: BOWEN

Substation	BOWEN
Substation Location	Campton Rd
Circuit	114 Natural Bridge
Circuit Location	Campton Rd and Natural Bridge Rd
Total Circuit Length (miles)	47.42
Average Member Count	484
Date of last Trim	TRIM 2021 AND HERBICIDE 2024

	Tot	als	5 Year A	verage
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	459.45	2.05	359.61	1.41
Animals	0.11%	0.40%	3.62%	17.09%
600 Small Animal/Bird	0.02%	0.10%	0.10%	0.31%
601 Squirrel	0.08%	0.30%	3.52%	16.78%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0 %	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	2.54%	4.23%	1.18%	3.10%
300 Material or Equipment Fault/Failure	2.00%	2.92%	0.89%	2.30%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0.53%	1.31%	0.29%	0.80%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	51.50%	79.84%	87.54%	69.88%
400 Decay/Age of Material/Equipment	0.22%	0.30%	0.13%	1.35%
410 Corrosion/Abrasion of	0%	0%	0.05%	0.15%
Material/Equipment				0 100
420 Tree Growth	8.02%	7.16%	0.36%	2.12%
430 Tree failure from overhang or deadtr	43.18%	71.98%	77.29%	62.69%
440 Trees With Ice/Snow	0%	0%	9.68%	3.44%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: BOWEN

	_, ,
Substation	BOWEN
Substation Location	
Circuit	114 Natural Bridge
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	484
Date of last Trim	

	Totals		5 Year A	5 Year Average		
	SAIDI	SAIFI	SAIDI	SAIFI		
Total Minutes/Frequency	<u>4</u> 59.45	2.05	359.61	1.41		
Maintenance	51.50%	79.84%	87.54%	69.88%		
490 Maintenance, Other	0.08%	0.40%	0%	0%		
Other	0.44%	1.92%	0%	0%		
800 Other	0.44%	1. 92%	0%	0%		
801 Supervisor Review	0%	0%	0%	0%		
Planned Outage	0%	0%	0%	0%		
100 Construction	0%	0%	0%	0%		
110 Maintenance	0%	0%	0%	0 %		
190 Other Planned	0%	0%	0%	0%		
Power Supply	0%	0%	0%	0%		
000 Power Supply	0%	0%	0%	0%		
Public	0.09%	0.30%	1.81%	4.30%		
700 Customer-Caused	0.03%	0.10%	0.02%	0.09%		
710 Motor Vehicle	0.02%	0.10%	1. 25%	2.92%		
720 Aircraft	0%	0%	0%	0%		
730 Fire	0%	0%	0%	0%		
740 Public Cuts Tree	0%	0%	0.54%	1.29%		
750 Vandalism	0%	0%	0%	0 %		
760 Switching error or caused by construe	0%	0%	0%	0%		
790 Public, Other	0.04%	0.10%	0%	0%		
Unknown	1.56%	0.71%	1.23%	2.24%		
999 Cause Unknown	1.56%	0.71%	1. 23%	2.24%		
Weather	43.77%	12.60%	4.63%	3.38%		
500 Lightning	0.02%	0.91%	0.98%	<b>1.</b> 84%		

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: BOWEN

Substation	BOWEN
Substation Location	
Circuit	114 Natural <u>Bridge</u>
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	484
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	459.45	2.05	359.61	1.41
Weather	43.77%	12.60%	4.63%	3.38%
510 Wind, Not Trees	0%	0%	0.06%	0.18%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	3.59%	<b>1.</b> 35%
590 Weather, Other	43.75%	11.69%	0%	0%

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: BOWEN

Substation	BOWEN
Substation Location	Campton Rd
Circuit	124 Cow Creek
Circuit Location	Cow Creek Rd
Total Circuit Length (miles)	11.3
Average Member Count	42
Date of last Trim	TRIM 2019 HERBICIDE 2024

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	715.50	1.81	518.48	3.69
Animals	0%	0%	1.57%	3.98%
600 Small Animal/Bird	0%	0%	0%	0%
601 Squirrel	0%	0%	1. 57%	3.98%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	0%	0%	0.58%	0.40%
300 Material or Equipment Fault/Failure	0%	0%	0.55%	0.32%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or InadequateClearance	0%	0%	0%	0%
340 Overload	0%	0%	0.03%	0.08%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	100%	100%	68.86%	61.83%
400 Decay/Age of Material/Equipment	0%	0%	0.51%	0.08%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	0%	0%	6.20%	4.86%
430 Tree failure from overhang or deadtr	99.73%	96.05%	56.36%	52.51%
440 Trees With Ice/Snow	0%	0%	5.79%	4.38%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%
				Printed 3/31/2025

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: BOWEN

Substation BOWEN

Substation Location
Circuit Circuit Location
Total Circuit Length (miles)
Average Member Count

1/1/2024 12:00:00 AM to 12/31/2024 11:59:59 PM

BOWEN

124 Cow Creek

Creek

42

Date of last Trim

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	715.50	1.81	518.48	3 <u>.69</u>
Maintenance	100%	100%	68.86%	61.83%
490 Maintenance, Other	0.27%	3.95%	0%	0%
Other	0%	0%	0 %	0 %
800 Other	0%	0%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0%	0 %
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0 %	0%	0%
000 Power Supply	0%	0%	0%	0%
Public	0%	0 %	0.48%	1.04%
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	0%	0%	0.48%	1.04%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0 %	0%	0%	0%
750 Vandalism	0%	0%	0 %	0%
760 Switching error or caused by construe	0%	0%	0 %	0%
790 Public, Other	0%	0%	0%	0%
Unknown	0%	0%	8.33%	20.32%
999 Cause Unknown	0%	0%	8.33%	20.32%
Weather	0 %	0 %	20.17%	12.43%
500 Lightning	0%	0%	5.07%	4.38%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: BOWEN

Substation	BOWEN
Substation	DOWEN
Substation Location	
Circuit	124 Cow Creek
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	42
Date of last Trim	

	Totals		5 YearAverage	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	715.50	1.81	<u>518.48 3</u>	<u>.69</u>
Weather	0%	0%	20.17%	12.43%
510 Wind, Not Trees	0%	0%	2.14%	<b>1</b> . 91%
520 Ice, Sleet, Frost, Not Trees	0%	0%	12.97%	6.14%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: BOWEN

Substation	BOWEN
Substation Location	Campton Rd
Circuit	134 Bowen
Circuit Location	Campton Rd
Total Circuit Length (miles)	39.02
Average Member Count	427
Date of last Trim	TRIM 2019 HERBICIDE 2024

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	470.84	2.10	169.22	1.39
Animals	0.48%	1.11%	4.27%	16.15%
600 Small Animal/Bird	0.36%	0.33%	0.23%	0.75%
601 Squirrel	0.12%	0.78%	4.04%	15.41%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	3.03%	6.01%	2.99%	3.62%
300 Material or Equipment Fault/Failure	3.03%	6.01%	1.79%	2.64%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	1.20%	0.98%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	63.82%	69.71%	72.07%	61.60%
400 Decay/Age of Material/Equipment	0.74%	7.02%	0.21%	0.47%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	0%	0%	5.10%	7.59%
430 Tree failure from overhang or deadtr	63.03%	62.58%	50.99%	42.36%
440 Trees With Ice/Snow	0%	0%	15.76%	11.18%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: BOWEN

Substation	BOWEN
Substation Location	
Circuit	134 Bowen
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	427
Date of last Trim	

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
	470.84	2.10	169.22	1.39
Maintenance	63.82%	69.71%	72.07%	61.60%
490 Maintenance, Other	0.06%	0.11%	0%	0%
Other	0%	0%	0%	0%
800 Other	0%	0%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0%	0 %
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0 %
Power Supply	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
Public	0.21%	1.89%	5.84%	4.40%
700 Customer-Caused	0.03%	0.11%	0%	0%
710 Motor Vehicle	0%	0%	3.63%	2.51%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0.18%	1.78%	2.21%	1.90%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0 %
Unknown	<b>1.</b> 48%	7.35%	0.54%	1.29%
999 Cause Unknown	1.48%	7.35%	0.54%	1.29%
Weather	30.97%	13.92%	14.29%	12.94%
500 Lightning	0.40%	1.00%	7.11%	8.03%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: BOWEN

Substation	BOWEN
Substation Location	
Circuit	134 Bowen
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	427
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	470.84	2.10	169.22	1.39
Weather	30.97%	13.92%	14.29%	12.94%
510 Wind, Not Trees	30.58%	12.92%	0.09%	0.03%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	7.09%	4.88%
590 Weather, Other	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: CAVE RUN

Substation	CAVE RUN
Substation Location	Hwy 801
Circuit	124 <u>Curry Flats-Airport</u>
Circuit Location	Hwy 801
Total Circuit Length (miles)	4.3
Average Member Count	87
Date of last Trim	TRIM 2022

	To	tals	5 Year A	5 Year Average		
	SAIDI	SAIFI	SAIDI	SAIFI		
Total	<u>6</u> 50.53	.89	11208.28	.00		
inutes/Frequency						
Animals		0%	0 %	0%		
600 Small Animal/Bird		0%	0%	0%		
601 Squirrel		0%	0%	0%		
610 Large Animal		0%	0%	0%		
611 Cattle Rubbing		0%	0%	0%		
612 Animal/Large Bird		0 %	0%	0%		
620 Animal damage-gnawing or boring		0%	0%	0%		
690 Animal, Other		0%	0%	0%		
quipment or Installation/Design		0%	0%	0%		
300 Material or Equipment Fault/Failure		0%	0%	0%		
310 Installation Fault		0%	0%	0%		
320 Conductor Sag or Inadequate Clearance		0%	0%	0%		
340 Overload		0%	0%	0%		
350 Miscoordination of Protection Devices		0%	0%	0% Printed 3/31		
				111111111111111111111111111111111111111		

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

360 Other Equipment Installation/Design	CAVE RUN	0%	0%
Maintenance 98.36% 400 Decay/Age of Material/Equipment	98.70% 0%	100.00% 0%	100% 0%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%
420 Tree Growth	0%	0%	0%
430 Tree failure from overhang or deadtr	98.70%	100.00%	100%
440 Trees With Ice/Snow	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%
460 Moisture	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: CAVE RUN

	_, _,
Substation	CAVE RUN
Substation Location	
Circuit	124 <u>Curry Flats-Airport</u>
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	87
Date of last Trim	

	Totals		5 Year <i>P</i>	5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI	
Total Minutes/Frequency	<u>6</u> 50.53	.89	11208.28	. 00	
Maintenance	98.36%	98.70%	100.00%	100%	
490 Maintenance, Other	0%	0%	0%	0%	
Other	0%	0%	0%	0%	
800 Other	0%	0%	0%	0%	
801 Supervisor Review	0%	0%	0%	0%	
Planned Outage	0 %	0 %	0%	0%	
100 Construction	0%	0%	0%	0%	
110 Maintenance	0%	0%	0%	0%	
190 Other Planned	0%	0%	0%	0%	
Power Supply	0%	0%	0%	0%	
000 Power Supply	0%	0 %	0%	0 %	
Public	<b>1</b> . 64%	<b>1</b> . 3 0%	0%	0 %	
700 Customer-Caused	1.64%	<b>1</b> . 30%	0%	0%	
710 Motor Vehicle	0%	0%	0%	0%	
720 Aircraft	0%	0%	0%	0%	
730 Fire	0%	0 %	0%	0%	
740 Public Cuts Tree	0%	0%	0%	0%	
750 Vandalism	0%	0%	0%	0%	
760 Switching error or caused by construe	0 %	0%	0%	0%	
790 Public, Other	0%	0 %	0%	0%	
Unknown	0%	0%	0%	0%	
999 Cause Unknown	0 %	0 %	0%	0%	
Weather	0 %	0%	0%	0%	
500 Lightning	0%	0%	0%	0%	

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: CAVE RUN

Substation	CAVE RUN
Substation Location	
Circuit	124 Curry Flats-Airport
Circuit Location	<del></del>
Total Circuit Length (miles)	
Average Member Count	87
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	650.53	. 89	1£208.28	.00
Weather	0%	0%	0 %	0 %
510 Wind, Not Trees	0%	0%	0%	0%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: CLAY CITY

Substation CLAY CITY
Substation Location Lofty Heights Rd
Circuit 114 Hwy 89 Snow Creek
Circuit Location Snow Creek Rd and Hwy 89

Total Circuit Length (miles) 28.95

Average Member Count 479

Date of last Trim TRIM 2020

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	166.62	1.42	123.24	1.08
Animals	1.10%	3.39%	<b>1.</b> 91%	3.96%
600 Small Animal/Bird	0.48%	1.62%	0.40%	0.70%
601 Squirrel	0.62%	1.77%	1.51%	3.26%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	64.82%	71.28%	2.01%	2.91%
300 Material or Equipment Fault/Failure	64.82%	71.28%	1.54%	1.90%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.48%	1.01%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	23.82%	18.26%	89.02%	85.25%
400 Decay/Age of Material/Equipment	0%	0%	0.69%	1.32%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	0%	0%	0.46%	0.50%
430 Tree failure from overhang or deadtr	23.82%	18.26%	87.81%	83.35%
440 Trees With Ice/Snow	0%	0%	0.06%	0.08%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: CLAY CITY

Substation	CLAY CITY
Substation Location	
Circuit	114 Hwy 89 Snow Creek
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	479
Date of last Trim	

	Totals		5 Year A	5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI	
Total Minutes/Frequency	166.62	1.42	123.24	1.08	
Maintenance	23.82%	18.26%	89.02%	85.25%	
490 Maintenance, Other	0%	0%	0%	0%	
Other	0.68%	<b>1.</b> 33%	0.08%	0.04%	
800 Other	0.68%	1. 33%	0.08%	0.04%	
801 Supervisor Review	0%	0 %	0%	0%	
Planned Outage	0%	0 %	0%	0%	
100 Construction	0%	0 %	0%	0%	
110 Maintenance	0%	0%	0%	0%	
190 Other Planned	0%	0%	0%	0%	
Power Supply	0%	0 %	0%	0%	
000 Power Supply	0%	0%	0%	0%	
Public	2.21%	<b>1</b> . 47%	2.85%	3.14%	
700 Customer-Caused	0%	0%	0%	0%	
710 Motor Vehicle	0%	0%	<b>1</b> . 75%	2.83%	
720 Aircraft	0%	0%	0%	0%	
730 Fire	0%	0%	0.01%	0.04%	
740 Public Cuts Tree	0%	0%	<b>1</b> . 09%	0.27%	
750 Vandalism	0%	0%	0%	0%	
760 Switching error or caused by construe	0%	0%	0%	0%	
790 Public, Other	2.21%	1.47%	0%	0%	
Unknown	0.74%	<b>1</b> . 47%	0.66%	<b>1.</b> 55%	
999 Cause Unknown	0.74%	1.47%	0.66%	1.55%	
Weather	6.63%	2.80%	3.46%	3.14%	
500 Lightning	0.20%	0.44%	2.87%	2.87%	

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: CLAY CITY

	1/1/2024 12:00:00 AM to 12/31/2024 11:59:59 PM
Substation	CLAY CITY
Substation Location	
Circuit	114 Hwy 89 Snow Creek
Circuit Location	
Total Circuit Length (miles)	
Average Member Count Date of last Trim	479

	Total		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	166,62	1.42	123.24	1.08
Weather	6.63%	2.80%	3.46%	3.14%
510 Wind, Not Trees	<b>1</b> . 82%	0.29%	0.59%	0.27%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	4.61%	2.06%	0%	0%

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: CLAY CITY

1/1/2024 12:00:00 AM to 12/31/2024 11:59:59 PM

Substation	CLAY CITY
Substation Location	Lofty Heights Rd
Circuit	124 Virden <u>Ridge-Hwy</u> 15
Circuit Location	Virden Ridge and Hwy 15
Total Circuit Length (miles)	42.84
Average Member Count	702
Date of last Trim	TRIM 2020

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	338.27	1.23	<u>76.</u> 38	. 74
Animals	0.99%	6.03%	2.16%	3.93%
600 Small Animal/Bird	0.02%	0.12%	0.67%	1.13%
601 Squirrel	0.80%	5.10%	1.49%	2.80%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0.18%	0.81%	0%	0%
Equipment or Installation/Design	7.12%	9.27%	15.55%	19.28%
300 Material or Equipment Fault/Failure	2.53%	2.67%	15.51%	19.24%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	4.44%	6.14%	0%	0%
340 Overload	0.15%	0.46%	0.04%	0.04%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	58.03%	54.69%	65.08%	63.40%
400 Decay/Age of Material/Equipment	1.46%	7.42%	1.73%	1.44%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	1.62%	3.94%	15.04%	10.24%
430 Tree failure from overhang or deadtr	54.70%	42.18%	48.05%	51.32%
440 Trees With Ice/Snow	0%	0%	0.04%	0.08%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%
				Printed 3/31/

Printed 3/31/2025 10:16:22 AM

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: CLAY CITY

Substation	CLAY CITY
Substation Location	
Circuit	124 Virden <u>Ridge-Hwy</u> 15
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	702
Date of last Trim	

	Totals		5 Year A	5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI	
Total Minutes/Frequency	338.27	1.23	76.38	. 74	
Maintenance	58.03%	54.69%	65.08%	63.40%	
490 Maintenance, Other	0.25%	1.16%	0.22%	0.31%	
Other	0.02%	0.23%	0 %	0 %	
800 Other	0.02%	0.23%	0%	0%	
801 Supervisor Review	0%	0%	0%	0%	
Planned Outage	0%	0%	0%	0 %	
100 Construction	0%	0%	0%	0%	
110 Maintenance	0%	0%	0%	0%	
190 Other Planned	0%	0%	0%	0%	
Power Supply	0%	0%	0%	0%	
000 Power Supply	0%	0%	0%	0%	
Public	2.26%	4.87%	7.20%	3.04%	
700 Customer-Caused	0.02%	0.35%	0.19%	0.27%	
710 Motor Vehicle	0.05%	0.35%	6.84%	2.61%	
720 Aircraft	0%	0%	0%	0%	
730 Fire	0.01%	0.12%	0.16%	0.12%	
740 Public Cuts Tree	0.60%	0.58%	0%	0%	
750 Vandalism	0%	0%	0%	0 %	
760 Switching error or caused by construe	0%	0%	0%	0%	
790 Public, Other	1.57%	3.48%	0.02%	0.04%	
Unknown	9.02%	9.04%	2.80%	4.87%	
999 Cause Unknown	9.02%	9.04%	2.80%	4.87%	
Weather	22.56%	15.87%	7.20%	5.49%	
500 Lightning	0%	0%	7.05%	5.10%	

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: CLAY CITY

Substation Substation Location	CLAY CITY
	104 11 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
Circuit	124 Virden <u>Ridge-Hwy</u> 15
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	702
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI SAIFI	
Total Minutes/Frequency	338.27	1.23	76.38 .74	
Weather	22.56%	15.87%	7.20% 5.49%	
510 Wind, Not Trees	0%	0%	0.05% 0.16%	
520 Ice, Sleet, Frost, Not Trees	0%	0%	0.09% 0.23%	
530 Flood	0%	0%	0% 0%	
590 Weather, Other	22.56%	15.87%	0% 0%	

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: FRENCHBURG

Substation	FRENCHBURG
Substation Location	Hwy 36
Circuit	114 Hwy 460 West
Circuit Location	Hwy 36 and Hwy 460 West
Total Circuit Length (miles)	24.76
Average Member Count	462
Date of last Trim	TRIM 2017 and 2024

	Totals		<b>5 Year Average</b>	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	373.38	2 . 57	83.74	.89
Animals	0.41%	<b>1.</b> 52%	0.29%	0.88%
600 Small Animal/Bird	0%	0%	0.18%	0.34%
601 Squirrel	0.41%	<b>1.</b> 52%	0.12%	0.54%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0 %
Equipment or Installation/Design	0%	0%	3.02%	4.57%
300 Material or Equipment Fault/Failure	0%	0%	2.27%	3.60%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.74%	0.97%
350 Miscoordination of Protection Devices	0%	0%	0 %	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	87.89%	58.05%	72.14%	79.90%
400 Decay/Age of Material/Equipment	0%	0%	0.16%	0.10%
410 Corrosion/Abrasion of	0%	0%	0%	0%
Material/Equipment				
420 Tree Growth	<b>1</b> . 32%	0.93%	0.45%	0.92%
430 Tree failure from overhang or deadtr	86.57%	57.12%	68.40%	76.45%
440 Trees With Ice/Snow	0%	0%	1.60%	0.92%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%
				Printed 3/31/20

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: FRENCHBURG

Substation	FRENCHBURG
Substation Location	
Circuit	114 Hwy 460 West
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	462
Date of last Trim	

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	373.38	2.57	83.74	. 8 <u>9</u>
Maintenance	87.89%	58.05%	72.14%	79.90%
490 Maintenance, Other	0%	0%	<b>1</b> . 54%	<b>1</b> .51%
Other	0.14%	0.34%	0.82%	0.34%
800 Other	0.14%	0.34%	0.82%	0.34%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0%	0%
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0 %	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
Public	10.62%	39.17%	20.59%	10.90%
700 Customer-Caused	2.22%	3.29%	0.06%	0.10%
710 Motor Vehicle	8.40%	35.89%	20.53%	10.80%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
Unknown	0.85%	0.84%	0.73%	<b>1</b> . 46%
999 Cause Unknown	0.85%	0.84%	0.73%	1.46%
Weather	0.10%	0.08%	2.41%	1.95%
500 Lightning	0%	0%	0.81%	0.97%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: FRENCHBURG

	2, 2, 2021 22100100 1 00 22, 02, 2021 2210010
Substation	FRENCHBURG
Substation Location	
Circuit	114 Hwy 460 West
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	462
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	373.38	2.57	83.74	<u>.</u> 89
Weather	0.10%	0.08%	2.41%	1.95%
510 Wind, Not Trees	0%	0%	1.60%	0.97%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0.10%	0.08%	0%	0%

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: FRENCHBURG

Substation	FRENCHBURG
Substation Location	Hwy 36
Circuit	124 <u>Hwy 36-Hwy</u> 211
Circuit Location	Hwy 36 and Hwy 211
Total Circuit Length (miles)	45.26
Average Member Count	447
Date of last Trim	TRIM 2018 and 2024

	Totals	5 Year Average		
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	486.70	3.53	233.48	2.16
Animals	0.58%	1.46%	0.46%	0.99%
600 Small Animal/Bird	0.31%	0.76%	0.13%	0.21%
601 Squirrel	0.27%	0.70%	0.30%	0.74%
610 Large Animal	0%	0%	0.03%	0.04%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0 %	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	0.30%	0.57%	1.92%	1.54%
300 Material or Equipment Fault/Failure	0.30%	0.57%	1.87%	1.50%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.04%	0.04%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	85.44%	73.37%	82.99%	76.66%
400 Decay/Age of Material/Equipment	0%	0%	8.73%	9.96%
410 Corrosion/Abrasion of Material/Equipment	0%	0 %	1.14%	0.91%
420 Tree Growth	0.20%	0.13%	2.00%	2.14%
430 Tree failure from overhang or deadtr	85.24%	73.24%	69.85%	62.41%
440 Trees With Ice/Snow	0%	0%	1. 24%	<b>1.</b> 21%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: FRENCHBURG

	_, _,
Substation	FRENCHBURG
Substation Location	
Circuit	124 <u>Hwy 36-Hwy</u> 211
Circuit Location	· <del>-</del> -
Total Circuit Length (miles)	
Average Member Count	447
Date of last Trim	

	Tot	als	5 Year A	verage
	SAIDI	SAIFI	SAIDI	SAIFI
Total <u>Minutes/Frequent</u>	486.70	3, 53	233.48	2.16
Maintenance	85.44%	73.37%	82.99%	76.66%
490 Maintenance, Other	0%	0%	0.03%	0.04%
Other	0%	0%	0%	0%
800 Other	0%	0%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	O %	0 %	0%	0 %
100 Construction	0 %	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0%	0%	0 %
000 Power Supply	0%	0%	0%	0%
Public	0.04%	0.13%	6.29%	9.58%
700 Customer-Caused	0%	0%	0.04%	0.11%
710 Motor Vehicle	0%	0%	6.00%	9.03%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0.25%	0.44%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0.04%	0.13%	0%	0%
Unknown	9.92%	18.01%	6.18%	9.62%
999 Cause Unknown	9.92%	18.01%	6.18%	9.62%
Weather	3.72%	6.47%	2.16%	1.61%
500 Lightning	0.11%	0.19%	1.94%	1.01%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: FRENCHBURG

Substation Substation Location	FRENCHBURG
Circuit Circuit Location	124 <u>Нwy</u> 36-Нw <u>y</u> 211
Total Circuit Length (miles)	
Average Member Count Date of last Trim	447

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<u>Total Minutes/Frequency</u>	486.70	3.53	<u>233.48</u>	2.16
Weather	3.72%	6.47%	2.16%	1.61%
510 Wind, Not Trees	0.09%	0.19%	0.21%	0.55%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0.01%	0.04%
530 Flood	0%	0%	0%	0%
590 Weather, Other	3.52%	6.09%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: GRAYSON METER PT

### Substation: GRAYSON METER PT.

Substation	GRAYSON METER PT
Substation Location	Hwy 801 and Hwy 1274
Circuit	Grayson Meter PT
Circuit Location	Hwy 801 and Hwy 1274
Total Circuit Length (miles)	2.9
Average Member Count	14
Date of last Trim	TRIM 2024

	Totals		5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	557.14	3.64	270.11	.78
Animals	5.96%	11.76%	0 %	0%
600 Small Animal/Bird	0%	0%	0%	0%
601 Squirrel	5.96%	11.76%	0%	0%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	0 %	0%	0%	0%
300 Material or Equipment Fault/Failure	0%	0%	0%	0%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	50.58%	29.41%	98.14%	94.12%
400 Decay/Age of Material/Equipment	0%	0%	0%	0%
410 Corrosion/Abrasion of	0%	0%	0%	0 %
Material/Equipment				
420 Tree Growth	0%	0%	35.91%	25.49%
430 Tree failure from overhang or deadtr	50.58%	29.41%	32.77%	60.78%
440 Trees With Ice/Snow	0%	0%	29.46%	7.84%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: GRAYSON METER PT

Substation	GRAYSON METER PT
Substation Location	
Circuit	Grayson Meter PT
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	14
Date of last Trim	

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	557.14	3.64	270.11	. 78
Maintenance	50.58%	29.41%	98.14%	94.12%
490 Maintenance, Other	0%	0%	0%	0 %
Other	0%	0%	0%	0%
800 Other	0%	0 %	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0%	0%
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0%	0%	0 %
000 Power Supply	0%	0%	0%	0%
Public	0%	0%	<b>1</b> . 86%	5.88%
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	0%	0%	1.86%	5.88%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
Unknown	43.46%	58.82%	0%	0%
999 Cause Unknown	43.46%	58.82%	0%	0%
Weather	0%	0%	0 %	0 %
500 Lightning	0%	0%	0%	0%

Excluding Major Event Day outages, Power Supply Outages, Planned Outages, Customer Responsible outages and Momentary outages

### Substation: GRAYSON METER PT

Substation	GRAYSON METER PT
Substation Location	
Circuit	Grayson Meter PT
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	14
Date of last Trim	

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	557.14	3.64	270.11	. 78
Weather	0%	0%	0%	0%
510 Wind, Not Trees	0%	0%	0%	0%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: HARDWICKS CREEK

HARDWICKS CREEK
Hardwicks Creek Rd
114 Little Hardwicks Crk
Little Hardwicks Creek Rd
35.09
421
TRIM 2024 HERBICIDE 2024

	Totals		5 Year 2	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	187.05	. 96	166.50	1.28
Animals	3.21%	10.17%	2.98%	6.54%
600 Small Animal/Bird	0.46%	1.99%	0.83%	1.38%
601 Squirrel	2.33%	6.45%	2.12%	5.12%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0.03%	0.04%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0.42%	1.74%	0%	0%
Equipment or Installation/Design	0%	0%	6.06%	6.09%
300 Material or Equipment Fault/Failure	0%	0%	6.06%	6.09%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or InadequateClearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0 %
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	92.53%	80.89%	34.25%	41.07%
400 Decay/Age of Material/Equipment	0%	0%	1.10%	0.90%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	0.83%	1.99%	1.67%	1.35%
430 Tree failure from overhang or deadtr	91.70%	78.91%	30.30%	38.45%
440 Trees With Ice/Snow	0%	0%	1.18%	0.37%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%
				Printed 3/31/

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: HARDWICK\$ CREEK

Substation	HARDWICKS CREEK
Substation Location	
Circuit	114 Little Hardwicks Crk
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	421
Date of last Trim	

	Tot	als	5 Year A	verage
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	187_05	.96	166.50	1.28
Maintenance	92.53%	80.89%	34.25%	41.07%
490 Maintenance, Other	0%	0%	0%	0%
Other	0.08%	0.50%	0.05%	0.15%
800 Other	0.08%	0.50%	0.05%	0.15%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0 %	0 %	0 %	0%
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0 %	0 %	0 %	0%
000 Power Supply	0%	0%	0%	0%
Public	0.54%	1.99%	35.77%	31.99%
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	0.48%	1.74%	32.01%	16.18%
720 Aircraft	0%	0%	0%	0%
730 Fire	0.06%	0.25%	0%	0%
740 Public Cuts Tree	0%	0%	3.76%	15.81%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
Unknown	1.77%	1.74%	0.82%	1.72%
999 Cause Unknown	1.77%	1.74%	0.82%	1.72%
Weather	1.87%	4.71%	20.08%	12.44%
500 Lightning	0%	0%	0.85%	0.86%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: HARDWICKS CREEK

	_, _,
Substation	HARDWICKS CREEK
Substation Location	
Circuit	114 Little Hardwicks Crk
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	421
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	187.05	. 96	166.50	1.28
Weather	<b>1</b> . 87%	4.71%	20.08%	12.44%
510 Wind, Not Trees	0.02%	0.25%	0.33%	0.07%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	18.90%	11.51%
590 Weather, Other	<b>1.</b> 84%	4.47%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: HARDWICKS CREEK

Substation	HARDWICKS CREEK
Substation Location	Hardwicks Creek Rd
Circuit	124 Hardwicks Crk to PKWY
Circuit Location	Hardwicks Creek Rd
Total Circuit Length (miles	4.58
Average Member Count	43
Date of last Trim	TRIM 2024 HERBICIDE 2024

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	165.42	1.12	40.53	. 54
Animals	5.97%	8.33%	3.04%	7.21%
600 Small Animal/Bird	0%	0%	0.25%	0.90%
601 Squirrel	5.97%	8.33%	2.79%	6.31%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	· 0%	0%	3.11%	2.70%
300 Material or Equipment Fault/Failure	0%	0%	3.11%	2.70%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	0%	0%	53.11%	48.65%
400 Decay/Age of Material/Equipment	0 %	0%	0%	0%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	0%	0%	0%	0%
430 Tree failure from overhang or deadtr	0%	0%	48.35%	43.24%
440 Trees With Ice/Snow	0%	0%	4.77%	5.41%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%
				Printed 3/31/

Excluding Major Event Day outages, Power Supply outages, Planned outages, Customer Responsible outages and Momentary Outages

### Substation: HARDWICK\$ CREEK

Substation	HARDWICKS CREEK
Substation Location	
Circuit	124 Hardwicks Crk to PKWY
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	43
Date of last Trim	

	Tot	als	5 Year A	verage	
	SAIDI	SAIFI	SAIDI	SAIFI	
Total Minutes/Frequency	165.42	1.12	40.53	. 54	
Maintenance	0%	0%	53.11%	48.65%	
490 Maintenance, Other	0%	0%	0%	0%	
Other	94.03%	91.67%	0%	0%	
800 Other	0%	0%	0%	0%	
801 Supervisor Review	94.03%	91.67%	0%	0%	
Planned outage	0%	0%	0%	0%	
100 Construction	0%	0%	0%	0%	
110 Maintenance	0%	0 %	0%	0%	
190 Other Planned	0%	0%	0%	0%	
Power Supply	0%	0%	0%	0%	
000 Power Supply	0%	0%	0%	0%	
Public	0%	0%	0%	0%	
700 Customer-Caused	0%	0%	0%	0%	
710 Motor Vehicle	0%	0%	0%	0%	
720 Aircraft	0%	0%	0%	0%	
730 Fire	0%	0%	0%	0%	
740 Public Cuts Tree	0%	0%	0%	0%	
750 Vandalism	0%	0%	0%	0%	
760 Switching error or caused by construe	0%	0%	0%	0%	
790 Public, Other	0%	0%	0%	0%	
Unknown	0%	0%	0.48%	0.90%	
999 Cause Unknown	0%	0%	0.48%	0.90%	
Weather	0%	0%	40.26%	40.54%	
500 Lightning	0%	0%	0%	0%	

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: HARDWICKS CREEK

1/1/2024 12:00:00 AM to 12/31/2024 11:59:59 PM

Substation	HARDWICKS CREEK
Substation Location	
Circuit	124 Hardwicks Crk to PKWY
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	43
Date of last Trim	

Y ...

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	165.42	1.12	40.53	.54
Weather	0%	0%	40.26%	40.54%
510 Wind, Not Trees	0%	0%	26.79%	37.84%
520 Ice, Sleet, Frost, Not Trees	0%	0%	13.47%	2.70%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: HIGH ROCK

Substation HIGH ROCK
Substation Location South Fork
Circuit 104 High Rock
Circuit Location South Fork and High Rock
Total Circuit Length (miles) 37.1

Average Member Count 205
Date of last Trim TRIM 2019 HERBICIDE 2022 and 2024

	Tot	als	5 Year A	verage
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	534.55	2.49	521.44	2.94
Animals	0.38%	0.98%	0.86%	2.23%
600 Small Animal/Bird	0.07%	0.20%	0%	0%
601 Squirrel	0.31%	0.78%	0.86%	2.23%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	5.52%	2.74%	1.36%	<b>1.</b> 37%
300 Material or Equipment Fault/Failure	0.31%	0.59%	1. 23%	1.25%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0 %
340 Overload	0%	0%	0.12%	0.12%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	5.21%	2.15%	0%	0%
Maintenance	44.41%	53.42%	91.34%	89.32%
400 Decay/Age of Material/Equipment	0.18%	0.39%	0%	0%
410 Corrosion/Abrasion of	0%	0%	0%	0%
Material/Equipment				
420 Tree Growth	0%	0%	4.35%	7.36%
430 Tree failure from overhang or deadtr	44.23%	53.03%	72.81%	76.13%
440 Trees With Ice/Snow	0%	0%	14.18%	5.83%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: HIGH ROCK

Substation	HIGH ROCK
Substation Location	
Circuit	104 High Rock
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	205
Date of last Trim	

	Totals		5 Year A	5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI	
Total Minutes/Frequency	534.55	2.49	521.44	2.94	
Maintenance	44.41%	53.42%	91.34%	89.32%	
490 Maintenance, Other	0%	0%	0%	0%	
Other	0%	0%	0%	0 %	
800 Other	0 %	0%	0%	0%	
801 Supervisor Review	0%	0%	0%	0%	
Planned outage	0%	0%	0%	0%	
100 Construction	0%	0%	0%	0%	
110 Maintenance	0%	0%	0%	0%	
190 Other Planned	0%	0%	0%	0%	
Power Supply	0%	0%	0%	0%	
000 Power Supply	0 %	0%	0%	0%	
Public	0.23%	0.78%	0.15%	0.16%	
700 Customer-Caused	0.00%	0.20%	0%	0%	
710 Motor Vehicle	0%	0 %	0.09%	0.08%	
720 Aircraft	0%	0 응	0%	0%	
730 Fire	0%	0%	0%	0%	
740 Public Cuts Tree	0%	0%	0%	0%	
750 Vandalism	0%	0%	0%	0%	
760 Switching error or caused by construe	0%	0%	0%	0 %	
790 Public, Other	0.22%	0.59%	0.05%	0.08%	
Unknown	45.07%	40.51%	1.54%	2.19%	
999 Cause Unknown	45.07%	40.51%	<b>1.</b> 54%	2.19%	
Weather	4.39%	1.57%	4.76%	4.74%	
500 Lightning	0%	0%	4.63%	4.58%	

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: HIGH ROCK

Substation Substation Location	HIGH ROCK
Circuit	104 High Rock
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	205
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	534.55	2.49	521.44	2.94
Weather	4.39%	<b>1</b> . 57%	4.76%	4.74%
510 Wind, Not Trees	0%	0%	0%	0%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	4.39%	<b>1.</b> 57%	0.13%	0.16%

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: HINKSTON

Substation	HINKSTON
Substation Location	Hinkston Pike
Circuit	214 Langley-Hwy Garage
Circuit Location	Midland Trail
Total Circuit Length (miles)	1.89
Average Member Count	29
Date of last Trim	Trim 2021 HERBICIDE 2022

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	57.28	.14	14.36	.09
Animals	0%	0%	13.28%	25%
600 Small Animal/Bird	0%	0%	0%	0%
601 Squirrel	0%	0%	7.26%	8.33%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	5.62%	8.33%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0.40%	8.33%
Equipment or Installation/Design	0%	0%	45.67%	33.33%
300 Material or Equipment Fault/Failure	0%	0%	45.67%	33.33%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	48.71%	25%	2.74%	8.33%
400 Decay/Age of Material/Equipment	0%	0%	0%	0%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	0%	0%	0%	0%
430 Tree failure from overhang or deadtr	48.71%	25%	2.74%	8.33%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%
				Printed 3/31/

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: HINKSTON

Substation	HINKSTON
Substation Location	
Circuit	214 Langley-Hwy Garage
Circuit Location	, – – – –
Total Circuit Length (miles)	
Average Member Count	29
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	57.28	.14	14.36	.09
Maintenance	48.71%	25%	2.74%	8.33%
490 Maintenance, Other	0%	0%	0%	0%
Other	0%	0%	0 %	0 %
800 Other	0%	0%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0 %	0 %
100 Construction	0%	0%	0%	0 %
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0 %	0%	0 %
000 Power Supply	0%	0%	0%	0%
Public	51.29%	75%	0%	0%
700 Customer-Caused	51.29%	75%	0%	0%
710 Motor Vehicle	0%	0%	0%	0%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
Unknown	0 %	0%	19.70%	16.67%
999 Cause Unknown	0%	0%	19.70%	16.67%
Weather	0 %	0%	18.61%	16.67%
500 Lightning	0%	0%	18.61%	16.67%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: HINKSTON

Substation	HINKSTON
Substation Location	
Circuit	214 <u>Langley-Hwy Garage</u>
Circuit Location	·
Total Circuit Length (miles)	
Average Member Count	29
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	57.28	. 14	14.36	.09
Weather	0%	0%	18.61%	16.67%
510 Wind, Not Trees	0%	0%	0%	0%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: HINKSTON

Substation	HINKSTON
Substation Location	Hinkston Pike
Circuit	234 Hwy 60-Mtn View
Circuit Location	Hwy 60 and Stepstone
Total Circuit Length (miles)	19.19
Average Member Count	188
Date of last Trim	TRIM 2023

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	366.86	1.61	206.70	1.22
Animals	0.77%	<b>1.</b> 66%	6.08%	6.49%
600 Small Animal/Bird	0.77%	1.66%	0.55%	0.90%
601 Squirrel	0%	0%	0.16%	0.09%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	5.37%	5.50%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	61.00%	61.92%	36.76%	38.47%
300 Material or Equipment Fault/Failure	61.00%	61.92%	36.70%	38.29%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or InadequateClearance	0%	0%	0%	0%
340 Overload	0%	0%	0.06%	0.18%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	19.00%	18.54%	13.11%	20.81%
400 Decay/Age of Material/Equipment	19.00%	18.54%	0.19%	0.27%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	4.08%	6.67%
420 Tree Growth	0%	0%	0.05%	0.09%
430 Tree failure from overhang or deadtr	0%	0%	8.79%	13.78%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%
				Printed 3/31/2

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: HINKSTON

Substation	HINKSTON
Substation Location	
Circuit	234 Hwy 60-Mtn View
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	188
Date of last Trim	

	Totals		5 Year A	5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI	
Total Minutes/Freguency	366.86	1.61	206.70	1.22	
Maintenance	19.00%	18.54%	13.11%	20.81%	
490 Maintenance, Other	0%	0%	0%	0%	
Other	6.54%	4.30%	0 %	0 %	
800 Other	6.54%	4.30%	0%	0%	
801 Supervisor Review	0%	0%	0%	0%	
Planned Outage	0%	0 %	0%	0 응	
100 Construction	0%	0%	0%	0%	
110 Maintenance	0%	0%	0%	0%	
190 Other Planned	0%	0%	0%	0 %	
Power Supply	0%	0%	0%	0 %	
000 Power Supply	0%	0%	0%	0%	
Public	2.02%	3.97%	0.08%	0.45%	
700 Customer-Caused	0%	0%	0.02%	0.09%	
710 Motor Vehicle	2.02%	3.97%	0.06%	0.36%	
720 Aircraft	0%	0%	0%	0%	
730 Fire	0%	0%	0%	0 %	
740 Public Cuts Tree	0%	0%	0%	0%	
750 Vandalism	0%	0%	0%	0 %	
760 Switching error or caused by construe	0%	0%	0%	0%	
790 Public, Other	0%	0%	0%	0%	
Unknown	0.15%	0.33%	42.37%	31.26%	
999 Cause Unknown	0.15%	0.33%	42.37%	31.26%	
Weather	10.51%	9.27%	1.60%	2.52%	
500 Lightning	10.51%	9.27%	1.60%	2.52%	

Excluding Major Event Day outages, Power Supply outages, Planned outages, Customer Responsible outages and Momentary outages

#### Substation: HINKSTON

Substation	HINKSTON
Substation Location	
Circuit	234 Hwy 60-Mtn View
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	188
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	366.86	1.61	206.70	1.22
Weather	10.51%	9.27%	<b>1</b> . 60%	2.52%
510 Wind, Not Trees	0%	0%	0%	0%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: HOPE

Substation	HOPE
Substation Location	Hope Means Rd
Circuit	224 Stull town Rd
Circuit Location	Stull town Rd
Total Circuit Length (miles)	13.44
Average Member Count	135
Date of last Trim	TRIM 2020

	Totals		5 Year A	5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI	
Total Minutes/Frequency	134.53	. 59	81.88	. 71	
Animals	3.50%	15.19%	0.35%	0.61%	
600 Small Animal/Bird	0%	0%	0.27%	0.41%	
601 Squirrel	3.50%	15.19%	0.09%	0.20%	
610 Large Animal	0%	0%	0%	0%	
611 Cattle Rubbing	0%	0%	0%	0 %	
612 Animal/Large Bird	0%	0%	0%	0%	
620 Animal damage-gnawing or boring	0%	0%	0%	0%	
690 Animal, Other	0%	0%	0%	0%	
Equipment or Installation/Design	0%	0%	23.75%	25.77%	
300 Material or Equipment Fault/Failure	0%	0%	23.75%	25.77%	
310 Installation Fault	0%	0%	0%	0 %	
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0 %	
340 Overload	0%	0%	0%	0 %	
350 Miscoordination of Protection Devices	0%	0%	0%	0 %	
360 Other Equipment Installation/Design	0%	0%	0%	0 %	
Maintenance	1.42%	7.59%	56.25%	45.19%	
400 Decay/Age of Material/Equipment	0%	0%	15.97%	16.56%	
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%	
420 Tree Growth	0.11%	1.27%	2.08%	3.27%	
430 Tree failure from overhang or deadtr	1. 30%	6.33%	35.83%	25.15%	
440 Trees With Ice/Snow	0%	0%	2.37%	0.20%	
450 Contamination (leakage/external)	0%	0%	0%	0%	
460 Moisture	0%	0%	0%	0%	

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: HOPE

Substation	HOPE
Substation Location	
Circuit	224 Stull town Rd
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	135
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes_	134.53	. 59	81.88	. 71
Frequency				
Maintenance	<b>1.</b> 42%	7.59%	56.25%	45.19%
490 Maintenance, Other	0%	0%	0%	0 %
Other	0%	0%	0%	0 %
800 Other	0 %	0%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0%	0 %
100 Construction	0%	0%	0%	0 %
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
Public	87.69%	74.68%	6.92%	12.27%
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	87.69%	74.68%	6.92%	12.27%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0 %	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0 %	0%
Unknown	0%	0%	0%	0%
999 Cause Unknown	0%	0%	0%	0%
Weather	7.39%	2.53%	12.72%	16.16%
500 Lightning	0%	0%	11.70%	15.54%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: HOPE

	, , , , , , , , , , , , , , , , , , , ,
Substation	HOPE
Substation Location	
Circuit	224 Stull town Rd
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	135
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequer	ncy 134.53	. 59	81.88	. 71
Weather	7.39%	2.53%	12.72%	16.16%
510 Wind, Not Trees	7.39%	2.53%	1.03%	0.61%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0 %

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: HOPE

Substation	HOPE
Substation Location	Hope Means Rd
Circuit	234 Hope Means Rd
Circuit Location	Hope Means Rd
Total Circuit Length (miles)	31.10
Average Member Count	351
Date of last Trim	TRIM 2020

	Totals		5 Year 1	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	123.91	2.46	273.41	1.97
Animals	4.85%	1.51%	0.37%	0.88%
600 Small Animal/Bird	4.85%	1.51%	0.23%	0.54%
601 Squirrel	0%	0%	0.14%	0.34%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	5.83%	1.97%	0.72%	1.46%
300 Material or Equipment Fault/Failure	5.83%	1.97%	0.63%	1.20%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.09%	0.26%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
[aintenance	88.79%	95.59%	88.10%	85.39%
400 Decay/Age of Material/Equipment	0.56%	0.70%	0.65%	1.06%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0.04%	0.03%
420 Tree Growth	0.29%	0.35%	0.12%	0.26%
430 Tree failure from overhang or deadtr	87.95%	94.55%	86.27%	73.97%
440 Trees With Ice/Snow	0%	0%	1.02%	10.07%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%
				Printed 3/31/2025 10:2

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: HOPE

Substation	HOPE
Substation Location	
Circuit	234 Hope Means Rd
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	351
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	123.91	2.46	273.41	1.97
Maintenance	88.79%	95.59%	88.10%	85.39%
490 Maintenance, Other	0%	0%	0%	0%
Other	0.05%	0.12%	0.03%	0.06%
800 Other	0.05%	0.12%	0.03%	0.06%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0%	0%
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0 %	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
Public	0.10%	0.23%	7.84%	7.22%
700 Customer-Caused	0.10%	0.23%	0.04%	0.17%
710 Motor Vehicle	0%	0%	3.69%	3.37%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	4.11%	3.68%
750 Vandalism	0 %	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0 %	0%	0%	0%
Unknown	0.02%	0.12%	0.48%	0.60%
999 Cause Unknown	0.02%	0.12%	0.48%	0.60%
Weather	0.36%	0.46%	2.46%	4.39%
500 Lightning	0.36%	0.46%	2.37%	4.25%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: HOPE

Substation	HOPE
Substation Location	
Circuit	234 Hope Means Rd
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	351
Date of last Trim	

	Tot	als	5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	123.91	2.46	<u>273.41</u>	1.97
Weather	0.36%	0.46%	2.46%	4.39%
510 Wind, Not Trees	0%	0%	0.02%	0.06%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0.06%	0.09%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

Excluding Major Event Day outages, Power Supply outages, Planned outages, Customer Responsible outages and Momentary Outages

### Substation: HUNT

Substation	HUNT
Substation Location	Muddy Creek Rd
Circuit	214 College Hill
Circuit Location	College Hill
Total Circuit Length (miles)	76.70
Average Member Count	716
Date of last Trim	TRIM 2024 HERBICIDE 2024 Helicopter 2022_

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	556.62		597.41	2.78
Animals	0.38%	0.63%	13.07%	14.84%
600 Small Animal/Bird	0.12%	0.11%	0.24%	0.53%
601 Squirrel	0.10%	0.22%	12.82%	14.29%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0.01%	0.02%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0.17%	0.30%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	29.64%	32.19%	9.18%	13.76%
300 Material or Equipment Fault/Failure	29.64%	32.19%	9.12%	13.66%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.07%	0.10%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	22.92%	23.57%	39.63%	43.86%
400 Decay/Age of Material/Equipment	0.03%	0.04%	1.84%	1.91%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0.04%	0.09%
420 Tree Growth	5.62%	8.92%	2.86%	4.94%
430 Tree failure from overhang or deadtr	17.26%	14.57%	33.72%	36.07%
440 Trees With Ice/Snow	0%	0%	1.11%	0.75%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0.08%	0.08%

\_)

## PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: HUNT

Substation	HUNT
Substation Location	
Circuit	214 College Hill
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	716
Date of last Trim	

	Tot	als	5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	556 62	3.76	<u>597.41</u>	2.78
Maintenance	22.92%	23.57%	39.63%	43.86%
490 Maintenance, Other	0.02%	0.04%	0.00%	0.01%
Other	1.94%	1.64%	0.02%	0.05%
800 Other	1.94%	1.64%	0%	0%
801 Supervisor Review	0%	0%	0.02%	0.05%
Planned Outage	0%	0%	0 %	0 %
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0 %	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0 %	0%	0 %
000 Power Supply	0%	0%	0%	0%
Public	3.61%	1.67%	7.65%	7.76%
700 Customer-Caused	0%	0%	0.01%	0.03%
710 Motor Vehicle	0.04%	0.11%	5.62%	5.44%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	2.02%	2.29%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	3.57%	1.56%	0%	0%
Unknown	26.51%	27.36%	1.84%	3.04%
999 Cause Unknown	26.51%	27.36%	1.84%	3.04%
Weather	14.99%	12.94%	28.61%	16.69%
500 Lightning	10.34%	11.75%	27.38%	16.17%

Excluding Major Event Day outages, Power Supply outages, Planned outages, Customer Responsible outages and Momentary outages

### Substation: HUNT

1/1/2024 12:00:00 AM to 12/31/2024 11:59:59 PM	1/	1/2024	12:00:00	AM	to	12/31/2024	11:59:59	PM
--	----	--------	----------	----	----	------------	----------	----

Substation	HUNT
Substation Location	
Circuit	214 College Hill
Circuit Location	_
Total Circuit Length (miles)	
Average Member Count	716
Date of last Trim	

	Totals			5 Year Average		
	SAIDI	SAIFI	SAIDI	SAIFI		
Total Minutes/Frequency	_556.62	3.76	597.41	2.78_		
Weather	14.99%	12.94%	28.61%	16.69%		
510 Wind, Not Trees	0%	0%	0%	0%		
520 Ice, Sleet, Frost, Not Trees	0%	0%	1.23%	0.52%		
530 Flood	0 %	0%	0%	0%		
590 Weather, Other	4.65%	1.19%	0%	0%		

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: HUNT

1/1/2024	12:00:00	AM	to	12/31/2024	11:59:59	PM
----------	----------	----	----	------------	----------	----

Substation	HUNT
Substation Location	Muddy Creek Rd
Circuit	224 Bybee-Elkin Station
Circuit Location	Muddy creek and Bybee
Total Circuit Length (miles)	34.76
Average Member Count	268
Date of last Trim	TRIM 2024 and hotspot

	Tot	als	5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	957.45	5.31	264.67	1.47
Animals	0.25%	0.42%	1.02%	2.47%
600 Small Animal/Bird	0%	0%	0.26%	0.67%
601 Squirrel	0.25%	0.42%	0.74%	<b>1</b> . 75%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0.02%	0.05%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0 %
Equipment or Installation/Design	10.03%	20.80%	3.66%	4.73%
300 Material or Equipment Fault/Failure	10.03%	20.80%	3.12%	4.11%
310 Installation Fault	0%	0 %	0%	0 %
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.52%	0.57%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0.02%	0.05%
Maintenance	85.04%	68.10%	77.52%	78.15%
400 Decay/Age of Material/Equipment	8.10%	6.32%	5.68%	12.39%
410 Corrosion/Abrasion of	0%	0%	3.70%	2.16%
Material/Equipment				
420 Tree Growth	<b>1</b> . 97%	3.23%	17.44%	10.28%
430 Tree failure from overhang or deadtr	74.97%	58.54%	50.62%	53.16%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: HUNT

Substation	HUNT
Substation Location	
Circuit	224 Bybee-Elkin Station
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	268
Date of last Trim	

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	957.45	5.31	264.67	1.47
Maintenance	85.04%	68.10%	77.52%	78.15%
490 Maintenance, Other	0%	0%	0.05%	0.10%
Other	3.90%	9.35%	0%	0%
800 Other	3.90%	9.35%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0%	0 %
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0 %	0%	0 %
000 Power Supply	0%	0%	0%	0%
Public	0%	0 %	2.43%	2.31%
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	0%	0%	2.37%	2.16%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0.05%	0.10%
740 Public Cuts Tree	0%	0%	0.02%	0.05%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
Unknown	0.29%	0.28%	6.88%	5.81%
999 Cause Unknown	0.29%	0.28%	6.88%	5.81%
Weather	0.50%	1.05%	8.48%	6.53%
500 Lightning	0.48%	0.77%	7.38%	6.07%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: HUNT

Substation	HUNT
Substation Location	
Circuit	224 Bybee-Elkin Station
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	268
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI_
Total Minutes/Frequency	957.45	5.31	264.67	1.47
Weather	0.50%	1.05%	8.48%	6.53%
510 Wind, Not Trees	0.03%	0.28%	0.65%	0.15%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0.45%	0.31%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: HUNT

Substation	HUNT
Substation Location	Muddy Creek Rd
Circuit	244 Red River
Circuit Location	Red River Rd
Total Circuit Length (miles)	25.08
Average Member Count	124
Date of last Trim	TRIM 2019

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total <u>Minutes/Frequency</u>	190. <u>0</u> 8	2.01	465.59	1. 9 <u>5</u>
Animals	0.59%	0.80%	0.16%	0.40%
600 Small Animal/Bird	0.22%	0.40%	0.04%	0.08%
601 Squirrel	0.37%	0.40%	0.11%	0.32%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	0.88%	0.40%	3.69%	6.13%
300 Material or Equipment Fault/Failure	0.88%	0.40%	2.35%	4.54%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	1.04%	0.80%
340 Overload	0%	0%	0.30%	0.80%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	79.94%	55.02%	84.48%	77.23%
400 Decay/Age of Material/Equipment	73.90%	52.21%	0%	0%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	<b>1</b> . 01%	1.11%
420 Tree Growth	3.40%	0.80%	12.96%	13.85%
430 Tree failure from overhang or deadtr	2.63%	2.01%	66.57%	58.44%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	3.94%	3.82%
				Printed 3/31/2025 1

Excluding Major Event Day outages, Power Supply outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: HUNT

	1/1/2024 12:00:00 AM to 12/31/2024 11:59:59 PM
Substation	HUNT
Substation Location	
Circuit	244 Red River
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	124

Date of last Trim

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	190.08	2.01	465.59	1.95
Maintenance	79.94%	55.02%	84.48%	77.23%
490 Maintenance, Other	0%	0%	0%	0%
Other	0%	0%	0.96%	1.11%
800 Other	0%	0%	0.96%	1.11%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0 %	0%	0%
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
Public	1.06%	1.20%	4.22%	5.49%
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	1.06%	1.20%	0.04%	0.08%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	4.18%	5.41%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
Unknown	0%	0%	3.04%	4.06%
999 Cause Unknown	0%	0%	3.04%	4.06%
Weather	17.54%	42.57%	3.46%	5.57%
500 Lightning	0.93%	0.80%	3.40%	5.49%

Excluding Major Event Day outages, Power Supply outages, Planned outages, Customer Responsible Outages and Momentary Outages

### Substation: HUNT

Substation	HUNT
Substation Location	
Circuit	244 Red River
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	124
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	190.08	2.01	465.59	1.95
Weather	17.54%	42.57%	3.46%	5.57%
510 Wind, Not Trees	16.61%	41.77%	0%	0%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0.05%	0.08%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: JEFFERSONVILLE

1/1/2024 12:00:00 AM to 12/31/2024 11:59:59 PM

Substation

JEFFERSONVILLE

Substation Location	Hwy 1050
Circuit	234 Pine Hill-Cream Alley
Circuit Location	Pine Hill and Cream Alley
Total Circuit Length (miles)	66.99
Average Member Count	976
Date of last Trim	TRIM 2020

PSC Report

е

Excluding Major Event Day Outages, Power Supply Outages, Planted Catages, Customer Responsible Outages and Momentages Substatismid IJEFFERROWVILLE SAIDI SAIFI Total Minu es/Firequency00:00954, 260 12/31/7624 11:59:59 PM 87.50 95 Animals 1.00% 1.75% 1.68% 2.27% 600 Small Animal/Bird 0.85% 1.34% 0.63% 0.90% 601 Squirrel 0.15% 0.40% 1.00% 1.32% 610 Large Animal () 음 0 응 0 응 0 응 611 Cattle Rubbing 0 응 0 응 0.04% 0.04% 612 Animal/Large Bird O 음 () 응 0 응 620 Animal damage-gnawing or boring 0 응 0 응 0 응 0 응 690 Animal, Other () 음 () 음 0 응 () 음 Equipment or Installation/Design 1.04% 1.48% 11.77% 21.90% 300 Material or Equipment Fault/Failure 1.04% 1.48% 11.59% 21.70% 310 Installation Fault () 음 () 음 () 음 () 음 320 Conductor Sag or Inadequate Clearance 0 응 0 응 0 응 0 응 340 Overload 0 응 () 음 0.18% 0.20% 350 Miscoordination of Protection Devices N % ) 음 0 응 360 Other Equipment Installation/Design 0 응 ) 음 () 음 0 응 Maintenance 63.73% 49.73% 57.76% 52.17% 400 Decay/Age of Material/Equipment 4.16% 7.128 2.53% 3.06% 410 Corrosion/Abrasion of 0 응 0 응 0.03% 0.02% Material/Equipment 420 Tree Growth 9.14% 1.28% 24.49% 1.03% 430 Tree failure from overhang or deadtr 35.08% 33.47% 41.50% 33.46% 440 Trees With Ice/Snow 0왕 0% 12.66% 14.35% 450 Contamination (leakage/external) 0 응 () 음 0 응 0 응 460 Moisture () 음 0 응 0 응 0 응

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: JEFFERSONVILLE

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	95.26	.76	87.50	. 95
Maintenance	63.73%	49.73%	57.76%	52.17%
490 Maintenance, Other	0%	0%	0%	0%
Other	0%	0 %	0.03%	0.09%
800 Other	0%	0%	0.03%	0.09%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0 %	0 %	0 응
100 Construction	0%	0 %	0%	0 %
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0 %	0 %	0%	0%
000 Power Supply	0%	0%	0%	0%
Public	22.91%	26.88%	9.85%	7.07%
700 Customer-Caused	0.38%	1.08%	0%	0%
710 Motor Vehicle	22.53%	25.81%	9.01%	5.59%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0.73%	1.39%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0.11%	0.09%
Unknown	0.71%	1.88%	11.72%	13.10%
999 Cause Unknown	0.71%	1.88%	11.72%	13.10%
Weather	10.60%	18.28%	7.20%	3.41%
500 Lightning	0.05%	0.13%	2.39%	1.83%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: JEFFERSONVILLE

Substation	JEFFERSONVILLE
Substation Location	
Circuit	234 Pine Hill-Cream Alley
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	976
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	95.26	. 76	87.50	. 95
Weather	10.60%	18.28%	7.20%	3.41%
510 Wind, Not Trees	10.55%	18.15%	1.17%	1.08%
520 Ice, Sleet, Frost, Not Trees	0%	0%	3.63%	0.51%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

Excluding Major Event Day outages, Power Supply outages, Planned outages, Customer Responsible outages and Momentary outages

#### Substation: JEFFERSONVILLE

Substation	JEFFERSONVILLE
Substation Location	Hwy 1050
Circuit	244 Means
Circuit Location	Hwy 1050 and Hwy 460
Total Circuit Length (miles)	46.54
Average Member Count	592
Date of last Trim	TRIM 2020

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
	183.39	1.10	139.50	1.10
Animals	0.28%	1. 23%	1.21%	1.90%
600 Small Animal/Bird	0.10%	0.61%	0.68%	0.87%
601 Squirrel	0.11%	0.31%	0.49%	0.87%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0.07%	0.31%	0.04%	0.16%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	0.61%	0.61%	4.65%	4.65%
300 Material or Equipment Fault/Failure	0.61%	0.61%	4.61%	4.56%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.03%	0.09%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	62.95%	62.06%	60.30%	58.75%
400 Decay/Age of Material/Equipment	0%	0%	2.20%	2.09%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0.02%	0.06%
420 Tree Growth	0.29%	<b>1.</b> 54%	0.50%	0.56%
430 Tree failure from overhang or deadtr	62.65%	60.52%	36.56%	34.88%
440 Trees With Ice/Snow	0%	0%	7.20%	2.90%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0 %
				Drinted 3/31/

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: JEFFERSONVILLE

Substation	JEFFERSONVILLE
Substation Location	
Circuit	244 Means
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	592
Date of last Trim	

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	183.39	1.10	139.50	1.10
Maintenance	62.95%	62.06%	60.30%	58.75%
490 Maintenance, Other	0%	0%	13.81%	18.25%
Other	2.70%	2.76%	0 %	0 %
800 Other	2.70%	2.76%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0 %	0 %	0 %	0 응
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0 %	0%	0%
Power Supply	0 %	0 %	0%	0 %
000 Power Supply	0 %	0 %	0%	0%
Public	22.28%	22.73%	10.91%	18.56%
700 Customer-Caused	0.29%	0.92%	0%	0%
710 Motor Vehicle	12.71%	18.28%	10.75%	18.35%
720 Aircraft	0%	0%	0%	0%
730 Fire	9.24%	3.38%	0%	0%
740 Public Cuts Tree	0%	0%	0.16%	0.22%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0.03%	0.15%	0%	0%
Unknown	0.02%	0.31%	6.03%	8.71%
999 Cause Unknown	0.02%	0.31%	6.03%	8.71%
Weather	11.16%	10.29%	16.91%	7.43%
500 Lightning	7.93%	9.98%	0.86%	1.12%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: JEFFERSONVILLE

Substation	JEFFERSONVILLE
Substation Location	
Circuit	244 Means
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	592
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	183.39	1.10	139.50	1.10
Weather	11.16%	10.29%	16.91%	7.43%
510 Wind, Not Trees	3.23%	0.31%	12.36%	3.84%
520 Ice, Sleet, Frost, Not Trees	0%	0%	3.27%	<b>1.</b> 90%
530 Flood	0%	0%	0.41%	0.56%
590 Weather, Other	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: MILLER HUNT

Substation	MILLER HUNT
Substation Location	Miller Hunt Rd
Circuit	224 Miller Hunt Rd
Circuit Location	Miller Hunt and Hwy 15
Total Circuit Length (miles)	36.48
Average Member Count	361
Date of last Trim	TRIM 2019

	Totals		5 Year A	verage
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	412.80	2.01	86.74	. 91
Animals	3.27%	15.19%	2.98%	3.21%
600 Small Animal/Bird	2.71%	13.95%	2.54%	2.81%
601 Squirrel	0.16%	0.41%	0.37%	0.33%
610 Large Animal	0.14%	0.41%	0%	0%
611 Cattle Rubbing	0%	0%	0.07%	0.07%
612 Animal/Large Bird	0.25%	0.41%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	53.09%	50%	20.47%	15.76%
300 Material or Equipment Fault/Failure	0.19%	0.28%	15.55%	11.42%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	4.92%	4.34%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	52.91%	49.72%	0%	0%
Maintenance	9.69%	13.95%	35.67%	22.78%
400 Decay/Age of Material/Equipment	0%	0%	0.66%	0.47%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	0.78%	1. 66%	9.80%	6.68%
430 Tree failure from overhang or deadtr	8.91%	12.29%	25.03%	15.23%
440 Trees With Ice/Snow	0%	0%	0.14%	0.20%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: MILLER HUNT

Substation	MILLER HUNT
Substation Location	
Circuit	224 Miller Hunt Rd
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	361
Date of last Trim	

	Totals		5 Year A	5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI	
Total Minutes/Frequency	412.80	2.01	86.74	. 91	
Maintenance	9.69%	13.95%	35.67%	22.78%	
490 Maintenance, Other	0%	0%	0.04%	0.20%	
Other	0.01%	0.41%	0.03%	0.07%	
800 Other	0.01%	0.41%	0.03%	0.07%	
801 Supervisor Review	0%	0%	0%	0%	
Planned Outage	0%	0 %	0%	0 %	
100 Construction	0%	0%	0%	0%	
110 Maintenance	0%	0%	0%	0%	
190 Other Planned	0%	0%	0%	0 %	
Power Supply	0%	0%	0%	0%	
000 Power Supply	0 %	0 %	0%	0%	
Public	0.42%	0.97%	6.46%	6.95%	
700 Customer-Caused	0%	0%	0.09%	0.07%	
710 Motor Vehicle	0.42%	0.97%	0.05%	0.13%	
720 Aircraft	0%	0%	0%	0%	
730 Fire	0%	0%	0%	0%	
740 Public Cuts Tree	0%	0%	6.33%	6.75%	
750 Vandalism	0%	0%	0%	0%	
760 Switching error or caused by construe	0%	0%	0%	0%	
790 Public, Other	0%	0%	0%	0%	
Unknown	4.83%	8.15%	4.33%	3.81%	
999 Cause Unknown	4.83%	8.15%	4.33%	3.81%	
Weather	28.69%	11.33%	30.06%	47.43%	
500 Lightning	1.09%	3.73%	9.62%	8.15%	

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: MILLER HUNT

	1/1/2024 12:00:00 AM to 12/31/2024 11:59:59 PM
Substation	MILLER HUNT
Substation Location	
Circuit	224 Miller Hunt Rd
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	361

Date of last Trim

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes Frequency	412.80	2.01	86.74	. 91
Weather	28.69%	11.33%	30.06%	47.43%
510 Wind, Not Trees	27.61%	7.60%	0%	0%
520 Ice, Sleet, Frost, Not Trees	0%	0%	20.44%	39.28%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: MILLER HUNT

<u> </u>	, - ,
Substation	MILLER HUNT
Substation Location	Miller Hunt Rd
Circuit	234 Office
Circuit Location	Hwy 15
Total Circuit Length (miles)	9.63
Average Member Count	119
Date of last Trim	TRIM 2019

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	44.34	.82	78.75	. 37
Animals	0%	0 %	61.40%	59.35%
600 Small Animal/Bird	0%	0%	0.16%	0.47%
601 Squirrel	0%	0%	61.24%	58.88%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	4.45%	47.96%	0.76%	2.34%
300 Material or Equipment Fault/Failure	0%	0%	0.76%	2.34%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	4.45%	47.96%	0%	0%
Maintenance	0 %	0%	32.22%	30.84%
400 Decay/Age of Material/Equipment	0%	0%	0.43%	<b>1.</b> 40%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	0%	0%	<b>1</b> . 40%	0.93%
430 Tree failure from overhang or deadtr	0%	0%	30.38%	28.50%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0 %	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%
				Printed 3/31/

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: MILLER HUNT

Substation	MILLER HUNT
Substation Location	
Circuit	234 Office
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	119
Date of last Trim	

	Totals		5 Year A	5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI	
Total Minutes/Frequency	44.34	82	78.75	37_	
Maintenance	0%	0%	32.22%	30.84%	
490 Maintenance, Other	0%	0%	0%	0%	
Other	0%	0%	0%	0 %	
800 Other	0%	0%	0%	0 %	
801 Supervisor Review	0%	0%	0%	0%	
Planned Outage	0%	0%	0%	0%	
100 Construction	0%	0%	0%	0%	
110 Maintenance	0%	0 %	0%	0%	
190 Other Planned	0%	0%	0%	0%	
Power Supply	0%	0 %	0%	0 %	
000 Power Supply	0%	0 %	0%	0%	
Public	0%	0%	0.85%	0.93%	
700 Customer-Caused	0%	0%	0%	0 %	
710 Motor Vehicle	0%	0%	0.85%	0.93%	
720 Aircraft	0%	0%	0%	0%	
730 Fire	0%	0%	0%	0%	
740 Public Cuts Tree	0%	0%	0%	0%	
750 Vandalism	0%	0%	0%	0%	
760 Switching error or caused by construe	0%	0%	0%	0%	
790 Public, Other	0%	0%	0%	0%	
Unknown	26.80%	4.08%	0.05%	<b>1.</b> 40%	
999 Cause Unknown	26.80%	4.08%	0.05%	1.40%	
Weather	68.75%	47.96%	4.72%	5.14%	
500 Lightning	0.74%	1.02%	4.72%	5.14%	

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: MILLER HUNT

Substation	MILLER HUNT
Substation Location	
Circuit	234 Office
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	119
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	44.34	.82	78.75	.37
Weather	68.75%	47.96%	4.72%	5.14%
510 Wind, Not Trees	68.01%	46.94%	0%	0%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: MILLER HUNT

Substation	MILLER HUNT
Substation Location	Miller Hunt Rd
Circuit	244 Hwy 89
Circuit Location	Hwy 89
Total Circuit Length (miles)	22.6
Average Member Count	281
Date of last Trim	TRIM 2019

	Totals		5 Year A	5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI	
<u>Total Minutes/Frequency</u>	99.52	. 51	137.72	91	
Animals	1.97%	6.34%	0.08%	0.24%	
600 Small Animal/Bird	0.79%	1.41%	0.03%	0.08%	
601 Squirrel	1.18%	4.93%	0.05%	0.16%	
610 Large Animal	0%	0%	0%	0%	
611 Cattle Rubbing	0%	0%	0%	0%	
612 Animal/Large Bird	0%	0%	0%	0%	
620 Animal damage-gnawing or boring	0%	0%	0%	0%	
690 Animal, Other	0%	0%	0%	0%	
Equipment or Installation/Design	0.14%	1. 41%	6.92%	7.45%	
300 Material or Equipment Fault/Failure	0%	0 %	6.92%	7.45%	
310 Installation Fault	0%	0%	0%	0%	
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0 %	
340 Overload	0%	0%	0%	0%	
350 Miscoordination of Protection Devices	0%	0%	0%	0%	
360 Other Equipment Installation/Design	0.14%	<b>1.</b> 41%	0%	0%	
Maintenance	19.46%	25.35%	22.73%	23.24%	
400 Decay/Age of Material/Equipment	0%	0%	8.80%	5.71%	
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%	
420 Tree Growth	0%	0%	4.88%	6.03%	
430 Tree failure from overhang or deadtr	19.46%	25.35%	9.06%	11.50%	
440 Trees With Ice/Snow	0%	0%	0%	0%	
450 Contamination (leakage/external)	0%	0%	0%	0 %	
460 Moisture	0%	0%	0%	0 %	
470 Borrower crew cuts tree	0%	0%	0%	0%	

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: MILLER HUNT

Substation	MILLER HUNT
Substation Location	
Circuit	244 Hwy 89
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	281
Date of last Trim	

	Tot	als	5 Year A	verage
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	99.52	51	137.72	91
Maintenance	19.46%	25.35%	22.73%	23.24%
490 Maintenance, Other	0%	0%	0%	0%
Other	0.03%	0.70%	0.05%	0.16%
800 Other	0.03%	0.70%	0.05%	0.16%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0 %	0 %	0 %
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0 %	0%	0 %
000 Power Supply	0%	0%	0%	0 %
Public	0.14%	1.41%	20.62%	16.65%
700 Customer-Caused	0.14%	<b>1</b> . 41%	0%	0%
710 Motor Vehicle	0%	0%	18.79%	14.12%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	1.83%	2.54%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
Unknown	0.48%	3.52%	3.33%	4.04%
999 Cause Unknown	0.48%	3.52%	3.33%	4.04%
Weather	77.79%	61.27%	46.26%	48.22%
500 Lightning	6.24%	16.20%	24.24%	25.22%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: MILLER HUNT

	_, _,
Substation	MILLER HUNT
Substation Location	
Circuit	244 Hwy 89
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	281
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI SAIFI	
Total Minutes/Frequency	99.52	. 51	<u> 137.72 .91</u>	
Weather	77.79%	61.27%	46.26% 48.22%	
510 Wind, Not Trees	71.56%	45.07%	1.09% 3.57%	
520 Ice, Sleet, Frost, Not Trees	0%	0%	20.94% 19.43%	
530 Flood	0%	0%	0% 0%	
590 Weather, Other	0%	0%	0% 0%	

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: MT. STERLING

Substation	MT. STERLING
Substation Location	Hwy 11
Circuit	144 Kiddville
Circuit Location	Kiddville Rd
Total Circuit Length (miles)	60.17
Average Member Count	510
Date of last Trim	TRIM 2019

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	257.20	2.22	225.19	1.34
Animals	7.29%	8.75%	1.13%	2.56%
600 Small Animal/Bird	3.80%	4.33%	0.35%	0.77%
601 Squirrel	3.50%	4.42%	0.69%	1.73%
610 Large Animal	0%	0%	0%	0 %
611 Cattle Rubbing	0%	0%	0.08%	0.03%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0.02%	0.03%
Equipment or Installation/Design	27.41%	24.14%	4.83%	6.79%
300 Material or Equipment Fault/Failure	25.09%	22.46%	3.36%	5.03%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	2.32%	1.68%	1.47%	1.76%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	7.15%	4.24%	79.00%	64.52%
400 Decay/Age of Material/Equipment	0%	0%	12.65%	16.49%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0.15%	0.15%
420 Tree Growth	0%	0%	24.85%	15.98%
430 Tree failure from overhang or deadtr	7.15%	4.24%	41.35%	31.90%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0% Printed 3/31/202

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: MT. STERLING

Substation	MT. STERLING
Substation Location	
Circuit	144 Kiddville
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	510
Date of last Trim	

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	<u>257</u> .20	2.22	225.19	1.34
Maintenance	7.15%	4.24%	79.00%	64.52%
490 Maintenance, Other	0%	0%	0%	0%
Other	4.12%	5.39%	0%	0%
800 Other	4.12%	5.39%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0%	0%
100 Construction	0%	0 %	0%	0 %
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0%	0%	0 %
000 Power Supply	0%	0%	0%	0%
Public	37.55%	45.36%	2.01%	2.02%
700 Customer-Caused	0%	0%	0.03%	0.03%
710 Motor Vehicle	37.55%	45.36%	0.54%	0.21%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0.16%	0.06%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0 %	1. 28%	<b>1</b> . 73%
Unknown	3.99%	3.80%	8.07%	17.47%
999 Cause Unknown	3.99%	3.80%	8.07%	17.47%
Weather	12.50%	8.31%	4.96%	6.64%
500 Lightning	9.92%	7.87%	3.86%	5.77%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: MT. STERLING

Substation	MT. STERLING
Substation Location	
Circuit	144 Kiddville
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	510
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	257.20	2.22	225.19	1.34
Weather	12.50%	8.31%	4.96%	6.64%
510 Wind, Not Trees	2.58%	0.44%	0.87%	0.71%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0.23%	0.15%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: REID VILLAGE

	, ,
Substation	REID VILLAGE
Substation Location	Hwy 60
Circuit	134 <u>Airport-Single</u> Phase
Circuit Location	Airport Rd
Total Circuit Length (miles)	7.15
Average Member Count	84
Date of last Trim	TRIM 2024

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	138.82	1.82	8.00	. 07
Animals	2.85%	2.61%	16.85%	10.34%
600 Small Animal/Bird	2.85%	2.61%	16.85%	10.34%
601 Squirrel	0%	0%	0%	0%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	61.23%	55.56%	0%	0%
300 Material or Equipment Fault/Failure	61.23%	55.56%	0%	0%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	35.92%	41.83%	0%	0%
400 Decay/Age of Material/Equipment	0%	0%	0%	0%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	5.80%	9.15%	0%	0 %
430 Tree failure from overhang or deadtr	27.18%	30.07%	0%	0%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: REID VILLAGE

Substation	REID VILLAGE
Substation Location	
Circuit	134 <u>Airport-Single</u> Phase
Circuit Location	<del></del> ,
Total Circuit Length (miles)	
Average Member Count	8 4
Date of last Trim	

	Totals		<b>5 Year Average</b>	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	138.82	1.82	8.00	. 07
Maintenance	35.92%	41.83%	0%	0%
490 Maintenance, Other	2.95%	2.61%	0%	0%
Other	0%	0%	0%	0%
800 Other	0%	0%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0%	0%
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
Public	0%	0%	16.46%	34.48%
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	0%	0%	16.46%	34.48%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0 %	0%
Unknown	0%	0%	0%	0 %
999 Cause Unknown	0%	0%	0 %	0%
Weather	0%	0%	66.69%	55.17%
500 Lightning	0%	0%	49.31%	48.28%
		= -		

Excluding Major Event Day outages, Power Supply outages, Planned outages, Customer Responsible outages and Momentary outages

#### Substation: REID VILLAGE

Substation	REID VILLAGE
Substation Location	
Circuit	134 <u>Airport-Single</u> Phase
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	84
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	138.82	1.82	8.00	.07
Weather	0 %	0 %	66.69%	55.17%
510 Wind, Not Trees	0%	0%	17.37%	6.90%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: SIDEVIEW

Substation	SIDEVIEW
Substation Location	Donaldson Rd
Circuit	214 Plumlick-Bunker Hill
Circuit Location	Plumlick and Bunker Hill
Total Circuit Length (miles)	61.34
Average Member Count	3 65
Date of last Trim	TRIM 2024

	Totals		5 Year A	5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI	
Total Minutes/Frequency	363.22	3.04	280.37	1.59	
Animals	5.70%	2.43%	2.62%	5.15%	
600 Small Animal/Bird	5.19%	1.71%	1.82%	3.67%	
601 Squirrel	0.27%	0.45%	0.25%	0.49%	
610 Large Animal	0%	0%	0.16%	0.28%	
611 Cattle Rubbing	0.05%	0.09%	0.08%	0.11%	
612 Animal/Large Bird	0.19%	0.18%	0.31%	0.56%	
620 Animal damage-gnawing or boring	0%	0%	0%	0%	
690 Animal, Other	0%	0%	0.01%	0.04%	
Equipment or Installation/Design	5.95%	2.88%	17.00%	13.65%	
300 Material or Equipment Fault/Failure	5.95%	2.88%	16.82%	13.36%	
310 Installation Fault	0%	0%	0%	0%	
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%	
340 Overload	0%	0%	0.19%	0.28%	
350 Miscoordination of Protection Devices	0%	0%	0%	0%	
360 Other Equipment Installation/Design	0%	0%	0%	0%	
Maintenance	57.49%	72.52%	61.01%	63.15%	
400 Decay/Age of Material/Equipment	44.01%	34.68%	0.09%	0.11%	
410 Corrosion/Abrasion of	0%	0%	0.02%	0.04%	
Material/Equipment					
420 Tree Growth	0.33%	0.54%	12.28%	12.62%	
430 Tree failure from overhang or deadtr	8.42%	4.05%	33.49%	24.68%	
440 Trees With Ice/Snow	0%	0%	0.03%	0.04%	
450 Contamination (leakage/external)	0%	0%	0 %	0 %	
460 Moisture	0%	0%	0%	0%	

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: SIDEVIEW

Substation	SIDEVIEW
Substation Location	
Circuit	214 Plumlick-Bunker Hill
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	365
Date of last Trim	

	Tot	als	5 Year A	verage
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	<u>3</u> 63.22	3.04	280.37	1.59
Maintenance	57.49%	72.52%	61.01%	63.15%
490 Maintenance, Other	4.73%	33.24%	14.00%	12.83%
Other	1.82%	6.76%	0.03%	0.04%
800 Other	1.82%	6.76%	0.03%	0.04%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0 %	0 %
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0 %	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
Public	10.26%	5.59%	3.28%	2.72%
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	10.14%	5.41%	0.18%	0.21%
720 Aircraft	0%	0%	0%	0%
730 Fire	0.12%	0.18%	0%	0%
740 Public Cuts Tree	0%	0%	3.01%	2.36%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0.09%	0.14%
Unknown	1.25%	1.80%	2.80%	3.21%
999 Cause Unknown	1. 25%	1. 80%	2.80%	3.21%
Weather	17.54%	8.02%	13.26%	12.09%
500 Lightning	16.09%	7.30%	6.12%	7.55%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

# **Substation: SIDEVIEW**1/1/2024 12:00:00 AM to 12/31/2024 11:59:59 PM

Substation	SIDEVIEW
Substation Location	
Circuit	214 Plumlick-Bunker Hill
Circuit Location	

Total Circuit Length (miles)

Average Member Count

365

Date of last Trim

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	363.22	3.04	280.37	1.59
Weather	17.54%	8.02%	13.26%	12.09%
510 Wind, Not Trees	1.44%	0.72%	0.44%	0.21%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0.11%	0.11%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	6.59%	4.23%

PSC Report

Excluding Major Event Day Outages, Power Supply Cutages, Planned Cutages, Customer Responsible Outages and Momentary Outages

Substation: SIDEVIEW

	1/1/2024 12:00:00 AM to 12/31/2024 11:59:59 PM
Substation	SIDEVIEW
Substation Location	Donaldson Rd
Circuit	
Circuit Location	Judy Pike and Hwy 11
Total Circuit Length (miles)	43.93
Average Member Count	373
Date of last Trim	TRIM 2024 and hotspot

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	310.30	1.71	152.90	. <u>95</u>
Animals	0.19%	0.31%	0.78%	<b>1</b> . 26%
600 Small Animal/Bird	0.19%	0.31%	0.68%	<b>1.</b> 09%
601 Squirrel	0%	0%	0.04%	0.11%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0.06%	0.06%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	0%	0%	35.41%	17.88%
300 Material or Equipment Fault/Failure	0%	0%	35.41%	17.88%
310 Installation Fault	0%	0 %	0%	0%
320 Conductor Sag or InadequateClearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	7.96%	7.70%	50.98%	43.18%
400 Decay/Age of Material/Equipment	0.17%	0.16%	0.78%	0.86%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	0.21%	0.31%	14.89%	13.19%
430 Tree failure from overhang or deadtr	7.58%	7.23%	35.30%	29.13%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%
				Printed 3/31/20

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: SIDEVIEW

Substation	SIDEVIEW
Substation Location	
Circuit	224 Judy
Circuit Location	
otal Circuit Length (miles)	
verage Member Count	373
ate of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	310.30	1.71	152.90	. 95
Maintenance	7.96%	7.70%	50.98%	43.18%
490 Maintenance, Other	0%	0%	0%	0%
Other	0.18%	0.94%	0.01%	0.06%
800 Other	0.18%	0.94%	0.01%	0.06%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0 %	0 %
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0 %	0 %	0 %	0 %
000 Power Supply	0%	0%	0%	0%
Public	0%	0 %	2.36%	9.99%
700 Customer-Caused	0%	0%	0.00%	0.06%
710 Motor Vehicle	0%	0%	2.36%	9.94%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
Unknown	6.60%	58.81%	0.03%	0.11%
999 Cause Unknown	6.60%	58.81%	0.03%	0.11%
Weather	85.07%	32.23%	10.42%	27.53%
500 Lightning	2.89%	2.83%	10.12%	27.36%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: SIDEVIEW

	, , , , , , , , , , , , , , , , , , , ,
Substation	SIDEVIEW
Substation Location	
Circuit	224 Judy
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	373
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	310.30	1.71	152.90	. 95
Weather	85.07%	32.23%	10.42%	27.53%
510 Wind, Not Trees	82.19%	29.40%	0.30%	0.17%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: STANTON

Substation	STANTON
Substation Location	Hall Ln
Circuit	114 Maple St
Circuit Location	Maple St
Total Circuit Length (miles)	8.31
Average Member Count	420
Date of last Trim	TRIM 2024

	<b>Totals</b>		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	66.38	. 42	12.55	.18
Animals	3.22%	14.04%	5.92%	8.76%
600 Small Animal/Bird	1.97%	8.99%	4.97%	7.22%
601 Squirrel	1.25%	5.06%	0.95%	1.55%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	0%	0%	10.02%	18.56%
300 Material or Equipment Fault/Failure	0%	0%	10.02%	18.56%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	3.21%	8.99%	73.97%	63.66%
400 Decay/Age of Material/Equipment	0%	0%	1.99%	4.12%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	0%	0%	1.47%	1.29%
430 Tree failure from overhang or deadtr	3.21%	8.99%	70.38%	57.73%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0 %

Excluding Major Event Day outages, Power Supply outages, Planned Outages, Customer Responsible outages and Momentary Outages

Substation: STANTON

Substation	STANTON
Substation Location	
Circuit	114 Maple St
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	420
Date of last Trim	

Totals		<b>5 Year Average</b>	
SAIDI	SAIFI	SAIDI	SAIFI
66.38	. 42	12.55	. 18
3.21%	8.99%	73.97%	63.66%
0%	0%	0.12%	0.52%
0%	0%	0.12%	0.52%
0%	0%	0.12%	0.52%
0%	0%	0%	0%
0 %	0%	0%	0%
0%	0%	0%	0%
0%	0%	0%	0%
0%	0%	0%	0%
0 %	0%	0%	0%
0 %	0%	0%	0%
92.08%	72.47%	4.03%	0.77%
0 %	0%	4.03%	0.77%
92.08%	72.47%	0%	0%
0%	0%	0%	0%
0%	0%	0%	0%
0 %	0%	0%	0%
0%	0%	0%	0%
0%	0 %	0%	0%
0 %	0%	0%	0%
0.10%	1.12%	3.39%	5.67%
0.10%	1.12%	3.39%	5.67%
<b>1.</b> 38%	3.37%	2.55%	2.06%
1.18%	2.25%	0.71%	1.29%
	SAIDI 66.38  3.21% 0% 0% 0% 0% 0% 0% 0% 0% 0% 0% 0% 0% 0%	SAIDI         SAIFI           66.38         .42           3.21%         8.99%           0%         0%           0	SAIDI         SAIFI         SAIDI           66.38         .42         12.55           3.21%         8.99%         73.97%           0%         0%         0.12%           0%         0%         0.12%           0%         0%         0.12%           0%         0%         0.12%           0%         0%         0.0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%         0%         0%           0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: STANTON

Substation	STANTON
Substation Location	
Circuit	114 Maple St
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	420
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	66.38	.42	12.55	.18
Weather	<b>1.</b> 38%	3.37%	2.55%	2.06%
510 Wind, Not Trees	0%	0%	0.50%	0.52%
520 Ice, Sleet, Frost, Not Trees	0%	0%	<b>1.</b> 34%	0.26%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0.21%	1.12%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: STANTON

Substation	STANTON	
Substation Location	Halls Ln	
Circuit	124 Morris Creek	
Circuit Location	Hwy 213	
Total Circuit Length (m:	iles) 40.13	
Average Member Count	740	
Date of last Trim	TRIM 2024	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	171.93	3.70	159.25	1.53
Animals	1.06%	0.91%	5.90%	14.49%
600 Small Animal/Bird	0.37%	0.22%	0.68%	1.08%
601 Squirrel	0.52%	0.59%	5.22%	13.41%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0.17%	0.11%	0 %	0%
Equipment or Installation/Design	2.32%	1.02%	11.27%	12.67%
300 Material or Equipment Fault/Failure	1.98%	0.73%	11.09%	12.35%
310 Installation Fault	0%	0%	0 응	0%
320 Conductor Sag or Inadequate Clearance	0%	0 %	0 응	0%
340 Overload	0.21%	0.22%	0.17%	0.32%
350 Miscoordination of Protection Devices	0%	0%	0 %	0%
360 Other Equipment Installation/Design	0.12%	0.07%	0 응	0%
Maintenance	39.20%	54.44%	63.73%	55.82%
400 Decay/Age of Material/Equipment	0%	0%	21.23%	11.68%
410 Corrosion/Abrasion of	0%	0%	0.00%	0.02%
Material/Equipment				
420 Tree Growth	2.24%	0.84%	1.73%	2.37%
430 Tree failure from overhang or deadtr	36.96%	53.60%	38.97%	39.17%
440 Trees With Ice/Snow	0%	0%	1.79%	2.57%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%
				Printed 3/31/

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: STANTON

Substation	STANTON
Substation Location	
Circuit	124 Morris Creek
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	740
Date of last Trim	

490 Maintenance, Other       0%       0%       0%         Other       0%       0%       0%         800 Other       0%       0%       0%         801 Supervisor Review       0%       0%       0%         Planned Outage       0%       0%       0%         100 Construction       0%       0%       0%         110 Maintenance       0%       0%       0%         190 Other Planned       0%       0%       0%         Power Supply       0%       0%       0%	
Maintenance         39.20%         54.44%         63.73%         55.43%           490 Maintenance, Other         0%         0%         0%           Other         0%         0%         0%           800 Other         0%         0%         0%           801 Supervisor Review         0%         0%         0%           Planned Outage         0%         0%         0%           100 Construction         0%         0%         0%           110 Maintenance         0%         0%         0%           190 Other Planned         0%         0%         0%           Power Supply         0%         0%         0%	_ 82%
490 Maintenance, Other       0%       0%       0%         Other       0%       0%       0%         800 Other       0%       0%       0%         801 Supervisor Review       0%       0%       0%         Planned Outage       0%       0%       0%         100 Construction       0%       0%       0%         110 Maintenance       0%       0%       0%         190 Other Planned       0%       0%       0%         Power Supply       0%       0%       0%	
Other         0%         0%         0%           800 Other         0%         0%         0%           801 Supervisor Review         0%         0%         0%           Planned Outage         0%         0%         0%           100 Construction         0%         0%         0%           110 Maintenance         0%         0%         0%           190 Other Planned         0%         0%         0%           Power Supply         0%         0%         0%	Nδ
800 Other       0%       0%       0%         801 Supervisor Review       0%       0%       0%         Planned Outage       0%       0%       0%         100 Construction       0%       0%       0%         110 Maintenance       0%       0%       0%         190 Other Planned       0%       0%       0%         Power Supply       0%       0%       0%	0 0
801 Supervisor Review       0%       0%       0%         Planned Outage       0%       0%       0%         100 Construction       0%       0%       0%         110 Maintenance       0%       0%       0%         190 Other Planned       0%       0%       0%         Power Supply       0%       0%       0%	0%
Planned Outage         0%         0%         0%           100 Construction         0%         0%         0%           110 Maintenance         0%         0%         0%           190 Other Planned         0%         0%         0%           Power Supply         0%         0%         0%	0%
100 Construction       0%       0%       0%         110 Maintenance       0%       0%       0%         190 Other Planned       0%       0%       0%         Power Supply       0%       0%       0%	0 %
110 Maintenance       0%       0%       0%         190 Other Planned       0%       0%       0%         Power Supply       0%       0%       0%	0%
190 Other Planned       0%       0%       0%         Power Supply       0%       0%       0%	0%
Power Supply 0% 0% 0%	0%
Toner bupping	0%
	0%
000 Power Supply 0% 0% 0%	0%
<b>Public</b> 0% 0% 1.88% 2.	50%
700 Customer-Caused 0% 0% 0.06% 0.06%	09%
710 Motor Vehicle 0% 0% 0.25% 0	40%
720 Aircraft 0% 0% 0%	0%
730 Fire 0% 0%	0%
740 Public Cuts Tree 0% 0% 1.57% 2	01%
750 Vandalism 0% 0% 0%	0%
760 Switching error or caused by construe 0% 0% 0%	0%
790 Public, Other 0% 0%	0%
Unknown 50.29% 42.34% 14.19% 11.	09%
999 Cause Unknown 50.29% 42.34% 14.19% 11.	09%
Weather 7.13% 1.28% 3.04% 3.	43%
500 Lightning 1.59% 0.40% 2.51% 3	

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: STANTON

Substation	STANTON
	SIANION
Substation Location	
Circuit	124 Morris Creek
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	740
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	171.93	3.70	159.25	1.53
Weather	7.13%	1.28%	3.04%	3.43%
510 Wind, Not Trees	0.58%	0.11%	0.41%	0.02%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	4.96%	0.77%	0.12%	0.18%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: STANTON

Substation	STANTON
Substation Location	Halls Ln
Circuit	154 Hatton Crk-Furnance
Circuit Location	Hatton Creek and Furnace Rd
Total Circuit Length (miles)	44.47
Average Member Count	555
Date of last Trim	TRIM 2019 HERBICIDE 2024

	Tot	als	5 Year <i>F</i>	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total nutes/Frequency	266.47	3.54	103.21	1.20
Animals	13.92%	29.82%	2.50%	2.80%
600 Small Animal/Bird	0.07%	0.20%	0.13%	0.12%
601 Squirrel	13.85%	29.61%	2.37%	2.68%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0 %
612 Animal/Large Bird	0%	0%	0%	0 %
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	0%	0%	5.17%	7.95%
300 Material or Equipment Fault/Failure	0%	0%	3.96%	5.21%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	1.20%	2.74%
350 Miscoordination of Protection Devices	0%	0%	0%	0 %
360 Other Equipment Installation/Design	0%	0%	0%	0 %
Maintenance	49.47%	16.82%	70.85%	79.38%
400 Decay/Age of Material/Equipment	0.11%	0.10%	16.26%	18.57%
410 Corrosion/Abrasion of	0%	0%	0.10%	0.24%
Material/Equipment 420 Tree Growth	0 %	0%	0.83%	0.76%
	49.36%	16.72%	48.44%	52.68%
430 Tree failure from overhang or deadtr 440 Trees With Ice/Snow	49.30°	10.72° 0%	4.74%	5.51%
450 Contamination (leakage/external)	0 % 0 %	0%	0%	0%
450 Containination (leakage/external) 460 Moisture	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: STANTON

Substation	STANTON
Substation Location	
Circuit	154 Hatton Crk-Furnance
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	555
Date of last Trim	

	Tot	als	5 Year A	verage
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	<u> 26</u> 6.47	_3.54	103.21	1.20
Maintenance	49.47%	16.82%	70.85%	79.38%
490 Maintenance, Other	0%	0%	0%	0%
Other	0.08%	0.15%	0%	0%
800 Other	0.08%	0.15%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0 %	0 %
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0%	0%	0 %
000 Power Supply	0%	0%	0%	0 %
Public	11.94%	23.65%	1.28%	0.61%
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	11.87%	23.60%	1.00%	0.46%
720 Aircraft	0%	0%	0%	0%
730 Fire	0.08%	0.05%	0.17%	0.06%
740 Public Cuts Tree	0%	0%	0.10%	0.09%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0 %
Unknown	20.14%	28.29%	2.11%	2.34%
999 Cause Unknown	20.14%	28.29%	2.11%	2.34%
Weather	4.46%	1.27%	18.10%	6.91%
500 Lightning	0.61%	0.87%	2.46%	1.98%

Excluding Major Event Day outages, Power Supply outages, Planned outages, Customer Responsible outages and Momentary outages

#### Substation: STANTON

Substation	STANTON
Substation Location	
Circuit	154 Hatton Crk-Furnance
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	555
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	266.47	3.54	103.21	1.20
Weather	4.46%	<b>1</b> . 27%	18.10%	6.91%
510 Wind, Not Trees	0.37%	0.10%	0.04%	0.03%
520 Ice, Sleet, Frost, Not Trees	0%	0%	15.28%	3.26%
530 Flood	0%	0%	0.29%	<b>1.</b> 58%
590 Weather, Other	3.48%	0.31%	0.03%	0.06%

PSC Report

Excluding Major Event Day outages, Power Supply outages, Planned outages, Customer Responsible outages and Momentary outages

#### Substation: THREE FORKS

Substation	THREE FORKS
Substation Location	Three Forks Rd
Circuit	214 Madison Village
Circuit Location	Madison Village
Total Circuit Length (miles)	12.39
Average Member Count	464
Date of last Trim	TRIM 2019 HERBICIDE 2024

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	198.43	1.17	154.48	1.41
Animals	<b>1.</b> 48%	4.99%	10.87%	14.99%
600 Small Animal/Bird	0%	0%	10.30%	14.53%
601 Squirrel	1.48%	4.99%	0.58%	0.46%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	3.07%	4.44%	12.06%	14.86%
300 Material or Equipment Fault/Failure	3.07%	4.44%	11.86%	14.65%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.20%	0.21%
350 Miscoordination of Protection Devices	0%	0%	0%	0 %
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	66.50%	73.57%	74.02%	66.90%
400 Decay/Age of Material/Equipment	0.62%	1.48%	20.36%	14.83%
410 Corrosion/Abrasion of	0%	0%	0%	0%
Material/Equipment				
420 Tree Growth	9.97%	11.46%	2.61%	2.51%
430 Tree failure from overhang or deadtr	55.91%	60.63%	50.66%	49.28%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0 %	0%	0.30%	0.06%
470 Borrower crew cuts tree	0%	0%	0%	0%
				Printed 3/31/2

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: THREE FORKS

Substation	THREE FORKS
Substation Location	
Circuit	214 Madison Village
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	464
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	198.43	1.17	154.48	1.41
Maintenance	66.50%	73.57%	74.02%	66.90%
490 Maintenance, Other	0%	0%	0.08%	0.21%
Other	0.29%	0.74%	0.02%	0.06%
800 Other	0.29%	0.74%	0.02%	0.06%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0%	0 %
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0 %	0%	0%
000 Power Supply	0%	0 %	0%	0%
Public	0.34%	0.55%	0.52%	0.15%
700 Customer-Caused	0.34%	0.55%	0%	0%
710 Motor Vehicle	0%	0%	0.52%	0.15%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
Unknown	1.62%	3.33%	1.13%	<b>1.</b> 41%
999 Cause Unknown	1.62%	3.33%	1.13%	1.41%
Weather	26.71%	12.38%	<b>1.</b> 38%	1.62%
500 Lightning	10.18%	10.35%	1.38%	1.62%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: THREE FORKS

	, , , , , , , , , , , , , , , , , , , ,
Substation	THREE FORKS
Substation Location	
Circuit	214 Madison Village
Circuit Location	-
Total Circuit Length (miles)	
Average Member Count	464
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total <u>Minutes/Frequency</u>	198.43	1.17	154.48	1.41
Weather	26.71%	12.38%	<b>1.</b> 38%	1.62%
510 Wind, Not Trees	0.68%	0.37%	0%	0%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	15.85%	1. 66%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: TRAPP

	-,-,
Substation	TRAPP
Substation Location	Trapp Goff Corner Rd
Circuit	114 <u>Trapp Goff</u> corner
Circuit Location	Trapp Goff Corner
Total Circuit Length (miles)	23.94
Average Member Count	224
Date of last Trim	TRIM 2019 HERBICIDE 2024

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	308.01	2.29	235.89	1.60
Animals	1.36%	3.70%	1.09%	2.35%
600 Small Animal/Bird	0.03%	0.58%	0.45%	0.80%
601 Squirrel	<b>1</b> . 33%	3.12%	0.64%	<b>1</b> . 55%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	0.01%	0.19%	4.11%	6.70%
300 Material or Equipment Fault/Failure	0.01%	0.19%	4.10%	6.64%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.02%	0.06%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	86.48%	67.45%	76.49%	69.36%
400 Decay/Age of Material/Equipment	0.81%	0.78%	2.57%	4.35%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	0%	0%	3.69%	6.19%
430 Tree failure from overhang or deadtr	85.68%	66.67%	70.18%	58.76%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%
				D :

Excluding Major Event Day outages, Power Supply outages, Planned outages, Customer Responsible Outages and Momentary Outages

### Substation: TRAPP

Substation	TRAPP
Substation Location	
Circuit	114 Trapp Goffs Corner Rd
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	224
Date of last Trim	

	Totals		5 Year A	5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI	
Total Minutes/Frequency	<u>3</u> 08.01	2.29	235.89	1.60	
Maintenance	86.48%	67.45%	76.49%	69.36%	
490 Maintenance, Other	0%	0%	0.04%	0.06%	
Other	0%	0%	0%	0%	
800 Other	0%	0%	0%	0%	
801 Supervisor Review	0%	0%	0%	0%	
Planned Outage	0%	0%	0%	0%	
100 Construction	0%	0%	0%	0%	
110 Maintenance	0%	0%	0%	0%	
190 Other Planned	0%	0%	0%	0 %	
Power Supply	0%	0%	0%	0 %	
000 Power Supply	0%	0%	0%	0%	
Public	0%	0%	0.84%	1.72%	
700 Customer-Caused	0%	0%	0%	0%	
710 Motor Vehicle	0%	0%	0.17%	0.23%	
720 Aircraft	0%	0%	0%	0%	
730 Fire	0%	0%	0%	0%	
740 Public Cuts Tree	0%	0%	0.35%	0.69%	
750 Vandalism	0%	0%	0%	0%	
760 Switching error or caused by construe	0%	0%	0%	0%	
790 Public, Other	0%	0%	0.33%	0.80%	
Unknown	2.00%	3.12%	7.66%	10.25%	
999 Cause Unknown	2.00%	3.12%	7.66%	10.25%	
Weather	10.14%	25.54%	9.80%	9.62%	
500 Lightning	0.15%	0.58%	6.34%	6.53%	

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: TRAPP

	1, 1, 1011 11100100 1111 00 121, 011, 1011
Substation	TRAPP
Substation Location	
Circuit	114 <u>Trapp</u> Goffs Corner Rd
Circuit Location	·
Total Circuit Length (miles)	
Average Member Count	224
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
T9tal inutes/Frequency	308.01	2.29	235.89	1.60
Weather	10.14%	25.54%	9.80%	9.62%
510 Wind, Not Trees	9.99%	24.95%	3.47%	3.09%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

PSC Report

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: TRAPP

Substation	TRAPP
Substation Location	Trapp Goff Corner Rd
Circuit	124 Red River Rd
Circuit Location	Red River Rd
Total Circuit Length (miles)	35.19
Average Member Count	247
Date of last Trim	TRIM 2024

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Tota]. Minutes/Frequency	11281.19	3.42	268.44	1.38
Animals	<b>1</b> . 38%	3.67%	2.72%	2.94%
600 Small Animal/Bird	0%	0%	1.20%	2.04%
601 Squirrel	1.16%	3.20%	1.49%	0.78%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0.20%	0.36%	0.03%	0.12%
612 Animal/Large Bird	0.03%	0.12%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	0.37%	0.12%	5.60%	6.00%
300 Material or Equipment Fault/Failure	0.37%	0.12%	5.55%	5.88%
310 Installation Fault	0%	0%	0%	0 %
320 Conductor Sag or Inadequate Clearance	0%	0%	0 %	0%
340 Overload	0%	0%	0.03%	0.06%
350 Miscoordination of Protection Devices	0%	0%	0 응	0%
360 Other Equipment Installation/Design	0%	0%	0.01%	0.06%
Maintenance	15.07%	32.35%	74.99%	73.32%
400 Decay/Age of Material/Equipment	3.16%	8.18%	3.37%	0.90%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0.08%	0.12%
420 Tree Growth	0.55%	<b>1.</b> 30%	3.39%	3.78%
430 Tree failure from overhang or deadtr	11.36%	22.87%	61.94%	53.42%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	6.21%	15.11%
				Duinted 2/21/2

Excluding Major Event Day outages, Power Supply Outages, Planned outages, Customer Responsible outages and Momentary Outages

### Substation: TRAPP

Substation	TRAPP
Substation Location	
Circuit	124 Red River Rd
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	247
Date of last Trim	

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	1(281.19	3.42	268.44	1.38
Maintenance	15.07%	32.35%	74.99%	73.32%
490 Maintenance, Other	0%	0%	0%	0%
Other	0 %	0%	0.30%	0.90%
800 Other	0%	0%	0.30%	0.90%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0%	0 %
100 Construction	0 %	0 %	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0 %	0 %	0%	0%
000 Power Supply	0%	0%	0%	0%
Public	0.01%	0.12%	3.75%	4.38%
700 Customer-Caused	0%	0%	0.15%	0.12%
710 Motor Vehicle	0%	0%	0.08%	0.18%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	2.76%	3.96%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0 %
790 Public, Other	0.01%	0.12%	0.76%	0.12%
Unknown	67.98%	59.00%	2.59%	5.88%
999 Cause Unknown	67.98%	59.00%	2.59%	
Weather	15.19%	4.74%	10.05%	6.59%
500 Lightning	0.59%	<b>1.</b> 66%	7.68%	6.29%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: TRAPP

Substation	TRAPP
Substation Location	
Circuit	124 Red River Rd
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	247
Date of last Trim	

	Tot	als	5 Year A	verage
	SAIDI	SAIFI	SAIDI	SAIFI
Total <u>Minutes/Frequency</u>	1,281.19	3.42	<u> 2 R− · 44</u>	1.38
Weather	15.19%	4.74%	10.05%	6.59%
510 Wind, Not Trees	14.60%	3.08%	2.37%	0.30%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

Excluding Major Event Day outages, Power Supply outages, Planned outages, Customer Responsible outages and Momentary outages

### Substation: TRAPP

Substation	TRAPP
Substation Location	Trapp Goff Corner Rd
Circuit	134 Log Lick Rd
Circuit Location	Log Lick Rd
Total Circuit Length (miles)	37.67
Average Member Count	350
Date of last Trim	TRIM 2018 HERBICIDE 2024

	Totals		5 Year A	verage
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	135.89	. 73	65.88	.44
Animals	5.74%	20.31%	3.67%	8.01%
600 Small Animal/Bird	0.54%	1.17%	0.54%	1.34%
601 Squirrel	5.09%	18.36%	3.12%	6.68%
610 Large Animal	0%	0%	0 응	0%
611 Cattle Rubbing	0.12%	0.78%	0 %	0%
612 Animal/Large Bird	0%	0%	0 응	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	0.33%	0.78%	4.75%	5.07%
300 Material or Equipment Fault/Failure	0.33%	0.78%	4.59%	4.81%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or InadequateClearance	0%	0%	0%	0 %
340 Overload	0%	0%	0.16%	0.27%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	77.16%	34.77%	35.64%	36.72%
400 Decay/Age of Material/Equipment	1.27%	1.17%	1.06%	1.07%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	2.26%	3.13%	0.14%	0.27%
430 Tree failure from overhang or deadtr	73.63%	30.47%	34.08%	34.71%
440 Trees With Ice/Snow	0%	0%	0.36%	0.67%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%
				Printed 3/31/

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

Substation: TRAPP

Substation	TRAPP
Substation Location	
Circuit	134 Log Lick Rd
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	350
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	135.89	73	65.88	. 44
Maintenance	77.16%	34.77%	35.64%	36.72%
490 Maintenance, Other	0%	0%	0%	0%
Other	0.96%	0.78%	0%	0%
800 Other	0.96%	0.78%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0 %	0 %	0 %
100 Construction	0%	0%	0 %	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0%	0 %	0 %
000 Power Supply	0%	0%	0%	0%
Public	0%	0%	14.89%	8.01%
700 Customer-Caused	0%	0%	2.43%	2.67%
710 Motor Vehicle	0%	0 %	12.05%	4.81%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0.26%	0.27%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0.15%	0.27%
Unknown	<b>1.</b> 57%	3.91%	17.87%	24.97%
999 Cause Unknown	1.57%	3.91%	17.87%	24.97%
Weather	14.23%	39.45%	23.18%	17.22%
500 Lightning	10.61%	11.72%	22.91%	16.69%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: TRAPP

Substation	TRAPP
Substation Location	
Circuit	134 Log Lick Rd
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	350
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	135.89	.73	65.88	. 44
Weather	14.23%	39.45%	23.18%	17.22%
510 Wind, Not Trees	3.62%	27.73%	0%	0%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0.27%	0.53%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: TREEHAVEN

Substation	TREEHAVEN
Substation Location	Rockwell Rd
Circuit	104 Jenmar
Circuit Location	Gawthorp Rd
Total Circuit Length (miles)	1.13
Average Member Count	72
Date of last Trim	TRIM 2024 and Herbicide 2022

	Tot	als	5 Year <i>P</i>	Average
	SAIDI	SAIFI	SAIDI	SAIFI
<u>Total Minutes/Frequency</u>	17.89	. 22	13.24	. 21
Animals	10.87%	12.50%	18.94%	24.68%
600 Small Animal/Bird	0%	0%	0%	0%
601 Squirrel	10.87%	12.50%	18.94%	24.68%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	0%	0%	29.46%	35.06%
300 Material or Equipment Fault/Failure	0%	0%	0%	0%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	29.46%	35.06%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	0%	0 %	31.90%	22.08%
400 Decay/Age of Material/Equipment	0 %	0%	10.74%	3.90%
410 Corrosion/Abrasion of	0%	0%	0%	0%
Material/Equipment				
420 Tree Growth	0%	0%	0 %	0%
430 Tree failure from overhang or deadtr	0%	0%	21.16%	18.18%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

#### Substation: TREEHAVEN

Substation	TREEHAVEN
Substation Location	
Circuit	104 Jenmar
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	72
Date of last Trim	

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Totaj Minu es/Frequency	17.89	. 22	13.24	.21
Maintenance	0%	0 %	31.90%	22.08%
490 Maintenance, Other	0%	0%	0%	0%
Other	0%	0%	0 %	0 %
800 Other	0%	0%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0 %	0 %	0%	0 %
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0 %
Power Supply	0 %	0%	0%	0 %
000 Power Supply	0%	0 %	0%	0%
Public	0%	0%	0 %	0 %
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	0%	0%	0%	0%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
Unknown	0 %	0 %	0 %	0%
999 Cause Unknown	0%	0%	0 %	0 %
Weather	89.13%	87.50%	19.71%	18.18%
500 Lightning	0%	0%	19.71%	18.18%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: TREEHAVEN

Substation	TREEHAVEN
Substation Location	
Circuit	104 Jenmar
Circuit Location	
Total Circuit Length (miles)	-
Average Member Count	72
Date of last Trim	

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total. Minutes/Frequency	17.89	. 22	13.24	. 21
Weather	89.13%	87.50%	19.71%	18.18%
510 Wind, Not Trees	89.13%	87.50%	0%	0%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

PSC Report

Excluding Major Event Day outages, Power Supply outages, Planned outages, Customer Responsible outages and Momentary outages

### Substation: TREEHAVEN

Substation	TREEHAVEN
Substation Location	Rockwell Rd_
Circuit	134 Treehaven
Circuit Location	Treehaven subdivision
Total Circuit Length (miles)	.967
Average Member Count	102
Date of last Trim	TRIM 2024

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<u>Total Minutes/Frequency</u>	268.24	. 65	48.82	. 54
Animals	0%	0%	50.65%	48.08%
600 Small Animal/Bird	0%	0%	24.46%	22.69%
601 Squirrel	0%	0%	26.19%	25.38%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
Equipment or Installation/Design	0%	0%	9.28%	11.15%
300 Material or Equipment Fault/Failure	0%	0%	0%	0%
310 Installation Fault	0%	0%	0%	0 %
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0 %
340 Overload	0%	0%	9.28%	11.15%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	13.16%	50%	11.61%	13.08%
400 Decay/Age of Material/Equipment	13.16%	50%	0%	0%
410 Corrosion/Abrasion of Material/Equipment	0%	0%	0%	0%
420 Tree Growth	0%	0%	0%	0%
430 Tree failure from overhang or deadtr	0%	0%	11.61%	13.08%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0 %
460 Moisture	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: TREEHAVEN

Substation	TREEHAVEN
Substation Location	
Circuit	134 Treehaven
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	102
Date of last Trim	

	Tot	als	5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	268.24	65	48.82	54
Maintenance	13.16%	50%	. 11.61%	13.08%
490 Maintenance, Other	0%	0%	0%	0%
Other	0%	0%	0%	0 %
800 Other	0%	0%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
Planned Outage	0%	0%	0 %	0 %
100 Construction	0%	0%	0%	0%
110 Maintenance	0%	0%	0%	0%
190 Other Planned	0%	0%	0%	0%
Power Supply	0%	0 %	0 %	0 %
000 Power Supply	0%	0%	0%	0%
Public	0%	0%	0%	0 %
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	0%	0%	0%	0%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
Unknown	0%	0%	17.06%	15.00%
999 Cause Unknown	0%	0%	17.06%	15.00%
Weather	86.84%	50%	11.41%	12.69%
500 Lightning	0%	0%	11.41%	12.69%

Excluding Major Event Day outages, Power Supply outages, Planned outages, Customer Responsible Outages and Momentary outages

### Substation: TREEHAVEN

	1, 1, 2021 22100 000 1m1 00 12, 01, 2021 21 00 00
Substation	TREEHAVEN
Substation Location	
Circuit	134 Treehaven
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	102
Date of last Trim	

	Totals		5 Year A	verage
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	268.24	. 65	48.82	.54
Weather	86.84%	50%	11.41%	12.69%
510 Wind, Not Trees	86.84%	50%	0%	0%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0 %
530 Flood	0%	0%	0%	0 %
590 Weather, Other	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: VAN METER

Substation	VAN METER
Substation Location	Van Meter Rd
Circuit	114 Clintonville
Circuit Location	Clintonville Rd
Total Circuit Length (miles)	65.87
Average Member Count	574
Date of last Trim	Hotspot and Due to cut 2025

	Tot	als	5 Year <i>F</i>	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	357.82	2.38	168.90	. 99
Animals	1.90%	2.56%	2.69%	4.73%
600 Small Animal/Bird	0.79%	1.02%	0.95%	1.47%
601 Squirrel	1.11%	1.54%	1.52%	2.77%
610 Large Animal	0%	0%	0.02%	0.07%
611 Cattle Rubbing	0%	0%	0.20%	0.42%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0 %
Equipment or Installation/Design	0%	0%	1.63%	3.40%
300 Material or Equipment Fault/Failure	0%	0%	1.11%	2.35%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.52%	1.05%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
Maintenance	28.28%	50.48%	61.82%	37.46%
400 Decay/Age of Material/Equipment	0.58%	0.66%	0.95%	1.47%
410 Corrosion/Abrasion of	0%	0%	0.26%	0.46%
Material/Equipment				
420 Tree Growth	0.79%	1.76%	5.29%	6.20%
430 Tree failure from overhang or dead tr	26.90%	48.06%	55.09%	29.26%
440 Trees With Ice/Snow	0%	0%	0.21%	0.07%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%

Excluding Major Event Day outages, Power Supply outages, Planned outages, Customer Responsible outages and Momentary Outages

### Substation: VAN METER

VAN METER
114 Clintonville
574

Totals		Totals 5 Year Average	
SAIDI	SAIFI	SAIDI	SAIFI
<u>357.82</u>	2.38	168.90	. 99
28.28%	50.48%	61.82%	37.46%
0%	0%	0%	0%
0.28%	0.51%	0.04%	0.04%
0.28%	0.51%	0.04%	0.04%
0%	0%	0%	0%
0%	0%	0%	0%
0%	0 %	0%	0%
0%	0%	0%	0%
0%	0%	0%	0%
0%	0 %	0%	0 %
0%	0%	0%	0%
0.03%	0.07%	2.35%	3.12%
0.03%	0.07%	0.01%	0.04%
0%	0%	0.21%	0.28%
0%	0%	0%	0%
0%	0%	0%	0%
0%	0%	2.13%	2.80%
0%	0%	0%	0%
0%	0%	0%	0%
0%	0%	0%	0%
67.99%	42.87%	22.62%	43.69%
67.99%	42.87%	22.62%	43.69%
1.53%	3.51%	8.84%	7.57%
1.25%	1.24%	8.39%	7.39%
	\$\frac{357.82}{28.28\%}  0\%  0.28\%  0\q	SAIDI     SAIFI       357.82     2.38       28.28%     50.48%       0%     0%       0.28%     0.51%       0%     0%       0%     0%       0%     0%       0%     0%       0%     0%       0%     0%       0%     0%       0%     0%       0%     0%       0%     0%       0%     0%       0%     0%       0%     0%       0%     0%       0%     0%       0%     0%       0%     0%       0%     0%       67.99%     42.87%       1.53%     3.51%	SAIDI         SAIFI         357.82         2.38         168.90           28.28%         50.48%         61.82%         0%         0%           0%         0%         0%         0%         0%         0%           0.28%         0.51%         0.04%         0.04%         0.04%         0.04%         0.04%         0.04%         0.04%         0.04%         0.04%         0.04%         0.04%         0.06%         0%

Excluding Major Event Day Outages, Power Supply Outages, Planned Outages, Customer Responsible Outages and Momentary Outages

### Substation: VAN METER

Substation	VAN METER
Substation Location	
Circuit	114 Clintonville
Circuit Location	
Total Circuit Length (miles)	
Average Member Count	574
Date of last Trim	

	Totals		5 Year A	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	357.82	2.38	168.90	. 99
Weather	1.53%	3.51%1	8.84%	7.57%
510 Wind, Not Trees	0.18%	2.12%	0.36%	0.11%
520 Ice, Sleet, Frost, Not Trees	0.09%	0.15%	0.09%	0.07%
530 Flood	0%	0%1	0%	0%
590 Weather, Other	0%	0%	0%	0%