




**LICKING VALLEY**  
RURAL ELECTRIC COOPERATIVE CORPORATION  
P. O. Box 605 • 271 Main Street  
West Liberty, KY 41472-0605  
(606) 743-3179



KERRY K. HOWARD  
General Manager/CEO

RECEIVED

APR 23 2015

PUBLIC SERVICE  
COMMISSION

April 20, 2015

Ms. Linda Faulkner  
Filings Director  
Kentucky Public Service Commission  
211 Sower Boulevard  
Post Office Box 615  
Frankfort, Kentucky 40602-0615

RE: Case Number 2012-00013  
Application of LVRECC for a Certificate of Public Convenience  
and Necessity for its 2012-2015 Construction Work Plan

Dear Ms. Faulkner:

In response to the Public Service Commission's Order in the above referenced Case, page 6, number 2 a-f, please find enclosed Licking Valley Rural Electric Cooperative Corporation's 2014 Supplemental Report.

We are currently in a 100 Meter Pilot Project in an effort to upgrade our System to a radio frequency metering system (RF) and feel there is no need to continue with this report on an annual basis. At the end of the Pilot Project we will be asking for a CPCN to go forward with this RF Metering Project.

If additional information is needed or required at this time, please let us know.

Sincerely,

Kerry K. Howard  
General Manager/CEO

KKH:slv

Enclosure

Supplement to the Annual Report to the Public Service Commission of Kentucky for 2014  
Licking Valley Rural Electric Cooperative Corporation

In compliance with the Certificate of Public Convenience for Automatic Meter Reading Devices issued in case number 2012-00013, Licking Valley RECC submits the following.

2. a. The number of single-phase electro-mechanical meters Licking Valley has retrofitted during the year and placed into inventory:

0

2. b. The number of single-phase electro-mechanical meters Licking Valley has retrofitted during the year and returned to service:

0

2. c. The number of three-phase electro-mechanical meters Licking Valley has retrofitted during the year and placed into inventory.

N/A

Licking Valley no longer has any three-phase electro-mechanical meters.

2. d. The number of three-phase electro-mechanical meters Licking Valley has retrofitted during the year and returned to service:

N/A

Licking Valley no longer has any three-phase electro-mechanical meters.

2. e. The remaining useful lives of the meters that were retrofitted and placed into inventory.

Estimated 8-10 years.

2. f. The remaining useful lives of the meters that were retrofitted and returned to service.

Estimated 8-10 years.

Licking Valley RECC has determined that it is no longer feasible to retrofit our electro-mechanical meters. The dependability of the new electronic meters has improved to the point that we feel comfortable with retiring the electro-mechanical meters and replacing them with the electronic meters. Also, the age of the electro-mechanical meters are now to the point that we feel that they need to be phased out. The newer meters will also better meet the needs of our AMR/AMI system.