

Supplement to the Annual Report to the Public Service Commission of Kentucky for 2013
Licking Valley Rural Electric Cooperative Corporation

In compliance with the Certificate of Public Convenience for Automatic Meter Reading Devices issued in case number 2012-00013, Licking Valley RECC submits the following.

2. a. The number of single-phase electro-mechanical meters Licking Valley has retrofitted during the year and placed into inventory:

213

2. b. The number of single-phase electro-mechanical meters Licking Valley has retrofitted during the year and returned to service:

213

2. c. The number of three-phase electro-mechanical meters Licking Valley has retrofitted during the year and placed into inventory.

N/A

Licking Valley no longer has any three-phase electro-mechanical meters.

2. d. The number of three-phase electro-mechanical meters Licking Valley has retrofitted during the year and returned to service:

N/A

Licking Valley no longer has any three-phase electro-mechanical meters.

2. e. The remaining useful lives of the meters that were retrofitted and placed into inventory.

Estimated 10-12 years.

2. f. The remaining useful lives of the meters that were retrofitted and returned to service.

Estimated 10-12 years.

Licking Valley RECC has determined that it is no longer feasible to retrofit our electro-mechanical meters. The dependability of the new electronic meters has improved to the point that we feel comfortable with retiring the electro-mechanical meters and replacing them with the electronic meters. Also, the age of the electro-mechanical meters are now to the point that we feel that they need to be phased out. The newer meters will also better meet the needs of our AMR/AMI system.

RECEIVED

APR 24 2015

PUBLIC SERVICE
COMMISSION