

DOC11R

Case Management System - KY Public Service Commission*Regular Cases Before the Commission as of May 09, 2025***2011-00220**

RECEIVED: 06/29/11

FILED: 06/29/11

FINAL: 03/05/13

REOPENED:

SUSPENSION DATE:

CASE CODE

Deviation

UTILITIES:

Warren County Water District

Simpson County Water District

Butler County Water System, Inc.

INDEX OF EVENTS:

05/05/17	POST CASE: Warren County Water District Annual Sample Meter Testing Report
08/05/16	POST CASE: Warren County Water District Annual Sample Meter Testing Report
07/13/15	POST CASE: Warren and Simpson Counties Water Districts and Butler County Water System, Inc. Meter Reports
11/10/14	POST CASE: Warren County WD, Simpson County WD, and Butler County Water System Random Sample Meter Test Results
03/05/13	Order Entered: 1. Joint Applicants' application for a deviation from 807 KAR 5:066, Section 16(1), to permit their Sensus Model SR II meters to remain in service without periodic testing for a period no longer than 21 years is denied. 2. Joint Applicants are authorized to deviate from 807 KAR 5066, Section 16(1), to permit each utility to maintain its Sensus Model SR II meters in service without periodic testing for a period no longer than 15 years. 3. Within 180 days of the date of this Order, Joint Applicants shall test all meters that have been in service for 15 years or longer and have not been tested for accuracy since being placed into service. Testing on these meters shall be performed regardless of whether a Joint Applicant intends to retire the meter from service immediately upon removal. 4. Within 210 days of the date of this Order, each Joint Applicant shall file with the Commission the results of all tests performed to comply with ordering paragraph 3 of this Order. 5. Should any of its meters tested in accordance with ordering paragraph 3 fail to meet the accuracy standards set forth in 807 KAR 51066, Section 15, a Joint Applicant shall proceed in accordance with 807 KAR 5:006, Section 1 I(2). 6. Authorization to establish and maintain, a sample group of Sensus Model SR II meters from each year of manufacture from 1990 to 1997 that will remain in service 20 years is withdrawn effective 180 days from the date of this Order.
02/01/12	WCWD's Responses to Commission Staff's 2nd Request for Info
01/12/12	COMMISSION STAFF'S SECOND REQUEST FOR INFORMATION TO JOINT APPLICANTS
11/14/11	Warren Co Water District's Response to Commission Staff's Request for Information
10/25/11	Commission Staff's Request for Information to Joint Applicants
10/20/11	Order Entered: (1) The records of Cases No. 97-434 and No. 2003-00391 are incorporated by reference into the record of this proceeding. (2) Any party that objects to the incorporation of these records shall file its objections in writing with the Commission within ten days of the date of this Order.
06/29/11	Acknowledge Receipt of Filing
06/29/11	Joint Application of Warren County Water District, Simpson County Water District and Butler County Water System, Inc. for a Deviation from Approved Meter Testing Program

Total Number of Cases: 1