

DOC11R

Case Management System - KY Public Service Commission*Regular Cases Before the Commission as of April 24, 2024***2011-00009**

RECEIVED: 01/05/11

FILED: 01/05/11

FINAL: 05/17/11

REOPENED:

SUSPENSION DATE:

CASE NATURE: 807 KAR 5:066, Section 16, Periodic Test Schedule

CASE CODE

Deviation

UTILITIES:

Hardin County Water District #1

INDEX OF EVENTS:

| | |
|----------|--|
| 10/03/13 | POST CASE: Response of Hardin County WD No 1 to Order of May 17, 11 |
| 03/28/13 | POST CASE: Hardin County Water District No 1 Current Progress Report |
| 10/04/12 | POST CASE: Hardin CO WD No 1 Progress Report for AMR Project |
| 04/04/12 | POST CASE: HARDIN CO WD NO. 1 AMR PROJECT CURRENT PROGRESS REPORT |
| 09/16/11 | POST CASE: Hardin Co Water District No. 1 Progress Report for AMR Project |
| 05/17/11 | Order Entered: |
| | (1) Hardin District's request for an extension is granted in part and denied in part. |
| | (2) Hardin District is permitted until December 31, 2013 to deviate from 807 KAR 5:066, Section 16(1) on the condition that upon its replacement of a small meter that has been in service without testing for a period of 10 years or more with an AMR meter, Hardin District shall test the removed meter for compliance with the accuracy standards set for in 807 KAR 5:066, Section 15. |
| | (3) On or before September 30 and March 31 of each year until 2014, Hardin District shall file with the Commission a written report on the progress of its AMR meter installations |
| 01/06/11 | Acknowledge Receipt of Filing |
| 01/05/11 | Hardin County Water District No. 1's Request for Extension of Deviation from Administrative Regulation 807 KAR 5:041, Section 15, Periodic Test Schedule |

 Total Number of Cases: 1