

DOC11R

**Case Management System - KY Public Service Commission***Regular Cases Before the Commission as of August 09, 2025***2010-00137**

RECEIVED: 03/29/10

FILED: 03/29/10

FINAL: 05/18/10

REOPENED:

SUSPENSION DATE:

CASE NATURE: Warrior Path Water Line Extension

**CASE CODE**

Deviation

**UTILITIES:**

Knox County Utility Commission

**INDEX OF EVENTS:**

05/18/10	Order Entered: KCUC is granted a deviation from 807 KAR 5:066 section 10 (2) (a): Shall comply with 807 KAR 5:066 section 8(2): Shall monitor the adequacy of this water main and if the level of service on this water main is inadequate or declining or if its water pressure fails to meet requirements of 807 KAR 5:066 section 5 (1) KCUC shall take necessary actions to maintain the level of service at the standards set forth in PSC regulations: KCUC shall provide service on this main or any other water main to any customer who is entitled to service under PSC regulations and KCUC tariff: Shall construct no further extension or lateral to this water main until appropriate eng studies are performed and all requisite approvals are obtained: This case is closed and removed from the PSC docket
04/30/10	Memo to file e-mail from Daniel Kulik and Plan Approval Letter and Permit into the record
04/29/10	Knox County Utility Commission's Supplemental Information Filing with Topographic Maps
03/31/10	Acknowledge Receipt of Filing
03/29/10	Knox County Utility Commission's request for deviation from 807 KAR 5:066 Section 10(2)(a) minimum pipe size

---

Total Number of Cases: 1