

DOC11R

Case Management System - KY Public Service Commission*Regular Cases Before the Commission as of January 21, 2025***2011-00009**

RECEIVED: 01/05/11

FILED: 01/05/11

FINAL: 05/17/11

REOPENED:

SUSPENSION DATE:

CASE NATURE: 807 KAR 5:066, Section 16, Periodic Test Schedule

CASE CODE

Deviation

UTILITIES:

Hardin County Water District #1

INDEX OF EVENTS:

10/03/13	POST CASE: Response of Hardin County WD No 1 to Order of May 17, 11
03/28/13	POST CASE: Hardin County Water District No 1 Current Progress Report
10/04/12	POST CASE: Hardin CO WD No 1 Progress Report for AMR Project
04/04/12	POST CASE: HARDIN CO WD NO. 1 AMR PROJECT CURRENT PROGRESS REPORT
09/16/11	POST CASE: Hardin Co Water District No. 1 Progress Report for AMR Project
05/17/11	Order Entered: (1) Hardin District's request for an extension is granted in part and denied in part. (2) Hardin District is permitted until December 31, 2013 to deviate from 807 KAR 5:066, Section 16(1) on the condition that upon its replacement of a small meter that has been in service without testing for a period of 10 years or more with an AMR meter, Hardin District shall test the removed meter for compliance with the accuracy standards set for in 807 KAR 5:066, Section 15. (3) On or before September 30 and March 31 of each year until 2014, Hardin District shall file with the Commission a written report on the progress of its AMR meter installations
01/06/11	Acknowledge Receipt of Filing
01/05/11	Hardin County Water District No. 1's Request for Extension of Deviation from Administrative Regulation 807 KAR 5:041, Section 15, Periodic Test Schedule

 Total Number of Cases: 1