

DOC11R

Case Management System - KY Public Service Commission*Regular Cases Before the Commission as of June 30, 2024***2011-00213**

RECEIVED: 06/21/11

FILED: 06/21/11

FINAL: 02/14/12

REOPENED:

SUSPENSION DATE:

CASE NATURE: Waiver of Weekly Odorization Testing

CASE CODE

Deviation

UTILITIES:

Indiana Utilities Corporation

HEARINGS:

12/06/11 Teleconference

INDEX OF EVENTS:

02/14/12 Final Order Entered. (1)Indiana Utilities' request for a deviation from 807 KAR 5:022, Section 13(17)(g)4 is denied. (2) Indiana Utilities shall test its gas for the proper odorant level at least once weekly. (3) Indiana Utilities shall test its gas for the proper odorant level at the furthest point in Kentucky from injection of the odorant or at a location in Indiana.

12/20/11 Memorandum dated 12/07/2011 for Informal Conference of 12/06/2011; Comments, if any, due within five days of receipt of letter

10/14/11 Indiana Utilities Corporation's Response to Data Requests

09/19/11 Initial Information Request of Commission Staff to Indiana Utilities Corporation

06/21/11 Acknowledge Receipt of Filing

06/21/11 Indiana Utilities Corporation's Request for Deviation from 807 KAR 5:022, Section 13 (17)(G)(4)

 Total Number of Cases: 1