

DOC11R

Case Management System - KY Public Service Commission*Regular Cases Before the Commission as of June 30, 2024***2013-00038**

RECEIVED: 01/28/13

FILED: 01/28/13

FINAL: 02/10/15

REOPENED:

SUSPENSION DATE:

CASE NATURE: 807 KAR 5:022, Section 13 (17) (g) 4

CASE CODE

Deviation

UTILITIES:

Irvington Gas Company, Inc.

INDEX OF EVENTS:

02/10/15 Final Order Entered: 1. Irvington Gas's request for a deviation from 807 KAR 5:022, Section 13(17)(g), is denied. 2. Irvington Gas's request for a deviation from 49 CFR 192.625(f) is denied. 3. Irvington Gas shall test the odorant level of its propane, using equipment designed to detect and verify proper levels of odorant, at the furthest point from each underground storage tank that serves customers through its underground pipeline systems, in compliance with 807 KAR 5:022, Section 13(17)(g). 4. In the Irvington Gas system, if the gas odorant level drops at any location below the concentration specified in 807 KAR 5:022, Section 13(17)(a), Irvington Gas shall immediately report such occurrence to the Commission and install odorization facilities to inject odorant into its propane gas.

05/20/13 Irvington Gas Company Inc Response to Commission Staffs Request for Information

05/09/13 Irvington Gas Company Inc Response to Commission Staffs Request for Information, and Request for an Extension of Time to Complete Until June 1, 2013 for the Remaining Data

04/24/13 COMMISSION STAFF'S INITIAL REQUEST FOR INFORMATION TO IRVINGTON GAS COMPANY

01/29/13 Acknowledge Receipt of Filing

01/28/13 Irvington Gas Company Request for Deviation from 807 KAR 5:022, Section 13 (17)(g) 4

 Total Number of Cases: 1