DOC11R

Case Management System - KY Public Service Commission

Regular Cases Before the Commission as of October 24, 2025

2014-00277 RECEIVED: 08/01/14 FILED: 08/01/14 FINAL: 12/16/14 REOPENED:

SUSPENSION DATE:

CASE NATURE: 807 KAR 5:071, Section 7(4)

CASE CODE

Deviation

UTILITIES:

Springcrest Sewer Company, Inc.

HEARINGS:

10/17/14 Informal Conference

INDEX OF EVENTS:

		'1
12/03		POST CASE: Springcrest Sewer Co. Inc. Notice of Intent to Borrow Funding and Possible Rate
12/16	E C ta	Final Order Entered: (1) Springcrest is not in compliance with 807 KAR 5:071, Section 7(4). (2) Because of the time needed to plan, finance, and construct facilities, Springcrest should be given until December 15, 2015, to comply with the provisions of 807 KAR 5:071, Section 7(4). (3) Springcrest shall ake all necessary actions to bring its inspections of mechanical equipment into compliance with Commission regulations prior to December 15, 2015. (4) Springcrest shall conduct the inspections equired by 807 KAR 5:071, Section 7(4), on no less than a weekly basis.
11/06		Memorandum dated 11/06/2014 for Informal Conference of October 17, 2014; comments if any due vithin five days of receipt
10/27	/14 5	Springcrest Sewer Co request for deviation
10/13	/14 (Commission Staff's Notice of Informal Conference
09/19	/14 5	Springcrest Sewer Co, Inc. response to PSC request for info
09/08		Commission Staff's First Request for Information to Springcrest Sewer Company, Inc.
08/05	/14 <i>A</i>	Acknowledge Receipt of Filing
08/01	/14	Springcrest Sewer Company, Inc. Request for Deviation from 807 KAR 5:071, Section 7(4)

Total Number of Cases: 1