DOC11R

Case Management System - KY Public Service Commission

Regular Cases Before the Commission as of November 14, 2026

2014-00479 RECEIVED: 12/31/14 FILED: 12/31/14 FINAL: 03/24/16 REOPENED:
SUSPENSION DATE:

CASE CODE
Deviation
Declaratory Order

UTILITIES:
Kentucky Power Company

INDEX OF EVENTS:

03/24/16	Final Order Entered: 1. Kentucky Power's request for a declaration that the biannual ground-inspection requirements of 807 KAR 5:006, Section 26(4)(e), are inapplicable to its 34.5-kV and 46-kV electric line facilities and that these facilities are instead subject to the ground-inspection requirements of 807 KAR 5:006, Section 26(4)(c), is denied. 2. Kentucky Power's request for a declaration that, to the extent that it complies with the ground-inspection requirements of 807 KAR 5:006, Section 26(4)(c), with respect to its electric lines operating at or above 69 kV, it may make the inspections required by 807 KAR 5:006, Section 26(4)(b)4 aerially is granted. 3. Kentucky Power's request for a deviation from the inspection requirements of 807 KAR 5:006, Section 26(4)(e), for its 34.5-kV and 46-kV electric line facilities is denied. 4. Kentucky Power's request for a deviation from the prohibition in 807 KAR 5:006, Section 26(4)(g), as it applies to inspection requirements under 807 KAR 5:006, Section 26(4)(b)4 is denied as moot.
06/19/15	Everett G. Phillips Affidavit
06/17/15	Kentucky Power Co. Response to Second Request for Information
06/03/15	COMMISSION STAFF'S SECOND REQUEST FOR INFORMATION TO KENTUCKY POWER COMPANY
04/01/15	Kentucky Power Co. Petition for Confidential Treatment and Response to Information Request
03/18/15	COMMISSION STAFF'S FIRST REQUEST FOR INFORMATION TO KENTUCKY POWER COMPANY
12/31/14	Acknowledge Receipt of Filing
12/31/14	Kentucky Power Company Application For: (1) An Order Declaring And Clarifying The Application Of The Inspection Requirements Of 807 KAR 5:006, Section 26(4) To Certain Of The Company's Transmission Facilities; Or (2) In The Alternative, And To The Extent Required, A Deviation In Part From The Inspection Requirements Of 807 KAR 5:006, Section 26(4) With Respect To The Company's Transmission Facilities; And (3) All Other Required Approvals And Relief

---

Total Number of Cases: 1