

DOC11R

Case Management System - KY Public Service Commission*Regular Cases Before the Commission as of May 23, 2026***2014-00479**

RECEIVED: 12/31/14

FILED: 12/31/14

FINAL: 03/24/16

REOPENED:

SUSPENSION DATE:

CASE CODE

Deviation

Declaratory Order

UTILITIES:

Kentucky Power Company

INDEX OF EVENTS:

03/24/16 Final Order Entered: 1. Kentucky Power's request for a declaration that the biannual ground-inspection requirements of 807 KAR 5:006, Section 26(4)(e), are inapplicable to its 34.5-kV and 46-kV electric line facilities and that these facilities are instead subject to the ground-inspection requirements of 807 KAR 5:006, Section 26(4)(c), is denied. 2. Kentucky Power's request for a declaration that, to the extent that it complies with the ground-inspection requirements of 807 KAR 5:006, Section 26(4)(c), with respect to its electric lines operating at or above 69 kV, it may make the inspections required by 807 KAR 5:006, Section 26(4)(b)4 aerially is granted. 3. Kentucky Power's request for a deviation from the inspection requirements of 807 KAR 5:006, Section 26(4)(e), for its 34.5-kV and 46-kV electric line facilities is denied. 4. Kentucky Power's request for a deviation from the prohibition in 807 KAR 5:006, Section 26(4)(g), as it applies to inspection requirements under 807 KAR 5:006, Section 26(4)(b)4 is denied as moot.

06/19/15 Everett G. Phillips Affidavit

06/17/15 Kentucky Power Co. Response to Second Request for Information

06/03/15 COMMISSION STAFF'S SECOND REQUEST FOR INFORMATION TO KENTUCKY POWER COMPANY

04/01/15 Kentucky Power Co. Petition for Confidential Treatment and Response to Information Request

03/18/15 COMMISSION STAFF'S FIRST REQUEST FOR INFORMATION TO KENTUCKY POWER COMPANY

12/31/14 Acknowledge Receipt of Filing

12/31/14 Kentucky Power Company Application For: (1) An Order Declaring And Clarifying The Application Of The Inspection Requirements Of 807 KAR 5:006, Section 26(4) To Certain Of The Company's Transmission Facilities; Or (2) In The Alternative, And To The Extent Required, A Deviation In Part From The Inspection Requirements Of 807 KAR 5:006, Section 26(4) With Respect To The Company's Transmission Facilities; And (3) All Other Required Approvals And Relief

 Total Number of Cases: 1