

DOC11R

Case Management System - KY Public Service Commission*Regular Cases Before the Commission as of October 20, 2024***2016-00275**

RECEIVED: 07/28/16

FILED: 07/28/16

FINAL: 05/04/17

REOPENED:

SUSPENSION DATE:

CASE NATURE: Sample Meter Testing

CASE CODE

Deviation

UTILITIES:

Nolin R.E.C.C.

HEARINGS:

11/22/16 Teleconference

INDEX OF EVENTS:

05/04/17 Final Order Entered: 1. Nolin's application requesting approval to implement a sample meter testing program for its single-phase meters is approved. 2. Nolin shall comply with all applicable meter-testing requirements set forth in 807 KAR 5:006 and 807 KAR 5:041, including maintaining all test records related to its sample meter testing in accordance with 807 KAR 5:006, Section 18. 3. Nolin shall provide the additional information below with its Quarterly Meter Reports, which are required to be filed by 807 KAR 5:006, Section 4(4), and include an electronic version compatible with Microsoft Excel. a. A detailed report in tabular format that records the following information for each meter, including new meters, tested under the sampling plan: (1) Serial Number; (2) Date/Time of Test; (3) Manufacturer; (4) Model/Form/type; (5) Version/Firmware; (6) As-Found Meter Registration, Full Load, Light Load, and Power Factor Results; (7) As-Left Meter Registration, Full Load, Light Load, and Power Factor Results; (8) Description of Any Billing Adjustment.

11/23/16 Memorandum dated 11/23/2016 for Informal Conference of 11/22/2016; Comments, if any, due within five days of receipt

10/11/16 Nolin RECC Response to Request for Information

09/27/16 Commission Staff's First Request for Information to Nolin Rural Electric Cooperative Corporation

07/28/16 Acknowledge Receipt of Filing

07/28/16 Nolin RECC Request to Adopt Scientific Sample Meter Testing for Single Phase Meters

 Total Number of Cases: 1