DOC11R

Case Management System - KY Public Service Commission

Regular Cases Before the Commission as of November 11, 2026

2016-00275 RECEIVED: 07/28/16 FILED: 07/28/16 FINAL: 05/04/17 REOPENED: SUSPENSION DATE:

CASE NATURE: Sample Meter Testing

CASE CODE
Deviation

UTILITIES:
Nolin R.E.C.C.

HEARINGS:
11/22/16 Teleconference

INDEX OF EVENTS:

10/28/26	POST CASE: Nolin RECC Request for Approval of Changes to Sample Meter Testing Plan
05/04/17	Final Order Entered: 1. Nolin's application requesting approval to implement a sample meter testing program for its single-phase meters is approved. 2. Nolin shall comply with all applicable meter-testing requirements set forth in 807 KAR 5:006 and 807 KAR 5:041, including maintaining all test records related to its sample meter testing in accordance with 807 KAR 5:006, Section 18. 3. Nolin shall provide the additional information below with its Quarterly Meter Reports, which are required to be filed by 807 KAR 5:006, Section 4{4), and include an electronic version compatible with Microsoft Excel. a. A detailed report in tabular format that records the following information for each meter, including new meters, tested under the sampling plan: (1) Serial Number; (2) Date/Time of Test; (3) Manufacturer; (4) Model/Form/type; (5) Version/Firmware; (6) As-Found Meter Registration, Full Load, Light Load, and Power Factor Results; (7) As-Left Meter Registration, Full Load, Light Load, and Power Factor Results; {8) Description of Any Billing Adjustment.
11/23/16	Memorandum dated11/23/2016 for Informal Conference of 11/22/2016; Comments, if any, due within five days of receipt
10/11/16	Nolin RECC Response to Request for Information
09/27/16	Commission Staff's First Request for Information to Nolin Rural Electric Cooperative Corporation
07/28/16	Acknowledge Receipt of Filing
07/28/16	Nolin RECC Request to Adopt Scientific Sample Meter Testing for Single Phase Meters

---

Total Number of Cases: 1