

DOC11R

Case Management System - KY Public Service Commission*Regular Cases Before the Commission as of June 02, 2025***2016-00427**

RECEIVED: 12/16/16

FILED: 12/16/16

FINAL: 02/01/18

REOPENED:

SUSPENSION DATE:

CASE NATURE: 807 KAR 5:006 § 26(6)(b)

CASE CODE

Deviation

UTILITIES:

Northern Kentucky Water District

INDEX OF EVENTS:

| | |
|----------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 02/01/18 | Final Order Entered: 1. NKWD's motion for a deviation from 807 KAR 5:006, Section 26(6)(b), on inspection of meters and meter settings is granted. 2. NKWD will be required to inspect 36 percent of its meters annually. 3. NKWD's motion for a deviation from 807 KAR 5:006, Section 26(6)(b), on inspection of valves is granted. 4. NKWD shall inspect valves 30 inches or larger annually. 5. NKWD shall inspect valves 16 inches or larger every two years. 6. NKWD shall inspect valves measuring less than 16 inches and fire hydrant valves every five years. |
| 12/08/17 | Order Entered: Northern Kentucky's Motion for an extension of time is granted, and Northern Kentucky's responses to Staff's Second Request are accepted for filing as of October 12, 2017. |
| 10/18/17 | Lindsey Rehtin Northern Kentucky Water District Affidavits |
| 10/12/17 | Stacey Kampsen Northern Kentucky Water District Responses to Data Request 2 |
| 09/11/17 | Northern Kentucky Water District Motion for Extension of Time |
| 09/07/17 | Commission Staff's Second Request for Information to Northern Kentucky Water District |
| 04/10/17 | Order Entered: Northern Kentucky's motion for an extension of time is granted, and Northern Kentucky's responses to Staff's First Request are accepted for filing as of April 4, 2017. |
| 04/04/17 | Lindsey Rehtin Northern Kentucky Water District Response to Data Request 1 |
| 03/14/17 | Lindsey Rehtin Northern Kentucky Water District Motion for Extension |
| 03/08/17 | Commission Staff's First Request for Information to Northern Kentucky Water District |
| 12/16/16 | Lindsey Rehtin Northern Kentucky Water District Petition for Deviation |
| 12/08/16 | Acknowledge Receipt of Filing |
| 12/08/16 | Northern Kentucky Water District Notice of Intent to File Application for a Deviation from 807 KAR 5:006 § 26(6)(b) using Electronic Filing Procedures |

 Total Number of Cases: 1