

DOC11R

Case Management System - KY Public Service Commission

Regular Cases Before the Commission as of May 13, 2026

2017-00142

RECEIVED: 03/21/17

FILED: 04/10/17

FINAL: 12/18/17

REOPENED:

SUSPENSION DATE:

CASE NATURE: Minimum Pipe Size

CASE CODE

Deviation

UTILITIES:

Whitley County Water District #1

INDEX OF EVENTS:

- 12/18/17 Final Order Entered: 1. WCWD's request for a deviation is granted. 2. WCWD shall be allowed to deviate from 807 KAR 5:066, Section 10(2)(a), to allow it to install approximately 475 feet of 2-inch pipe as part of the Blackhawk Road and Clyde Strunk Road Water Line Extensions.
- 09/18/17 Whitley County Water District No. 1 Information Response
- 09/11/17 Commission Staff's First Request for Information to Whitley County Water District No. 1
- 04/12/17 Deficiency Cured Letter
- 04/10/17 Whitley County Water District Response to Deficiencies
- 03/28/17 Deficiency letter, information due within 10 days
- 03/23/17 Acknowledge Receipt of Filing
- 03/21/17 Whitley County Water District #1 Request for Variance per 807 KAR 5:066, Section 10(2)(a) - Minimum Pipe Size

Total Number of Cases: 1