

DOC11R

Case Management System - KY Public Service Commission*Regular Cases Before the Commission as of June 05, 2026***2017-00307**

RECEIVED: 08/18/17

FILED: 08/18/17

FINAL: 01/31/18

REOPENED:

SUSPENSION DATE:

CASE CODE

Deviation

UTILITIES:

Wood Creek Water District

INDEX OF EVENTS:

01/31/18 Final Order Entered: 1. WCWD's Application proposing an alternative inspection schedule for its grinder/pump stations pursuant to 807 KAR 5:071, Section 7(4), is approved. 2. Simplex grinder/pump stations shall be inspected annually.

10/23/17 Wood Creek Water District Response to Request for Information

10/19/17 Larry G. Bryson Wood Creek Water District Response to Commission Staffs First Request for Informatoin

10/10/17 Commission Staff's First Request for Information to Wood Creek Water District

08/15/17 Larry G. Bryson Wood Creek Water District Application for Wood Creek Water District Pursuant to 807 KAR 5:071, Section 7(4) for Approval of Proposed Inspection Procedures

07/24/17 Letter Updating Proposed File Date

07/21/17 Acknowledge Receipt of Filing

07/21/17 Wood Creek Water District Notice of Intent to File Application Pursuant to 807 KAR 5:071, Section 7(4) for Approval of Proposed Inspection Procedures Using Electronic Filing Procedures

 Total Number of Cases: 1