

DOC11R

**Case Management System - KY Public Service Commission***Regular Cases Before the Commission as of June 27, 2026***2019-00069**

RECEIVED: 05/07/19

FILED: 05/07/19

FINAL: 05/07/19

REOPENED:

SUSPENSION DATE:

CASE NATURE: NOTIFICATION TO SEWER UTILITIES REGARDING DEVIATION REQUESTS PURSUANT TO 807 KAR 5:071 SECTION 7(4) CONCERNING THE INSPECTION SCHEDULE OF MECHANICAL GRINDER PUMP STATIONS

**CASE CODE**

Administrative

**INDEX OF EVENTS:**

05/07/19

Final Order Entered: 1. All sewer utilities are granted deviation from the daily inspection requirements in 807 KAR 5:071 Section 7(4) for grinder pump stations located on or near the customer's property. 2. An alternate inspection schedule for grinder pump stations is approved pursuant to 807 KAR 5:071 Section 7(4), and grinder pump stations located on or near the customer's property shall be inspected once every five years. 3. This order supersedes any other order granting an alternative inspection schedule for grinder pump stations previously granted by the Commission. 4. This case is closed and removed from the Commission's docket.

---

Total Number of Cases: 1