DOC11R Case Management System - KY Public Service Commission

Regular Cases Before the Commission as of November 28, 2025

**2019-00284** RECEIVED: 08/30/19 FILED: 08/30/19 FINAL: 06/11/20 REOPENED:

SUSPENSION DATE:

**CASE CODE**Deviation

UTILITIES:

Water Service Corporation of Kentucky

## **INDEX OF EVENTS:**

06/11/20	Final Order Entered: 1. WSCK's petition for a deviation from 807 KAR 5:006, Section 26, is granted. 2. The inspection requirement in 807 KAR 5:006, Section 26, shall be extended for values that are 8 inches or smaller such that WSCK shall only be required to inspect each such valve every three years. 3. All other valves in WSCK's system shall be inspected on an annual basis pursuant to 807 KAR 5:006, Section 26. 4. This matter is closed and may be removed from the Commission's active docket.
11/25/19	M Todd Osterloh Water Service Corporation of Kentucky Response to Staffs First Request for Information
11/12/19	M Todd Osterloh Water Service Corporation of Kentucky Motion for Extension to File Response
10/31/19	Commission Staff's First Request for Information to Water Service Corporation of Kentucky
08/30/19	M Todd Osterloh Water Service Corporation of Kentucky Petition for Deviation
08/19/19	Acknowledge Receipt of Filing
08/16/19	Water Service Corporation of Kentucky Notice of Intent to File an Application for a Deviation from 807 KAR 5:006 (26) (2) (b) Using Electronic Filing Procedures

Total Number of Cases: 1