

DOC11R

**Case Management System - KY Public Service Commission***Regular Cases Before the Commission as of July 26, 2025***2020-00137**

RECEIVED: 06/08/20

FILED: 06/08/20

FINAL: 12/02/20

REOPENED:

SUSPENSION DATE:

**CASE CODE**

Deviation

**UTILITIES:**

West Daviess County Water District

**INDEX OF EVENTS:**

12/02/20 Final Order Entered: 1. West Daviess District's application for a deviation from 807 KAR 5:066, Section 16(1), is granted. 2. West Daviess District shall not be required to test its 5/8-inch x 3/4-inch Sensus SR11 meters pursuant to 807 KAR 5:066, Section 16(1), subject to the conditions set forth herein. 3. West Daviess District shall sample test its 5/8-inch x 3/4-inch meters for which a deviation was granted herein, pursuant to its Sample Testing Plan, as modified by the Commission herein. 4. West Daviess District shall submit annual reports of its sample testing detailing the results of the sample testing for that year, including: a. The serial number, manufacturer, and model/form/type of each meter tested; b. The date that each meter was tested; c. The total water flow through the meter from the date it was placed in service through the date of sample testing as recorded at the time of testing; d. An Excel spreadsheet, with formulas intact, containing the raw data collected from each meter tested and showing the calculations detailed in the ANSI/ASQ Standards on which West Daviess District relied on when conducting and analyzing its sample testing; e. The results of West Daviess District's calculations and an explanation of whether each sample was passed at each flow rate using the relevant ANSI/ASQ Standards; f. An explanation of any abnormal meter results that were excluded or otherwise not used in determining whether a sample passed

11/24/20 Mary Ellen Wimberly West Daviess County Water District West Daviess County Water District Motion for Temporary Deviation

08/31/20 Mary Ellen Wimberly West Daviess County Water District West Daviess County Water District Statement for Decision on the Record

08/28/20 Mary Ellen Wimberly West Daviess County Water District West Daviess County Water District Response to Commission Staffs Second Request for Information

08/11/20 Commission Staff's Second Request for Information to West Daviess County Water District

08/06/20 Mary Ellen Wimberly West Daviess County Water District West Daviess County Water District Amended Application

07/24/20 Mary Ellen Wimberly West Daviess County Water District West Daviess County Water District Response to Commission Staffs First Request for Information

07/09/20 Commission Staff's First Request for Information to West Daviess County Water District

06/18/20 Order Entered: 1. The procedural schedule set forth in the Appendix to this Order shall be followed. 2. a. Responses to requests for information shall be appropriately bound, tabbed, and indexed, with the original in paper medium and an electronic version to the Commission. Electronic documents shall be in portable document format (PDF), shall be searchable, and shall be appropriately bookmarked. b. Each response shall be answered under oath, or for representatives of a public or private corporation or a partnership or an association or a governmental agency, be accompanied by a signed certification of the preparer or person supervising the preparation of the response on behalf of the entity that the response is true and accurate to the best of that person's knowledge, information, and belief formed after a reasonable inquiry. c. Any party shall make timely amendment to any prior response if it obtains information which indicates that the response was incorrect when made or, though correct when made, is now incorrect in any material respect. d. For any request to which a party fails or refuses to furnish all or part of the requested information, that party shall provide a written explanation of the specific grounds for its failure to completely and precisely respond.

06/08/20 Mary Ellen Wimberly West Daviess County Water District West Daviess County Water District Application for a Deviation from Meter Testing Requirements

04/22/20 Acknowledge Receipt of Filing

04/22/20 West Daviess County Water District Notice of Intent to File an Application for a Deviation from Meter Testing Requirements Using Electronic Filing Procedures