

DOC11R

**Case Management System - KY Public Service Commission***Regular Cases Before the Commission as of February 03, 2026***2024-00380**RECEIVED: 11/27/24    FILED: 11/27/24    FINAL: 01/30/25  
SUSPENSION DATE:

REOPENED:

**CASE CODE**

Deviation

**UTILITIES:**

Dexter-Almo Heights Water District

**INDEX OF EVENTS:**

01/30/25    Final Order Entered: 1. Dexter-Almo Heights District's request to deviate from the water storage requirements of 807 KAR 5:066, Section 4(4), is approved through December 31, 2026. 2. Dexter-Almo Heights District shall inform the Commission if changes occur in either system that would cause Murray to have insufficient storage for Dexter-Almo Heights District. 3. Any documents filed in the future pursuant to ordering paragraph 2 of this Order shall reference this case number and shall be retained in the post-case correspondence file. 4. This case is closed and removed from the Commission's docket.

11/27/24    Jasper Wyatt Dexter Almo Heights Water District Application for Deviation from 807 KAR 5:066, Section 4(4)

11/25/24    Acknowledge Receipt of Filing

11/22/24    Dexter-Almo Heights Water District Notice of Intent to File an Application for a Deviation from 807 KAR 5:066, Section 4(4) Using Electronic Filing Procedures

---

Total Number of Cases: 1