DOC11R

Case Management System - KY Public Service Commission

Regular Cases Before the Commission as of May 04, 2024

2011-00017 RECEIVED: 01/11/11 FILED: 01/11/11 FINAL: 02/21/12 REOPENED:

SUSPENSION DATE:

CASE NATURE: Waiver of Weekly Odorization Testing

CASE CODE

Deviation

UTILITIES:

Kentucky Frontier Gas, LLC

INDEX OF EVENTS:

02/21/12	Order Entered: 1. Frontier is granted a deviation from 807 KAR 5022, Section 13(17)(g)(4). Frontier shall sample its gas for proper odorant level at each of its 14 separate locations, except Dema, at least once each month. 2. Dema shall sample its gas for proper odorant level at least once every 95 days. If Dema's customers increase, it shall increase its sampling of its gas for proper odorant level to at least once monthly. 3. Frontier shall comply with the instructions set forth in Findings 8 and 9 above.
01/17/12	KY Frontier Gas response to PSC third information request
12/21/11	Order Entered: Kentucky Frontier's motion for an extension of time is granted and that it shall have
12/21/11	until January 14, 2012 to file its response to Commission Staff's Third Information Request.
12/14/11	KY Frontier Gas Request for Deviation
11/14/11	Commission Staff's Third Information Request to Kentucky Frontier Gas, LLC
08/24/11	KY Frontier Gas Response to Commission Staff's 2nd Info Request
08/18/11	Letter to Larry Rich requesting Kentucky Frontier Gas, LLC's response to Commission Staff's Second Information Request within 10 days of the date of this letter or application will be dismissed
07/12/11	COMMISSION STAFF'S SECOND INFORMATION REQUEST TO KENTUCKY FRONTIER GAS, LLC
06/02/11	Kentucky Frontier Gas Odorant Test Records
05/02/11	Notice of Extension of Time to Reply to Data Request of Commission Staff
04/14/11	Kentucky Frontier Gas Request for Extension
04/04/11	COMMISSION STAFF'S FIRST INFORMATION REQUEST TO KENTUCKY FRONTIER GAS, LLC
01/11/11	Acknowledge Receipt of Filing
01/11/11	Kentucky Frontier Gas' Request for Deviation from 807 KAR 5:022, Section $13(17)(g)(4)$ - Weekly Odorization Testing

Total Number of Cases: 1