

DOC11R

Case Management System - KY Public Service Commission*Regular Cases Before the Commission as of May 04, 2024***2017-00307**

RECEIVED: 08/18/17

FILED: 08/18/17

FINAL: 01/31/18

REOPENED:

SUSPENSION DATE:

CASE CODE

Deviation

UTILITIES:

Wood Creek Water District

INDEX OF EVENTS:

01/31/18	Final Order Entered: 1. WCWD's Application proposing an alternative inspection schedule for its grinder/pump stations pursuant to 807 KAR 5:071, Section 7(4), is approved. 2. Simplex grinder/pump stations shall be inspected annually.
10/23/17	Wood Creek Water District Response to Request for Information
10/19/17	Larry G. Bryson Wood Creek Water District Response to Commission Staffs First Request for Informatoin
10/10/17	Commission Staff's First Request for Information to Wood Creek Water District
08/15/17	Larry G. Bryson Wood Creek Water District Application for Wood Creek Water District Pursuant to 807 KAR 5:071, Section 7(4) for Approval of Proposed Inspection Procedures
07/24/17	Letter Updating Proposed File Date
07/21/17	Acknowledge Receipt of Filing
07/21/17	Wood Creek Water District Notice of Intent to File Application Pursuant to 807 KAR 5:071, Section 7(4) for Approval of Proposed Inspection Procedures Using Electronic Filing Procedures

Total Number of Cases: 1