

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF THE CANNONSBURG)
WATER DISTRICT, INC., A WATER)
DISTRICT ORGANIZED PURSUANT TO)
CHAPTER 74 OF THE KENTUCKY REVISED)
STATUTES OF BOYD COUNTY KENTUCKY,)
FOR (1) A CERTIFICATE OF PUBLIC) CASE NO. 8806
CONVENIENCE AND NECESSITY, AUTHOR-)
ING AND PERMITTING SAID WATER)
DISTRICT TO CONSTRUCT A NEW ONE)
MILLION GALLON WATER TANK (2))
APPROVAL OF THE PROPOSED PLAN OF)
FINANCING OF SAID PROJECT; AND (3))
APPROVAL OF THE WATER RATES PROPOSED)
TO BE CHARGED BY THE DISTRICT TO)
CUSTOMERS OF THE DISTRICT.)

O R D E R

IT IS ORDERED that Cannonsburg Water District ("Cannonsburg") shall file an original and seven copies of the following information with the Commission with a copy to all parties of record by May 20, 1983. Cannonsburg shall also furnish with each response the name of the witness who will be available at the public hearing for responding to questions concerning each area of information requested. If neither the requested information nor a motion for an extension of time is filed by the stated date, the case may be dismissed.

(1) Provide hydraulic analyses, supported by computations and field measurements, of typical operational sequences of the existing water distribution system. Computations are to be documented by a schematic map of the system that shows pipeline sizes, lengths, connections, pumps,

and sea level elevations of key points, as well as allocations of actual customer demands.

(2) Provide hydraulic analyses, supported by computations and field measurements, of typical operational sequences of the water distribution system after the proposed improvements have been made.

(3) Provide a pressure recording chart showing the actual 24-hour continuously measured pressure available at Cannonsburg's Princess tank. Identify the 24-hour period recorded, the exact location of the pressure recorder and the sea level elevation of the recorder.

(4) Provide a copy of the pump curve for the Rockdale pump station.


(5) Provide a copy of the approval of the proposed improvements Engineer's estimate by the Natural Resources and Environmental Protection Cabinet.


(6) Provide a copy of the Bid Tabulations including unit prices, etc.


(7) Provide a breakdown of the Total Project Costs utilizing the low bids. Also state exactly what portion of the Total Project Cost is to be funded by Cannonsburg.

Done at Frankfort, Kentucky, this 3rd day of May, 1983.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Secretary