

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF DEXTER-ALMO HEIGHTS)
WATER DISTRICT FOR A DEVIATION FROM THE) CASE NO. 10101
WATER STORAGE REQUIREMENTS)

O R D E R

On March 9, 1988, the Commission granted Dexter-Almo Heights Water District ("Dexter-Almo") a deviation from 807 KAR 5:066, Section 5(4), which requires a water utility to provide water storage to insure one day's supply of its average daily water usage, until July 1, 1991. The Commission further ordered Dexter-Almo to retain a professional engineer, who is registered in the Commonwealth of Kentucky and is experienced in the design and operation of water distribution systems, to conduct a comprehensive engineering study of Dexter-Almo's water system.

On June 23, 1988, Dexter-Almo requested that the Commission reconsider that portion of our order of March 9 which required a comprehensive engineering study of its water system. Dexter-Almo contends that it lacks the fund to commission such a study. The Commission shall consider Dexter-Almo's request as a motion for reconsideration of its final Order.

Dexter-Almo has not presented any evidence to show the cost of an engineering study or its financial inability to incur such cost. Absent the presentation of such evidence, our earlier Order must stand.

IT IS THEREFORE ORDERED that:

1. Dexter-Almo's motion for reconsideration be and hereby is denied.

2. Dexter-Almo shall retain a professional engineer to conduct a comprehensive engineering study of its water distribution system as previously ordered. Dexter-Almo shall file a copy of the report of this study with the Commission no later than December 1, 1988.

Done at Frankfort, Kentucky, this 9th day of September, 1988.

PUBLIC SERVICE COMMISSION

Richard D. Hemmelf
Chairman

Robert M. Davis
Vice Chairman

James M. Williams
Commissioner

ATTEST:

Executive Director