

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF MILFORD WATER )  
COMPANY, INC., FOR A DEVIATION )  
FROM THE MINIMUM WATER STORAGE ) CASE NO: 10203  
REQUIREMENT OF 807 KAR 5:066, )  
SECTION 5(4) )

O R D E R

By letter received March 22, 1988, Milford Water Company, Inc., ("Milford Water") requested a deviation from 807 KAR 5:066, Section 5(4). Said request proposed that Milford Water be relieved of the requirement to provide a volume of storage that would insure one day's supply of its average daily water usage.

Additional information is needed for an adequate and proper consideration of the deviation requested by Milford Water.

IT IS THEREFORE ORDERED that Milford Water shall file an original and five copies of the following information to all parties of record no later than April 29, 1988.

1. Provide the total volumes purchased monthly for the 12 months ending December 31, 1987.
2. Provide average 24-hour volume purchased during the 12 months ending December 31, 1987.
3. Provide a map of Milford Water's distribution system that shows the location of storage tanks and master meters.
4. Provide information of Milford Water's storage facilities.

5. Describe past periods of interruptions by the supplier for Milford Water. List dates and total days or hours of interruptions.

6. Does Milford Water's purchase agreement place a limit on the daily or monthly volumes that its supplier will furnish? If so, define these limits. If supplier provides certain volumes of storage for Milford Water, provide a copy of the agreement that insures the provision of this storage by supplier and a statement reflecting Milford Water's assessment of reliability of the agreement. Provide a copy of Milford Water's purchase agreement if its particulars cannot be readily described and note the particulars of interest to the instant case. Describe any curtailment aspects of the contract.

7. Describe supplier's capability for delivery of water pressure and volume at each point of delivery to Milford Water. Describe those features of supplier's system that limit its capacity for delivery of water pressure and volume to Milford Water. Such features may include: (a) distance between supplier's tank and supplier's point of connection with Milford Water, (b) size of the connecting main between Milford Water and its supplier's tank, (c) capacity of supplier's treatment plant, (d) age of supplier's treatment plant, (e) condition of supplier's treatment plant, (f) capacity and condition of supplier's pumping stations and tanks and supplier's general ability to respond to the needs of Milford Water.

8. If the Farmers Home Administration ("FmHA") is the holder of either all or a part of Milford Water's long-term debt,

provide a copy of an FmHA letter stating its position with regard to the storage volume provided by Milford Water and its request for a deviation from PSC regulations.

9. Describe Milford Water's planning to date including its efforts to secure financing for construction of additional storage facilities.

If the above listed items of information cannot be provided by April 29, 1988, Milford Water should submit a motion for an extension of time stating the reason a delay is necessary and include a date by which it will be furnished. Such motion will be considered by the Commission. Milford Water shall furnish with each response the name of the witness who will be available for responding to questions concerning each item of information requested should a public hearing be required in this matter.

Done at Frankfort, Kentucky, this 5th day of April, 1988.

PUBLIC SERVICE COMMISSION

  
For the Commission

ATTEST:

---

Executive Director