## COMMONWEALTH OF KENTUCKY

## BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF KINGSTON-TERRILL	)			
WATER DISTRICT FOR A DEVIATION FROM	)			
807 KAR 5:066, SECTION 5(4) REGARDING	)	CASE	NO.	89-005
WATER STORAGE	)			

## ORDER

By letter received January 5, 1989, Kingston-Terrill Water District ("Kingston-Terrill") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a utility to provide water storage to insure a minimum of 1 day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

- 1. Kingston-Terrill's current water storage capacity is 100,000 gallons.
- 2. Kingston-Terrill's average daily water usage including unaccounted-for water is 448,800 gallons.
- 3. Kingston-Terrill is presently pursuing financing in order to construct additional water storage facilities.
- 4. Because of the time needed to plan, finance and implement a program to construct water storage facilities, Kingston-Terrill should be given until April 1, 1992 to bring it within compliance of the Commission's water storage requirements.

## IT IS THEREFORE ORDERED that:

- 1. Kingston-Terrill be and it hereby is given until April 1, 1992 to comply with the provisions of 807 KAR 5:066, Section 5(4).
- 2. Kingston-Terrill shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to April 1, 1992.

Done at Frankfort, Kentucky, this 28th day of March, 1989.

PUBLIC SERVICE COMMISSION

Chairman

Vice Chairman

Completioner

ATTEST: