

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF LYON COUNTY WATER)
DISTRICT FOR A DEVIATION FROM 807 KAR) CASE NO. 89-164
5:066, SECTION 9(2) REGARDING DEAD ENDS)

O R D E R

By letter received June 19, 1989, Lyon County Water District ("Lyon Water") requested a three year time period to bring its facilities into compliance with 807 KAR 5:066, Section 9(2). This regulation requires a water utility to provide blow-off valves for the purpose of flushing dead-end water mains.




The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that Lyon Water should be allowed additional time to comply with 807 KAR 5:066, Section 9(2).

IT IS THEREFORE ORDERED that Lyon Water be and it hereby is given until July 31, 1992 to comply with the provisions of 807 KAR 5:066, Section 9(2).

Done at Frankfort, Kentucky, this 18th day of July, 1989.

ATTEST:

Executive Director

PUBLIC SERVICE COMMISSION

Chairman

Vice Chairman

Commissioner