COMMONWEALTH OF KENTUCKY

BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF SANDY VALLEY WATER)		
DISTRICT FOR A DEVIATION FROM THE	}		
REQUIREMENTS OF 807 KAR 5:066, SECTION)	CASE NO.	89-264
5(4) REGARDING WATER STORAGE)		

ORDER

By application received September 21, 1989, Sandy Valley Water District ("Sandy Valley") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Sandy Valley states in its application that its average daily water usage, including unaccounted-for water, is approximately 470,000 gallons, and its current water storage capacity is 100,000 gallons.

The Commission, having reviewed the application and being advised, finds that:

- 1. Sandy Valley is not in compliance with the requirements of Commission Regulation 807 KAR 5:066, Section 5(4).
- 2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Sandy Valley should be given until November 1, 1992 to bring it within compliance of the Commission's water storage requirements.

IT IS THEREFORE ORDERED that:

- 1. Sandy Valley be and it hereby is given until November 1, 1992 to comply with the provisions of 807 KAR 5:066, Section 5(4).
- 2. Sandy Valley shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to the expiration date of the deviation herein granted.

Done at Frankfort, Kentucky, this 17th day of October, 1989.

Chairman

Vice Chairman

Chairman

Vice Chairman

Chairman

Vice Chairman

Chairman

Chairman

Chairman

ATTEST: