

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

AN APPLICATION BY LEXINGTON-SOUTH)	
ELKHORN WATER DISTRICT FOR A DEVIATION)	CASE NO.
FROM THE STORAGE REQUIREMENTS OF 807)	10131
KAR 5:066, SECTION 5(4))	

O R D E R

By letter filed on July 3, 1991, the Lexington-South Elkhorn Water District ("South Elkhorn") requested additional time to comply with Commission Regulation 807 KAR 5:066, Section 5(4), which requires that each utility shall maintain water storage to ensure a minimum of one day's supply of its average daily water usage. South Elkhorn was ordered by the Commission's Order of November 30, 1988 in this proceeding to bring its water storage facilities into compliance with Commission regulations by December 1, 1991.

On July 3, 1991, South Elkhorn informed the Commission that Horne Engineering, Inc. is working on the engineering plans for a new 500,000-gallon water storage tank. South Elkhorn further stated that it anticipated its loan approval by December 1, 1991 and completion of construction by July 1, 1993.

The Commission, having reviewed the information submitted and being otherwise sufficiently advised, finds that South Elkhorn is making substantial progress toward bringing its facilities into compliance with the Commission's Order of November 30, 1988, and

that additional time is necessary to comply with the requirements of Commission Regulation 807 KAR 5:066, Section 5(4).

IT IS THEREFORE ORDERED that:

1. South Elkhorn be and it hereby is granted a deviation until July 1, 1993 to comply with the provisions of 807 KAR 5:066, Section 5(4).

2. South Elkhorn shall take all necessary action to bring its water storage facilities into compliance with Commission regulations prior to July 1, 1993.

Done at Frankfort, Kentucky, this 5th day of August, 1991.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman

Commissioner

ATTEST:



Executive Director