

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF NELSON VALLEY WATER )  
ASSOCIATION, INC. FOR A DEVIATION )  
PURSUANT TO 807 KAR 5:066, SECTION ) CASE NO. 91-239  
5(4) REGARDING WATER STORAGE )

O R D E R

By application received July 15, 1991, Nelson Valley Water Association, Inc. ("Nelson Valley") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Nelson Valley states in its application that its average daily water usage, including unaccounted-for water, is approximately 200,000 gallons, and that its current water storage capacity is 36,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Nelson Valley is not in compliance with Commission Regulation 807 KAR 5:066, Section 5(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Nelson Valley should be given until July 1, 1994 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 5(4).


IT IS THEREFORE ORDERED that:


1. Nelson Valley be and it hereby is given until July 1, 1994 to comply with the provisions of 807 KAR 5:066, Section 5(4).

2. Nelson Valley shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to July 1, 1994.

Done at Frankfort, Kentucky, this 24th day of September, 1991.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

\_\_\_\_\_  
Commissioner

ATTEST:

  
Executive Director