

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF WESTERN FLEMING)
COUNTY WATER DISTRICT FOR A DEVIATION) CASE NO. 91-265
FROM 807 KAR 5:066, SECTION 5(4))
REGARDING WATER STORAGE)

O R D E R

By application received August 2, 1991, Western Fleming County Water District ("Western Fleming") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Western Fleming states in its application that its average daily water usage, including unaccounted-for water, is approximately 650,000 gallons, and that its current water storage capacity is 550,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Western Fleming is not in compliance with Commission Regulation 807 KAR 5:066, Section 5(4).
2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Western Fleming should be given until January 1, 1995 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 5(4).

IT IS THEREFORE ORDERED that:


1. Western Fleming be and it hereby is given until January 1, 1995 to comply with the provisions of 807 KAR 5:066, Section 5(4).

2. Western Fleming shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 1995.

Done at Frankfort, Kentucky, this 18th day of September, 1991.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman

Commissioner

ATTEST:


Executive Director